

**Proposed Outage for 153rd OCC meeting**

S.No	Request by	Element Owner	Element Type	Element Name	Mode	Reason	Outage Request				Total Hours	Last OCC Number
							From Date	From Time	To Date	To Time		
1	ADHPL	ADHPL	GENCO	AD Hydro-U1/96	CONTINUOUS	Replacement of service seals of MIV & attending leakage of HRT.	2018-12-01	00:00	2018-12-10	23:59	240	152
2	ADHPL	ADHPL	GENCO	AD Hydro-U2/96	CONTINUOUS	Replacement of service seal of MIVs and attending leakage of HRT	2018-12-01	00:00	2018-12-10	23:59	240	152
3	ADHPL	ADHPL	GENCO	AD Hydro-U2/96	CONTINUOUS	Annual maintenance of UNIT.	2018-12-11	00:00	2018-12-25	23:59	360	152
4	APL	APL	GENCO	Adani Power Ltd Mundra-U9/660	CONTINUOUS	COH	2019-01-01	00:30	2019-01-30	23:50	719	-
5	JSW	JSW	GENCO	Karcham Wangtoo-U4/250	CONTINUOUS	Annual Maintenance of Unit-4	2018-11-20	00:00	2018-12-06	23:59	408	-
6	JSW	JSW	GENCO	Karcham Wangtoo-U3/250	CONTINUOUS	Annual Maintenance of Unit-3	2018-12-11	00:00	2019-01-02	23:59	552	-
7	JSW	JSW	GENCO	Karcham Wangtoo-U2/250	CONTINUOUS	Annual Maintenance of Unit-2	2019-01-07	00:00	2019-01-23	23:59	408	-
8	NTPC	NTPC	GENCO	Rihand TPS-U2/500	CONTINUOUS	10 days s/d for hfo-ldo conversion	2018-12-26	00:00	2019-01-05	00:00	240	145
9	NTPC	NTPC	GENCO	Koldam-U1/200	CONTINUOUS	Annual Inspection	2018-12-18	00:10	2018-12-23	00:00	120	-
10	RRVFN	RRVUNL	GENCO	Suratgarh TPS-U4/250	CONTINUOUS	Annual Boiler overhaul	2018-12-16	00:00	2019-01-04	23:59	480	152
11	RRVFN	RRVUNL	GENCO	Kota TPS-U2/110	CONTINUOUS	Annual Boiler overhaul	2018-12-14	00:00	2019-01-28	23:59	1104	-
12	RRVFN	RRVUNL	GENCO	Kota TPS-U7/195	CONTINUOUS	Annual Boiler overhaul	2018-11-29	00:00	2018-12-13	23:59	360	-
13	SJVNL	SJVNL	GENCO	Rampur HEP-U1/68.67	CONTINUOUS	Annual Plant Maintenance	2018-11-19	00:00	2018-11-27	17:00	209	-
14	SJVNL	SJVNL	GENCO	Rampur HEP-U2/68.67	CONTINUOUS	Annual Planned Maintenance	2018-11-26	00:00	2018-12-03	17:00	185	-
15	SJVNL	SJVNL	GENCO	Rampur HEP-U3/68.67	CONTINUOUS	Annual Planned Maintenance	2018-12-11	00:00	2018-12-18	17:00	185	-
16	SJVNL	SJVNL	GENCO	Rampur HEP-U4/68.67	CONTINUOUS	Annual Planned Maintenance	2018-12-22	00:00	2018-12-29	17:00	185	-
17	SJVNL	SJVNL	GENCO	Nathpa-Jhakri-U1/250	CONTINUOUS	Annual Planned Maintenance	2018-11-19	00:00	2018-11-27	17:00	209	-
18	SJVNL	SJVNL	GENCO	Nathpa-Jhakri-U2/250	CONTINUOUS	Annual Planned Maintenance	2018-11-30	00:00	2018-12-08	17:00	209	-
19	SJVNL	SJVNL	GENCO	Nathpa-Jhakri-U3/250	CONTINUOUS	Annual Planned Maintenance	2018-12-11	00:00	2018-12-18	17:00	185	-
20	SJVNL	SJVNL	GENCO	Nathpa-Jhakri-U4/250	CONTINUOUS	Annual Planned Maintenance	2018-12-22	00:00	2018-12-29	17:00	185	-
21	POWERGRID	POWERGRID	BAY	707 BAY (Main Bay of 765 KV Fatehpur-AGRA-1 Line ) at Fatehpur	DAILY	AMP and Tightening Work	2018-12-07	09:30	2018-12-07	18:00	8.5	-
22	POWERGRID	POWERGRID	BAY	765kV Bareilly Line Main Bay at Lucknow	DAILY	For AMP Work	2018-12-02	09:00	2018-12-03	18:00	18	-
23	POWERGRID	POWERGRID	BAY	765kV Bareilly Line Tie Bay at Lucknow	DAILY	For AMP Work	2018-12-04	09:00	2018-12-05	18:00	18	-
24	POWERGRID	POWERGRID	BAY	765 KV Bareilly Line Reactor Bay, at Lucknow	DAILY	For AMP Work	2018-12-19	09:00	2018-12-20	18:00	18	151
25	POWERGRID	POWERGRID	BAY	765kV Bareilly Line Reactor Bay at Lucknow	DAILY	For AMP Work	2018-12-17	09:00	2018-12-18	18:00	18	-
26	POWERGRID	POWERGRID	BAY	765 KV JHATIKRA /ICT-1T/BAY 711 AT BHIWANI	DAILY	For Bay Equipment AMP work	2018-12-19	09:30	2018-12-20	18:30	18	151
27	POWERGRID	POWERGRID	BAY	765 KV ICT-1 M/BAY 712 AT BHIWANI	DAILY	For Bay Equipment AMP work	2018-12-21	09:00	2018-12-22	18:00	18	151
28	POWERGRID	POWERGRID	BAY	765KV MOGA/BUS REACTOR -I T/BAY 714 AT BHIWANI	DAILY	For Bay Equipment AMP work	2018-12-28	09:30	2018-12-28	18:30	9	151
29	POWERGRID	POWERGRID	BAY	765 KV B/R-II T/BAY 717 BHIWANI	DAILY	For Bay Equipment AMP work	2018-12-24	09:00	2018-12-25	18:00	18	-
30	POWERGRID	POWERGRID	BAY	765 KV B/R-II M/BAY 718 BHIWANI	DAILY	For Bay Equipment AMP work	2018-12-26	09:00	2018-12-27	18:00	18	-

31	POWERGRID	POWERGRID	BAY	765 KV PHAGI-II M/BAY 719 BHIWANI	DAILY	For Bay Equipment AMP work	2018-12-29	09:00	2018-12-29	18:00	9	-
32	POWERGRID	POWERGRID	BAY	765 KV PHAGI-II T/BAY 720 BHIWANI	DAILY	For Bay Equipment AMP work	2018-12-31	09:00	2018-12-31	18:00	9	-
33	POWERGRID	POWERGRID	BAY	765 KV PHAGI-I M/BAY 720 BHIWANI	CONTINUOUS	For Attending Gas Leakage in CB	2018-12-17	09:00	2018-12-18	18:00	33	-
34	POWERGRID	POWERGRID	BUS	765 KV Bus-1, at Agra	DAILY	For Future Bay Isolator Anchoring work., and AMP work.	2018-12-15	09:00	2018-12-16	18:00	18	145
35	POWERGRID	POWERGRID	BUS	765 KV Bus-2, at Agra	DAILY	For Future Bay Isolator Anchoring work., and AMP work.	2018-12-17	09:00	2018-12-18	18:00	18	145
36	POWERGRID	POWERGRID	BUS	765KV BUS-I BHIWANI	DAILY	RTV Coating on Line Equipment BPIs & Cleaning of Equipment	2018-12-07	09:30	2018-12-07	18:30	9	151
37	POWERGRID	POWERGRID	BUS	765KV BUS-II AT BHIWANI	DAILY	RTV Coating on Line Equipment BPIs & Cleaning of Equipment	2018-12-08	08:00	2018-12-08	18:00	10	152
38	POWERGRID	POWERGRID	BUS	BUS I CHITTORGARH(765KV)	DAILY	AMP of BUS & associated equipment.	2018-12-17	09:00	2018-12-18	18:00	18	151
39	POWERGRID	POWERGRID	BUS	BUS II CHITTORGARH(765KV)	DAILY	AMP of BUS & associated equipment	2018-12-19	09:00	2018-12-20	18:00	18	145
40	POWERGRID	POWERGRID	BUS	765 KV Bus-1, at fatehpur	DAILY	AMP and Tightening Work	2018-12-14	09:30	2018-12-14	18:00	8.5	-
41	POWERGRID	POWERGRID	ICT	ICT -I AGRA-PG (765KV)(POWERGRID)/1500	DAILY	Making Double conductor arragnement in Neutral, and AMP works.	2018-12-10	09:00	2018-12-10	18:00	9	150
42	POWERGRID	POWERGRID	LINE	MEERUT (765KV)-MOGA( 765KV)	DAILY	For Tower strengthening works.Also NR-I will be do work with co-ordination with NR-II	2018-12-12	09:00	2018-12-31	17:30	170	151
43	POWERGRID	POWERGRID	LINE	FATEHPUR-PG (765 KV)-SASARAM-ER (765KV)	DAILY	For Strengthening work of Suspension Towers .	2018-12-01	08:00	2018-12-10	18:00	100	150
44	POWERGRID	POWERGRID	LINE	VARANASI (765KV)-FATEHPUR-PG (765 KV)	DAILY	For Balance Strengthening work of Suspension Towers Delta Configuration .	2018-11-19	08:00	2018-11-25	18:00	70	151
45	POWERGRID	POWERGRID	LINE	GAYA-ER (765KV)-VARANASI (765KV)1	DAILY	CLEANING OF GLASS DISC INSULATORS	2018-11-19	08:00	2018-11-19	18:00	10	146
46	POWERGRID	POWERGRID	LINE	GAYA-ER (765KV)-VARANASI (765KV)2	DAILY	CLEANING OF GLASS DISC INSULATORS	2018-11-20	08:00	2018-11-20	18:00	10	-
47	POWERGRID	POWERGRID	LINE	VARANASI (765KV)-BALIA (765KV)	DAILY	CLEANING OF GLASS DISC INSULATORS	2018-11-21	08:00	2018-11-21	18:00	10	150
48	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-JHATIKALA(765 KV)	DAILY	For Line Isolator Anchoring work.	2018-12-17	08:00	2018-12-17	19:30	11.5	151

49	POWERGRID	POWERGRID	LINE	MEERUT (765KV)-BHIWANI-PG (765 KV)	DAILY	RTV Coating on Line Equipment BPIs & Cleaning of Equipment.L/R will be in outage also at bhiwani end.	2018-12-03	09:30	2018-12-03	15:30	6	151
50	POWERGRID	POWERGRID	LINE	JHATIKALA(765 KV)-BHIWANI-PG (765 KV)	DAILY	RTV Coating on Line Equipment BPIs & Cleaning of Equipment	2018-12-04	09:30	2018-12-04	15:30	6	151
51	POWERGRID	POWERGRID	LINE	BHIWANI-PG (765 KV)-PHAGI (765KV)1	DAILY	RTV Coating on Line Equipment BPIs & Cleaning of Equipment	2018-12-05	09:00	2018-12-05	15:00	6	152
52	POWERGRID	POWERGRID	LINE	BHIWANI-PG (765 KV)-PHAGI (765KV)2	DAILY	RTV Coating on Line Equipment BPIs & Cleaning of Equipment	2018-12-06	09:00	2018-12-06	15:00	6	151
53	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-JHATIKALA(765 KV)	CONTINUOUS	For diversion work due to DFCC	2018-12-01	09:00	2018-12-15	19:00	346	151
54	POWERGRID	POWERGRID	LINE	ALIGARH-PG (765KV)-JHATIKALA(765 KV)	DAILY	For diamond formation at crossing point of 765 KV Agra-Jhatikra Line	2018-12-01	10:00	2018-12-01	16:00	6	151
55	POWERGRID	POWERGRID	LINE	PHAGI (765KV)-GWALIOR-WR (765KV)2	DAILY	For erection of Line Isolator post Insulator in phase where wave trap are not available,and ckt -1 will be kept in non auto mode by WR.Actual avail dt is 30.11.18 one	2018-11-29	10:00	2018-11-29	20:00	10	152
56	POWERGRID	POWERGRID	LINE	MOGA( 765KV)-BHIWANI-PG (765 KV)	DAILY	For tower strengthening works.	2018-12-01	09:30	2018-12-11	18:30	99	151
57	POWERGRID	POWERGRID	LINE	LUCKNOW(765 KV)-PG-BALIA (765KV)	DAILY	For Tower Strengthening (delta type) & other maintenance work under AM-TL/Lucknow	2018-12-01	09:30	2018-12-06	17:30	48	151
58	POWERGRID	POWERGRID	LINE	LUCKNOW(765 KV)-PG-BAREILY-PG (765 KV)	DAILY	For Tower Strengthening (delta type) & other maintenance work under AM-TL/Lucknow	2018-12-17	09:30	2018-12-21	17:30	40	151
59	POWERGRID	POWERGRID	LINE	LUCKNOW(765 KV)-PG-BALIA (765KV)	DAILY	for tower strengthening (delta type) & other maintenance work under AM-TL/Lucknow	2018-12-10	09:30	2018-12-14	17:30	40	151
60	POWERGRID	POWERGRID	REACTOR	REACTOR-II BHIWANI-PG (765 KV)/240.00	DAILY	RTV Coating on Line Equipment BPIs & AMP of Reactor	2018-12-09	09:30	2018-12-10	18:30	18	-
61	RRVFN	RRVFN	BAY	706-52T tie CB for 765kV ANTA-1 & GWALIOR-1 LINES AT 765KV PHAGI	DAILY	1. To check the operation timings of CB& measurement of contact resistance.. 2. Measurement of Tan-delta of CTs. 3.Tightening of clamps & connectors.	2018-12-04	10:00	2018-12-05	18:00	16	146
62	RRVFN	RRVFN	BAY	800kV CB (701-52 B) for 3*500 MVA ICT-1 at 765kV GSS Phagi	DAILY	. To check the operation timings of CB& measurement of contact resistance.. 2. Measurement of Tan-delta of CTs. 3.Tightening of clamps & connectors.	2018-12-14	10:00	2018-12-15	18:00	16	-

63	RRVPN	RRVPN	BAY	800kV CB (706-52 B) for 765kV Phagi-Anta-1 line at 765kV GSS Phagi	DAILY	1. To check the operation timings of CB& measurement of contact resistance.. 2. Measurement of Tan-delta of CTs. 3.Tightening of clamps & connectors.	2018-12-10	10:00	2018-12-11	18:00	16	-
64	RRVPN	RRVPN	BAY	Bay of 400kV Chittorgarh-Mangalwar(765kV Chittorgarh(PG))-II	CONTINUOUS	FOR MAINTAINCE WORK	2018-12-26	09:00	2018-12-29	17:00	80	147
65	RRVPN	RRVPN	BUS	765 kV Main Bus-II at 765 kV GSS Anta	DAILY	2nd Half yearly maintenace work	2018-12-05	09:00	2018-12-05	18:00	9	151
66	RRVPN	RRVPN	BUS	765 kV Main Bus-I at 765 kV GSS Anta	DAILY	2nd Half yearly maintenace work	2018-12-20	09:00	2018-12-20	18:00	9	151
67	RRVPN	RRVPN	BUS	400 kV Main Bus-I at 765 kV GSS Anta	DAILY	2nd Half yearly maintenace work	2018-12-06	09:00	2018-12-06	18:00	9	151
68	RRVPN	RRVPN	BUS	400 kV Main Bus-II AT 765 kV GSS Anta	DAILY	2nd Half yearly maintenace work	2018-12-11	09:00	2018-12-11	18:00	9	151
69	RRVPN	RRVPN	ICT	ICT03 ANTA(765KV)(RRVPN)/1500	DAILY	4th quaterly maintenace work & For Maintaining air cell in main conservator	2018-12-26	09:00	2018-12-26	18:00	9	150
70	RRVPN	RRVPN	ICT	ICT01 ANTA(765KV)(RRVPN)/1500	DAILY	4th quaterly maintenace work	2018-12-27	09:00	2018-12-27	18:00	9	150
71	RRVPN	RRVPN	ICT	ICT01 PHAGI (765KV)(RRVPN)/1500	DAILY	1.Maintenance of Transformers 2. Tightening of clamps & connectors.	2018-12-27	09:00	2018-12-28	18:00	18	-
72	RRVPN	RRVPN	ICT	ICT02 PHAGI (765KV)(RRVPN)/1500	CONTINUOUS	1. Maintenance of Transformers. 2. Tightening of clamps and connectors. 3.To connect the R-Phase Transformer in circuit of ICT-2 in place of spare Transformer.	2018-12-19	09:00	2018-12-20	19:00	34	145
73	RRVPN	RRVPN	LINE	ANTA(765KV)-PHAGI (765KV)I	DAILY	REPLACEMENT OF DEFECTIVE M-1 RELAY	2018-12-21	09:00	2018-12-21	18:00	9	152
74	RRVPN	RRVPN	REACTOR	Reactor Bank 2 ANTA(765KV)/240.00	DAILY	4th quaterly maintenace work & For Maintaining air cell in main conservator	2018-12-28	09:00	2018-12-28	18:00	9	148
75	UPPTCL	UPPTCL	ICT	ICT GREATER NOIDA(765 KV)(UPPTCL)/1500	CONTINUOUS	Annual Maintenance & charging of spare ICT.	2018-12-03	06:00	2018-12-04	06:00	24	151
76	UPPTCL	UPPTCL	ICT	765/400KV 1500MVA ICT-II at Fatehabad S/S/1500MVA	DAILY	Spare ICT charging, Tan delta of bushing, PRD covers Fixing, CSD commissioning of 414 bay and Annual Maintenance Program.	2018-12-02	08:00	2018-12-04	18:00	30	152
77	UPPTCL	UPPTCL	ICT	765/400KV 1500MVA ICT-I at Fatehabad S/S/1500MVA	CONTINUOUS	Spare ICT charging, Tan delta of bushing, PRD covers Fixing and Annual Maintenance Program.	2018-11-29	08:00	2018-12-01	18:00	58	152
78	UPPTCL	UPPTCL	ICT	ICT GREATER NOIDA(765 KV)(UPPTCL)/1500	DAILY	Annual Maintenance (One hour)	2018-12-06	09:00	2018-12-06	10:00	1	151

79	UPPTCL	UPPTCL	ICT	ICT GREATER NOIDA(765 KV)(UPPTCL)/1500	DAILY	Annual Maintenance (One hour)	2018-12-08	09:00	2018-12-08	10:00	1	151
80	UPPTCL	UPPTCL	ICT	ICT GREATER NOIDA(765 KV)(UPPTCL)/1500	DAILY	Annual Maintenance (One hour)	2018-12-12	09:00	2018-12-12	10:00	1	151
81	UPPTCL	UPPTCL	ICT	765/400/33 kV, 3x500 MVA ICT-1 HAPUR/3x500 MVA	DAILY	Annual Maintenance (One hour)	2018-12-03	09:00	2018-12-03	10:00	1	151
82	UPPTCL	UPPTCL	ICT	765/400/33 kV, 3x500 MVA ICT-1 HAPUR/3x500 MVA	DAILY	Annual Maintenance (One hour)	2018-12-05	09:00	2018-12-05	10:00	1	151
83	UPPTCL	UPPTCL	ICT	765/400/33 kV, 3x500 MVA ICT-1 HAPUR/3x500 MVA	DAILY	Annual Maintenance (One hour)	2018-12-07	09:00	2018-12-07	10:00	1	151
84	UPPTCL	UPPTCL	ICT	765/400/33 kV, 3x500 MVA ICT-1 HAPUR/3x500 MVA	DAILY	Annual Maintenance (One hour)	2018-12-10	09:00	2018-12-10	10:00	1	151
85	UPPTCL	UPPTCL	LINE	LALITPUR-TPS (765KV)-FATEHBAD_AGRA(765KV)I	DAILY	Regular Maintenance of Line	2018-12-17	08:00	2018-12-19	18:00	30	152
86	UPPTCL	UPPTCL	LINE	LALITPUR-TPS (765KV)-FATEHBAD_AGRA(765KV)II	DAILY	Regular Maintenance of Line	2018-12-20	08:00	2018-12-22	18:00	30	152
87	UPPTCL	UPPTCL	LINE	GREATER NOIDA(765 KV)-MAINPURI-UP (765KV)	DAILY	For Tightening . Replenishment of Tower Parts near to cross arms, CC Rings, Jumper Bolts, Insulators etc. and Tree Cutting	2018-12-05	08:00	2018-12-05	18:00	10	151
88	UPPTCL	UPPTCL	LINE	GREATER NOIDA(765 KV)-GREATER NOIDA (400KV)	DAILY	For cleaning of Disc Insulators.	2018-12-08	08:00	2018-12-11	18:00	40	151
89	UPPTCL	UPPTCL	LINE	GREATER NOIDA(765 KV)-GREATER NOIDA (400KV)II	DAILY	For cleaning of Disc Insulators and attending problematic PG isolator of Main Bus-B.	2018-12-12	08:00	2018-12-15	17:00	36	152
90	UPPTCL	UPPTCL	LINE	FATEHBAD_AGRA(765KV)-MATHURA (400KV)I	DAILY	Jumpers Tightening work on the respective line.	2018-12-26	08:00	2018-12-27	19:00	22	150
91	UPPTCL	UPPTCL	REACTOR	765kV Bus reactor at Fatehabad S/S/80.00	DAILY	Charging of Spare Bus reactor and annual Maintenance Program	2018-12-05	08:00	2018-12-07	18:00	30	151
92	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	CONTINUOUS	For shifting and rerouting of one tower coming in four laining of Nagchala to Kiratpur Nation Highway road by NHAI.	2018-12-01	00:00	2018-12-10	18:00	234	152
93	ADHPL	ADHPL	LINE	NALLAGARH (220KV)-CHHAUR (220KV)	CONTINUOUS	For shifting and rerouting of one tower coming in four laining of Nagchala to Kiratpur Nation Highway road by NHAI.	2018-12-01	00:00	2018-12-10	18:00	234	152
94	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans. Line.	2018-12-11	11:00	2018-12-11	16:30	5.5	152
95	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-12	11:00	2018-12-12	16:30	5.5	152

96	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-13	11:00	2018-12-13	16:30	5.5	152
97	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-14	11:00	2018-12-14	16:30	5.5	152
98	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-15	11:00	2018-12-15	16:30	5.5	152
99	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-17	11:00	2018-12-17	16:30	5.5	152
100	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-18	11:00	2018-12-18	16:30	5.5	152
101	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-19	11:00	2018-12-19	16:30	5.5	152
102	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-20	11:00	2018-12-20	16:30	5.5	152
103	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-21	11:00	2018-12-21	16:30	5.5	152
104	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-22	11:00	2018-12-22	16:30	5.5	152
105	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-24	11:00	2018-12-24	16:30	5.5	152
106	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-25	11:00	2018-12-25	16:30	5.5	152
107	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-26	11:00	2018-12-26	16:30	5.5	152
108	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-27	11:00	2018-12-27	16:30	5.5	152
109	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-28	11:00	2018-12-28	16:30	5.5	152
110	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-29	11:00	2018-12-29	16:30	5.5	152

111	ADHPL	ADHPL	LINE	AD HYDRO (220KV)-NALLAGARH (220KV)	DAILY	Pre-winter preventive maintenance work of the 220kV Trans.Line	2018-12-31	11:00	2018-12-31	16:30	5.5	152
112	APL	APL	BUS	400 KV BUS-1 HVDC Mundra Terminal SS	DAILY	Annual Maintenance and Testing of BUS-1 Connected Equipment at HVDC Mundra Terminal.	2018-12-05	08:00	2018-12-06	16:00	16	-
113	APL	APL	BUS	400 KV BUS-2 HVDC Mundra Terminal SS	DAILY	Annual Maintenance and Testing of BUS-2 Connected Equipment at HVDC Mundra Terminal.	2018-12-01	08:00	2018-12-02	18:00	20	-
114	APL	APL	HVDC	ACF-2 Filter Main 10C 01A Bay & Tie Bay 10C01B/120	DAILY	Annual Maintenance and Testing of AC Filter BUS-2 Connected equipment's & RTV Si coating at HVDC Mundra Terminal.	2018-12-11	08:00	2018-12-12	18:00	20	-
115	APL	APL	HVDC	ACF-1 Filter Main 10C 01C Bay & Tie Bay 10C01B/120	DAILY	Annual Maintenance and Testing of AC FILTER BUS-1 Connected Equipment & RTV Si coating at HVDC Mundra Terminal.	2018-12-09	08:00	2018-12-10	18:00	20	-
116	APL	APL	HVDC	ADANI MUNDRA-MAHINDERGARH POLE-1/500	DAILY	Insulator replacement work from porcelain to polymer in HVDC Transmission Line.	2018-12-05	07:00	2018-12-08	19:00	48	152
117	APL	APL	HVDC	ADANI MUNDRA-MAHINDERGARH POLE-2/500	DAILY	Insulator replacement,work in HVDC Line.	2018-12-01	07:00	2018-12-04	19:00	48	147
118	BBMB	BBMB	BUS	400KV Bus-1 at Panipat	DAILY	Cleaning of insulators.	2018-12-06	08:00	2018-12-06	17:00	9	145
119	BBMB	BBMB	BUS	400 KV Bus-2 at Panipat	DAILY	Cleaning of insulators.	2018-12-11	08:00	2018-12-11	17:00	9	145
120	BBMB	BBMB	BUS	400 kV Bus-1 DEHAR (400KV)	CONTINUOUS	Replacement of CVT and Bus isolators.	2018-12-04	08:30	2018-12-06	17:00	56.5	151
121	BBMB	BBMB	LINE	PANCHKULA-PG (400KV)-PANIPAT BBMB (400KV)	DAILY	Cleaning of disc insulators in polluted area and maintenance of line due to foggy season.	2018-12-15	08:00	2018-12-15	17:00	9	152
122	BBMB	BBMB	LINE	BHIWANI BBMB (400KV)-RAJPURA (400KV)	DAILY	Cleaning of disc insulators in polluted area and maintenance of line due to foggy season.	2018-12-22	08:00	2018-12-22	17:00	9	152
123	BBMB	BBMB	LINE	NARELA (220KV)-ROHTAK ROAD DELHI (220KV)1	DAILY	Cleaning of remaining conventional disc insulators.	2018-12-12	08:00	2018-12-12	17:00	9	152
124	BBMB	BBMB	LINE	NARELA (220KV)-ROHTAK ROAD DELHI (220KV)1	DAILY	To replace the remaining disc insulators of yard with polymer insulators. (220KV Bus- I shall remain under shutdown during this period).	2018-12-08	08:00	2018-12-08	17:00	9	152

125	BBMB	BBMB	LINE	NARELA (220KV)-ROHTAK ROAD DELHI (220KV)1	DAILY	To replace the remaining disc insulators of yard with polymer insulators. (220KV Bus- I shall remain under shutdown during this period).	2018-12-10	08:00	2018-12-10	17:00	9	152
126	BBMB	BBMB	LINE	NARELA (220KV)-ROHTAK ROAD DELHI (220KV)1	DAILY	To replace the remaining disc insulators of yard with polymer insulators. (220KV Bus- I shall remain under shutdown during this period).	2018-12-13	08:00	2018-12-13	17:00	9	152
127	BBMB	BBMB	LINE	NARELA (220KV)-ROHTAK ROAD DELHI (220KV)1	DAILY	To replace the remaining disc insulators of yard with polymer insulators. (220KV Bus- II shall remain under shutdown during this period).	2018-12-15	08:00	2018-12-15	17:00	9	152
128	BBMB	BBMB	LINE	NARELA (220KV)-ROHTAK ROAD DELHI (220KV)2	DAILY	Cleaning of conventional disc insulators and mtc work.	2018-12-05	08:00	2018-12-05	17:00	9	152
129	BBMB	BBMB	LINE	PANIPAT BBMB (220KV)-NARELA (220KV)1	DAILY	Annual mtc. works.	2018-12-06	08:00	2018-12-06	17:00	9	151
130	BBMB	BBMB	LINE	PANIPAT BBMB (220KV)-NARELA (220KV)2	DAILY	Annual mtc work.	2018-12-03	08:00	2018-12-03	17:00	9	151
131	BBMB	BBMB	LINE	PANIPAT BBMB (220KV)-NARELA (220KV)3	DAILY	Annual mtc work.	2018-12-04	08:00	2018-12-04	17:00	9	151
132	BBMB	BBMB	LINE	PANIPAT BBMB (220KV)-CHARKHI DADRI (220KV)	DAILY	Annual mtc work.	2018-12-18	08:00	2018-12-18	17:00	9	152
133	BBMB	BBMB	LINE	BALLABGARH BBMB (220KV)-CHARKHI DADRI (220KV)	DAILY	Cleaning of disc insulators.	2018-12-01	08:00	2018-12-01	17:00	9	152
134	BBMB	BBMB	LINE	CHARKHI DADRI (220KV)-SAMAYPUR (220KV)	DAILY	Replacement of 2 No. CVT with PT and coupling capacitor at Samaypur and cleaning of disc insulators along with other mtc work.	2018-12-07	08:00	2018-12-07	17:00	9	150
135	BBMB	BBMB	LINE	BALLABGARH BBMB (220KV)-SAMAYPUR (220KV)2	CONTINUOUS	Replacement of 1 No. isolator and 2 No. mechanism at Samaypur along with annual mtc work.	2018-12-10	08:00	2018-12-12	20:00	60	-
136	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-HISSAR BBMB (220KV)1	CONTINUOUS	Replacement of 220 KV Breaker at Bhiwani.	2018-11-29	08:00	2018-12-03	17:00	105	151
137	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-HISSAR BBMB (220KV)2	CONTINUOUS	Replacement of 220 KV Breaker at Bhiwani.	2018-12-07	08:00	2018-12-11	17:00	105	151
138	BBMB	BBMB	LINE	HISSAR BBMB (220KV)-SANGRUR (220KV)I	DAILY	Cleaning of remaining disc insulators and mtc work.	2018-12-03	08:00	2018-12-04	17:00	18	152
139	BBMB	BBMB	LINE	HISSAR BBMB (220KV)-SANGRUR (220KV)II	DAILY	Cleaning of remaining disc insulators and mtc work.	2018-12-05	08:00	2018-12-06	17:00	18	152



140	BBMB	BBMB	LINE	GANGUWAL (220KV)-JAGADHRI (220KV)	DAILY	Cleaning of disc insulators of polluted towers & mtc. of line	2018-12-04	09:00	2018-12-04	17:00	8	152
141	BBMB	BBMB	LINE	JAMALPUR (220KV)-SANGRUR (220KV)I	DAILY	Half yearly mtc.	2018-12-10	08:00	2018-12-12	17:00	27	151
142	BBMB	BBMB	LINE	JAMALPUR (220KV)-JALLANDHAR BBMB (220KV)I	DAILY	Half yearly mtc.	2018-12-13	08:00	2018-12-15	17:00	27	151
143	BBMB	BBMB	LINE	BHAKRA RIGHT (220KV)-JAMALPUR (220KV)I	CONTINUOUS	1.Replacement installation and commissioning of 3 Nos. LAs with new LAs and foundation/Civil work. 2. Installation and commissioning of 2 Nos. new IBTs and annual mtc of equipment.	2018-12-13	08:00	2019-01-07	17:00	609	145
144	BBMB	HVPNL	LINE	PANIPAT BBMB (220KV)-PANIPAT THERMAL POWER STATIONIII	DAILY	Annual mtc. work.	2018-12-07	08:00	2018-12-07	17:00	9	146
145	BBMB	HVPNL	LINE	PANIPAT BBMB (220KV)-PANIPAT THERMAL POWER STATIONIV	DAILY	Annual mtc. work.	2018-12-06	08:00	2018-12-06	17:00	9	-
146	BBMB	HVPNL	LINE	CHARKHI DADRI (220KV)-MAHINDERGARH HVPNL (220KV)1	DAILY	Annual mtc. work.	2018-12-05	08:00	2018-12-05	17:00	9	152
147	BBMB	HVPNL	LINE	CHARKHI DADRI (220KV)-MAHINDERGARH HVPNL (220KV)2	DAILY	Annual mtc. work.	2018-12-06	08:00	2018-12-06	17:00	9	151
148	BBMB	HVPNL	LINE	CHARKHI DADRI (220KV)-LULAHIRS/C	DAILY	Annual mtc. work.	2018-12-07	08:00	2018-12-07	17:00	9	151
149	BBMB	PSTCL	LINE	JAMALPUR (220KV)-DHANDARIKALANI	DAILY	Half yearly mtc.	2018-12-03	08:00	2018-12-05	17:00	27	146
150	BBMB	PSTCL	LINE	JAMALPUR (220KV)-DHANDARIKALANII	DAILY	half yearly mtc.	2018-12-06	08:00	2018-12-08	17:00	27	146
151	DTL	DTL	BAY	CB NO 2052 CONTROLLING 315 MVA ICT - 01 AT BAMNAULI	DAILY	FOR BREAKER TESTING(CRM AND TIMING) AS PER PMS.	2018-12-04	09:30	2018-12-04	13:30	4	-
152	DTL	DTL	BAY	CB NO 2152 CONTROLLING 315MVA ICT - 01 AT BAMNAULI	DAILY	FOR BREAKER TESTING(CRM AND TIMING) AS PER PMS.	2018-12-04	14:30	2018-12-04	17:30	3	-
153	DTL	DTL	BAY	CB NO 2352 CONTROLLING 315 MVA ICT - 04 AT BAMNAULI	DAILY	FOR BREAKER TESTING(CRM AND TIMING) AS PER PMS.	2018-12-05	09:30	2018-12-05	13:30	4	-
154	DTL	DTL	BAY	CB NO 2452 CONTROLLING 315 MVA ICT - 04 AT BAMNAULI	DAILY	FOR BREAKER TESTING(CRM AND TIMING) AS PER PMS.	2018-12-05	14:30	2018-12-05	17:30	3	-
155	DTL	DTL	BUS	400KV BUS-1 AT BAWANA-DTL (400KV)	CONTINUOUS	MAJOR OVERHAULING OF BUS-1 ISOLATOR 189, 389, 1589 & 1789.	2018-12-03	08:00	2018-12-05	17:00	57	152
156	DTL	DTL	BUS	400KV BUS-2 AT BAWANA	CONTINUOUS	MAJOR OVERHAULING OF BUS-1 ISOLATOR 289, 489, 1689 & 1889.	2018-12-06	08:00	2018-12-08	17:00	57	152
157	DTL	DTL	ICT	ICT02 BAMNAULI(DTL)/500	DAILY	FOR TRANSFORMER TESTING(TAN DELTA, CAPACITANCE, IR VALUE, SFRA, LOW VOLTAGE TEST, WINDING RESISTANCE).	2018-12-27	09:00	2018-12-27	17:30	8.5	151

158	DTL	DTL	ICT	ICT02 BAWANA-DTL (400KV)(DTL)/315	DAILY	GENERAL MAINTENANCE OF ICT AND ITS BAY EQUIPMENTS.	2018-12-12	09:00	2018-12-12	17:00	8	-
159	DTL	DTL	ICT	ICT04 BAWANA-CCGT (400KV)(DTL)/315	DAILY	GENERAL MAINTENANCE OF ICT AND ITS BAY EQUIPMENTS.	2018-12-14	09:00	2018-12-14	17:00	8	150
160	DTL	DTL	ICT	ICT05 BAWANA-CCGT (400KV)(DTL)/315	DAILY	GENERAL MAINTENANCE OF ICT, INCLUDING TAN DELTA TESTING AND ITS BAY EQUIPMENTS.	2018-12-15	09:00	2018-12-15	17:00	8	-
161	DTL	DTL	ICT	ICT06 BAWANA-CCGT (400KV)(DTL)/315	DAILY	GENERAL MAINTENANCE OF ICT AND ITS BAY EQUIPMENTS.	2018-12-19	09:00	2018-12-19	17:00	8	150
162	DTL	DTL	ICT	ICT01 LONI-HARSHVIHAR (400KV)(DTL)/315	DAILY	TAN DELTA TESTING.	2018-12-01	09:00	2018-12-01	13:00	4	-
163	DTL	DTL	ICT	ICT02 LONI-HARSHVIHAR (400KV)(DTL)/315	DAILY	TAN DELTA TESTING.	2018-12-03	09:30	2018-12-03	13:30	4	-
164	DTL	DTL	ICT	ICT03 LONI-HARSHVIHAR (400KV)(DTL)/315	DAILY	TAN DELTA TESTING.	2018-12-04	09:30	2018-12-04	13:30	4	-
165	DTL	DTL	ICT	ICT04 MUNDKA (400KV)(DTL)/315	DAILY	OVERHAULING OF ISOLATOR 416-89T, 415-89B.	2018-12-10	09:30	2018-12-13	17:00	30	152
166	DTL	DTL	ICT	ICT03 MUNDKA (400KV)(DTL)/315	DAILY	OVERHAULING OF ISOLATOR 413-89T, 412-89B.	2018-12-14	09:30	2018-12-17	17:00	30	150
167	DTL	DTL	ICT	ICT02 MUNDKA (400KV)(DTL)/315	CONTINUOUS	INTERNAL INSPECTION OF TRANSFORMER.	2018-12-01	09:30	2018-12-07	18:30	153	152
168	DTL	POWERGRID	ICT	ICT 01 BAWANA-CCGT (400KV)(DTL)/315	DAILY	GENERAL MAINTENANCE OF ICT AND ITS BAY EQUIPMENTS.	2018-12-10	09:00	2018-12-10	17:00	8	147
169	DTL	APCPL	LINE	JHAJJAR-APCPL (400KV)-MUNDKA (400KV)2	DAILY	OVERHAULING OF ISOLATOR 411-89L, 411-89B.	2018-12-18	09:30	2018-12-22	17:00	37.5	151
170	DTL	DTL	LINE	BAMNOLI (400KV)-JHATIKALA (400KV)2	DAILY	FOR BREAKER TESTING (CRM AND TIMING) AND LINE CVT TESTING AS PER PMS.	2018-12-19	09:30	2018-12-19	15:30	6	151
171	DTL	DTL	LINE	BAMNOLI (400KV)-JHATIKALA (400KV)1	DAILY	FOR BREAKER TESTING(CRM AND TIMING) AND LINE CVT TESTING AS PER PMS.	2018-12-20	09:30	2018-12-20	15:30	6	151
172	DTL	DTL	LINE	OKHLA (220KV)-BADARPUR (220KV)1	DAILY	TIGHTENING OF JUMPER AND TREE TRIMMING.	2018-12-09	10:00	2018-12-09	17:00	7	152
173	DTL	DTL	LINE	OKHLA (220KV)-BADARPUR (220KV)2	DAILY	TIGHTENING OF JUMPER AND TREE TRIMMING.	2018-12-16	10:00	2018-12-16	17:00	7	152
174	DTL	DTL	LINE	MUNDKA (400KV)-JHATIKALA (400KV)1	DAILY	OVERHAULING OF ISOLATOR 401-89L, 401-89B.	2018-12-23	09:30	2018-12-27	17:00	37.5	-
175	DTL	DTL	LINE	MUNDKA (400KV)-JHATIKALA (400KV)2	DAILY	OVERHAULING OF ISOLATOR 403-89L, 403-89B.	2018-12-28	09:30	2019-01-01	17:00	37.5	-

176	DTL	DTL	LINE	BADARPUR (220KV)-SARITA VIHAR (220KV)I	DAILY	TREE TRIMMING.	2018-12-05	09:30	2018-12-05	17:30	8	151
177	DTL	DTL	LINE	BADARPUR (220KV)-SARITA VIHAR (220KV)II	DAILY	TREE TRIMMING.	2018-12-06	09:30	2018-12-06	17:30	8	151
178	HVPNL	HVPNL	BUS	400kv Bus-2 D/Bad	DAILY	Erection work of 4th ICT. TIE breaker is defective due to which ICT-2 remain off during the shutdown of Bus-bar-2	2018-12-19	10:00	2018-12-21	17:00	21	152
179	HVPNL	HVPNL	ICT	ICT 01 KIRORI (400KV)(HVPNL)/315	CONTINUOUS	For replacement of defective flexible separator with new	2018-12-03	09:00	2018-12-07	17:00	104	-
180	HVPNL	HVPNL	ICT	ICT02 KIRORI (400KV)(HVPNL)/315	CONTINUOUS	For replacement of defective flexible separator with new	2018-12-10	09:00	2018-12-14	17:00	104	147
181	HVPNL	HVPNL	ICT	ICT01 DAULTABAD (400KV)(HVPNL)/315	DAILY	annual mtc.	2018-12-05	10:00	2018-12-05	17:00	7	150
182	HVPNL	HVPNL	ICT	ICT03 DAULTABAD (400KV)(HVPNL)/315	DAILY	annual mtc	2018-12-10	10:00	2018-12-10	17:00	7	150
183	HVPNL	HVPNL	ICT	ICT02 DAULTABAD (400KV)(HVPNL)/315	DAILY	Erection work of 4th ICT. TIE breaker is defective due to which ICT-2 remain off during the shutdown of Bus-bar-2	2018-12-19	10:00	2018-12-21	17:00	21	152
184	HVPNL	HVPNL	ICT	ICT01 NUHIANWALI (400KV)(HVPNL)/315	DAILY	For gen mtc of T/F and bay equipment.	2018-12-10	10:00	2018-12-10	15:00	5	-
185	HVPNL	HVPNL	ICT	ICT02 NUHIANWALI (400KV)(HVPNL)/315	DAILY	For gen mtc of T/F and bay equipment.	2018-12-12	10:00	2018-12-12	15:00	5	-
186	HVPNL	HVPNL	ICT	ICT02 DEEPALPUR (400KV)(KT JHAJJAR)/315	DAILY	Annual mtc and testing	2018-12-04	10:00	2018-12-04	18:00	8	-
187	HVPNL	APL	LINE	MAHINDERGARH-APL (400KV)-DHANONDA (400KV)1	DAILY	Tan delta testing of line CTs and CVTs & attending the hot spots during thermovision scanning	2018-12-14	10:00	2018-12-14	12:00	2	-
188	HVPNL	HVPNL	LINE	DHANONDA (400KV)-DAULTABAD (400KV)2	DAILY	Tan delta testing of line CTs and CVTs & attending the hot spots during thermovision scanning	2018-12-11	10:00	2018-12-11	13:00	3	152
189	HVPNL	HVPNL	LINE	DHANONDA (400KV)-DAULTABAD (400KV)2	DAILY	Tree cutting and tightening of Nut bolts and mtc/replacement and alignment of isolators.	2018-12-04	10:00	2018-12-04	17:00	7	152
190	HVPNL	HVPNL	LINE	DHANONDA (400KV)-DAULTABAD (400KV)1	DAILY	Tree cutting and tightening of Nut bolts and mtc/replacement and alignment of isolators.	2018-12-11	10:00	2018-12-11	17:00	7	152
191	HVPNL	HVPNL	LINE	KHEDAR (400KV)-NUHIANWALI (400KV)1	DAILY	For disc cleaning of line	2018-12-06	10:00	2018-12-06	17:00	7	152
192	HVPNL	HVPNL	LINE	FATEHABAD PG (400KV)-NUHIANWALI (400KV)	DAILY	For disc cleaning of line	2018-12-13	10:00	2018-12-13	17:00	7	146
193	HVPNL	KT JHAJJAR	LINE	KABULPUR (400KV)-DEEPALPUR (400KV)1	DAILY	Annual mtc.	2018-12-17	10:00	2018-12-17	15:00	5	152

194	HVPLN	KT JHAJJAR	LINE	KABULPUR (400KV)-DEEPALPUR (400KV)2	DAILY	Annual mtc.	2018-12-18	10:00	2018-12-18	15:00	5	152
195	JSW	JSW	LINE	BASPA (400KV)-KARCHAM WANGTOO (400KV)1	CONTINUOUS	Replacement of existing Main-II Distance Protection Relay (EPAC 3000, ALSTOM Make) of 400 kV Baspa- Karcham Wangtoo EHV line with GE T&D make DPR Model: D-60.	2018-12-10	10:00	2018-12-12	17:00	55	152
196	JSW	JSW	LINE	KARCHAM WANGTOO (400KV)-NATHPA-JHAKRI (NJPC) (400KV)1	DAILY	Line maintenance work such as checking of Insulator, cutting of trees, checking / tightening of all bolt & nuts of hardware fittings, dead end jumpers, bundle spacers and terminal conductor of all three phases above waist level between tower no. 42 - 121.	2018-11-22	09:00	2018-12-11	17:30	170	-
197	JSW	JSW	LINE	KARCHAM WANGTOO (400KV)-NATHPA-JHAKRI (NJPC) (400KV)2	DAILY	Line maintenance work such as checking of Insulator, cutting of trees, checking / tightening of all bolt & nuts of hardware fittings, dead end jumpers, bundle spacers and terminal conductor of all three phases above waist level between tower no. 42 - 121.	2018-12-12	09:00	2018-12-27	17:30	136	-
198	K-THDC	RRVPN	BUS	400kV Bus-II at 400KV GSS Bhadla	DAILY	Quarterly Maintenance work	2018-12-28	15:00	2018-12-28	19:00	4	152
199	NHPC	NHPC	BUS	400KV Salal-Bus-A	CONTINUOUS	Shutdown of Transmission lines are required for shifting of Panel of Transmission lines from Control Room, Power House to Switchyard, Control Room and other associated works for implementation of SCADA system.	2018-12-03	09:00	2018-12-08	18:00	129	-
200	NHPC	NHPC	BUS	220KV Salal-Bus-B	CONTINUOUS	Shutdown of Transmission lines are required for shifting of Panel of Transmission lines from Control Room, Power House to Switchyard, Control Room and other associated works for implementation of SCADA system.	2018-12-10	09:00	2018-12-15	18:00	129	151

201	NHPC	NHPC	BUS	400KV BUS I	CONTINUOUS	Shutdown of 400KV Bus-1 is required for installation of repaired CB Poles (3 Nos.) of Bus reactors GIS bay and further its testing.	2018-12-01	09:00	2018-12-10	18:00	225	149
202	NHPC	POWERGRID	LINE	SALAL (220KV)-KISHENPUR (220KV)I	CONTINUOUS	Shutdown of Transmission lines are required for shifting of Panel of Transmission lines from Control Room, Power House to Switchyard, Control Room and other associated works for implementation of SCADA system.	2018-11-19	09:30	2018-11-20	18:30	33	152
203	NHPC	POWERGRID	LINE	SALAL (220KV)-KISHENPUR (220KV)II	CONTINUOUS	Shutdown of Transmission lines are required for shifting of Panel of Transmission lines from Control Room, Power House to Switchyard, Control Room and other associated works for implementation of SCADA system.	2018-11-21	09:30	2018-11-22	18:00	32.5	152
204	NHPC	POWERGRID	LINE	SALAL (220KV)-KISHENPUR (220KV)III	CONTINUOUS	Shutdown of Transmission lines are required for shifting of Panel of Transmission lines from Control Room, Power House to Switchyard, Control Room and other associated works for implementation of SCADA system.	2018-11-23	09:00	2018-11-24	18:00	33	-
205	NHPC	POWERGRID	LINE	SALAL (220KV)-KISHENPUR (220KV)IV	CONTINUOUS	Shutdown of Transmission lines are required for shifting of Panel of Transmission lines from Control Room, Power House to Switchyard, Control Room and other associated works for implementation of SCADA system.	2018-11-26	09:00	2018-11-27	18:00	33	148
206	NHPC	POWERGRID	LINE	SALAL (220KV)-JAMMU(220KV)1	CONTINUOUS	Shutdown of Transmission lines are required for shifting of Panel of Transmission lines from Control Room, Power House to Switchyard, Control Room and other associated works for implementation of SCADA system.	2018-11-28	09:00	2018-11-29	18:00	33	151

207	NHPC	POWERGRID	LINE	SALAL (220KV)-JAMMU(220KV)2	CONTINUOUS	Shutdown of Transmission lines are required for shifting of Panel of Transmission lines from Control Room, Power House to Switchyard, Control Room and other associated works for implementation of SCADA system.	2018-11-30	09:00	2018-12-01	18:00	33	151
208	NRSS-XXIX	NRSS-XXIX	LINE	AMARGARH (400KV)-SAMBA (400KV)1	DAILY	A/R in non Auto Mode,for installation of OPGW in palce of Earth wire.	2018-12-01	08:00	2018-12-31	19:00	341	-
209	NRSS-XXIX	NRSS-XXIX	LINE	AMARGARH (400KV)-SAMBA (400KV)2	DAILY	A/R in non Auto Mode,for installation of OPGW in palce of Earth wire.	2018-12-01	08:00	2018-12-31	19:00	341	-
210	NRSS-XXIX	NRSS-XXIX	LINE	SHUJALPUR-WR (400KV)-RAPP D (400KV)1	DAILY	For AMP Work	2018-12-10	10:00	2018-12-10	18:00	8	150
211	NRSS-XXIX	POWERGRID	LINE	AGRA-PG (400KV)-BALLABGARH-PG (400KV)	DAILY	For Over Head Crossing of 400kV Prithala-Kadarpur line of GPTL	2018-11-24	07:00	2018-11-25	19:00	24	-
212	NRSS-XXIX	POWERGRID	LINE	KANPUR (400KV)-BALLABGARH-PG (400KV)III	DAILY	For Over Head Crossing of 400kV Alighar-Prithala line of GPTL	2018-11-29	07:00	2018-11-30	19:00	24	151
213	NRSS-XXIX	POWERGRID	LINE	KANPUR (400KV)-BALLABGARH-PG (400KV)I	DAILY	For Over Head Crossing of 400kV Alighar-Prithala line of GPTL	2018-11-26	07:00	2018-11-27	19:00	24	-
214	NRSS-XXIX	POWERGRID	LINE	KANPUR (400KV)-BALLABGARH-PG (400KV)II	DAILY	For Over Head Crossing of 400kV Alighar-Prithala line of GPTL	2018-11-26	07:00	2018-11-27	19:00	24	151
215	NTPC	NTPC	BUS	KOLDAM BUS 1	CONTINUOUS	Annual Maintenance & Testing	2018-12-12	09:00	2018-12-12	18:30	9.5	-
216	NTPC	NTPC	BUS	KOLDAM BUS 2	CONTINUOUS	Annual Maintenance & Testing	2018-12-13	09:00	2018-12-13	18:30	9.5	-
217	NTPC	NTPC	BUS	Bus 1 dadri thermal	CONTINUOUS	WORK TO BE DONE ON BUS SECTIONALIZER	2018-12-04	09:30	2018-12-20	18:30	393	151
218	NTPC	PKTCL	LINE	KOLDAM (400KV)-BANALA (400KV)	CONTINUOUS	Annual Maintenance & Testing	2018-12-05	09:00	2018-12-06	17:30	32.5	152
219	NTPC	PKTCL	LINE	KOLDAM (400KV)-LUDHIANA (400KV)1	CONTINUOUS	Annual Maintenance & Testing	2018-12-07	09:00	2018-12-08	17:30	32.5	152
220	NTPC	PKTCL	LINE	KOLDAM (400KV)-LUDHIANA (400KV)2	CONTINUOUS	Annual Maintenance & Testing	2018-12-10	09:00	2018-12-11	17:30	32.5	152
221	NTPC	POWERGRID	LINE	NALLAGARH (400KV)-KOLDAM (400KV)I	CONTINUOUS	Annual Maintenance & Testing	2018-12-03	09:00	2018-12-04	17:30	32.5	152
222	NTPC	POWERGRID	LINE	SINGRAULI NTPC (400KV)-RIHAND NTPC (400KV)II	DAILY	annual PM for two days on daily basis on 6th Dec and 7 th dec 2018. further line to be normalised in Transfer Bus and to be put in transfer bus for 30 minutes.	2018-12-06	08:30	2018-12-07	18:30	20	151

223	NTPC	POWERGRID	LINE	UNCHAHAHAR (220KV)-RAEBAREILLY (220KV)3	CONTINUOUS	1.Bus 1 or Bus 2 shut down required for stability test. 2. Bus bar protection will be out during the period.	2018-12-06	08:30	2018-12-06	18:30	10	151
224	NTPC	POWERGRID	LINE	UNCHAHAHAR (220KV)-BAREILLY-CB GANJ (220KV)II	CONTINUOUS	1.Bus 1 or Bus 2 shut down required for stability test. 2. Bus bar protection will be out during the period.	2018-12-08	08:30	2018-12-08	18:30	10	-
225	NTPC	UPPTCL	LINE	AURAIYA-UP (220KV)-MEHGAON MPSEB-WR (220KV)+MPPT	DAILY	Mntc of Bay equipment's & Testing	2018-12-10	08:30	2018-12-10	18:30	10	-
226	NTPC	UPPTCL	LINE	AURAIYA-UP (220KV)-MEHGAON MPSEB-WR (220KV)+MPPT	DAILY	Mntc of bay equipment's & testing.	2018-12-11	08:30	2018-12-11	18:30	10	-
227	NTPC	UPPTCL	LINE	TANDA (220KV)-BASTI (220KV)	CONTINUOUS	Annual maintenance and testing of Bay Equipments	2018-12-04	08:30	2018-12-05	18:30	34	146
228	NTPC	UPPTCL	LINE	UNCHAHAHAR (220KV)-RAEBAREILLY (220KV)1	CONTINUOUS	1.Bus 1 or Bus 2 shut down required for stability test. 2. Bus bar protection will be out during the period.	2018-12-04	08:30	2018-12-04	18:30	10	152
229	NTPC	UPPTCL	LINE	UNCHAHAHAR (220KV)-RAEBAREILLY (220KV)2	CONTINUOUS	1.Bus 1 or Bus 2 shut down required for stability test. 2. Bus bar protection will be out during the period.	2018-12-05	08:30	2018-12-05	18:30	10	152
230	NTPC	UPPTCL	LINE	UNCHAHAHAR (220KV)-FATEHPUR-UP (220KV)1	CONTINUOUS	1.Bus 1 or Bus 2 shut down required for stability test. 2. Bus bar protection will be out during the period.	2018-12-07	08:30	2018-12-07	18:30	10	-
231	POWERGRID	POWERGRID	BAY	703 BAY (Main bay of 1500 MVA ICT-1),at fatehpur	DAILY	AMP and Tightening Work	2018-12-04	09:30	2018-12-04	18:00	8.5	-
232	POWERGRID	POWERGRID	BAY	703 Bay, (ICT-1 Main Bay), at Lucknow	DAILY	For AMP Work	2018-12-06	09:00	2018-12-07	18:00	18	151
233	POWERGRID	POWERGRID	BAY	400 KV T/BAY 417 ROORKEE	DAILY	POLYMER INSULATOR REPLACEMENT.	2018-12-03	09:00	2018-12-03	14:00	5	-
234	POWERGRID	POWERGRID	BAY	400 KV M/BAY 418 ROORKEE	DAILY	POLYMER INSULATOR REPLACEMENT.	2018-12-03	09:00	2018-12-03	14:00	5	-
235	POWERGRID	POWERGRID	BAY	400KV ICT-II M/BAY 412 KOTA	CONTINUOUS	Pneumatic drive overhauling	2018-12-10	09:30	2018-12-12	18:30	57	150
236	POWERGRID	POWERGRID	BAY	220 KV ICT-II M/BAY 203 KOTA	CONTINUOUS	PNEUMATIC DRIVE OVERHAULING.	2018-12-13	09:00	2018-12-15	18:00	57	-
237	POWERGRID	POWERGRID	BAY	400 KV RAPPD M/BAY 407 KOTA	DAILY	AMP OF CB, CT	2018-12-17	09:00	2018-12-17	18:00	9	-
238	POWERGRID	POWERGRID	BAY	400 KV ANTA M/BAY 413 KOTA	DAILY	AMP OF CB, CT	2018-12-18	09:00	2018-12-18	18:00	9	-
239	POWERGRID	POWERGRID	BAY	400KV ANTA T/BAY (414) KOTA	DAILY	AMP OF CB, CT	2018-12-18	09:00	2018-12-18	18:00	9	-
240	POWERGRID	POWERGRID	BAY	400KV B/R -I M/BAY 403 BASSI	CONTINUOUS	For CT replacement work	2018-12-26	09:00	2018-12-28	18:00	57	150
241	POWERGRID	POWERGRID	BAY	Ballabgarh-1 Main Bay at Kanpur	DAILY	CB Retrofitment work under CERC Add Cap	2018-12-01	09:00	2018-12-15	17:00	120	-

242	POWERGRID	POWERGRID	BAY	CB of 400 kV Gorakhpur(PG)-Gorakhpur (UP) Line-1 Bay	CONTINUOUS	For SF6 Gas leakage Arrest in Main Bay R Pole CB for 400 kV GKP UPPTCL Line 1	2018-12-26	09:00	2018-12-28	17:30	56.5	150
243	POWERGRID	POWERGRID	BAY	PANKI-I MAIN BAY at UPPCL end	DAILY	AMP works. DMT Scheme is at Panki UPPCL) End	2018-12-03	09:00	2018-12-03	18:00	9	151
244	POWERGRID	POWERGRID	BUS	220 KV Bus-I at Abdullapur	DAILY	For AMP Works.	2018-12-10	09:00	2018-12-11	17:00	16	151
245	POWERGRID	POWERGRID	BUS	220 KV Bus-II at Abdullapur	DAILY	For AMP Works.	2018-12-12	09:00	2018-12-13	17:00	16	151
246	POWERGRID	POWERGRID	BUS	BUS-II 220 KV AT KOTA	DAILY	REPLACEMENT OF PORCELAIN INSULATORS WITH POLYMER INSULATORS .	2018-12-03	09:00	2018-12-08	18:00	54	-
247	POWERGRID	POWERGRID	BUS	BUS-I AT 400 KV KOTA	DAILY	REPLACEMENT OF PORCELAIN INSULATORS WITH POLYMER INSULATORS .	2018-12-09	09:00	2018-12-09	18:00	9	150
248	POWERGRID	POWERGRID	BUS	400KV BUS-I BASSI	CONTINUOUS	INSULATOR REPLACEMENT IN SWITCHYARD OF BASSI S/S.	2018-12-17	09:00	2018-12-19	18:00	57	150
249	POWERGRID	POWERGRID	BUS	400KV BUS-II KOTA	CONTINUOUS	INSULATOR REPLACEMENT IN SWITCHYARD OF BASSI S/S.	2018-12-20	09:00	2018-12-22	19:00	58	150
250	POWERGRID	POWERGRID	BUS	400KV BUS-I CHIOTRGARH PG	DAILY	AMP OF BUS-I	2018-12-10	09:30	2018-12-11	18:30	18	-
251	POWERGRID	POWERGRID	BUS	400KV BUS-II CHIOTRGARH PG	DAILY	AMP OF BUS-II	2018-12-12	09:00	2018-12-13	18:00	18	-
252	POWERGRID	POWERGRID	BUS	BUS-I	DAILY	For replacement of Porcelain insulators by Polymer insulators at bhiwadi	2018-12-03	09:30	2018-12-05	18:30	27	152
253	POWERGRID	POWERGRID	BUS	BUS-II	DAILY	For replacement of Porcelain insulators by Polymer insulators at bhiwadi	2018-12-07	09:30	2018-12-09	18:30	27	152
254	POWERGRID	POWERGRID	BUS	BUS-I AT 400KV SIKAR	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-12	09:00	2018-12-21	18:00	90	151
255	POWERGRID	POWERGRID	BUS	BUS-II AT 400KV SIKAR	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-03	09:00	2018-12-06	18:00	36	151
256	POWERGRID	POWERGRID	BUS	BUS-I AT 220KV SIKAR PG	DAILY	Final Busbar/LBB Relay testing for pending defects under augmentation scheme of 02 no. of 220 kV Line bays at Sikar s/S	2018-12-25	08:00	2018-12-26	18:00	20	151
257	POWERGRID	POWERGRID	BUS	BUS-II AT 220KV SIKAR	DAILY	Final Busbar/LBB Relay testing for pending defects under augmentation scheme of 02 no. of 220 kV Line bays at Sikar s/S	2018-12-27	08:00	2018-12-28	18:00	20	151
258	POWERGRID	POWERGRID	BUS	220 KV Bus I Mandola	DAILY	For AMP works	2018-12-05	09:00	2018-12-05	18:00	9	-
259	POWERGRID	POWERGRID	BUS	220 KV Bus II Mandola	DAILY	For AMP works	2018-12-06	09:00	2018-12-06	18:00	9	145
260	POWERGRID	POWERGRID	BUS	220 KV Bus III Mandola	DAILY	For AMP works	2018-12-07	09:00	2018-12-07	18:00	9	145
261	POWERGRID	POWERGRID	BUS	220 KV Bus IV Mandola	DAILY	For AMP works	2018-12-08	09:00	2018-12-08	18:00	9	145



262	POWERGRID	POWERGRID	BUS	BUS-2,at Kanpur	DAILY	AMP WORK	2018-12-05	09:00	2018-12-05	17:00	8	-
263	POWERGRID	POWERGRID	BUS	Bus-2, at Lucknow	DAILY	AMP OF WORK	2018-12-11	10:00	2018-12-11	18:00	8	152
264	POWERGRID	POWERGRID	BUS	Bus-1 at AGRA	DAILY	For repalcment of Jack Bus above 400kV Bus-1	2018-12-11	09:00	2018-12-12	18:00	18	152
265	POWERGRID	POWERGRID	BUS	400kV Bus-2 at AGRA	DAILY	For repalcment of Jack Bus above 400kV Bus-2	2018-12-13	09:00	2018-12-14	18:00	18	152
266	POWERGRID	POWERGRID	BUS	220 KV BUS-1 , at Allahabad	DAILY	REPLACEMENT OF BUS ISOLATORS , at Allahabad	2018-12-03	08:00	2018-12-04	18:00	20	150
267	POWERGRID	POWERGRID	BUS	220KV BUS -2 , at Allahabad	DAILY	REPLACEMENT OF BUS ISOLATORS. at Allahabad	2018-12-06	08:00	2018-12-07	18:00	20	150
268	POWERGRID	POWERGRID	BUS	220KV Bus -1, at Mainpuri S/S (PG)	DAILY	AMP work & replacement of B Ph CVT	2018-12-06	09:00	2018-12-06	18:00	9	-
269	POWERGRID	POWERGRID	BUS	220 KV BUS-I at Jalandhar	DAILY	For retrofitting of Bus Bar protection relay as existing relay has no scope for extension.	2018-12-03	09:30	2018-12-04	17:30	16	150
270	POWERGRID	POWERGRID	BUS	220 KV BUS-II at Jalandhar	DAILY	For retrofitting of Bus Bar protection relay as existing relay has no scope for extension.	2018-12-05	09:30	2018-12-06	17:30	16	150
271	POWERGRID	POWERGRID	BUS	220KV Bus-1 at Powergrid, Sitarganj	DAILY	The commissioning of ICT-3 and its associated bays at 220/132 kv substation Sitarganj is in progress. So shut down is required for 220 kv Bus-1 for erection and of Jack bus and IPS tube..	2018-11-25	08:00	2018-11-26	18:00	20	-
272	POWERGRID	POWERGRID	BUS	220KV Bus-2 at Powergrid,Sitarganj	DAILY	The commissioning of ICT-3 and its associated bays at 220/132 kv substation Powergrid, Sitarganj is in progress. So shut down is required for 220 kv Bus -2 also for erection of Jack bus and IPS tube.	2018-11-25	08:00	2018-11-26	18:00	20	-
273	POWERGRID	RRVFN	BUS	400 kV MAIN BUS-A AT 400 kV CHITTORGARH	DAILY	AMP of Bus & All equipment and line will remain in service 765KV Bus-II	2018-12-10	09:30	2018-12-11	18:30	18	150
274	POWERGRID	POWERGRID	FACT	TCSC-FSC System for 400 kV Gkp Mzp Line -1	DAILY	For Annual Capacitance Measurement of TCSC & FSC System and Other AMP activities for other equipments including Timing/DCRM of Bypass CB's, Cleaning of Thyristor, Insulators etc.	2018-12-03	09:00	2018-12-05	17:30	25.5	-

275	POWERGRID	POWERGRID	FACT	TCSC-FSC System for 400 kV Gkp Mzp Line II	DAILY	For Annual Capacitance Measurement of TCSC & FSC System and Other AMP activities for other equipments including Timing/DCRM of Bypass CB's, Cleaning of Thyristor, Insulators etc.	2018-12-06	09:00	2018-12-08	17:30	25.5	-
276	POWERGRID	APL	HVDC	ADANI MUNDRA-MAHINDERGARH POLE-1/500	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 24/0-25/0) at 500 kV HVDC Mundra-Mahendranagar (Adani Power Limited) Line location no 1896-1897.	2018-12-20	09:30	2018-12-21	18:30	18	152
277	POWERGRID	APL	HVDC	ADANI MUNDRA-MAHINDERGARH POLE-2/500	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 24/0-25/0) at 500 kV HVDC Mundra-Mahendranagar (Adani Power Limited) Line location no 1896-1897.	2018-12-20	09:00	2018-12-21	18:00	18	147
278	POWERGRID	POWERGRID	HVDC	BALIA-BHIWADI POLE-1/500	DAILY	FOR RTV Coating	2018-12-08	08:30	2018-12-10	18:30	30	-
279	POWERGRID	POWERGRID	HVDC	BALIA-BHIWADI POLE-2/500	DAILY	FOR RTV Coating	2018-12-11	08:00	2018-12-13	18:00	30	152
280	POWERGRID	BBMB	ICT	ICT DEHAR (400KV)(BBMB)/315	DAILY	For AMP works.	2018-12-04	09:30	2018-12-04	17:30	8	151
281	POWERGRID	POWERGRID	ICT	ICT01 NALLAGARH (400KV)(POWERGRID)/315	DAILY	For AMP Works.	2018-12-04	10:00	2018-12-04	17:00	7	151
282	POWERGRID	POWERGRID	ICT	ICT02 NALLAGARH (400KV)(POWERGRID)/315	DAILY	For AMP Works.	2018-12-05	10:00	2018-12-05	17:00	7	151
283	POWERGRID	POWERGRID	ICT	ICT03 NALLAGARH (400KV)(POWERGRID)/315	DAILY	For AMP Works.	2018-12-06	10:00	2018-12-06	17:00	7	-
284	POWERGRID	POWERGRID	ICT	ICT01 KOTA (400KV)(POWERGRID)/315	DAILY	REPLACEMENT OF PORCELAIN INSULATORS WITH POLYMER INSULATORS .	2018-12-03	09:00	2018-12-08	18:00	54	150
285	POWERGRID	POWERGRID	ICT	ICT01 BASSI (400KV)(POWERGRID)/315	DAILY	INSULATOR REPLACEMENT IN SWITCHYARD OF BASSI S/S.	2018-12-14	09:00	2018-12-14	17:30	8.5	151
286	POWERGRID	POWERGRID	ICT	ICT02 BASSI (400KV)(POWERGRID)/315	DAILY	INSULATOR REPLACEMENT IN SWITCHYARD OF BASSI S/S.	2018-12-15	09:00	2018-12-15	17:30	8.5	151
287	POWERGRID	POWERGRID	ICT	ICT03 BASSI (400KV)(POWERGRID)/500	DAILY	INSULATOR REPLACEMENT IN SWITCHYARD OF BASSI S/S.	2018-12-24	09:00	2018-12-24	17:30	8.5	151
288	POWERGRID	POWERGRID	ICT	ICT-I CHITORGARH/1500	DAILY	AMP of ICT Bank.ICT bank Will be OUT of Service during AMP period	2018-12-03	09:30	2018-12-05	18:30	27	148

289	POWERGRID	POWERGRID	ICT	ICT-II CHITORGARH/1500	DAILY	AMP of ICT Bank.ICT bank Will be OUT of Service during AMP period	2018-12-06	09:00	2018-12-08	18:00	27	151
290	POWERGRID	POWERGRID	ICT	ICT02 ROORKEE (400KV)(POWERGRID)/315	DAILY	Polymer Insulator Replacement in place of Existing Porcelain Insulator	2018-12-05	09:00	2018-12-05	18:00	9	-
291	POWERGRID	POWERGRID	ICT	ICT01 ROORKEE (400KV)(POWERGRID)/315	DAILY	Polymer Insulator Replacement in place of Existing Porcelain Insulator	2018-12-06	09:00	2018-12-06	18:00	9	-
292	POWERGRID	POWERGRID	ICT	ICT02 KOTA (400KV)(POWERGRID)/315	DAILY	Replacement of Porcelain Insulators with Polymer Insulators	2018-12-03	09:30	2018-12-08	18:30	54	150
293	POWERGRID	POWERGRID	ICT	ICT01 BHIWADI-PG (400KV)(POWERGRID)/315	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-07	09:30	2018-12-07	13:30	4	150
294	POWERGRID	POWERGRID	ICT	ICT02 BHIWADI-PG (400KV)(POWERGRID)/315	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-07	14:00	2018-12-07	18:00	4	152
295	POWERGRID	POWERGRID	ICT	ICT03 BHIWADI-PG (400KV)(POWERGRID)/315	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-08	09:00	2018-12-08	13:00	4	150
296	POWERGRID	POWERGRID	ICT	ICT01 BHINMAL (400KV)(POWERGRID)/315	DAILY	AMP WORK	2018-12-13	09:00	2018-12-13	18:00	9	-
297	POWERGRID	POWERGRID	ICT	ICT02 BHINMAL (400KV)(POWERGRID)/315	DAILY	AMP WORK	2018-12-14	09:00	2018-12-14	18:00	9	152
298	POWERGRID	POWERGRID	ICT	ICT01 SIKAR (400KV)(POWERGRID)/315	DAILY	Replacement of Porcelain Insulators with Polymer Insulators & Final testing/commissioning of Impedance relay of ICT at 400 KV Sikar S/s	2018-12-03	09:00	2018-12-03	18:00	9	151
299	POWERGRID	POWERGRID	ICT	ICT02 SIKAR (400KV)(POWERGRID)/315	DAILY	Replacement of Porcelain Insulators with Polymer Insulators & Final testing/commissioning of Impedance relay of ICT at 400 KV Sikar S/s	2018-12-04	09:00	2018-12-04	17:00	8	151
300	POWERGRID	POWERGRID	ICT	ICT-3 SIKAR/500	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s & Impedance relay & CSD relay testing of MAIN bay of ICT-3	2018-12-05	09:00	2018-12-06	18:00	18	152

301	POWERGRID	POWERGRID	ICT	ICT04 MANDOLA (220KV)(POWERGRID)/500	CONTINUOUS	Replacement of ICT-4 Line Isolator (415-89L, retrofitment RK make isolators with new 400 KV Isolator)	2018-12-10	08:00	2018-12-12	18:00	58	146
302	POWERGRID	POWERGRID	ICT	ICT02 MANDOLA (220KV)(POWERGRID)/500	CONTINUOUS	Replacement of ICT-2Line Isolator (413-89L, retrofitment RK make isolators with new 400 KV Isolator)	2018-12-13	08:00	2018-12-15	18:00	58	150
303	POWERGRID	POWERGRID	ICT	ICT-2 KANPUR 400 KV/315 MVA	CONTINUOUS	For LV Bushing (Y Ph) replacement work	2018-11-25	09:00	2018-11-27	17:00	56	-
304	POWERGRID	POWERGRID	ICT	ICT01 MALERKOTLA (400KV)(POWERGRID)/315	CONTINUOUS	For replacement of 220 kV CB. CB is 29 years old and giving frequent problems.	2018-12-04	09:30	2018-12-08	17:30	104	151
305	POWERGRID	POWERGRID	ICT	ICT02 WAGOORA (400KV)(POWERGRID)/315	DAILY	For AMP and canopy installation over PRD.	2018-12-06	09:30	2018-12-06	15:30	6	152
306	POWERGRID	POWERGRID	ICT	ICT02 GORAKHPUR-PG (400KV)(POWERGRID)/315	DAILY	AMP of 315 MVA ICT 2 (For replacement of B phase IV Bushing of 245 kV rating due to violation in Tan delta as per O&M Norms )	2018-11-25	09:00	2018-11-27	17:00	24	151
307	POWERGRID	APL	LINE	BIKANER (400KV)-DEEDWANA (400KV)	DAILY	Stringing of work of 765kv D/C Ajmer-Bikaner TL part IV bet Tower no-75/0 & 76/0	2018-11-18	10:51	2018-11-19	10:51	0	150
308	POWERGRID	BBMB	LINE	DEHAR (400KV)-PANCHKULA-PG (400KV)	DAILY	Rectification of open CC ring, S/damper, Jumper Tightening etc. (Shutdown of both Ckts. (400 KV Patiala - Panchkula Ckt.-I & 400 KV Dehar - Panchkula) required on same date as work to be done on Multi-Ckt. Towers)	2018-12-07	08:00	2018-12-07	17:00	9	152
309	POWERGRID	BBMB	LINE	PANCHKULA-PG (400KV)-PANIPAT BBMB (400KV)	DAILY	Rectification of open CC ring, S/damper, Jumper Tightening etc. (Shutdown of both Ckts. (400 KV Patiala - Panchkula Ckt.-II & 400 KV Panchkula-Panipat) required on same date as work to be done on Multi-Ckt. Towers)	2018-12-08	08:00	2018-12-08	17:00	9	152
310	POWERGRID	DTL	LINE	MANDOLA (400KV)-BAWANA-DTL (400KV)2	DAILY	For Porcelain insulator replacement of Bawana-2 bay at Mandola SS	2018-12-19	08:00	2018-12-20	18:00	20	151

311	POWERGRID	DTL	LINE	MANDOLA (400KV)-BAWANA-DTL (400KV)1	DAILY	For Porcelain insulator replacement of Bawana-1 bay at Mandola SS	2018-12-17	09:00	2018-12-18	18:00	18	151
312	POWERGRID	HVPNL	LINE	DHANONDA (400KV)-DAULTABAD (400KV)1	DAILY	For diversion work of 765 KV Agra-jhatikara line as this line is infringing the land which was acquired by HSIIDC for setting up a Sewerage Treatment Plant.	2018-12-09	09:00	2018-12-15	19:00	70	152
313	POWERGRID	HVPNL	LINE	DHANONDA (400KV)-DAULTABAD (400KV)2	CONTINUOUS	For diversion work of 765 KV Agra-jhatikara line as this line is infringing the land which was acquired by HSIIDC for setting up a Sewerage Treatment Plant.	2018-12-09	09:00	2018-12-15	19:00	154	152
314	POWERGRID	HVPNL	LINE	DAULTABAD (400KV)-JHAJJAR-APCPL (400KV)1	CONTINUOUS	For diversion work of 765 KV Agra-Jhatikra line as this line is infringing the Land which was acquired by HSIIDC for setting up a Sewerage Treatment Plant	2018-12-09	09:30	2018-12-15	18:30	153	152
315	POWERGRID	HVPNL	LINE	DAULTABAD (400KV)-JHAJJAR-APCPL (400KV)2	CONTINUOUS	For diversion work of 765 KV Agra-Jhatikra line as this line is infringing the Land which was acquired by HSIIDC for setting up a Sewerage Treatment Plant	2018-12-09	09:00	2018-12-15	18:00	153	152
316	POWERGRID	JKPDD	LINE	HIRANAGAR(220KV)-SARNA (220KV)	CONTINUOUS	For erection and shifting of conductor to new tower at location no. 66 of the line. Tower foundation severely damaged due to change in river flow. Line needs to be shifted to new tower.	2018-12-03	09:30	2018-12-07	18:00	105	151
317	POWERGRID	NRSS-XXIX	LINE	AMARGARH (400KV)-WAGOORA (400KV)1	DAILY	For AMP Works.	2018-12-03	10:00	2018-12-03	17:00	7	-
318	POWERGRID	NRSS-XXIX	LINE	AMARGARH (400KV)-WAGOORA (400KV)2	DAILY	For AMP Works.	2018-12-04	10:00	2018-12-04	17:00	7	-

319	POWERGRID	NTPC	LINE	VINDHYACHAL (400KV)-VINDHYACHAL HVDCFD-1	CONTINUOUS	<p>Retrofitment of Pantograph Isolators under Add. Cap. Scheme at Powergrid ,HVDC,BTB Station.</p> <p>N.B- HVDC Block#2 is already out of service due to failure of Transformer and HVDC Block#1 outage is approved for a period of 08 days and shall be availed from 26.11.18 to 03.12.18 for Overhauling works of OLTC. During this period , no POWERFLOW will be available through Vindhaychal. Further, meanwhile Retrofitment of PG isolator is started now. As during the above mentioned period , and as such no power flow is available and line and feeders are in float only. Therefore approved outage may be utilized as opportunity outage to carry out the Retrofitment of isolators under ADD -CAP.</p>	2018-11-26	09:30	2018-12-03	18:30	177	-
-----	-----------	------	------	---	------------	--	------------	-------	------------	-------	-----	---

320	POWERGRID	NTPC	LINE	VINDHYACHAL (400KV)-VINDHYACHAL HVDCFD-2	CONTINUOUS	Retrofitment of Bus Pantograph Isolators under Add.Cap.Scheme at Powergrid,HVDC,Vindhyachal ,BTB Station.  N.B=HVDC Block#2 is already out of service due to failure of Transformer and HVDC Block#1 outage is approved for a period of 08 days and shall be availed from 26.11.18 to 03.12.18 for Overhauling works of OLTC. During this period , no POWERFLOW will be available through Vindhaychal. Further, meanwhile Retrofitment of PG isolator is started now. As during the above mentioned period , and as such no power flow is available and line and feeders are in float only. Therefore approved outage may be utilized as opportunity outage to carry out the Retrofitment of isolators under ADD -CAP.	2018-11-26	09:00	2018-12-03	21:00	180	-
321	POWERGRID	PKTCL	LINE	KOLDAM (400KV)-BANALA (400KV)	DAILY	For testing of operation after remote integration at RTAMC control Center.	2018-12-06	10:30	2018-12-06	11:00	0.5	152
322	POWERGRID	PKTCL	LINE	NALLAGARH (400KV)-BANALA (400KV)	DAILY	For testing of operation after remote integration at RTAMC control Center.	2018-12-05	10:30	2018-12-05	11:00	0.5	-
323	POWERGRID	PKTCL	LINE	PARBATI-2 (400KV)-ParbatiPooling-BANALA (400KV)1	DAILY	For testing of operation after remote integration at RTAMC control Center.	2018-12-03	10:30	2018-12-03	11:00	0.5	-
324	POWERGRID	PKTCL	LINE	PARBATI-3 (400KV)-ParbatiPooling-BANALA (400KV)2	DAILY	For testing of operation after remote integration at RTAMC control Center.	2018-12-04	10:30	2018-12-04	11:00	0.5	147
325	POWERGRID	POWERGRID	LINE	SASARAM-ER (400KV)-VARANASI (400KV)	DAILY	CLEANING OF PORCELAIN DISC INSULATORS	2018-11-17	08:00	2018-11-18	18:00	20	-
326	POWERGRID	POWERGRID	LINE	MEERUT (400KV)-BAREILLY-PG (400KV)2	DAILY	AMP OF LINE BAY EQUIPMENTS.	2018-12-17	10:00	2018-12-17	17:00	7	152

327	POWERGRID	POWERGRID	LINE	BALIA(400KV)-BIHARSHARIF-ER (400KV)I	DAILY	For replacement of 03 nos(R,Y,B) Bushing with RIP Bushing of 400KV 63MVAR Line Reactor of Ballia-Biharsarif-1 line	2018-12-06	09:00	2018-12-07	18:00	18	150
328	POWERGRID	POWERGRID	LINE	PATIALA (400KV)-LUDHIANA (400KV)I	DAILY	For AMP Works.	2018-12-25	09:00	2018-12-25	17:00	8	148
329	POWERGRID	POWERGRID	LINE	PATIALA (400KV)-LUDHIANA (400KV)II	DAILY	For AMP Works.	2018-12-26	09:00	2018-12-26	17:00	8	145
330	POWERGRID	POWERGRID	LINE	LUDHIANA (400KV)-MALERKOTLA (400KV)	DAILY	For AMP Works.	2018-12-28	09:00	2018-12-28	17:00	8	-
331	POWERGRID	POWERGRID	LINE	MALERKOTLA (400KV)-PATIALA (400KV)	DAILY	For Fixing of loose/damaged grading Rings of Polymer Insulators & loose spacer damper.	2018-12-18	09:00	2018-12-18	17:00	8	-
332	POWERGRID	POWERGRID	LINE	AMRITSAR (400KV)-MALERKOTLA (400KV)1	DAILY	For Re-Orientation of corona rings & Jumper Tightening at Gantry.	2018-12-10	11:00	2018-12-10	14:00	3	-
333	POWERGRID	POWERGRID	LINE	AMRITSAR (400KV)-MALERKOTLA (400KV)2	DAILY	For Re-Orientation of corona rings & Jumper Tightening at Gantry at Malerkotla.	2018-12-10	15:00	2018-12-10	18:00	3	-
334	POWERGRID	POWERGRID	LINE	KURUKSHETRA-PG (400KV)-MALERKOTLA (400KV)1	DAILY	For Re-Orientation of corona rings & Jumper Tightening at Gantry at Malerkotla.	2018-12-11	11:00	2018-12-11	14:00	3	-
335	POWERGRID	POWERGRID	LINE	KURUKSHETRA-PG (400KV)-MALERKOTLA (400KV)2	DAILY	For Re-Orientation of corona rings & Jumper Tightening at Gantry at Malerkotla.	2018-12-11	15:00	2018-12-11	18:00	3	-
336	POWERGRID	POWERGRID	LINE	PATIALA (400KV)-PATRAN (400KV)I	DAILY	AMP and Line Maintenance work.	2018-12-03	08:00	2018-12-03	17:00	9	-
337	POWERGRID	POWERGRID	LINE	PATIALA (400KV)-PATRAN (400KV)II	DAILY	AMP and Line Maintenance work.	2018-12-04	08:00	2018-12-04	17:00	9	-
338	POWERGRID	POWERGRID	LINE	KAITHAL (400KV)-PATRAN (400KV)I	DAILY	AMP and Line Maintenance work.	2018-12-05	08:00	2018-12-05	17:00	9	-
339	POWERGRID	POWERGRID	LINE	KAITHAL (400KV)-PATRAN (400KV)II	DAILY	AMP and Line Maintenance work.	2018-12-06	08:00	2018-12-06	17:00	9	-
340	POWERGRID	POWERGRID	LINE	PATIALA (400KV)-PANCHKULA-PG (400KV)I	DAILY	Rectification of open CC ring, S/damper, Jumper Tightening etc. (Shutdown of both Ckts. (400 KV Patiala - Panchkula Ckt.-I & 400 KV Dehar - Panchkula) required on same date as work to be done on Multi-Ckt. Towers)	2018-12-07	08:00	2018-12-07	17:00	9	-



341	POWERGRID	POWERGRID	LINE	PATIALA (400KV)-PANCHKULA-PG (400KV)II	DAILY	Rectification of open CC ring, S/damper, Jumper Tightening etc. (Shutdown of both Ckts. (400 KV Patiala - Panchkula Ckt.-II & 400 KV Panchkula-Panipat) required on same date as work to be done on Multi-Ckt. Towers)	2018-12-08	08:00	2018-12-08	17:00	9	-
342	POWERGRID	POWERGRID	LINE	URI-2 (400KV)-WAGOORA (400KV)	DAILY	For AMP Works.	2018-12-05	10:00	2018-12-05	17:00	7	148
343	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-MORADABAD (400KV)I	DAILY	Insulators Cleaning work at Polluted stretch	2018-11-22	09:00	2018-11-22	18:00	9	149
344	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-MORADABAD (400KV)II	DAILY	Insulators Cleaning work at Polluted stretch	2018-11-23	09:00	2018-11-23	18:00	9	-
345	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-FATEHPUR -PG (400KV)I	CONTINUOUS	Diversion of 400 KV S/C Fatehpur-Kanpur-II TL between Tower Loc. No. 02 and 03 due to Construction of NH Bypass by NHAI	2018-12-17	08:00	2018-12-21	18:00	106	152
346	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-KANPUR (400KV)	CONTINUOUS	Diversion of 400 KV S/C Allahabad-Kanpur TL between Tower Loc. No. 890 and 894 due to Construction of NH Bypass by NHAI	2018-12-24	08:00	2018-12-30	18:00	154	151
347	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-FATEHPUR -PG (400KV)	DAILY	For taking out 80 MVAR Singrauli Line Reactor for internal Inspections due to rising trend of fault gases (C2H2),at Fatehpur ( S/D for 30 Minute from 10:00 Hrs) For taking 80 MVAR Singrauli Line Reactor into service after internal Inspections due to rising trend of fault gases (C2H2) ( S/D for 30 Minute from 17:00 Hrs), at Fatehpur	2018-12-17	10:00	2018-12-17	18:00	8	151
348	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)I	DAILY	For insulator cleaning and Other maintenance work	2018-11-21	08:00	2018-11-21	18:00	10	152
349	POWERGRID	POWERGRID	LINE	MEERUT (400KV)-KOTESHWAR (400KV)1	DAILY	Insulator Cleaning	2018-11-24	08:30	2018-11-26	18:30	30	-
350	POWERGRID	POWERGRID	LINE	MEERUT (400KV)-KOTESHWAR (400KV)2	DAILY	Insulator Cleaning	2018-11-27	08:00	2018-11-29	18:00	30	-
351	POWERGRID	POWERGRID	LINE	BHINMAL (400KV)-ZERDA-WR (400KV)	DAILY	To attend Nature defect rectification work by bhinmal	2018-12-11	08:30	2018-12-15	18:30	50	152

352	POWERGRID	POWERGRID	LINE	BASSI (400KV)-HEERAPURA (400KV)I	CONTINUOUS	Diversion of Line due to Construction of RING ROAD by NHAI	2018-12-01	08:00	2018-12-08	18:00	178	152
353	POWERGRID	POWERGRID	LINE	BASSI (400KV)-HEERAPURA (400KV)II	CONTINUOUS	Diversion of Line due to Construction of RING ROAD by NHAI	2018-12-09	08:00	2018-12-16	18:00	178	152
354	POWERGRID	POWERGRID	LINE	BASSI (400KV)-PHAGI(400KV)I	DAILY	INSULATOR REPLACEMENT WORK.	2018-12-10	08:00	2018-12-10	18:00	10	152
355	POWERGRID	POWERGRID	LINE	BASSI (400KV)-PHAGI(400KV)II	DAILY	INSULATOR REPLACEMENT WORK	2018-12-11	08:00	2018-12-11	18:00	10	152
356	POWERGRID	POWERGRID	LINE	BASSI (220KV)-BAGRU (220KV)	DAILY	Diversion of Line due to Construction of RING ROAD by NHAI.	2018-12-17	08:00	2018-12-24	18:00	80	152
357	POWERGRID	POWERGRID	LINE	BASSI (220KV)-INDIRA(IG) NAGAR (220KV)	CONTINUOUS	Diversion of Line due to Construction of RING ROAD by NHAI.	2018-12-17	08:00	2018-12-24	18:00	178	152
358	POWERGRID	POWERGRID	LINE	ROORKEE (400KV)-KASHIPUR (400KV)I	DAILY	Polymer Insulator Replacement inplace of Existing Porcelain Insulator	2018-12-08	09:00	2018-12-08	14:00	5	151
359	POWERGRID	POWERGRID	LINE	ROORKEE (400KV)-KASHIPUR (400KV)II	DAILY	Polymer Insulator Replacement inplace of Existing Porcelain Insulator	2018-12-08	14:00	2018-12-08	19:00	5	151
360	POWERGRID	POWERGRID	LINE	ROORKEE (400KV)-DEHRADUN (400KV)	DAILY	Polymer Insulator Replacement inplace of Existing Porcelain Insulator	2018-12-10	09:00	2018-12-10	14:00	5	-
361	POWERGRID	POWERGRID	LINE	ROORKEE (400KV)-SAHARANPUR (400KV)1	DAILY	Polymer Insulator Replacement inplace of Existing Porcelain Insulator	2018-12-10	14:00	2018-12-10	19:00	5	146
362	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)II	DAILY	For insulator cleaning and Other maintenance work	2018-11-23	08:00	2018-11-24	18:00	20	152
363	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-Meja-NTPC (400KV)1	DAILY	For insulator cleaning and Other maintenance work	2018-11-29	08:00	2018-11-29	18:00	10	-
364	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-Meja-NTPC (400KV)2	DAILY	For insulator cleaning and Other maintenance work	2018-11-30	08:00	2018-11-30	18:00	10	-
365	POWERGRID	POWERGRID	LINE	ALLAHABAD-PHULPUR (220KV)-REWA ROAD (220KV)1	CONTINUOUS	For Diversion work due to DFCCII railway Track	2018-12-01	08:00	2018-12-05	18:00	106	149
366	POWERGRID	POWERGRID	LINE	ALLAHABAD-PHULPUR (220KV)-REWA ROAD (220KV)2	CONTINUOUS	For Diversion work due to DFCCII railway Track	2018-12-06	08:00	2018-12-10	18:00	106	149
367	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-VARANASI (400KV)	DAILY	For insulator cleaning and Other maintenance work	2018-11-27	08:00	2018-11-28	18:00	20	151
368	POWERGRID	POWERGRID	LINE	DHAULIGANGA (220KV)-PITHORAGRH (220KV)	DAILY	AMP OF LINE EQUIPMENTS (CT, CVT & LA)	2018-12-07	08:00	2018-12-07	16:00	8	152

369	POWERGRID	POWERGRID	LINE	KANPUR SOUTH(220KV)-NAUBASTA (220KV)	DAILY	AMP WORK	2018-12-17	09:00	2018-12-17	17:00	8	-
370	POWERGRID	POWERGRID	LINE	KANPUR SOUTH(220KV)-PANKI(220KV)II	DAILY	AMP WORK	2018-12-18	09:00	2018-12-18	17:00	8	-
371	POWERGRID	POWERGRID	LINE	AJMER(400KV)-AJMER (400KV)I	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 8/0-9/0) at 400KV D/C Ajmer(New)-Ajmer(RVFN) line location no 7-8.  For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 8/0-9/0) at 400KV D/C Ajmer(New)-Ajmer(RVFN) line location no 7-8.	2018-12-18	09:00	2018-12-18	18:00	9	-
372	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-UNCHAHAR (220KV)I	DAILY	AMP WORK	2018-12-19	09:00	2018-12-19	17:00	8	152
373	POWERGRID	POWERGRID	LINE	AJMER(400KV)-AJMER (400KV)I	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 8/0-9/0) at 400KV D/C Ajmer(New)-Ajmer(RVFN) line location no 7-8.	2018-12-19	09:00	2018-12-19	18:00	9	-
374	POWERGRID	POWERGRID	LINE	AJMER(400KV)-AJMER (400KV)II	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 8/0-9/0) at 400KV D/C Ajmer(New)-Ajmer(RVFN) line location no 7-8.	2018-12-18	09:00	2018-12-18	18:00	9	-
375	POWERGRID	POWERGRID	LINE	AJMER(400KV)-AJMER (400KV)II	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 8/0-9/0) at 400KV D/C Ajmer(New)-Ajmer(RVFN) line location no 7-8.	2018-12-19	09:00	2018-12-19	18:00	9	-
376	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-UNCHAHAR (220KV)II	DAILY	AMP WORK	2018-12-20	09:00	2018-12-20	17:00	8	152
377	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-UNCHAHAR (220KV)III	DAILY	AMP WORK	2018-12-22	09:00	2018-12-22	17:00	8	-
378	POWERGRID	POWERGRID	LINE	KOTA (400KV)-MERTA (400KV)I	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 13/0-14/0) at 400 KV D/C Kot Merta line location no 565-566.	2018-11-15	09:00	2018-11-15	18:00	9	151

379	POWERGRID	POWERGRID	LINE	KOTA (400KV)-MERTA (400KV)I	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 13/0-14/0) at 400 KV D/C Kot Merta line location no 565-566.	2018-11-16	09:00	2018-11-16	18:00	9	151
380	POWERGRID	POWERGRID	LINE	MERTA (400KV)-BEAWAR (400KV)	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 13/0-14/0) at 400 KV D/C Kot Merta line location no 565-566.	2018-11-15	07:00	2018-11-16	18:00	22	150
381	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BASSI (400KV)I	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-01	09:00	2018-12-01	19:00	10	152
382	POWERGRID	POWERGRID	LINE	BASSI (400KV)-BHIWADI-PG (400KV)	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-03	09:00	2018-12-03	19:00	10	150
383	POWERGRID	POWERGRID	LINE	BASSI (400KV)-KOTPUTLI (400KV) (KHELNA)	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-04	09:00	2018-12-04	19:00	10	152
384	POWERGRID	POWERGRID	LINE	BASSI (400KV)-SIKAR (400KV)I	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-05	09:00	2018-12-05	19:00	10	151
385	POWERGRID	POWERGRID	LINE	BASSI (400KV)-SIKAR (400KV)II	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-06	09:00	2018-12-06	19:00	10	151
386	POWERGRID	POWERGRID	LINE	BASSI (400KV)-JAIPUR South (400KV)I	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-07	09:00	2018-12-07	19:00	10	150
387	POWERGRID	POWERGRID	LINE	BASSI (400KV)-JAIPUR South (400KV)II	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-08	09:00	2018-12-08	19:00	10	150
388	POWERGRID	POWERGRID	LINE	BASSI (400KV)-PHAGI(400KV)I	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-10	09:00	2018-12-10	19:00	10	152
389	POWERGRID	POWERGRID	LINE	BASSI (400KV)-PHAGI(400KV)II	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-11	09:00	2018-12-11	19:00	10	152
390	POWERGRID	POWERGRID	LINE	BASSI (400KV)-HEERAPURA (400KV)I	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-12	09:00	2018-12-12	19:00	10	152
391	POWERGRID	POWERGRID	LINE	BASSI (400KV)-HEERAPURA (400KV)II	DAILY	Replacement of porcelain Insulators with Polymer Insulators of Bassi s/s.	2018-12-13	09:00	2018-12-13	19:00	10	152

392	POWERGRID	POWERGRID	LINE	KAITHAL (400KV)-BAGHPAT (400KV)I	DAILY	For tightening of loose E/W and other tight or loose E/W (for maintain the proper clearance both E/W to crossing of 765 kv bhiwani-Meerut line.	2018-12-15	09:00	2018-12-15	19:00	10	-
393	POWERGRID	POWERGRID	LINE	KAITHAL (400KV)-BAGHPAT (400KV)II	DAILY	For tightening of loose E/W and other tight or loose E/W (for maintain the proper clearance both E/W to crossing of 765 kv bhiwani-Meerut line.	2018-12-15	09:00	2018-12-15	19:00	10	146
394	POWERGRID	POWERGRID	LINE	BAGHPAT (400KV)-DEHRADUN (400KV)	DAILY	INSULATOR CLEANING.	2018-11-16	09:00	2018-11-18	18:00	27	145
395	POWERGRID	POWERGRID	LINE	ROORKEE (400KV)-DEHRADUN (400KV)	DAILY	INSULATOR CLEANING.	2018-11-19	08:00	2018-11-20	18:00	20	-
396	POWERGRID	POWERGRID	LINE	BAGHPAT (400KV)-SAHARANPUR (400KV)	DAILY	INSULATOR CLEANING.	2018-11-21	08:00	2018-11-22	18:00	20	146
397	POWERGRID	POWERGRID	LINE	KOTA (400KV)-MERTA (400KV)I	DAILY	REPLACEMENT OF PORCELAIN INSULATORS WITH POLYMER INSULATORS .	2018-12-09	09:00	2018-12-09	18:00	9	151
398	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-PANKI KANPUR (400KV)I	CONTINUOUS	CT replacement work under CERC Add Cap	2018-12-10	09:00	2018-12-12	18:00	57	152
399	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-PANKI KANPUR (400KV)II	CONTINUOUS	CT replacement work under CERC Add Cap	2018-12-13	09:00	2018-12-15	18:00	57	152
400	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-AGRA-PG (400KV)	DAILY	For SFRA test of Agra Line Reactor as per RHQ AM Instructions	2018-12-01	09:00	2018-12-01	18:00	9	152
401	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-FATEHPUR -PG (400KV)I	DAILY	For SFRA test of Agra Line Reactor as per RHQ AM Instructions	2018-12-03	09:00	2018-12-03	18:00	9	152
402	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	DAILY	AMP OF LINE REACTOR (Line shutdown will be required for 15 min duration at 10:00 Hrs for taking Line reactor out of service and again S/d for 15 min required at 17:00 Hrs for taking Line reactor in service. During reactor AMP, Line will be in service )	2018-12-05	10:00	2018-12-05	17:00	7	152
403	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-SHAHJAHANPUR (400KV)I	DAILY	Insulators Cleaning work at Polluted stretch	2018-11-26	09:00	2018-11-27	18:00	18	-
404	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-SHAHJAHANPUR (400KV)II	DAILY	Insulators Cleaning work at Polluted stretch	2018-11-28	09:00	2018-11-29	18:00	18	-

405	POWERGRID	POWERGRID	LINE	SHREE CEMENTS (400KV)-MERTA (400KV)	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 13/0-14/0) at 400 KV D/C Kot Merta line location no 565-566.	2018-11-16	09:00	2018-11-16	18:00	9	152
406	POWERGRID	POWERGRID	LINE	KOTA (400KV)-RAPP D (400KV)	DAILY	For connecting/disconnecting of jumpers at 04 No. Locations in view of charging of 400 KV D/C Kota LILO Point to Jaipur south gantry transmission Line(PART-B). OR For stringing work of 400 KV D/C Kota LILO Point to Jaipur south gantry transmission line(PART-B).	2018-12-22	09:00	2018-12-23	18:00	18	152
407	POWERGRID	POWERGRID	LINE	BHIWADI-PG (400KV)-GURGAON (400KV)	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-03	09:00	2018-12-03	13:00	4	151
408	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BHIWADI-PG (400KV)I	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-04	09:30	2018-12-04	13:30	4	152
409	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BHIWADI-PG (400KV)II	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-04	14:00	2018-12-04	18:00	4	146
410	POWERGRID	POWERGRID	LINE	BHIWADI-PG (400KV)-HISSAR-PG (400KV)I	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-05	09:00	2018-12-05	13:00	4	152
411	POWERGRID	POWERGRID	LINE	BHIWADI-PG (400KV)-KOTPUTLI (400KV) (KHELNA)	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-09	09:00	2018-12-09	18:00	9	152
412	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-SIKAR (400KV)I	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-12	09:00	2018-12-13	18:00	18	152
413	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-SIKAR (400KV)II	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-14	09:00	2018-12-15	18:00	18	152
414	POWERGRID	POWERGRID	LINE	SIKAR (400KV)-BABAI GSS	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-18	09:00	2018-12-18	18:00	9	151
415	POWERGRID	POWERGRID	LINE	NEEMRANA (400KV)-SIKAR (400KV)II	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-19	09:00	2018-12-19	18:00	9	151

416	POWERGRID	POWERGRID	LINE	SIKAR (400KV)-RATANGARH (400KV)1	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-20	09:00	2018-12-20	18:00	9	151
417	POWERGRID	POWERGRID	LINE	SIKAR (400KV)-RATANGARH (400KV)2	DAILY	Replacement of Porcelain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-21	09:00	2018-12-21	18:00	9	151
418	POWERGRID	POWERGRID	LINE	KANKROLI (400KV)-ZERDA-WR (400KV)I	DAILY	Outage of Line for Testing of new NIFP system along with protection relays. After work completion, Line Reactor shall be taken into service. at zerda	2018-11-24	08:00	2018-11-24	17:00	9	152
419	POWERGRID	POWERGRID	LINE	BHINMAL (400KV)-ZERDA-WR (400KV)	DAILY	Taking out line reactor from line for NIFP work	2018-11-26	08:00	2018-11-26	08:15	0.25	152
420	POWERGRID	POWERGRID	LINE	BHINMAL (400KV)-ZERDA-WR (400KV)	DAILY	Outage of Line for Testing of new NIFP system along with protection relays. After work completion, Line Reactor shall be taken into service.	2018-11-30	08:00	2018-11-30	18:00	10	152
421	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-SASARAM-ER (400KV)	DAILY	For insulator cleaning and Other maintenance work	2018-11-25	09:00	2018-11-26	18:00	18	152
422	POWERGRID	POWERGRID	LINE	DEHRADUN (400KV)-ABDULLAPUR (400KV)1	DAILY	For testing Line differential feature of the relay at both ends.	2018-12-03	09:30	2018-12-03	13:30	4	151
423	POWERGRID	POWERGRID	LINE	DEHRADUN (400KV)-ABDULLAPUR (400KV)2	DAILY	For testing Line differential feature of the relay at both ends.	2018-12-04	09:30	2018-12-04	13:30	4	151
424	POWERGRID	POWERGRID	LINE	SARNA (220KV)-DASUYA (220KV)I	CONTINUOUS	For retrofitting of CB at Sarna. CB is over 25 years old.	2018-11-20	09:30	2018-11-28	17:30	200	148
425	POWERGRID	POWERGRID	LINE	AMRITSAR (400KV)-ParbatiPooling-BANALA (400KV)I	DAILY	For testing of operation after remote integration at RTAMC control Center.	2018-12-07	10:30	2018-12-07	11:00	0.5	150
426	POWERGRID	POWERGRID	LINE	HAMIRPUR-PG (400KV)-ParbatiPooling-BANALA (400KV)	DAILY	For testing of operation after remote integration at RTAMC control Center.	2018-12-08	10:30	2018-12-08	11:00	0.5	147
427	POWERGRID	POWERGRID	LINE	MUZAFFARPUR-ER (400KV)-GORAKHPUR-PG (400KV)2	DAILY	For testing of Autoreclose Protection Relay after Retrofitment of Obsolete Siemens make AR relay with new numerical AR Relay	2018-12-18	09:00	2018-12-18	16:00	7	152
428	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-VINDHYACHAL (400KV)I	CONTINUOUS	Retrofitment of Line Pantograph Isolators	2018-11-26	09:00	2018-12-03	21:00	180	152

429	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-VINDHYACHAL (400KV)II	CONTINUOUS	Retrofitment of Line Pantograph Isolators	2018-11-26	09:00	2018-12-03	21:00	180	152
430	POWERGRID	POWERGRID	LINE	GORAKHPUR-PG (400KV)-GORAKHPUR-UP (400KV)I	DAILY	AMP of Line Bay equipments	2018-12-12	09:00	2018-12-12	17:30	8.5	151
431	POWERGRID	POWERGRID	LINE	GORAKHPUR-PG (400KV)-GORAKHPUR-UP (400KV)II	DAILY	AMP of Line Bay equipments	2018-12-14	09:00	2018-12-14	17:30	8.5	151
432	POWERGRID	POWERLINK	LINE	MUZAFFARPUR-ER (400KV)-GORAKHPUR-PG (400KV)I	DAILY	For testing of Autoreclose Protection Relay after Retrofitment of Obsolete Siemens make AR relay with new numerical AR Relay	2018-12-17	09:30	2018-12-17	16:30	7	-
433	POWERGRID	POWERLINK	LINE	GORAKHPUR-PG (400KV)-LUCKNOW-Kursi Road (400KV) PGI	DAILY	For testing of Autoreclose Protection Relay after Retrofitment of Obsolete Siemens make AR relay with new numerical AR Relay	2018-12-19	09:00	2018-12-19	16:00	7	152
434	POWERGRID	POWERLINK	LINE	GORAKHPUR-PG (400KV)-LUCKNOW-Kursi Road (400KV) PGII	DAILY	For testing of Autoreclose Protection Relay after Retrofitment of Obsolete Siemens make AR relay with new numerical AR Relay	2018-12-20	09:00	2018-12-20	16:00	7	152
435	POWERGRID	PTCUL	LINE	ROORKEE (400KV)-MUZZAFARNAGAR-UP (400KV)	DAILY	Polymer Insulator Replacement inplace of Existing Porcelain Insulator	2018-12-07	09:00	2018-12-07	14:00	5	149
436	POWERGRID	PTCUL	LINE	Haridwar-SIDCUL (220KV)-ROORKEE PTCUL (220KV)	DAILY	Polymer Insulator Replacement inplace of Existing Porcelain Insulator This ckt has been lilo at prankaliyar both ckr will be in outage for the same.	2018-12-12	09:30	2018-12-12	18:30	9	152
437	POWERGRID	RRVPN	LINE	KOTA(220KV)-KTPS (220KV)1	DAILY	Replacement of porcelain Insulators with Polymer Insulators at Kota.	2018-12-03	09:00	2018-12-18	18:00	144	-
438	POWERGRID	RRVPN	LINE	KOTA(220KV)-KTPS (220KV)2	DAILY	Replacement of porcelain Insulators with Polymer Insulators at Kota.	2018-12-03	09:00	2018-12-08	18:00	54	-
439	POWERGRID	RRVPN	LINE	MERTA (400KV)-RATANGARH (400KV)	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-II line (loc AP 33/0-34/0) at400 kV S/C RVPN RTH -MRT Line location no 404-405.	2018-11-15	09:30	2018-11-16	18:30	18	151



440	POWERGRID	RRVPN	LINE	MERTA (400KV)-HEERAPURA (400KV)	DAILY	For the Stringing work of Power line crossing of 765KV Ajmer-Bikaner part-I line (loc AP 22/0-23/0) at 400 kV S/C Jaipur-Merta (RVPNL) Line location no 403-404.	2018-11-22	10:34	2018-11-23	10:34	0	151
441	POWERGRID	RRVPN	LINE	SURATGARH (400KV)-BIKANER (400KV)	DAILY	Stringing of work of 765kv D/C Ajmer-Bikaner TL part IV bet Tower no-93/0&94/0	2018-11-22	09:30	2018-11-23	18:30	18	152
442	POWERGRID	RRVPN	LINE	SIKAR (400KV)-BIKANER (400KV)1	DAILY	Stringing of work of 765kv D/C Ajmer-Bikaner TL part IV bet Tower no-86A /0 & 86B/0	2018-11-26	09:00	2018-11-27	18:00	18	152
443	POWERGRID	RRVPN	LINE	SIKAR (400KV)-BIKANER (400KV)2	DAILY	Stringing of work of 765kv D/C Ajmer-Bikaner TL part IV bet Tower no-86A/0&86B/0	2018-11-26	09:00	2018-11-27	18:00	18	152
444	POWERGRID	RRVPN	LINE	SIKAR (400KV)-BIKANER (400KV)1	DAILY	Testing & commissioning of PMU System of 400kV Bikaner ckt-1 line at 400 kV Sikar S/s	2018-12-25	09:00	2018-12-25	18:00	9	152
445	POWERGRID	RRVPN	LINE	SIKAR (400KV)-BIKANER (400KV)2	DAILY	Testing & commissioning of PMU System of 400kV Bikaner ckt-1 line at 400 kV Sikar S/s	2018-12-26	09:00	2018-12-26	18:00	9	152
446	POWERGRID	UPPTCL	LINE	Meja-NTPC (400KV)-REWA ROAD (400KV)I	DAILY	Over crossing by under construction 400kV S/C Singrauli- Allahabad Line at tower Location No. AP 159/0 - AP160/0 (In between tower Loc.No. (Existing Line)-42-43),	2018-12-05	08:00	2018-12-05	18:00	10	151
447	POWERGRID	UPPTCL	LINE	REWA ROAD (400KV)-Meja-NTPC (400KV)II	DAILY	Over crossing by under construction 400kV S/C Singrauli- Allahabad Line at tower Location No. AP 159/0 - AP160/0 (In between tower Loc.No. (Existing Line)-42-43),	2018-12-05	08:00	2018-12-05	18:00	10	152
448	POWERGRID	UPPTCL	LINE	Meja-NTPC (400KV)-BARA (400KV)I	DAILY	Over crossing by under construction 400kV S/C Singrouli- Allahabad Line at Tower Location No. 151A/0-151B/0 (In between tower Loc.No. (Existing Line)-46-47),	2018-12-10	08:00	2018-12-10	18:00	10	151

449	POWERGRID	UPPTCL	LINE	Meja-NTPC (400KV)-BARA (400KV)II	DAILY	Over crossing by under construction 400kV S/C Singrouli- Allahabad Line at Tower Location No. 151A/0-151B/0 (In between tower Loc.No. (Existing Line)-46-47),	2018-12-10	08:00	2018-12-10	18:00	10	151
450	POWERGRID	POWERGRID	REACTOR	REACTOR ALLAHABAD (400KV)/80.00	DAILY	REPLACEMENT OF BUS ISOLATORS.	2018-12-10	08:00	2018-12-10	18:00	10	145
451	POWERGRID	POWERGRID	REACTOR	80 MVAR Singrauli Line Reactor , at Fatehpur/80.00	CONTINUOUS	Internal inspection of 80 MVAR Line reactor to find out RCA of raing trend of Fault Gases	2018-12-17	10:00	2018-12-22	18:00	128	150
452	POWERGRID	POWERGRID	REACTOR	REACTOR ROORKEE (400KV)/125.00	DAILY	Polymer Insulator Replacement inplace of Existing Porcelain Insulator	2018-12-04	09:30	2018-12-04	18:30	9	-
453	POWERGRID	POWERGRID	REACTOR	REACTOR (S) BHIWADI-PG (400KV)/50.00	DAILY	For replacement of Porcelain insulators by Polymer insulators	2018-12-08	14:00	2018-12-08	18:00	4	152
454	POWERGRID	POWERGRID	REACTOR	REACTOR BHINMAL (400KV)/80.00	DAILY	AMP WORK	2018-12-12	09:30	2018-12-12	18:30	9	152
455	POWERGRID	POWERGRID	REACTOR	50MVAR S/R KANKROLI LINE at BHINML/400.00	DAILY	AMP WORK	2018-12-15	09:00	2018-12-15	18:00	9	152
456	POWERGRID	POWERGRID	REACTOR	REACTOR I SIKAR (400KV)/80.00	DAILY	Replacement of Porcleain Insulators with Polymer Insulators at 400 KV Sikar S/s	2018-12-09	09:00	2018-12-09	18:00	9	151
457	POWERGRID	POWERGRID	REACTOR	REACTOR I RATANGARH (400KV)/125.00	CONTINUOUS	For replacement of existing 125 MVAR Bus Reactor (Make-CGL) by new 125 MVAR Bus Reactor (Make-GE) at 400 KV Ratangarh S/s (RVPNL) for repairing at CGL, Mumbai	2018-12-05	09:00	2018-12-20	18:00	369	152
458	POWERGRID	POWERGRID	REACTOR	REACTOR MANDOLA (400KV)/50.00	CONTINUOUS	Replacement of 418-89 L, 418-89A & 417-89B isolators ( retrofitment of 03 nos RK make isolators with new 400 KV Isolators)	2018-11-27	09:30	2018-12-03	18:30	153	-
459	POWERGRID	POWERGRID	REACTOR	REACTOR KANPUR (400KV)/125.00	DAILY	AMP WORK	2018-12-29	09:00	2018-12-29	17:00	8	145
460	POWERGRID	POWERGRID	REACTOR	REACTOR BAREILY-PG (400KV)/80.00	DAILY	For Collecting oil samples of Bushing for DGA	2018-12-12	10:00	2018-12-12	17:00	7	147
461	POWERGRID	POWERGRID	REACTOR	REACTOR-II AGRA-PG (400KV)/125.00	CONTINUOUS	For repalcment of all 03 Nos. HV Bushings due Tan Delta Violation on Variable Frequency.	2018-12-19	09:00	2018-12-31	18:00	297	151
462	POWERGRID	POWERGRID	REACTOR	50 MVAR BUS REACTOR- 2B,at Bareilly/50.00	DAILY	For Collecting oil samples of Bushing for DGA	2018-12-11	10:00	2018-12-11	17:00	7	-

463	POWERGRID	POWERGRID	REACTOR	Ballabhgarh-1 LINE REACTOR,at Kanpur/50.00	CONTINUOUS	For Oil filtration and vacuum cycle due to in crease in H2	2018-11-19	09:00	2018-11-24	17:00	128	-
464	POWERGRID	POWERGRID	REACTOR	REACTOR PARBATI-POOL Banala (400KV)/80.00	DAILY	For testing of operation after remote integration at RTAMC control Center.	2018-12-10	10:30	2018-12-10	11:00	0.5	-
465	PSTCL	PSTCL	BUS	DHURI - BUS BAR 1	DAILY	General Maintenance	2018-12-03	09:00	2018-12-03	17:00	8	151
466	PSTCL	PSTCL	BUS	DHURI - BUS BAR 1	DAILY	General Maintenance	2018-12-04	09:00	2018-12-04	17:00	8	151
467	PSTCL	PSTCL	BUS	DHURI - BUS BAR 2	DAILY	General Maintenance	2018-12-05	09:00	2018-12-07	17:00	24	151
468	PSTCL	PSTCL	BUS	RAJPURA - BUS BAR 1	DAILY	Annual Protection, testing & maintenance	2018-12-05	09:00	2018-12-05	17:00	8	-
469	PSTCL	PSTCL	ICT	ICT01 MUKTSAR (400KV)(PSTCL)/315	DAILY	Periodical Testing	2018-12-03	09:00	2018-12-03	17:00	8	147
470	PSTCL	PSTCL	ICT	ICT01 NAKODAR (400KV)(PSTCL)/315	DAILY	Periodical Maintenance	2018-12-06	09:00	2018-12-06	17:00	8	147
471	PSTCL	PSTCL	ICT	ICT02 MUKTSAR (400KV)(PSTCL)/315	DAILY	Periodical Testing	2018-12-10	09:00	2018-12-10	17:00	8	147
472	PSTCL	PSTCL	ICT	ICT02 RAJPURA (400KV)(PSTCL)/500	DAILY	Annual Protection, testing & maintenance	2018-12-12	09:00	2018-12-13	17:00	16	152
473	PSTCL	PSTCL	ICT	ICT02 NAKODAR (400KV)(PSTCL)/315	DAILY	Periodical Maintenance	2018-12-13	09:00	2018-12-13	17:00	8	147
474	PSTCL	PSTCL	ICT	ICT02 MAKHU (400KV)(PSTCL)/315	DAILY	General Maintenance	2018-12-24	10:00	2018-12-24	17:00	7	150
475	PSTCL	POWERGRID	LINE	ROORKEE (400KV)-KASHIPUR (400KV)I	DAILY	For taking DCRM of circuit breaker and Tandelata measurement of CT, complete bay switchgear equipment tightening including checking & rectification of interlocking circuit of isolator and earthswitch.	2018-12-06	10:00	2018-12-06	18:00	8	151
476	PSTCL	PSTCL	LINE	NALLAGARH (220KV)-MOHALI (220KV)1	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 21 to 30	2018-12-03	10:00	2018-12-03	17:00	7	152
477	PSTCL	PSTCL	LINE	KANGRA (132KV)-SHANAN (132KV)	DAILY	Mtc of line,disc cleaning and tightening of jumper with ptw on CKT no. 1	2018-12-03	10:00	2018-12-05	16:00	18	152
478	PSTCL	PSTCL	LINE	KANGRA (132KV)-SHANAN (132KV)	DAILY	Mtc of line,disc cleaning and tightening of jumper with ptw on CKT no. 2	2018-12-06	10:00	2018-12-07	16:00	12	152
479	PSTCL	PSTCL	LINE	NALLAGARH (220KV)-MOHALI (220KV)2	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 21 to 30	2018-12-07	10:00	2018-12-07	17:00	7	152

480	PSTCL	PSTCL	LINE	KANGRA (132KV)-PATHANKOT (132KV)	DAILY	Mtc of line,disc cleaning and tightening of jumper with ptw on CKT no. 2	2018-12-08	10:00	2018-12-08	16:00	6	152
481	PSTCL	PSTCL	LINE	KANGRA (132KV)-PATHANKOT (132KV)	DAILY	Mtc of line,disc cleaning and tightening of jumper with ptw on CKT no. 1	2018-12-18	10:00	2018-12-19	16:00	12	152
482	PSTCL	PSTCL	LINE	KANGRA (132KV)-PATHANKOT (132KV)	DAILY	Mtc of line,disc cleaning and tightening of jumper with ptw on CKT no. 2	2018-12-17	10:00	2018-12-17	16:00	6	152
483	PSTCL	PSTCL	LINE	HAMIRPUR HSEB (132KV)-CHOHAL (132KV)	DAILY	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	2018-12-19	10:00	2018-12-19	16:00	6	152
484	PSTCL	PSTCL	LINE	KANGRA (132KV)-SHANAN (132KV)	DAILY	Mtc of line,disc cleaning and tightening of jumper with ptw on CKT no. 1	2018-12-20	10:00	2018-12-20	16:00	6	152
485	PSTCL	PSTCL	LINE	KANGRA (132KV)-SHANAN (132KV)	DAILY	Mtc of line,disc cleaning and tightening of jumper with ptw on CKT no. 2	2018-12-21	10:00	2018-12-21	16:00	6	152
486	PSTCL	PSTCL	LINE	RAJPURA (400KV)-DHURI (400KV)1	DAILY	Line jumper/nut bolt tightening	2018-12-01	09:00	2018-12-01	17:00	8	152
487	PSTCL	PSTCL	LINE	RAJPURA TPS (400KV)-RAJPURA (400KV)1	DAILY	Tightening of nut bolts of jumpers, dampers, suspension clamps and cleaning of disc insulators	2018-12-03	09:00	2018-12-04	17:00	16	152
488	PSTCL	PSTCL	LINE	NAKODAR (400KV)-MAKHU (400KV)1	DAILY	General Maintenance	2018-12-06	10:00	2018-12-06	16:00	6	152
489	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MUKTSAR (400KV)1	DAILY	Cleaning of ordinary porcelain disc insulators	2018-12-03	09:00	2018-12-04	17:00	16	152
490	PSTCL	PSTCL	LINE	KANGRA (132KV)-SHANAN (132KV)	DAILY	Mtc of line, disc cleaning and tightening of jumper with ptw	2018-12-03	10:00	2018-12-05	16:00	18	152
491	PSTCL	PSTCL	LINE	MUKTSAR (400KV)-MAKHU (400KV)1	DAILY	Cleaning of Porcelain Disc Insulators in Polluted area	2018-12-01	10:00	2018-12-01	16:00	6	152
492	PSTCL	PSTCL	LINE	NAKODAR (400KV)-MAKHU (400KV)2	DAILY	General Maintenance	2018-12-05	10:00	2018-12-05	16:00	6	152
493	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MUKTSAR (400KV)1	DAILY	Cleaning of ordinary porcelain disc insulators	2018-12-05	10:00	2018-12-07	17:00	21	152
494	PSTCL	PSTCL	LINE	RAJPURA TPS (400KV)-RAJPURA (400KV)2	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators	2018-12-07	09:00	2018-12-08	17:00	16	152
495	PSTCL	PSTCL	LINE	MUKTSAR (400KV)-MAKHU (400KV)2	DAILY	Cleaning of Porcelain Disc Insulators in Polluted area	2018-12-11	10:00	2018-12-11	16:00	6	152

496	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MUKTSAR (400KV)2	DAILY	Cleaning of ordinary porcelain disc insulators	2018-12-08	09:00	2018-12-10	17:00	24	152
497	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-NAKODAR (400KV)	DAILY	General Maintenance	2018-12-11	10:00	2018-12-11	16:00	6	152
498	PSTCL	PSTCL	LINE	RAJPURA TPS (400KV)-RAJPURA (400KV)2	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators	2018-12-10	09:00	2018-12-10	17:00	8	152
499	PSTCL	PSTCL	LINE	RAJPURA (400KV)-DHURI (400KV)2	DAILY	Line jumper/ Nut Bolt tightening	2018-12-13	09:00	2018-12-13	17:00	8	152
500	PSTCL	PSTCL	LINE	RAJPURA TPS (400KV)-RAJPURA (400KV)2	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators	2018-12-11	09:00	2018-12-11	17:00	8	152
501	PSTCL	PSTCL	LINE	MAKHU (400KV)-AMRITSAR (400KV)I	DAILY	Cleaning of Porcelain Disc Insulators in Polluted area	2018-12-14	10:00	2018-12-14	16:00	6	152
502	PSTCL	PSTCL	LINE	MOGA (400KV)-NAKODAR (400KV)	DAILY	General Maintenance	2018-12-13	10:00	2018-12-13	16:00	6	152
503	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MUKTSAR (400KV)2	DAILY	Cleaning of ordinary porcelain disc insulators	2018-12-12	09:00	2018-12-13	17:00	16	152
504	PSTCL	PSTCL	LINE	PONG (220KV)-DASUYA (220KV)1	DAILY	Tightening of Jumpers of Deadens Towers, Disc Cleaning & Tree Cutting	2018-12-12	10:00	2018-12-12	16:00	6	146
505	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MOGA (400KV)	DAILY	Cleaning of Ordinary Porcelain Disc Insulators	2018-12-14	09:00	2018-12-15	17:00	16	-
506	PSTCL	PSTCL	LINE	MAKHU (400KV)-AMRITSAR (400KV)II	DAILY	Cleaning of Porcelain Disc Insulators in Polluted area	2018-12-15	10:00	2018-12-15	16:00	6	152
507	PSTCL	PSTCL	LINE	RAJPURA TPS (400KV)-NAKODAR (400KV)1	DAILY	General Maintenance	2018-12-20	10:00	2018-12-20	16:00	6	152
508	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-NAKODAR (400KV)	DAILY	Cleaning of Ordinary Porcelain Disc Insulators	2018-12-17	09:00	2018-12-18	17:00	16	152
509	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-DHURI (400KV)1	DAILY	Line jumper/nut bolt tightening	2018-12-18	09:00	2018-12-18	17:00	8	152
510	PSTCL	PSTCL	LINE	RAJPURA TPS (400KV)-NAKODAR (400KV)2	DAILY	General Maintenance	2018-12-18	10:00	2018-12-19	16:00	12	152
511	PSTCL	PSTCL	LINE	MUKTSAR (400KV)-MAKHU (400KV)1	DAILY	General maintenance, Jumper tightening and Disc Cleaning	2018-12-21	09:00	2018-12-21	17:00	8	152
512	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MOGA (400KV)	DAILY	Cleaning of Ordinary Porcelain Disc Insulators	2018-12-19	09:00	2018-12-20	17:00	16	-
513	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-NAKODAR (400KV)	DAILY	Cleaning of Ordinary Porcelain Disc Insulators	2018-12-21	09:00	2018-12-22	17:00	16	152
514	PSTCL	PSTCL	LINE	MOGA (400KV)-NAKODAR (400KV)	DAILY	General Maintenance	2018-12-24	10:00	2018-12-24	16:00	6	152
515	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-DHURI (400KV)2	DAILY	Line Jumper / nut bolt tightening	2018-12-24	09:00	2018-12-24	17:00	8	152

516	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-DHURI (400KV)2	DAILY	Line jumper / nut bolt tightening	2018-12-26	09:00	2018-12-26	17:00	8	152
517	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MUKTSAR (400KV)1	DAILY	General Maintenance, jumper tightening and disc cleaning	2018-12-27	09:00	2018-12-27	17:00	8	152
518	PTCUL	POWERGRID	LINE	BAREILY-PG (400KV)-KASHIPUR (400KV)1	DAILY	For taking DCRM of circuit breaker and Tandelata measurement of CT, complete bay switchgear equipment tightening including checking & rectification of interlocking circuit of isolator and earth switch.	2018-12-04	10:00	2018-12-04	18:00	8	146
519	PTCUL	POWERGRID	LINE	BAREILY-PG (400KV)-KASHIPUR (400KV)2	DAILY	For taking DCRM of circuit breaker and Tandelata measurement of CT, complete bay switchgear equipment tightening including checking & rectification of interlocking circuit of isolator and earth switch.	2018-12-05	10:00	2018-12-05	18:00	8	151
520	PTCUL	POWERGRID	LINE	ROORKEE (400KV)-KASHIPUR (400KV)II	DAILY	For taking DCRM of circuit breaker and Tandelata measurement of CT, complete bay switchgear equipment tightening including checking & rectification of interlocking circuit of isolator and earth switch.	2018-12-07	10:00	2018-12-07	18:00	8	151
521	PTCUL	POWERGRID	LINE	ROORKEE (400KV)-KASHIPUR (400KV)I	DAILY	For taking DCRM of circuit breaker and Tandelata measurement of CT, complete bay switchgear equipment tightening including checking & rectification of interlocking circuit of isolator and earth switch.	2018-12-06	10:00	2018-12-06	18:00	8	151
522	RRVPN	RRVPN	BAY	4152T tie bay for ICT-1 AT 400KV GSS BHILWARA	DAILY	Yearly maintenane of 400 KV TIE-1 BAY (4152T)& ASSOCIATED EQUIPMENTS	2018-12-13	09:00	2018-12-13	17:00	8	149
523	RRVPN	RRVPN	BAY	4252T tie bay for ICT-2 AT 400KV GSS BHILWARA	DAILY	Yearly maintenane of 400 KV TIE-2 BAY (4252T)& ASSOCIATED EQUIPMENTS	2018-12-14	09:00	2018-12-14	17:00	8	149

524	RRVPN	RRVPN	BAY	4352T tie bay for 400kv Chhabra-Bhilwara line AT BHILWARA	DAILY	Yearly maintenane of 400 KV TIE-3 BAY (4352T)& ASSOCIATED EQUIPMENTS	2018-12-15	09:00	2018-12-15	17:00	8	149
525	RRVPN	RRVPN	BAY	4452T tie bay for 400kv Ajmer-Bhilwara-II AT BHILWARA	DAILY	Yearly maintenane of 400 KV TIE-4 BAY (4452T)& ASSOCIATED EQUIPMENTS	2018-12-16	09:00	2018-12-16	17:00	8	149
526	RRVPN	RRVPN	BAY	402-52T Tie CB of 400kv Bhilwara-II line at 400kv GSS Chittorgarh	DAILY	FOR MAINTAINCE WORK	2018-12-04	09:00	2018-12-04	17:00	8	148
527	RRVPN	RRVPN	BAY	401-52T CB of 400kv Bhilwara-I line at 400kv GSS Chittorgarh	DAILY	FOR MAINTAINCE WORK	2018-12-03	09:00	2018-12-03	17:00	8	148
528	RRVPN	RRVPN	BAY	TIE BAY OF ICT-I AND BUS REACTOR AT 400KV GSS CHITTORGARH	CONTINUOUS	FOR MAINTAINCE WORK	2018-12-05	09:00	2018-12-07	17:00	56	150
529	RRVPN	RRVPN	BAY	400KV 152B CB OF FUTURE JAIPUR NORTH AT 400KV HEERAPURA	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-24	10:00	2018-12-24	14:00	4	-
530	RRVPN	RRVPN	BAY	400KV 652B CB OF FUTURE HINDAUN-II AT 400KV HEERAPURA	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-24	14:00	2018-12-24	18:00	4	150
531	RRVPN	ADANIRJ	BUS	BUS -1 KAWAI SCTPS (400KV)	DAILY	For annual maintenance of bay isolators	2018-12-04	09:00	2018-12-04	18:30	9.5	-
532	RRVPN	ADANIRJ	BUS	BUS - 2 KAWAI SCTPS (400KV)	DAILY	For annual maintenance of bay isolators	2018-12-05	09:00	2018-12-05	18:30	9.5	-
533	RRVPN	RRVPN	BUS	400KV BUS-I AKAL JAISALMER (400KV)	DAILY	Half yearly maintenance	2018-12-03	08:30	2018-12-03	18:00	9.5	152
534	RRVPN	RRVPN	BUS	400KV BUS-II AKAL JAISALMER (400KV)	DAILY	Half yearly maintenance	2018-12-13	08:30	2018-12-13	18:00	9.5	151
535	RRVPN	RRVPN	BUS	400KV MAIN BUS A RATANGARH	DAILY	Maintenance work of bay equipment and line maintenance work.	2018-12-17	09:30	2018-12-17	18:00	8.5	150
536	RRVPN	RRVPN	BUS	400kv Main Bus-I at 400KV GSS Bhadla.	DAILY	Quarterly Maintenance work	2018-12-07	15:00	2018-12-07	19:00	4	152
537	RRVPN	RRVPN	BUS	400 kV MAIN BUS-A AT 400 kV CHITTORGARH	CONTINUOUS	FOR MAINTAINCE WORK	2018-12-05	09:00	2018-12-07	17:00	56	150
538	RRVPN	RRVPN	BUS	400KV MAIN BUS-B AT 400KV GSS CHITTORGARH	CONTINUOUS	FOR MAINTAINCE WORK	2018-12-26	09:00	2018-12-29	17:00	80	150
539	RRVPN	RRVPN	BUS	400 kV Main Bus - I at 400kV GSS Ramgarh	DAILY	Half Yearly Maintenance & Yearly Maintenance	2018-12-17	09:00	2018-12-17	15:00	6	-
540	RRVPN	RRVPN	BUS	400 kV Main Bus - II at 400 kV GSS Ramgarh	DAILY	Half Yearly Maintenance & Yearly Maintenance	2018-12-18	09:00	2018-12-18	15:00	6	-
541	RRVPN	RRVPN	ICT	ICT03 AKAL JAISALMER (400KV)(RRVPN)/315	DAILY	Half yearly maintenance	2018-12-05	08:30	2018-12-05	18:00	9.5	151
542	RRVPN	RRVPN	ICT	ICT01 AKAL JAISALMER (400KV)(RRVPN)/315	DAILY	Half yearly maintenance	2018-12-10	08:30	2018-12-10	18:00	9.5	148
543	RRVPN	RRVPN	ICT	ICT02 RATANGARH (400KV)(RRVPN)/315	DAILY	Maintenance work of bay equipment and line maintenance work.	2018-12-12	09:30	2018-12-12	18:00	8.5	150

544	RRVPN	RRVPN	ICT	ICT01 RATANGARH (400KV)(RRVPN)/315	DAILY	Maintenance work of bay equipment and line maintenance work.	2018-12-18	09:30	2018-12-18	18:00	8.5	150
545	RRVPN	RRVPN	ICT	ICT02 BARMER (400KV)(RRVPN)/315	DAILY	Quarterly Maintenance work	2018-12-20	10:00	2018-12-20	18:00	8	150
546	RRVPN	RRVPN	ICT	ICT01 BHADLA (400KV)(RRVPN)/500	DAILY	Quarterly Maintenance work	2018-12-05	14:00	2018-12-05	18:00	4	152
547	RRVPN	RRVPN	ICT	ICT02 BHADLA (400KV)(RRVPN)/500	DAILY	Quarterly Maintenance work	2018-12-12	15:00	2018-12-12	19:00	4	152
548	RRVPN	RRVPN	ICT	ICT03 BHADLA (400KV)(RRVPN)/500	DAILY	Quarterly Maintenance work	2018-12-14	15:00	2018-12-14	19:00	4	152
549	RRVPN	RRVPN	ICT	ICT01 BHILWARA (400KV)(RRVPN)/315	DAILY	Yearly maintenane of 400 KV ICT-1 bay WITH 315 MVA TR.-I (4152A)& ASSOCIATED EQUIPMENTS	2018-12-08	09:00	2018-12-08	17:00	8	150
550	RRVPN	RRVPN	ICT	ICT02 BHILWARA (400KV)(RRVPN)/315	DAILY	Yearly maintenane of 400 KV ICT-2 bay WITH 315 MVA TR.-2 (4252A)& ASSOCIATED EQUIPMENTS	2018-12-09	09:00	2018-12-09	17:00	8	150
551	RRVPN	RRVPN	ICT	ICT02 CHITTORGARH (400KV)(RRVPN)/315	DAILY	FOR MAINTAINCE WORK	2018-12-13	09:00	2018-12-13	17:00	8	150
552	RRVPN	RRVPN	ICT	ICT01 CHITTORGARH (400KV)(RRVPN)/315	DAILY	FOR MAINTAINCE WORK	2018-12-14	09:00	2018-12-14	17:00	8	150
553	RRVPN	RRVPN	ICT	ICT01 HEERAPURA (400KV)(RRVPN)/250	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-11	10:00	2018-12-11	17:00	7	150
554	RRVPN	RRVPN	ICT	ICT02 HEERAPURA (400KV)(RRVPN)/250	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-13	10:00	2018-12-13	17:00	7	150
555	RRVPN	RRVPN	ICT	ICT03 HEERAPURA (400KV)(RRVPN)/250	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-14	10:00	2018-12-14	17:00	7	150
556	RRVPN	RRVPN	ICT	ICT04 HEERAPURA (400KV)(RRVPN)/315	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-17	10:00	2018-12-17	17:00	7	150
557	RRVPN	RRVPN	ICT	ICT01 HEERAPURA (400KV)(RRVPN)/250	DAILY	4th Quaterly maintenance of 220 KV side bay Equipments	2018-12-18	10:00	2018-12-18	17:00	7	150
558	RRVPN	RRVPN	ICT	ICT02 HEERAPURA (400KV)(RRVPN)/250	DAILY	4th Quaterly maintenance of 220 KV side bay Equipments	2018-12-19	10:00	2018-12-19	17:00	7	150
559	RRVPN	RRVPN	ICT	ICT03 HEERAPURA (400KV)(RRVPN)/250	DAILY	4th Quaterly maintenance of 220 KV side bay Equipments	2018-12-20	10:00	2018-12-20	17:00	7	150
560	RRVPN	RRVPN	ICT	ICT04 HEERAPURA (400KV)(RRVPN)/315	DAILY	4th Quaterly maintenance of 220 KV side bay Equipments	2018-12-21	10:00	2018-12-21	17:00	7	150
561	RRVPN	RRVPN	ICT	400/220KV ICT-3 AT 400 KV GSS RAMGARH/315	DAILY	Half Yearly Maintenance & Yearly Maintenance	2018-12-11	09:00	2018-12-11	15:00	6	-
562	RRVPN	POWERGRID	LINE	BASSI (400KV)-PHAGI(400KV)II	DAILY	Maintenance of line isolator, CVTs& Wave Traps.	2018-12-22	10:00	2018-12-22	18:00	8	152
563	RRVPN	POWERGRID	LINE	SIKAR (400KV)-RATANGARH (400KV)1	DAILY	Maintenance work of bay equipment and line maintenance work.	2018-12-10	09:30	2018-12-10	18:00	8.5	151
564	RRVPN	POWERGRID	LINE	ANTA GPS (220KV)-SAWAI MADHOPUR (220KV)	DAILY	quarterly maintenance	2018-12-20	09:30	2018-12-20	14:30	5	151



565	RRVPN	POWERGRID	LINE	ANTA GPS (220KV)-BHILWARA (220KV)1	DAILY	General Maintenance	2018-12-13	08:00	2018-12-13	17:00	9	150
566	RRVPN	POWERGRID	LINE	ANTA GPS (220KV)-BHILWARA (220KV)2	DAILY	General Maintenance	2018-12-14	08:00	2018-12-14	17:00	9	150
567	RRVPN	POWERGRID	LINE	BASSI (400KV)-HEERAPURA (400KV)I	DAILY	4th Quarterly maintenance of 400 KV side bay Equipments	2018-12-05	10:00	2018-12-05	17:00	7	152
568	RRVPN	POWERGRID	LINE	BASSI (400KV)-HEERAPURA (400KV)II	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-04	10:00	2018-12-04	17:00	7	152
569	RRVPN	RRVPN	LINE	ANTA GPS (220KV)-KOTA(220KV)	DAILY	QUARTERLY MAINTENANCE WORK	2018-12-13	08:00	2018-12-13	18:00	10	151
570	RRVPN	RRVPN	LINE	MODAK (220KV)-BHANPURA MPSEB-WR (220KV)+MPSE	DAILY	QUARTERLY MAINTENANCE WORK	2018-12-13	09:30	2018-12-13	16:00	6.5	152
571	RRVPN	RRVPN	LINE	KOTA(220KV)-BAROD (220KV)	CONTINUOUS	For Tower Erection under the existing 132 KV Kota-Mandana line for Construction of LILO line for 220 KV GSS Ranpur (U/C in PPP mode) by M/s HPTSL and QUARTERLY MAINTENANCE WORK at Kota end.	2018-12-14	08:00	2018-12-15	18:00	34	151
572	RRVPN	RRVPN	LINE	RAPP A (220KV)-KOTA(220KV)1	DAILY	QUARTERLY MAINTENANCE WORK	2018-12-06	08:00	2018-12-06	18:00	10	151
573	RRVPN	RRVPN	LINE	JODHPUR (400KV)-AKAL JAISALMER (400KV)	DAILY	Half yearly maintenance ta both Akal & Jodhpur end.	2018-12-12	08:30	2018-12-12	18:00	9.5	150
574	RRVPN	RRVPN	LINE	SURATGARH (400KV)-RATANGARH (400KV)2	DAILY	Maintenance work of bay equipment and line maintenance work.	2018-12-11	09:30	2018-12-11	18:00	8.5	152
575	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-BARMER (400KV)	DAILY	Quarterly Maintenance	2018-12-27	10:00	2018-12-27	18:00	8	152
576	RRVPN	RRVPN	LINE	BIKANER (400KV)-BHADLA (400KV)1	DAILY	Quarterly Maintenance	2018-12-19	15:00	2018-12-19	19:00	4	152
577	RRVPN	RRVPN	LINE	BIKANER (400KV)-BHADLA (400KV)2	DAILY	Quarterly Maintenance at Bikaner & Bhadla both ends.	2018-12-21	15:00	2018-12-21	19:00	4	152
578	RRVPN	RRVPN	LINE	SIKAR (400KV)-BIKANER (400KV)1	DAILY	Routine Bay Maintenance Work	2018-12-06	10:00	2018-12-06	13:00	3	152
579	RRVPN	RRVPN	LINE	SIKAR (400KV)-BIKANER (400KV)2	DAILY	Routine Bay Maintenance Work	2018-12-07	10:00	2018-12-07	13:00	3	152
580	RRVPN	RRVPN	LINE	BIKANER (400KV)-MERTA (400KV)	DAILY	III th QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS AND END TO END TESTING WORK BY PLCC WING.	2018-12-06	09:00	2018-12-06	17:00	8	151
581	RRVPN	RRVPN	LINE	AJMER (400KV)-PHAGI(400KV)I	DAILY	IIIrd QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2018-12-07	09:00	2018-12-07	18:00	9	149
582	RRVPN	RRVPN	LINE	AJMER (400KV)-PHAGI(400KV)II	DAILY	IIIrd QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2018-12-14	09:00	2018-12-14	18:00	9	149

583	RRVPN	RRVPN	LINE	BHARATPUR (220KV)-SIKANDRA (220KV)	CONTINUOUS	Maintenance and tree cutting alongwith replacement of earthwire of 220kV Agra-Bharatpur line and Bay work at 220kV GSS Bharatpur.	2018-12-13	09:00	2018-12-29	18:00	393	152
584	RRVPN	RRVPN	LINE	HISSAR BBMB (220KV)-CHIRAWA (220KV)	DAILY	For maintenance of of line and to replace jumper of tower no. 01	2018-12-21	08:00	2018-12-22	19:00	22	152
585	RRVPN	RRVPN	LINE	CHARKHI DADRI (220KV)-KHETRI (220KV)1	DAILY	For Bay Maintenance work	2018-12-04	08:30	2018-12-04	18:00	9.5	151
586	RRVPN	RRVPN	LINE	CHARKHI DADRI (220KV)-KHETRI (220KV)2	DAILY	For Bay Maintenance work	2018-12-06	08:30	2018-12-06	18:00	9.5	151
587	RRVPN	RRVPN	LINE	SAWAI MADHOPUR (220KV)-DAUSA (220KV)I( PG	DAILY	quarterly maintenance	2018-12-18	09:30	2018-12-18	14:30	5	152
588	RRVPN	RRVPN	LINE	KHANDAR (132KV)-SHEOPUR MPSEB-WR (132KV)+MPSE	DAILY	For Quarterly/Half yearly/ yearly Maintenance of 132 sheopur bay.(CT,CVT and LA are connected on line at khandar GSS)	2018-12-20	09:00	2018-12-20	11:00	2	-
589	RRVPN	RRVPN	LINE	BHILWARA (400KV)-AJMER (400KV)II	DAILY	Yearly maintenane of 400 KV AJMER-BHILWARA CKT-2 LINE&BAY(4452B)& ASSOCIATED EQUIPMENTS	2018-12-06	09:00	2018-12-06	17:00	8	152
590	RRVPN	RRVPN	LINE	BHILWARA (400KV)-CHHABRA (400KV)	DAILY	Yearly maintenane of 400 KV CHHABRA LINE & BAY WITH REACTOR (4352A)& ASSOCIATED EQUIPMENTS	2018-12-10	09:00	2018-12-10	17:00	8	146
591	RRVPN	RRVPN	LINE	HINDAUN (400KV)-HEERAPURA (400KV)	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-06	10:00	2018-12-06	17:00	7	150
592	RRVPN	RRVPN	LINE	PHAGI(400KV)-HEERAPURA (400KV)II	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-07	10:00	2018-12-07	17:00	7	150
593	RRVPN	RRVPN	LINE	MERTA (400KV)-HEERAPURA (400KV)	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-10	10:00	2018-12-10	17:00	7	151
594	RRVPN	RRVPN	LINE	PHAGI(400KV)-HEERAPURA (400KV)I	DAILY	4th Quaterly maintenance of 400 KV side bay Equipments	2018-12-12	10:00	2018-12-12	17:00	7	150
595	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-RAMGARHI	DAILY	Half Yearly Maintenance & Yearly Maintenance of Bay (Dia-07) of 400kV Akal-Bhadla-I line which is presently charged as 400kV Rmagarh-Aklal-I	2018-12-10	09:00	2018-12-10	15:00	6	151
596	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-RAMGARHI	DAILY	Half Yearly Maintenance & Yearly Maintenance of Dia-05 bay - 552 A and associated equipments.	2018-12-13	09:00	2018-12-13	15:00	6	151

597	RRVPN	RRVUNL	LINE	BHILWARA (400KV)-AJMER (400KV)I	DAILY	Yearly maintenane of 400 KV AJMER-BHILWARA CKT-1 LINE&BAY(4352B)& ASSOCIATED EQUIPMENTS	2018-12-05	09:00	2018-12-05	17:00	8	152
598	RRVPN	RRVPN	REACTOR	REACTOR AKAL JAISALMER (400KV)/50.00	DAILY	Half yearly maintenance	2018-12-04	08:30	2018-12-04	18:00	9.5	151
599	RRVPN	RRVPN	REACTOR	50MVAR REACTOR AKAL JAISALMER/50.00	DAILY	Half yearly maintenance	2018-12-12	08:30	2018-12-12	18:00	9.5	146
600	RRVPN	RRVPN	REACTOR	Shunt Reactor RATANGARH (400KV)/50.00	DAILY	Maintenance work of bay equipment and line maintenance work.	2018-12-19	09:30	2018-12-19	18:00	8.5	151
601	RRVPN	RRVPN	REACTOR	Series Reactor 5 BHADLA (400KV)/125.00	DAILY	Quarterly Maintenance work	2018-12-17	11:00	2018-12-17	15:00	4	152
602	RRVPN	RRVPN	REACTOR	Series Reactor 1 BHADLA (400KV)/50.00	DAILY	Quarterly Maintenance work	2018-12-19	15:00	2018-12-19	19:00	4	152
603	RRVPN	RRVPN	REACTOR	Series Reactor 2 BHADLA (400KV)/50.00	DAILY	Quarterly Maintenance work	2018-12-21	15:00	2018-12-21	19:00	4	-
604	RRVPN	RRVPN	REACTOR	Series Reactor 3 BHADLA (400KV)/50.00	DAILY	Quarterly Maintenance work	2018-12-26	11:00	2018-12-26	15:00	4	-
605	RRVPN	RRVPN	REACTOR	SHUNT REACTOR BHILWARA (400KV)/50.00	DAILY	Yearly maintenane of 400 KV CHHABRA LINE & BAY WITH REACTOR (4352A)& ASSOCIATED EQUIPMENTS	2018-12-10	09:00	2018-12-10	17:00	8	152
606	RRVPN	RRVPN	REACTOR	400KV 50MVAR LINER REACTOR FOR 400KV AKAL-RAMGARH-I AT RAMGARH/50.00	DAILY	Half Yearly Maintenance & Yearly Maintenance	2018-12-10	09:00	2018-12-10	15:00	6	151
607	RRVPN	RRVPN	REACTOR	400 kV 125 MVAR Bus Reactor at 400kV GSS Ramgarh/125.00	DAILY	Half Yearly Maintenance & Yearly Maintenance	2018-12-12	09:00	2018-12-12	15:00	6	151
608	RRVPN	RRVPN	REACTOR	400KV 50MVAR LINER REACTOR FOR 400KV AKAL-RAMGARH-II AT RAMGARH/50.00	DAILY	Half Yearly Maintenance & Yearly Maintenance	2018-12-12	09:00	2018-12-12	15:00	6	151
609	SJVNL	SJVNL	BUS	400 KV GIS Bus Bar - II	CONTINUOUS	SF6 Gas Leakage Arrest work in 400 kV Rampur - Nalagarh (Ckt -1 & 2)	2018-12-10	09:00	2018-12-31	17:00	512	145
610	SJVNL	SJVNL	BUS	400 KV GIS BUS COUPLER(RAMPUR)	CONTINUOUS	SF6 Gas Leakage Arrest Work in kV Rampur - Nalagarh (Ckt 1 & 2)	2018-12-10	09:00	2018-12-31	17:00	512	-
611	SJVNL	JSW	LINE	KARCHAM WANGTOO (400KV)-NATHPA-JHAKRI (NJPC) (400KV)1	DAILY	Installation, Testing & Commissioning of Numerical Bus Bar Differential Protection for up coming 80MVAR Bus Reactor & 25MVA, 400KV/22KV Station Transformer at existing 420KV Bus Bar Protection System of NJHPS.	2018-12-01	09:00	2018-12-02	17:00	16	-

612	SJVNL	JSW	LINE	KARCHAM WANGTOO (400KV)-NATHPA-JHAKRI (NJPC) (400KV)2	DAILY	Installation, Testing & Commissioning of Numerical Bus Bar Differential Protection for up coming 80MVAR Bus Reactor & 25MVA, 400KV/22KV Station Transformer at existing 420KV Bus Bar Protection System of NJHPS.	2018-12-01	09:00	2018-12-02	17:00	16	-
613	SJVNL	JSW	LINE	KARCHAM WANGTOO (400KV)-NATHPA-JHAKRI (NJPC) (400KV)2	CONTINUOUS	Overhauling of Hydraulic Mechanism of 420KV GIS System from OEM Expert (Mandatory M-4 level GIS Maintenance between 12-18 Years of GIS operation), APM of GIS Line Bay & Relay Testing.	2018-12-10	09:00	2018-12-12	17:00	56	-
614	SJVNL	JSW	LINE	KARCHAM WANGTOO (400KV)-NATHPA-JHAKRI (NJPC) (400KV)1	CONTINUOUS	Overhauling of Hydraulic Mechanism of 420KV GIS System from OEM Expert (Mandatory M-4 level GIS Maintenance between 12-18 Years of GIS operation), APM of GIS Line Bay & Relay Testing.	2018-12-17	09:00	2018-12-19	17:00	56	-
615	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)I	DAILY	Installation, Testing & Commissioning of Numerical Bus Bar Differential Protection for up coming 80MVAR Bus Reactor & 25MVA, 400KV/22KV Station Transformer at existing 420KV Bus Bar Protection System of NJHPS.	2018-12-01	09:00	2018-12-02	17:00	16	145
616	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)II	DAILY	Installation, Testing & Commissioning of Numerical Bus Bar Differential Protection for up coming 80MVAR Bus Reactor & 25MVA, 400KV/22KV Station Transformer at existing 420KV Bus Bar Protection System of NJHPS.	2018-12-01	09:00	2018-12-02	17:00	16	-

617	SJVNL	POWERGRID	LINE	PANCHKULA-PG (400KV)-NATHPA-JHAKRI (NJPC) (400KV)I	DAILY	Installation, Testing & Commissioning of Numerical Bus Bar Differential Protection for up coming 80MVAR Bus Reactor & 25MVA, 400KV/22KV Station Transformer at existing 420KV Bus Bar Protection System of NJHPS.	2018-12-01	09:00	2018-12-02	17:00	16	-
618	SJVNL	POWERGRID	LINE	PANCHKULA-PG (400KV)-NATHPA-JHAKRI (NJPC) (400KV)II	DAILY	Installation, Testing & Commissioning of Numerical Bus Bar Differential Protection for up coming 80MVAR Bus Reactor & 25MVA, 400KV/22KV Station Transformer at existing 420KV Bus Bar Protection System of NJHPS.	2018-12-01	09:00	2018-12-02	17:00	16	-
619	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)II	CONTINUOUS	Overhauling of Hydraulic Mechanism of 420KV GIS System from OEM Expert (Mandatory M-4 level GIS Maintenance between 12-18 Years of GIS operation), APM of GIS Line Bay & Relay Testing.	2018-12-05	09:00	2018-12-07	17:00	56	-
620	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)I	CONTINUOUS	Overhauling of Hydraulic Mechanism of 420KV GIS System from OEM Expert (Mandatory M-4 level GIS Maintenance between 12-18 Years of GIS operation), APM of GIS Line Bay & Relay Testing.	2018-12-13	09:00	2018-12-15	17:00	56	145
621	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)I	CONTINUOUS	Preparation of Injection Point for HV Testing of GIS Bus Bar, Conducting HV Testing and Revival of Injection Point for HV testing of GIS bus Bar	2018-12-13	09:00	2018-12-31	17:00	440	145
622	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)II	DAILY	FK Breaker Mechanism Rectification / Testing	2018-12-05	08:00	2018-12-07	17:00	27	-
623	SJVNL	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)I	CONTINUOUS	SF6 Gas Leakage Arrest work in 400 kV Rampur- Nalagarh Ckt-1	2018-12-17	08:00	2018-12-21	17:00	105	149
624	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)I	DAILY	HV Testing of GIS Bus Bar	2018-12-20	08:00	2018-12-20	17:00	9	145

625	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)II	DAILY	HV Testing of GIS Bus Bar	2018-12-20	08:00	2018-12-20	17:00	9	-
626	SJVNL	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)I	DAILY	HV Testing of GIS Bus Bar	2018-12-20	08:00	2018-12-20	17:00	9	149
627	SJVNL	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)II	DAILY	HV Testing of GIS Bus Bar	2018-12-20	08:00	2018-12-20	17:00	9	148
628	SJVNL	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)II	CONTINUOUS	SF6 Gas Leakage Arrest work in kV Rampur - Nallagarh (Ckt-2)	2018-12-26	08:00	2018-12-29	17:00	81	148
629	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)I	DAILY	HV testing of GIS Rampur-Nalagarh (Ckt-2)	2018-12-28	08:00	2018-12-28	17:00	9	145
630	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)-RAMPUR HEP (400KV)II	DAILY	HV testing of GIS Rampur-Nalagarh (Ckt-2)	2018-12-28	08:00	2018-12-28	17:00	9	-
631	SJVNL	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)I	DAILY	HV testing of GIS Rampur-Nalagarh (Ckt-2)	2018-12-28	08:00	2018-12-28	17:00	9	149
632	SJVNL	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)II	DAILY	HV testing of GIS Rampur-Nalagarh (Ckt-2)	2018-12-28	08:00	2018-12-28	17:00	9	148
633	SJVNL	SJVNL	REACTOR	REACTOR RAMPUR HEP (400KV)/80.00	DAILY	HV Testing of GIS Bus Bar	2018-12-20	08:00	2018-12-20	16:00	8	-
634	SJVNL	SJVNL	REACTOR	REACTOR RAMPUR HEP (400KV)/80.00	DAILY	HV testing of GIS Rampur-Nalagarh (Ckt-2)	2018-12-28	08:00	2018-12-28	17:00	9	-
635	UJVNL	UJVNL	BUS	220 kV BUS 1	DAILY	For the purpose of setting of 220 kV Bus Isolator and checking of remote/ local close/ open operation of isolators.  *There will be no any load shedding, as all load and generation shall be fed through Bus 2*	2018-12-03	09:00	2018-12-03	15:00	6	-
636	UJVNL	UJVNL	BUS	220 kV BUS 2	DAILY	For the purpose of setting of 220 kV Bus Isolator and checking of remote/ local close/ open operation of isolators.  *There will be no any load shedding, as all load shall be fed through Bus 1*	2018-12-03	15:00	2018-12-03	20:00	5	-
637	UPPTCL	UPPTCL	BUS	Transfer bus-Kasara Mau	DAILY	For routine testing and maintenance work.	2018-12-06	10:00	2018-12-06	15:00	5	145
638	UPPTCL	UPPTCL	BUS	400KV A Bus Sultanpur	DAILY	For CT replacement and M&R Work along with Bus Coupler	2018-12-17	08:00	2018-12-18	18:00	20	152

639	UPPTCL	UPPTCL	BUS	transfer bus at Simbholi	DAILY	For attending problem of 220KV Bus Isolator of 220KV Simbhaoli-Hapur9220) Line.	2018-12-03	09:00	2018-12-03	12:00	3	152
640	UPPTCL	UPPTCL	BUS	bus 1 SARNATH	CONTINUOUS	General Maintenance during S/D of 400 KV Main Bus - II No supply disturbance as the load shall be fed through Main Bus - II.	2018-12-06	08:00	2018-12-21	18:00	370	151
641	UPPTCL	UPPTCL	BUS	400KV BUS 1 AGRA	DAILY	For bus maintenance	2018-12-05	09:00	2018-12-05	17:00	8	151
642	UPPTCL	UPPTCL	BUS	400KV BUS 2 AGRA	DAILY	For bus maintenance	2018-12-06	09:00	2018-12-06	17:00	8	151
643	UPPTCL	UPPTCL	BUS	BUS A -PANKI	CONTINUOUS	"Replacement of old pantograph isolator of ICT-I"	2018-12-10	08:00	2018-12-13	18:00	82	-
644	UPPTCL	UPPTCL	BUS	BUS B-PANKI	CONTINUOUS	"Replacement of old pantograph isolator of ICT-I"	2018-12-14	08:00	2018-12-17	18:00	82	151
645	UPPTCL	UPPTCL	BUS	MAIN BUS I GORAKHPUR	DAILY	For stringing of 400KV side Jack busbar for installation of additional 240MVA T.F bay and extension work of existing main busbar.I, II & Transfer busbar for new TBC bay.	2018-12-20	10:00	2018-12-22	17:00	21	-
646	UPPTCL	UPPTCL	BUS	400 kV Main bus 2 at Gorakhpur (UPPTCL)	DAILY	For stringing of 400KV side Jack busbar for installation of additional 240MVA T.F bay and extension work of existing main busbar.I, II & Transfer busbar for new TBC bay.	2018-12-20	10:00	2018-12-22	17:00	21	147
647	UPPTCL	UPPTCL	BUS	400 kV transfer bus at Gorakhpur	DAILY	For stringing of 400KV side Jack busbar for installation of additional 240MVA T.F bay and extension work of existing main busbar.I, II & Transfer busbar for new TBC bay.	2018-12-20	10:00	2018-12-22	17:00	21	-
648	UPPTCL	UPPTCL	BUS	400 kV Bus1 Greater Noida	DAILY	Annual Maintenance (without interruption)	2018-12-20	09:00	2018-12-20	17:00	8	-
649	UPPTCL	UPPTCL	BUS	400 kV Bus 2 Greater Noida	DAILY	Annual Maintenance (without interruption)	2018-12-21	09:00	2018-12-22	17:00	16	-

650	UPPTCL	UPPTCL	BUS	400 kV Bus 1 Hapur	DAILY	Annual Maintenance (without interruption)	2018-12-01	09:00	2018-12-01	17:00	8	-
651	UPPTCL	UPPTCL	BUS	400 kV Bus 2 Hapur	DAILY	Annual Maintenance (without interruption)	2018-12-03	09:00	2018-12-03	17:00	8	-
652	UPPTCL	UPPTCL	BUS	400 kV Bus coupler at Muradnagar	DAILY	For the work of replacement of 400KV CT.	2018-12-05	08:00	2018-12-05	17:00	9	-
653	UPPTCL	UPPTCL	BUS	400 kV transfer bus coupler at Muradnagar	DAILY	For the work of replacement of 400KV CT.	2018-12-06	08:00	2018-12-06	17:00	9	-
654	UPPTCL	POWERGRID	ICT	ICT01 RAEBAREILLY (220KV)(POWERGRID)/100	DAILY	Replacement of 132KV Jack bus at 132KV S.S Amawan from 1x Panther To 2x Moose	2018-12-17	09:00	2018-12-19	13:00	12	150
655	UPPTCL	POWERGRID	ICT	ICT032 RAEBAREILLY (220KV)(POWERGRID)/100	DAILY	Replacement of 132KV Jack bus at 132KV S.S Amawan from 1x Panther To 2x Moose	2018-12-17	09:00	2018-12-19	13:00	12	152
656	UPPTCL	POWERGRID	ICT	ICT02 RAEBAREILLY (220KV)(POWERGRID)/100	CONTINUOUS	Replacement of Jumpers of 132KV ICT . II (200MVA) at Amawan	2018-12-17	09:00	2018-12-19	18:00	57	152
657	UPPTCL	UPPTCL	ICT	ICT -2/3x500 MVA	DAILY	Annual Maintenance (One hour)	2018-12-13	09:00	2018-12-13	10:00	1	151
658	UPPTCL	UPPTCL	ICT	ICT -2/3x500 MVA	DAILY	Annual Maintenance (One hour)	2018-12-15	09:00	2018-12-15	10:00	1	151
659	UPPTCL	UPPTCL	ICT	ICT -2/3x500 MVA	DAILY	Annual Maintenance (One hour)	2018-12-17	09:00	2018-12-17	10:00	1	151
660	UPPTCL	UPPTCL	ICT	ICT -2/3x500 MVA	DAILY	Annual Maintenance (One hour)	2018-12-19	09:00	2018-12-19	10:00	1	151
661	UPPTCL	UPPTCL	ICT	ICT III MAU/200	DAILY	For routine testing and maintenance work.	2018-12-03	10:00	2018-12-03	15:00	5	149
662	UPPTCL	UPPTCL	ICT	ICT02 LUCKNOW (Sarojini Nagar) 400-UP(UPPTCL)/315	DAILY	For routine testing and bay maintenance works.	2018-12-05	09:00	2018-12-05	16:00	7	151
663	UPPTCL	UPPTCL	ICT	ICT01 SULTANPUR (400KV)(UPPTCL)/240	CONTINUOUS	For Complete gasket replacement by manufacturing Company	2018-12-17	08:00	2018-12-21	18:00	106	152
664	UPPTCL	UPPTCL	ICT	ICT02 SULTANPUR (400KV)(UPPTCL)/240	DAILY	For routine bay maintenance works	2018-12-05	08:00	2018-12-05	18:00	10	151
665	UPPTCL	UPPTCL	ICT	ICT03 SULTANPUR (400KV)(UPPTCL)/315	CONTINUOUS	For Complete gasket replacement by manufacturing Company	2018-12-24	08:00	2018-12-28	18:00	106	146
666	UPPTCL	UPPTCL	ICT	ICT03 GREATER NOIDA (400KV)(UPPTCL)/500	DAILY	For attending problematic tropozee of PG Isolator under main Bus A and replacement of old Las alongwith 400KV Main Bus-A .	2018-12-02	08:00	2018-12-02	14:00	6	152



667	UPPTCL	UPPTCL	ICT	ICT02 MUZZAFARNAGAR-UP (400KV)(UPPTCL)/240	CONTINUOUS	For top replacement of all top cover gasket recommended by M/s.EMCO Ltd.During S/D of 400/220/33KV ICT-II load demand can be met from remaining 02 Nos. ICTs.	2018-12-04	10:00	2018-12-08	18:00	104	149
668	UPPTCL	UPPTCL	ICT	ICT04 GREATER NOIDA (400KV)(UPPTCL)/500	DAILY	For routine testing and general maintenance and replacement of old LAs.	2018-12-09	09:00	2018-12-09	13:00	4	151
669	UPPTCL	UPPTCL	ICT	ICT02 MURADNAGAR NEW (400KV)(UPPTCL)/240	DAILY	For general maintenance works, testing and tightening	2018-12-11	10:00	2018-12-11	15:00	5	152
670	UPPTCL	UPPTCL	ICT	ICT02 GREATER NOIDA (400KV)(UPPTCL)/315	DAILY	For attending oil leakage and replacement of old LAs.	2018-12-16	08:00	2018-12-16	14:00	6	151
671	UPPTCL	UPPTCL	ICT	ICT01 GREATER NOIDA (400KV)(UPPTCL)/315	DAILY	For attending oil leakage and replacement of old LAs.	2018-12-23	09:00	2018-12-23	16:00	7	148
672	UPPTCL	UPPTCL	ICT	ICT01 SARNATH (400KV)(UPPTCL)/315	CONTINUOUS	General Maintenance during S/D of 400 KV Main Bus - II. During the S/D load will be taken by 315 MVA T/F - III & 500 MVA T/F.	2018-12-14	08:00	2018-12-15	18:00	34	152
673	UPPTCL	UPPTCL	ICT	ICT03 SARNATH (400KV)(UPPTCL)/315	CONTINUOUS	General Maintenance during S/D of 400 KV Main Bus - II. During the S/D load will be taken by 315 MVA T/F - I & 500 MVA T/F.	2018-12-18	08:00	2018-12-19	18:00	34	152
674	UPPTCL	UPPTCL	ICT	ICT01 PANKI (400KV)(UPPTCL)/240	CONTINUOUS	Replacement of 240 MVA ICT-I by 315 MVA ICT for increasing capacity	2018-12-10	08:00	2018-12-30	18:00	490	149
675	UPPTCL	UPPTCL	ICT	ICT ORAI (400KV)(UPPTCL)/315	CONTINUOUS	For Routine Maintenance of bay and Protection Checking of T/F	2018-12-11	09:00	2018-12-11	19:00	10	152
676	UPPTCL	UPPTCL	ICT	ICT02 SARNATH (400KV)(UPPTCL)/500	CONTINUOUS	General Maintenance during S/D of 400 KV Main Bus - II. During the S/D load will be taken by 315 MVA T/F - I & III.	2018-12-20	08:00	2018-12-21	18:00	34	151
677	UPPTCL	UPPTCL	ICT	ICT-II Agra South/200 MVA	DAILY	Maintenance and testing	2018-12-04	09:00	2018-12-04	17:00	8	151
678	UPPTCL	POWERGRID	LINE	ANPARA-B (400KV)-SARNATH (400KV)1	CONTINUOUS	For replacement of disc insulator by polymer and disc cleaning work.	2018-12-21	08:00	2018-12-30	18:00	226	152

679	UPPTCL	POWERGRID	LINE	ANPARA-B (400KV)-SARNATH (400KV)2	DAILY	For replacement of disc insulator by polymer and disc cleaning work.	2018-12-01	08:00	2018-12-10	18:00	100	152
680	UPPTCL	POWERGRID	LINE	BALIA(400KV)-MAU (400KV)I	DAILY	For routine testing and maintenance work.	2018-12-04	10:00	2018-12-04	15:00	5	-
681	UPPTCL	POWERGRID	LINE	BALIA(400KV)-MAU (400KV)II	DAILY	For routine testing and maintenance work.	2018-12-05	10:00	2018-12-05	15:00	5	-
682	UPPTCL	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-LUCKNOW (Sarojini Nagar) 400-UP	DAILY	Replacement of disc insulator & Lopping,Chopping of Trees	2018-12-14	09:00	2018-12-15	18:00	18	152
683	UPPTCL	POWERGRID	LINE	BAREILY-PG (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	DAILY	For routine testing and bay maintenance works.	2018-12-10	09:00	2018-12-10	16:00	7	152
684	UPPTCL	POWERGRID	LINE	NAWADA (400KV)-GREATER NOIDA (400KV)	CONTINUOUS	Stringing on diverted route on towers of 400KV Greater Noida-Nawada line due to DFCC works.	2018-12-02	08:00	2018-12-09	18:00	178	152
685	UPPTCL	POWERGRID	LINE	DADRI-THERMAL (400KV)-GREATER NOIDA (400KV)	CONTINUOUS	Stringing on diverted route on towers of 400KV Greater Noida-Dadri Line due to DFCC works.	2018-12-10	08:00	2018-12-20	18:00	250	149
686	UPPTCL	POWERGRID	LINE	VARANASI (400KV)-SARNATH (400KV)I	CONTINUOUS	General Maintenance during S/D of 400 KV Main Bus - II	2018-12-16	08:00	2018-12-17	18:00	34	152
687	UPPTCL	POWERGRID	LINE	VARANASI (400KV)-SARNATH (400KV)II	CONTINUOUS	General Maintenance during S/D of 400 KV Main Bus - II	2018-12-10	08:00	2018-12-11	18:00	34	152
688	UPPTCL	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-UNNAO (400KV)1	DAILY	General Maintenance of feeder at 400 KV S.S,Unnao	2018-12-13	08:00	2018-12-13	18:00	10	151
689	UPPTCL	POWERGRID	LINE	MEERUT (400KV)-MUZZAFARNAGAR-UP (400KV)	DAILY	For adjustment of interlocking of isolators.	2018-12-11	08:00	2018-12-12	18:00	20	-
690	UPPTCL	POWERGRID	LINE	AGRA-UP (400KV)-FATEHBAD _AGRA(400KV)	DAILY	Tightening of jumper and replacement of damage jumper and other line maintenance work.For replacement of analogue PLCC with DPC	2018-12-13	08:00	2018-12-17	18:00	50	152

691	UPPTCL	PTCUL	LINE	NARA (220KV)-ROORKEE PTCUL (220KV)+UPPT	DAILY	For tree cutting, repairing of conductor, inspection of insulators & other maintenance works.	2018-12-06	09:00	2018-12-07	18:00	18	152
692	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-MAU (400KV)	DAILY	For replacement of disc insulator by polymer and disc cleaning work.	2018-12-11	08:00	2018-12-25	18:00	150	152
693	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-OBRA (400KV)	CONTINUOUS	Diversion of 400 KV Obra.Anpara L.2 line from the proposed coal handling area of 2x660 MW Obra C TPP.	2018-12-15	08:00	2018-12-28	18:00	322	147
694	UPPTCL	UPPTCL	LINE	LUCKNOW (Sarojini Nagar) 400-UP-UNNAO (400KV)	DAILY	Replacement of disc insulator & Lopping.Chopping of Trees	2018-12-16	09:00	2018-12-17	18:00	18	152
695	UPPTCL	UPPTCL	LINE	SULTANPUR (400KV)-AZAMGARH (400KV)	CONTINUOUS	Erection of LILO Tower No. 196 of under construction LILO of Sultanpur . Azamgarh line at Tanda Thermal Stage.II	2018-12-02	08:00	2018-12-08	18:00	154	152
696	UPPTCL	UPPTCL	LINE	LUCKNOW-Kursi Road (400KV) PG-SULTANPUR (400KV)	DAILY	Line maintenance and other associated works	2018-12-12	08:00	2018-12-13	18:00	20	151
697	UPPTCL	UPPTCL	LINE	UNNAO (400KV)-BAREILY-UP (400KV)I	DAILY	Balance stringing of earthwire between tower no. 667 to 669 of Ckt.II. & Twer No. 661 to 663 Ckt.I, Conductor replacement between tower no. 745 to S.S gantry R & B Phase of IICkt.	2018-12-26	09:00	2018-12-28	18:00	27	152
698	UPPTCL	UPPTCL	LINE	UNNAO (400KV)-BAREILY-UP (400KV)II	DAILY	Balance stringing of earthwire between tower no. 667 to 669 of Ckt.II. & Twer No. 661 to 663 Ckt.I, Conductor replacement between tower no. 745 to S.S gantry R & B Phase of IICkt.	2018-12-26	09:00	2018-12-28	18:00	27	152
699	UPPTCL	UPPTCL	LINE	SULTANPUR (400KV)-TANDA	CONTINUOUS	Diversion of this line along with ROW of under construction UP Purvanchal Express way	2018-12-21	08:00	2018-12-23	18:00	58	152
700	UPPTCL	UPPTCL	LINE	UNCHAHAR (220KV)-RAEBAREILLY (220KV)1	DAILY	Disc cleaning	2018-12-07	09:00	2018-12-08	18:00	18	152
701	UPPTCL	UPPTCL	LINE	UNCHAHAR (220KV)-RAEBAREILLY (220KV)2	DAILY	Disc cleaning	2018-12-10	09:00	2018-12-11	18:00	18	152
702	UPPTCL	UPPTCL	LINE	MURADNAGAR (400KV)-ALIGARH (400KV)	CONTINUOUS	For the work of replacement of 400KV CT & CVT.	2018-12-01	08:00	2018-12-02	18:00	34	151
703	UPPTCL	UPPTCL	LINE	MURADNAGAR (400KV)-ataur (ghaziabad)	DAILY	For the work of replacement of 400KV CVT.	2018-12-07	08:00	2018-12-07	18:00	10	-

704	UPPTCL	UPPTCL	LINE	ataur (ghaziabad)-MUZZAFARNAGAR-UP (400KV)	DAILY	For tree cutting, repairing of conductor, inspection of insulators & other maintenance works.	2018-12-12	09:00	2018-12-13	18:00	18	150
705	UPPTCL	UPPTCL	LINE	MUZZAFARNAGAR-UP (400KV)-VISHNUPRAYAG (400KV)	DAILY	For lopping and chopping of tree branches, tree cutting & tightening of jumper.During S/D load will flow through 400KV Muzaffarangar-Sringagar and 400KV Srinagar-Vishnuprayag Line.	2018-12-20	09:00	2018-12-23	17:00	32	151
706	UPPTCL	UPPTCL	LINE	AZAMGARH (400KV)-SARNATH (400KV)	CONTINUOUS	General Maintenance during S/D of 400 KV Main Bus - II	2018-12-08	08:00	2018-12-09	18:00	34	152
707	UPPTCL	UPPTCL	LINE	ORAI (400KV)-BANDA (400KV)1	DAILY	Lopping chopping of trees and Jumper repairing. For Routine Maintenance of bay	2018-12-04	09:00	2018-12-04	19:00	10	148
708	UPPTCL	UPPTCL	LINE	MURADNAGAR II (400KV)-MATHURA (400KV)	DAILY	For general maintenance work and tightening works.	2018-12-19	10:00	2018-12-19	15:00	5	149
709	UPPTCL	UPPTCL	LINE	GAZIPUR (220KV)-NOIDA SECTOR 20 (220KV)	CONTINUOUS	LILO at 220KV Sub-station, Sector-38A (Botanical Garden).	2018-12-20	08:00	2018-12-27	18:00	178	-
710	UPPTCL	UPPTCL	LINE	MUZZAFARNAGAR-UP (400KV)-Srinagar HEP- ALAKANANDA (400KV)	DAILY	For lopping and chopping of tree branches, tree cutting & tightening of jumper.During S/D load will flow through 400KV Muzaffarangar-Vishnuprayag and 400KV Srinagar-Vishnuprayag Line.	2018-12-24	09:00	2018-12-27	17:00	32	151
711	UPPTCL	UPPTCL	LINE	Srinagar HEP- ALAKANANDA (400KV)-VISHNUPRAYAG (400KV)	DAILY	For lopping and chopping of tree branches, tree cutting & tightening of jumper.During S/D load will flow through 400KV Muzaffarangar-Srinagar and 400KV Muzaffarangar-Vishnuprayag Line	2018-12-28	09:00	2018-12-29	17:00	16	151
712	UPPTCL	UPPTCL	LINE	REWA ROAD (220KV)-SARANGPUR (400KV)1	CONTINUOUS	Replacement of relay panel under PSDF	2018-12-02	08:00	2018-12-03	18:00	34	-
713	UPPTCL	UPPTCL	LINE	REWA ROAD (220KV)-SARANGPUR (400KV)2	CONTINUOUS	Replacement of relay panel under PSDF	2018-12-04	08:00	2018-12-05	18:00	34	-
714	UPPTCL	UPPTCL	LINE	FATEHBAD _AGRA(400KV)-AGRA SOUTH2	DAILY	Tightening of jumper cutting of tree & other maintenance OPG etc.	2018-12-04	09:00	2018-12-06	17:00	24	-

715	UPPTCL	UPPTCL	LINE	ORAI (400KV)-Orai (400KV)1	DAILY	For Commissioning of new Energy Meter in series	2018-12-04	09:00	2018-12-04	19:00	10	-
716	UPPTCL	UPPTCL	LINE	ORAI (400KV)-Orai (400KV)2	CONTINUOUS	For Commissioning of new Energy Meter in series	2018-12-06	09:00	2018-12-06	19:00	10	-
717	UPPTCL	UPPTCL	LINE	SHERKOT-KALAGARHSC	CONTINUOUS	For shifting of 132KV Line as existing line is obstructing work under construction NH-74 Haridwar-Kashipur Highway. During S/D supply of 132KV S/S Afzalgarh will be fed through 132KV Afzalgarh-Kalagarh line for which at least 25MW load will be required from Kalagarh end.	2018-12-15	08:00	2018-12-24	17:00	225	152
718	UPPTCL	UPPTCL	LINE	NEHTAUR (220KV)-AFZALGARHSC	CONTINUOUS	For shifting of 132KV Line as existing line is obstructing work under construction NH-74 Haridwar-Kashipur Highway. During S/D supply of 132KV S/S Afzalgarh will be fed through 132KV Afzalgarh-Kalagarh line for which atleast 25MW load will be required from Kalagarh end.	2018-12-15	08:00	2018-12-24	17:00	225	152
719	UPPTCL	UPPTCL	REACTOR	400 kV Bus Reactor Bareilly/80.00	DAILY	For routine Maintenance of Reactor like tightening, Cleaning, Oiling, greasing including all equipments of associated Bay.	2018-12-06	09:00	2018-12-06	17:00	8	146
720	UPPTCL	UPPTCL	REACTOR	Unnao- Bareily Ckt-II line reactor/50.00	CONTINUOUS	For Complete Certrifusing of Oil including attending the leakage of oil from 50MVAR Line Reactor alongwith Routine maintenance.	2018-12-10	09:00	2018-12-15	17:00	128	-
721	UPPTCL	UPPTCL	REACTOR	REACTOR MATHURA (400KV)/80.00	DAILY	"Annual Testing: BDV,PPM,SFRA TAN DELTA of Bushings etc of Reactor and Testing of associated CB Relays, CT,CVT and LA. "	2018-12-05	08:00	2018-12-06	19:00	22	150