

**Report for Outage Approval by OCC meeting no. 163**

Sr.No	Request by	Element Owner	Element Type	Element Name	Mode	Reason	Outage Request				Total Hours	Last OCC Numbe
							From Date	From Time	To Date	To Time		
1	K-THDC	THDC	GENCO	Koteshwar-U4/100	CONTINUOUS	For Annual Maintenance of Unit 4	2019-10-01	10:00	2019-10-30	18:30	704.5	-
2	NTPC	NTPC	GENCO	Rihand TPS-U2/500	CONTINUOUS	Rihand U#2: Boiler+ APH Seal adjustment+ R&M of Mill APH+ Eco .coil replacement 50 days, already approved from 25.09.19-20.10.19 in 162nd OCC.	2019-10-20	00:00	2019-11-05	18:30	402.5	145
3	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-1/800	CONTINUOUS	section at Tower No.-3451 & 3474 due to Diversion Work of 800 KV HVDC BNC-Agra TL infringing the corridor of 'Purvanchal Expressway' (UPEIDA) (Diversion route Line	2019-10-02	06:00	2019-10-06	18:00	108	162
4	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-2/800	CONTINUOUS	section at Tower No.-3451 & 3474 due to Diversion Work of 800 KV HVDC BNC-Agra TL infringing the corridor of 'Purvanchal Expressway' (UPEIDA) (diversion route line	2019-10-02	06:00	2019-10-06	18:00	108	162
5	POWERGRID	POWERGRID	HVDC	KURUKSHETRA-CHAMPA POLE-1/1500	DAILY	For fixing Earth wire VD, Grading Ring, Copper bond, Rigid Spacer And CC Ring Nut bolts - By Orai S/S	2019-10-09	09:00	2019-10-09	17:00	8	-
6	POWERGRID	POWERGRID	HVDC	KUREKSHETRA -CHAMPA POLE -II/800	DAILY	For fixing Earth wire VD, Grading Ring, Copper bond, Rigid Spacer And CC Ring Nut bolts - by Orai S/S	2019-10-10	09:00	2019-10-10	17:00	8	158
7	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-2/800	DAILY	AMP of Valve cooling plant, DC Yard, Valve Hall, Conv trf, VESDA Testing, Cleaning, CNG set load test, C & Tan delta of DC side bushing at Agra S/S	2019-10-09	09:00	2019-10-12	18:00	36	162
8	POWERGRID	POWERGRID	HVDC	Agra-APD Pole 4/1500	DAILY	AMP of Valve cooling plant, DC Yard, Valve Hall, Conv trf, VESDA Testing, Cleaning, CNG set load test at Agra S/S	2019-10-14	09:00	2019-10-17	18:00	36	162
9	POWERGRID	POWERGRID	HVDC	Rihand-Dadri Pole 1/500	CONTINUOUS	For AMP WORK at Rihand S/S	2019-10-30	08:00	2019-11-04	18:00	130	-
10	POWERGRID	POWERGRID	HVDC	AGRA-ALIPURDUAR POLE-3/800	CONTINUOUS	section at Tower No.-3451 & 3474 due to Diversion Work of 800 KV HVDC BNC-Agra TL infringing the corridor of 'Purvanchal Expressway' (UPEIDA) (Diversion route Line	2019-10-02	06:00	2019-10-06	18:00	108	162
11	POWERGRID	POWERGRID	HVDC	Agra-APD Pole 4/1500	CONTINUOUS	section at Tower No.-3451 & 3474 due to Diversion Work of 800 KV HVDC BNC-Agra TL infringing the corridor of 'Purvanchal Expressway' (UPEIDA). (Diversion route Line	2019-10-02	06:00	2019-10-06	18:00	108	162
12	POWERGRID	POWERGRID	HVDC	BALIA-BHIWADI POLE-1/500	CONTINUOUS	For Stringing work for 03 nos. diversion of Line under Purvanchal Express way construction(Line sketch Enclosed)	2019-10-16	08:00	2019-10-19	18:00	82	161
13	POWERGRID	POWERGRID	HVDC	BALIA-BHIWADI POLE-2/500	CONTINUOUS	For Stringing work for 03 nos. diversion of Line under Purvanchal Express way construction. (Line sketch enclosed)	2019-10-16	08:00	2019-10-19	18:00	82	161
14	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-1/800	DAILY	For attending the broken jumper pad at tower location 2432. S/D requested by ER1	2019-10-11	10:00	2019-10-11	15:00	5	162

15	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-2/800	DAILY	For attending the broken jumper pad at tower location 2432. S/D requested by ER1	2019-10-10	10:00	2019-10-10	15:00	5	162
16	BBMB	BBMB	LINE	BALLABGARH BBMB (220KV)-SAMAYPUR (220KV)3	DAILY	Yearly Mtc.	2019-10-01	08:00	2019-10-01	17:00	9	157
17	BBMB	HVPNL	LINE	PANIPAT BBMB (220KV)-PANIPAT THERMAL POWER STATIONII	DAILY	Yearly Mtc.	2019-10-01	08:00	2019-10-01	17:00	9	156
18	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-HISSAR BBMB (220KV)1	CONTINUOUS	Replacement of breaker at Bhiwani S/S	2019-10-03	08:00	2019-10-06	17:00	81	158
19	BBMB	HVPNL	LINE	PANIPAT BBMB (220KV)-PANIPAT THERMAL POWER STATIONI	DAILY	Yearly Mtc.	2019-10-03	08:00	2019-10-03	17:00	9	156
20	BBMB	BBMB	LINE	BARNALA (220KV)-SANGRUR (220KV)	DAILY	Mtc. of transmission line	2019-10-03	08:00	2019-10-04	17:00	18	162
21	BBMB	BBMB	LINE	GANGUWAL (220KV)-JAMALPUR (220KV)I	CONTINUOUS	Replacement of HBB Ckt. Breaker with New CGL make Ckt. Breaker at Jamalpur	2019-10-03	08:00	2019-10-07	17:00	105	157
22	BBMB	BBMB	LINE	DHULKOTE (220KV)-PANIPAT BBMB (220KV)I	DAILY	Yearly Mtc.	2019-10-04	08:00	2019-10-04	17:00	9	156
23	BBMB	BBMB	LINE	DHULKOTE (220KV)-PANIPAT BBMB (220KV)II	DAILY	Yearly Mtc.	2019-10-07	08:00	2019-10-07	17:00	9	156
24	BBMB	BBMB	LINE	PANIPAT BBMB (220KV)-KURUKSHETRA BBMB (220KV)	DAILY	Yearly Mtc.	2019-10-09	08:00	2019-10-09	17:00	9	157
25	BBMB	BBMB	LINE	BALLABGARH BBMB (220KV)-CHARKHI DADRI (220KV)	CONTINUOUS	Replacement of breaker at Ch. Dadri S/S	2019-10-09	08:00	2019-10-13	17:00	105	160
26	BBMB	BBMB	LINE	DHULKOTE (220KV)-GANGUWAL (220KV)I	DAILY	Yearly mtc. of equipment & Substation.	2019-10-09	08:00	2019-10-10	17:00	18	158
27	BBMB	BBMB	LINE	BHAKRA RIGHT (220KV)-JAMALPUR (220KV)I	CONTINUOUS	Replacement of HBB Ckt. Breaker with New CGL make Ckt. Breaker at Jamalpur	2019-10-09	08:00	2019-10-13	17:00	105	157
28	BBMB	BBMB	LINE	JALLANDHAR BBMB (220KV)-JAMSHER (220KV)1	DAILY	Yearly mtc. of the substation equipment.	2019-10-10	08:00	2019-10-10	17:00	9	157
29	BBMB	BBMB	LINE	BARNALA (220KV)-LEHRA MOHABAT (200KV)	DAILY	Mtc. of transmission line	2019-10-10	08:00	2019-10-11	17:00	18	162
30	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-HISSAR BBMB (220KV)2	CONTINUOUS	Replacement of breaker at Bhiwani S/S	2019-10-14	08:00	2019-10-17	17:00	81	158
31	BBMB	BBMB	LINE	HISSAR BBMB (220KV)-SANGRUR (220KV)I	DAILY	Yearly mtc. of the substation equipment	2019-10-14	08:00	2019-10-14	17:00	9	158

32	BBMB	BBMB	LINE	BHAKRA RIGHT (220KV)-JAMALPUR (220KV)II	CONTINUOUS	Replacement of HBB Ckt. Breaker with New CGL make Ckt. Breaker at Jamalpur.	2019-10-14	08:00	2019-10-18	17:00	105	157
33	BBMB	BBMB	LINE	HISSAR BBMB (220KV)-SANGRUR (220KV)II	DAILY	Yearly mtc. of the substation equipment	2019-10-15	08:00	2019-10-15	17:00	9	158
34	BBMB	PSTCL	LINE	JALLANDHAR BBMB (220KV)-BUTARI	DAILY	Yearly mtc. of the substation equipment.	2019-10-15	08:00	2019-10-15	17:00	9	157
35	BBMB	BBMB	LINE	BARNALA (220KV)-SANGRUR (220KV)	DAILY	Yearly Mtc.	2019-10-18	08:00	2019-10-18	17:00	9	162
36	BBMB	BBMB	LINE	JAMALPUR (220KV)-SANGRUR (220KV)II	DAILY	Yearly mtc. of line & substation equipment.	2019-10-19	08:00	2019-10-19	17:00	9	158
37	BBMB	BBMB	LINE	JAMALPUR (220KV)-SANGRUR (220KV)I	CONTINUOUS	Replacement of HBB Ckt. Breaker with New CGL make Ckt. Breaker at Jamalpur	2019-10-21	08:00	2019-10-25	17:00	105	158
38	BBMB	BBMB	LINE	BATHINDA-LEHRA MOHABAT (200KV)S/C	DAILY	Mtc. of transmission line	2019-10-23	08:00	2019-10-24	17:00	18	151
39	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-CHARKHI DADRI (220KV)3	DAILY	Yearly Mtc.	2019-10-24	08:00	2019-10-24	17:00	9	156
40	BBMB	BBMB	LINE	DHULKOTE (220KV)-GANGUWAL (220KV)II	DAILY	Yearly Mtc.	2019-10-24	08:00	2019-10-25	17:00	18	158
41	BBMB	BBMB	LINE	GANGUWAL (220KV)-JAGADHRI (220KV)	DAILY	Pre-winter/Yearly Mtc. of Line & allied S/Stn. Equipment	2019-10-24	08:00	2019-10-26	17:00	27	158
42	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-CHARKHI DADRI (220KV)4	DAILY	Yearly Mtc.	2019-10-25	08:00	2019-10-25	17:00	9	156
43	BBMB	BBMB	LINE	BHIWANI BBMB (400KV)-RAJPURA (400KV)	DAILY	Yearly Mtc.	2019-10-29	08:00	2019-10-30	17:00	18	153
44	BBMB	BBMB	LINE	JAGADHRI (220KV)-KURUKSHETRA BBMB (220KV)	DAILY	Pre-winter/Yearly Mtc. of Line & allied S/Stn. Equipment	2019-10-30	08:00	2019-10-31	17:00	18	158
45	BBMB	BBMB	LINE	PANCHKULA-PG (400KV)-PANIPAT BBMB (400KV)	DAILY	Yearly Mtc.	2019-10-17	08:00	2019-10-18	17:00	18	154
46	BBMB	BBMB	LINE	JALLANDHAR BBMB (220KV)-DASUYA (220KV)	DAILY	Providing new coupling capacitor and mtc. of line	2019-10-31	08:00	2019-10-31	17:00	9	158
47	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-CHARKHI DADRI (220KV)1	CONTINUOUS	Errction of Tower No. 8o to 82 by NHAI authorities	2019-10-01	08:00	2019-10-21	17:00	489	162
48	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-CHARKHI DADRI (220KV)2	CONTINUOUS	Errction of Tower No. 8o to 82 by NHAI authorities	2019-10-01	08:00	2019-10-21	17:00	489	162

49	BBMB	BBMB	LINE	BHAKRA LEFT (220KV)-GANGUWAL (220KV)1	DAILY	yearly mtc of sub station equipment	2019-10-03	08:00	2019-10-04	17:00	18	151
50	BBMB	HVPNL	LINE	PANIPAT BBMB (220KV)-CHAJJPURI	DAILY	Yearly mtc	2019-10-24	08:00	2019-10-24	17:00	9	156
51	BBMB	HVPNL	LINE	PANIPAT BBMB (220KV)-CHAJJPURII	DAILY	yearly mtc	2019-10-30	08:00	2019-10-30	17:00	9	156
52	BBMB	BBMB	LINE	BHAKRA RIGHT (220KV)-GANGUWAL (220KV)1	DAILY	Annual mtc.	2019-10-03	08:00	2019-10-04	17:00	18	162
53	BBMB	BBMB	LINE	BHAKRA RIGHT (220KV)-GANGUWAL (220KV)2	DAILY	Annual mtc.	2019-10-09	08:00	2019-10-10	17:00	18	157
54	DTL	DTL	LINE	NARELA (220KV)-MANDOLA (220KV)1	CONTINUOUS	PSDF. 220kV Bus-II at Narela shall be made off because of crane movement for 01-02 days.	2019-10-03	06:00	2019-10-06	17:00	83	155
55	DTL	DTL	LINE	NARELA (220KV)-MANDOLA (220KV)2	CONTINUOUS	PSDF. 220kV Bus-II at Narela shall be made off because of crane movement for 01-02 days.	2019-10-07	06:00	2019-10-10	17:00	83	155
56	DTL	BBMB	LINE	NARELA (220KV)-ROHTAK ROAD DELHI (220KV)1	CONTINUOUS	PSDF. 220kV Bus-I at Narela shall be made off because of crane movement for 01-02 days.	2019-10-11	06:00	2019-10-14	17:00	83	155
57	DTL	DTL	LINE	WAZIRABAD (220KV)-MANDOLA (220KV)1	DAILY	Tightening of Jumpers as per Preventive maintenance schedule.	2019-10-09	07:00	2019-10-09	17:00	10	161
58	DTL	DTL	LINE	WAZIRABAD (220KV)-MANDOLA (220KV)2	DAILY	Tightening of Jumpers as per Preventive maintenance schedule.	2019-10-11	07:00	2019-10-11	17:00	10	161
59	DTL	DTL	LINE	WAZIRABAD (220KV)-MANDOLA (220KV)3	DAILY	Tightening of Jumpers as per Preventive maintenance schedule.	2019-10-16	07:00	2019-10-16	17:00	10	161
60	DTL	DTL	LINE	WAZIRABAD (220KV)-MANDOLA (220KV)4	DAILY	Tightening of Jumpers as per Preventive maintenance schedule.	2019-10-18	07:00	2019-10-18	17:00	10	161
61	DTL	DTL	LINE	WAZIRABAD (220KV)-MANDOLA (220KV)1	DAILY	Repair sleeve joint on Top phase conductor between tower no 19 & 20.	2019-10-23	17:16	2019-10-23	17:16	0	161
62	DTL	DTL	LINE	WAZIRABAD (220KV)-MANDOLA (220KV)3	DAILY	Jointing of Jumper on bottom phase conductor at Tower no. 52.	2019-10-25	07:00	2019-10-25	17:00	10	161
63	DTL	RRVPN	LINE	BADARPUR (220KV)-ALWAR MIA (220KV)	DAILY	ALIGNMENT OF BUS-2 ISLATOR OF ALWAR CKT.	2019-10-01	09:30	2019-10-01	15:30	6	160
64	HVPNL	HVPNL	LINE	DAULTABAD (400KV)-JHAJJAR-APCPL (400KV)1	DAILY	For half yearly maintenance of transmission line	2019-10-04	10:00	2019-10-04	17:00	7	162
65	HVPNL	HVPNL	LINE	DAULTABAD (400KV)-JHAJJAR-APCPL (400KV)2	DAILY	For half yearly maintenance of transmission line	2019-10-07	10:00	2019-10-07	17:00	7	157

66	HVPNL	HVPNL	LINE	DAULTABAD (400KV)-GURGAON (400KV)1	DAILY	For half yearly maintenance of transmission line	2019-10-09	10:00	2019-10-09	17:00	7	161
67	HVPNL	HVPNL	LINE	DAULTABAD (400KV)-GURGAON (400KV)2	DAILY	For half yearly maintenance of transmission line	2019-10-11	10:00	2019-10-11	17:00	7	161
68	HVPNL	HVPNL	LINE	DHANONDA (400KV)-JHAJJAR-CLP (400KV)2	DAILY	For replacement of Line breaker Driving Mechanism with new spare Drive by Firm Engineer	2019-10-10	08:00	2019-10-10	16:00	8	161
69	HVPNL	HVPNL	LINE	DHANONDA (400KV)-JHAJJAR-CLP (400KV)1	DAILY	Isolator jaw replacement work	2019-10-01	09:00	2019-10-01	17:00	8	161
70	PRADESH STATE ELECTRICITY	PTCUL	LINE	KHODRI (220KV)-MAJRI-HP (220KV)1	DAILY	(PTCUL) & Majri (HPSEBL) end. Installation, testing and commissioning of Disturbance Recorders, Bus Bar Protection at Majri end.	2019-09-29	09:00	2019-09-29	18:00	9	160
71	JKPDD	POWERGRID	LINE	KISHENPUR (400KV)-NEW WANPOH (400KV)II	CONTINUOUS	LILO at BHEP stage -II and also dismantling of existing PLCC panels, erections, testing, testing and commissioning of new PLCC Panels at both grids.	2019-10-21	09:00	2019-10-26	18:00	129	162
72	JKPDD	POWERGRID	LINE	SALAL (220KV)-JAMMU(220KV)1	DAILY	Routine maintenance	2019-10-13	07:00	2019-10-13	13:30	6.5	161
73	JKPDD	POWERGRID	LINE	SALAL (220KV)-JAMMU(220KV)2	DAILY	Routine maintenance	2019-10-13	07:00	2019-10-13	13:30	6.5	161
74	JKPDD	POWERGRID	LINE	JAMMU(220KV)-SAMBA (220KV)	DAILY	Routine maintenance	2019-10-13	07:00	2019-10-13	13:30	6.5	161
75	JKPDD	JKPDD	LINE	SARNA (220KV)-UDHAMPUR (220KV)	DAILY	Routine maintenance	2019-10-06	07:00	2019-10-06	13:00	6	146
76	JKPDD	POWERGRID	LINE	KISHENPUR (220KV)-UDHAMPUR (220KV)I	DAILY	Routine maintenance	2019-10-06	07:00	2019-10-06	13:00	6	-
77	JKPDD	POWERGRID	LINE	KISHENPUR (220KV)-UDHAMPUR (220KV)II	DAILY	Routine maintenance	2019-10-06	07:00	2019-10-06	13:00	6	-
78	JKPDD	JKPDD	LINE	BARN-KISHENPUR (220KV)I	DAILY	Routine maintenance	2019-10-20	07:00	2019-10-20	13:00	6	151
79	JKPDD	JKPDD	LINE	BARN-KISHENPUR (220KV)2	DAILY	Routine maintenance	2019-10-20	07:00	2019-10-20	13:00	6	-
80	JKPDD	JKPDD	LINE	KISHENPUR (220KV)-RAMBAN (220KV)	DAILY	Routine Maintenance	2019-10-06	07:00	2019-10-06	13:00	6	151
81	JKPDD	POWERGRID	LINE	SEWA II (132KV)-HIRANAGAR (132KV)I	DAILY	Routine Maintenance	2019-10-27	07:00	2019-10-27	13:00	6	154
82	JKPDD	POWERGRID	LINE	SEWA II (132KV)-HIRANAGAR (132KV)II	DAILY	Routine Maintenance	2019-10-27	07:00	2019-10-27	13:00	6	160

83	JKPDD	JKPDD	LINE	HIRANAGAR(220KV)-SARNA (220KV)	DAILY	Routine Maintenance	2019-10-27	07:00	2019-10-27	13:00	6	160
84	JKPDD	POWERGRID	LINE	SAMBA (220KV)-HIRANAGAR(220KV)	DAILY	Routine Maintenance	2019-10-27	07:00	2019-10-27	13:00	6	154
85	NTPC	POWERGRID	LINE	SINGRAULI NTPC (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	CONTINUOUS	Integration of relay and control panel with new SAS system.	2019-10-11	08:30	2019-10-14	17:30	81	162
86	NTPC	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)II	CONTINUOUS	Integration of relay and control panel with new SAS system.	2019-10-15	08:30	2019-10-18	17:30	81	162
87	NTPC	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ANPARA-B (400KV)	CONTINUOUS	Integration of relay and control panel with new SAS system.	2019-10-19	08:30	2019-10-22	17:30	81	162
88	NTPC	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)I	CONTINUOUS	Integration of relay and control panel with new SAS system.	2019-10-31	08:30	2019-11-03	17:30	81	162
89	POWERGRID	POWERGRID	LINE	FATEHPUR-PG (765 KV)-SASARAM-ER (765KV)	DAILY	For rectification work of damaged cross Arm at tower no 326 (Photograph enclosed)	2019-10-15	08:00	2019-10-17	17:00	27	162
90	POWERGRID	POWERGRID	LINE	LUCKNOW(765 KV)-PG-BALIA (765KV)	CONTINUOUS	For Rectification of K section Bent Member at Tower Location No. 103 of Ballia Lucknow Line (Photograph Enclosed)	2019-10-09	09:00	2019-10-11	18:00	57	155
91	POWERGRID	POWERGRID	LINE	Orai (765KV)-ALIGARH-PG (765KV)I	DAILY	For fixing Bundle Spacer, Copper bond And CC Ring Nut Bolts - Orai S/S and For AMP of Line side Equipment at Aligarh S/S	2019-10-11	09:00	2019-10-11	17:00	8	160
92	POWERGRID	POWERGRID	LINE	Orai (765KV)-ALIGARH-PG (765KV)II	DAILY	For fixing Bundle Spacer, Copper bond And CC Ring Nut Bolts - Orai S/S and For AMP of Line side Equipment at Aligarh S/S	2019-10-12	09:00	2019-10-12	17:00	8	160
93	POWERGRID	POWERGRID	LINE	VARANASI (765KV)-KANPUR GIS (765KV)I	DAILY	FOR AMP of Line side Equipment at 765kV kanpur GIS S/S	2019-09-25	08:00	2019-09-25	18:00	10	157
94	POWERGRID	POWERGRID	LINE	VARANASI (765KV)-KANPUR GIS (765KV)II	DAILY	FOR AMP of Line side Equipment at 765kV kanpur GIS S/S	2019-09-26	08:00	2019-09-26	18:00	10	161
95	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)I	DAILY	For Rectification of Snapped Earthwire AT LOC.NO. 317	2019-10-22	08:00	2019-10-22	11:00	3	162
96	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)II	DAILY	and For distance relay retrofitment and pre-commissioning checks such as Carrier Send / Receive , DT Send / Receive and Auto reclosure for individual phases and various testing	2019-10-25	08:00	2019-10-25	11:00	3	162
97	POWERGRID	UPPTCL	LINE	SHAMSAHABAD ROAD (220KV)-AGRA-PG (400KV)	DAILY	AMP, CT Tan delta measurement of line bay eqpt at Agra Substation	2019-10-16	09:00	2019-10-16	18:00	9	160
98	POWERGRID	RRVPN	LINE	AGRA-PG (220KV)-SIKANDRA (220KV)	DAILY	Replacement of faulty insulators, erection of pilot insulators by Agra Substation	2019-10-24	09:00	2019-10-25	18:00	18	162
99	POWERGRID	POWERGRID	LINE	AGRA-PG (220KV)-BHARATPUR (220KV)	DAILY	Replacement of faulty insulators, erection of pilot insulators by Agra Substation	2019-10-26	09:00	2019-10-27	18:00	18	-

100	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-AGRA-PG (400KV)	DAILY	For carrying out protection scheme testing within 01 year of commissioning of Protection system by Agra Substation	2019-10-03	09:00	2019-10-03	18:00	9	162
101	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BHIWADI-PG (400KV)I	DAILY	For carrying out protection scheme testing within 01 year of commissioning of Protection system by Agra Substation	2019-10-07	09:00	2019-10-07	18:00	9	159
102	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-JAIPUR South (400KV)II	DAILY	For carrying out Line reactor HV bushings VFTD testing at Agra Substation	2019-10-11	09:00	2019-10-11	18:00	9	155
103	POWERGRID	POWERGRID	LINE	RIHAND NTPC (400KV)-ALLAHABAD (400KV)I	DAILY	checks such as Carrier Send / Receive , DT Send / Receive and Auto reclosure for individual phases and various testing and other AMP works at Allahabad S/S	2019-10-10	09:00	2019-10-10	18:00	9	155
104	POWERGRID	POWERGRID	LINE	RIHAND NTPC (400KV)-ALLAHABAD (400KV)II	DAILY	checks such as Carrier Send / Receive , DT Send / Receive and Auto reclosure for individual phases and various testing and other AMP works at Allahabad S/S	2019-10-12	09:00	2019-10-12	18:00	9	151
105	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-KANPUR (400KV)	CONTINUOUS	For diversion of 400kv S/C Allahabad- Kanpur line due to construction of Fatehpur bypass by NHAI at Fatehpur (Line sketch enclosed)	2019-10-01	08:00	2019-10-07	18:00	154	160
106	POWERGRID	POWERGRID	LINE	BALIA(400KV)-PATNA-ER (400KV)1	DAILY	For DGA Sampling of BHEL Make HV Bushings of Line Reactor at Ballia S/S	2019-10-01	09:00	2019-10-01	13:00	4	150
107	POWERGRID	POWERGRID	LINE	BALIA(400KV)-PATNA-ER (400KV)4	DAILY	Replacement of Porcelain Insulator with Polymer Insulaor at Location no. 586, Balia	2019-10-03	09:00	2019-10-03	12:00	3	159
108	POWERGRID	POWERGRID	LINE	BALIA(400KV)-SOHAWAL (400KV)I	CONTINUOUS	For Line Reactor Switching CB erection & Commissioning at Ballia S/S. To make LR as Switchable LR and AMP of Line side Equipment at sohawal s/s	2019-10-08	09:00	2019-10-12	18:00	105	161
109	POWERGRID	POWERGRID	LINE	BALIA(400KV)-SOHAWAL (400KV)2	DAILY	For Line Reactor Switching CB erection & Commissioning at Ballia S/S to make LR as switchable LR and AMP of Line side Equipment at sohawal s/s	2019-10-15	09:00	2019-10-19	18:00	45	159
110	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	DAILY	For Line Bay elements AMP works at Bareilly S/S	2019-10-18	09:00	2019-10-18	18:00	9	160
111	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-KASHIPUR (400KV)1	DAILY	For Line Bay elements AMP works at 765kV bareilly S/S	2019-10-18	09:00	2019-10-18	18:00	9	158
112	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-KASHIPUR (400KV)2	DAILY	For Line Bay elements AMP works at 765kV bareilly S/S	2019-10-19	09:00	2019-10-19	18:00	9	158
113	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-BAREILY-PG (765 KV)II	DAILY	For Line Bay elements AMP works at 765kV bareilly S/S	2019-10-21	09:00	2019-10-21	18:00	9	156
114	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-BAREILY-PG (765 KV)I	DAILY	For Line Bay elements AMP works of 400kV Bareilly-765kV Bareilly Ckt #2 at 765kV bareilly S/S	2019-10-22	09:00	2019-10-22	18:00	9	156
115	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-FATEHPUR - PG (400KV)	DAILY	For taking Reactor out of service for AMP, Corona Shield Modification in HV Bushing ,CC-CL plate replacement work and internal Inspection Work at fatehpur S/S	2019-10-16	10:00	2019-10-16	11:00	1	162
116	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-FATEHPUR - PG (400KV)	DAILY	For taking Reactor into service after AMP, Corona Shield Modification in HV Bushing,CC-CL plate replacement work and internal Inspection Work at fatehpur S/S	2019-10-23	17:00	2019-10-23	18:00	1	162

117	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-FATEHPUR -PG (400KV)II	DAILY	For AMP & Tightening Work of Line Reactor and Line Side Equipments at fatehpur S/S	2019-10-29	18:00	2019-10-29	18:00	0	151
118	POWERGRID	POWERGRID	LINE	Orai (400KV)-ORAI (400KV)1	DAILY	For Fixing Rigid Spacer, Copper bond, Bundle Spacer, OPGW Earth wire VD, CC Ring Bolts and Bend Member In Cross arm at Orai S/S	2019-10-03	09:00	2019-10-03	18:00	9	-
119	POWERGRID	POWERGRID	LINE	Orai (400KV)-ORAI (400KV)2	DAILY	For Fixing Rigid Spacer, Copper bond, Bundle Spacer, OPGW Earth wire VD, CC Ring Bolts and Bend Member In Cross arm at Orai S/S	2019-10-04	09:00	2019-10-04	18:00	9	-
120	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-AURAIYA GPS (400KV)II	DAILY	AMP of Line Side Equipment at Kanpur Substation	2019-10-05	10:00	2019-10-05	17:00	7	151
121	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-BALLABGARH-PG (400KV)II	DAILY	AMP of Line Side Equipment at Kanpur Substation	2019-10-10	10:00	2019-10-10	17:00	7	162
122	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-KANPUR GIS (765KV)II	DAILY	AMP of Line Side Equipment at Kanpur Substation	2019-10-07	10:00	2019-10-07	17:00	7	145
123	POWERGRID	POWERGRID	LINE	DHAULIGANGA (220KV)-BAREILY-CB GANJ (220KV)II	DAILY	To take the 25 MVAR Line Reactor out of service for oil filtration of the reactor at Dhauliganaga(NHPC)	2019-10-01	10:00	2019-10-01	11:00	1	162
124	POWERGRID	POWERGRID	LINE	DHAULIGANGA (220KV)-BAREILY-CB GANJ (220KV)II	DAILY	To take the 25 MVAR Line Reactor into the service after oil filtration of the reactor at Dhauliganaga(NHPC)	2019-10-05	10:00	2019-10-05	11:00	1	162
125	POWERGRID	UPPTCL	LINE	SOHAWAL (220KV)-SOHAWAL (400KV)I	DAILY	For AMP Work of Line side Equipment at Sohawal S/S	2019-10-17	09:00	2019-10-17	18:00	9	161
126	POWERGRID	UPPTCL	LINE	SOHAWAL (220KV)-SOHAWAL (400KV)II	DAILY	For AMP Work of Line side Equipment at Sohawal S/S	2019-10-18	09:00	2019-10-18	18:00	9	161
127	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-ALIGARH-PG (765KV)S/C	DAILY	For AMP of Line side Equipment at Aligarh S/S	2019-10-18	09:00	2019-10-18	18:00	9	160
128	POWERGRID	POWERGRID	LINE	ALIGARH-PG (765KV)-GREATER NOIDA(765 KV)S/C	DAILY	For AMP of Line side Equipment at Aligarh S/S	2019-10-17	09:00	2019-10-17	18:00	9	155
129	POWERGRID	POWERGRID	LINE	KANPUR GIS (765KV)-ALIGARH-PG (765KV)S/C	DAILY	For AMP of Line side Equipment at Aligarh S/S	2019-10-19	09:00	2019-10-19	18:00	9	161
130	POWERGRID	POWERGRID	LINE	BHIWANI-PG (765 KV)-PHAGI (765KV)2	DAILY	For Line Reactor AMP work and replacment of Line LA insulating Base at Bhiwani end & insulator cleaning and line maintenance work.	2019-10-16	09:00	2019-10-18	18:00	27	159
131	POWERGRID	POWERGRID	LINE	ALIGARH-PG (765KV)-JHATIKALA(765 KV)	DAILY	For facilitating Construction of 765 kV GIS Exten. As this line causes Induction and Interference of Voltage injected during HV Test with System Voltage	2019-10-01	09:00	2019-10-01	18:00	9	158
132	POWERGRID	POWERGRID	LINE	ALIGARH-PG (765KV)-JHATIKALA(765 KV)	DAILY	For facilitating Construction of 765 kV GIS Exten. As this line causes Induction and Interference of Voltage injected during HV Test with System Voltage	2019-10-04	09:00	2019-10-04	18:00	9	158
133	POWERGRID	POWERGRID	LINE	GAYA-ER (765KV)-BALIA (765KV)	DAILY	For Replacement of insulators damaged by miscreant. S/D requested by ER1	2019-10-14	08:00	2019-10-14	18:00	10	162



134	POWERGRID	POWERGRID	LINE	GAYA-ER (765KV)-VARANASI (765KV)1	DAILY	For Strengthening of 765 kV line Suspension Delta Tower (wind zone -II) at 26 Nos Locations.S/D requested by ER1.	2019-10-17	08:00	2019-10-21	18:00	50	161
135	POWERGRID	POWERGRID	LINE	GAYA-ER (765KV)-VARANASI (765KV)2	DAILY	For Strengthening of 765 kV line Suspension Delta Tower (wind zone -II) at 26 Nos Locations.S/D requested by ER1	2019-10-23	09:00	2019-10-25	18:00	27	161
136	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-SASARAM-ER (400KV)	DAILY	Replacement of insulators at Road/Rail/River/Power Line Crossings and Relay Retrofitting S/D requested by ER1	2019-10-05	09:00	2019-10-10	18:00	54	162
137	POWERGRID	POWERGRID	LINE	SASARAM-ER (400KV)-VARANASI (400KV)	DAILY	Replacement of insulators at Road/Rail/River/Power Line Crossings and Relay Retrofitting S/D requested by ER1	2019-10-15	09:00	2019-10-20	19:00	60	162
138	POWERGRID	POWERGRID	LINE	BALIA(400KV)-BIHARSHARIF-ER (400KV)I	DAILY	Replacement of Polymer Insulator in Loc/ No.228 & 227(BESIDE SONE RIVER). S/D requested by ER1.	2019-10-17	09:00	2019-10-17	18:00	9	162
139	POWERGRID	POWERGRID	LINE	BALIA(400KV)-BIHARSHARIF-ER (400KV)II	DAILY	Replacement of Polymer Insulator in Loc/ No.228 & 227(BESIDE SONE RIVER). S/D requested by ER1	2019-10-18	09:00	2019-10-18	18:00	9	157
140	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-GWALIOR-WR (765KV)I	DAILY	Fixing of sleeve in D Type of Angle Tower and Tower strenthening work. S/D applied by WR-II	2019-10-14	09:45	2019-10-16	18:00	24.75	162
141	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-GWALIOR-WR (765KV)II	DAILY	Fixing of sleeve in D Type of Angle Tower and Tower strenthening work. S/D applied by WR-II	2019-10-17	09:45	2019-10-19	18:00	24.75	162
142	POWERGRID	POWERGRID	LINE	MOGA (400KV)-FATEHABAD PG (400KV)	DAILY	For AMP works.	2019-10-16	09:30	2019-10-16	17:30	8	157
143	POWERGRID	POWERGRID	LINE	AMRITSAR (400KV)-ParbatiPooling-BANALA (400KV)I	DAILY	insulators. The shut down will be taken on alternate days of the month. On the day of SD, 400 kV Banala Hamirpur line shall have to be put in Non-Auto mode.	2019-10-01	09:30	2019-10-31	17:30	248	157
144	POWERGRID	POWERGRID	LINE	HAMIRPUR-PG (400KV)-ParbatiPooling-BANALA (400KV)	DAILY	insulators. The shut down will be taken on alternate days of the month. On the day of SD, 400 kV Banala Amritsar line shall have to be put in Non-Auto mode.	2019-10-01	09:00	2019-10-31	17:30	263.5	157
145	POWERGRID	POWERGRID	LINE	LUCKNOW(765 KV)-PG-BAREILY-PG (765 KV)	DAILY	for Cleaning of polluted stretch of Insulators	2019-09-27	09:30	2019-09-28	18:30	18	158
146	POWERGRID	POWERGRID	LINE	VARANASI (765KV)-FATEHPUR-PG (765 KV)	DAILY	For cleaning of polluted stretch of insulators	2019-09-30	09:30	2019-10-01	18:30	18	162
147	POWERGRID	POWERGRID	LINE	PHAGI (765KV)-GWALIOR-WR (765KV)1	DAILY	For insulator cleaning & line Maintenance work	2019-10-21	08:18	2019-10-23	08:18	0	162
148	POWERGRID	POWERGRID	LINE	PHAGI (765KV)-GWALIOR-WR (765KV)2	DAILY	For insulator cleaning & line Maintenance work	2019-10-17	08:00	2019-10-19	18:00	30	162
149	POWERGRID	POWERGRID	LINE	WAGOORA(220KV)-PAMPPORE(220KV)I	DAILY	For AMP works.	2019-10-07	09:30	2019-10-07	17:30	8	161
150	POWERGRID	POWERGRID	LINE	KISHENPUR (400KV)-NEW WANPOH (400KV)III	CONTINUOUS	For dimantling and re-erection of tower no. 181 in Sanasar (Pir Panjanl Area). Tower got damaged during heavy snowfall in the area.	2019-10-10	09:30	2019-10-31	17:30	512	161

151	POWERGRID	POWERGRID	LINE	KISHENPUR (400KV)-NEW WANPOH (400KV)IV	CONTINUOUS	For dismantling and re-erection of tower no. 181 in Sanasar (Pir Panjanl Area). Tower got damaged during heavy snowfall in the area.	2019-10-10	09:30	2019-10-31	17:30	512	152
152	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-SHAHJAHANPUR (400KV)I	DAILY	Insulator replacement from Porclein to Polymer	2019-10-20	08:00	2019-10-22	18:00	30	159
153	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-SHAHJAHANPUR (400KV)II	DAILY	Insulator replacement from Porclein to Polymer	2019-10-23	08:00	2019-10-25	18:00	30	159
154	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	DAILY	Insulator replacement from Porclein to Polymer	2019-10-10	08:00	2019-10-13	18:00	40	160
155	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-SHAHJAHANPUR (400KV)I	DAILY	Insulator replacement from Porclein to Polymer	2019-10-14	08:00	2019-10-17	18:00	40	162
156	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-SHAHJAHANPUR (400KV)II	DAILY	Insulator replacement from Porclein to Polymer	2019-10-18	08:00	2019-10-21	18:00	40	153
157	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-MORADABAD (400KV)I	DAILY	Insulator replacement from Porclein to Polymer	2019-10-30	08:00	2019-11-01	18:00	30	156
158	POWERGRID	POWERGRID	LINE	KISHENPUR (220KV)-UDHAMPUR (220KV)I	DAILY	For AMP works.	2019-10-23	09:30	2019-10-23	17:30	8	-
159	POWERGRID	POWERGRID	LINE	KISHENPUR (220KV)-UDHAMPUR (220KV)II	DAILY	For AMP works.	2019-10-24	09:30	2019-10-24	17:30	8	-
160	POWERGRID	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)I	DAILY	For replacement of B-ph LA which has violated the THRC value.	2019-10-01	10:30	2019-10-01	16:30	6	158
161	POWERGRID	POWERGRID	LINE	URI-2 (400KV)-WAGOORA (400KV)	DAILY	For rectification of bent tower peak at location no. 77 which got damaged during snowfall.	2019-10-10	09:30	2019-10-10	17:30	8	154
162	POWERGRID	POWERGRID	LINE	URI-1 (400KV)-URI-2 (400KV)	CONTINUOUS	For rectification of damaged conductor in the span 21-22.	2019-10-22	09:30	2019-10-24	17:30	56	160
163	POWERGRID	POWERGRID	LINE	JALLANDHAR-PG (400KV)-CHAMBA POOL (400KV)1	DAILY	For AMP works.	2019-10-09	09:30	2019-10-09	17:30	8	156
164	POWERGRID	POWERGRID	LINE	JALLANDHAR-PG (400KV)-CHAMBA POOL (400KV)2	DAILY	For AMP works.	2019-10-10	09:30	2019-10-10	17:30	8	151
165	POWERGRID	POWERGRID	LINE	JALLANDHAR-PG (400KV)-MOGA (400KV)I	DAILY	For rectification of bent peak at location no. 418.	2019-10-22	09:30	2019-10-22	17:30	8	161
166	POWERGRID	POWERGRID	LINE	JALLANDHAR-PG (400KV)-MOGA (400KV)II	DAILY	For rectification of bent peak at location no. 418.	2019-10-22	09:30	2019-10-22	17:30	8	161
167	POWERGRID	POWERGRID	LINE	BHIWANI-PG (765 KV)-PHAGI (765KV)1	DAILY	For Line Maintenance work	2019-10-14	09:00	2019-10-15	18:00	18	162

168	POWERGRID	POWERGRID	LINE	RIHAND NTPC (400KV)-VINDHYACHAL POOL-WR (400KV)I	DAILY	For Insulator cleaning	2019-10-02	09:30	2019-10-02	18:30	9	157
169	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-MORADABAD (400KV)II	DAILY	For Insulator cleaning	2019-10-29	09:30	2019-10-29	18:30	9	156
170	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-GORAKHPUR-PG (400KV)III	DAILY	For Insulator cleaning	2019-10-11	09:30	2019-10-11	18:30	9	161
171	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-GORAKHPUR-PG (400KV)IV	DAILY	For Insulator cleaning	2019-10-12	09:30	2019-10-12	18:30	9	162
172	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-Meja-NTPC (400KV)1	DAILY	For Insulator cleaning	2019-10-09	09:30	2019-10-09	18:30	9	153
173	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-Meja-NTPC (400KV)2	DAILY	For Insulator cleaning	2019-10-10	09:30	2019-10-10	18:30	9	153
174	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-RIHAND NTPC (400KV)I	DAILY	For Insulator cleaning	2019-10-09	09:30	2019-10-09	18:30	9	161
175	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-RIHAND NTPC (400KV)II	DAILY	For Insulator cleaning	2019-10-10	09:30	2019-10-10	18:30	9	158
176	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-FATEHPUR -PG (400KV)I	DAILY	For Insulator cleaning	2019-10-11	09:30	2019-10-11	18:30	9	151
177	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-FATEHPUR -PG (400KV)II	DAILY	For Insulator cleaning	2019-10-12	09:30	2019-10-12	18:30	9	151
178	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-FATEHPUR -PG (400KV)III	DAILY	For Insulator cleaning	2019-10-06	09:30	2019-10-06	18:30	9	161
179	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	DAILY	For Insulator cleaning	2019-10-13	09:30	2019-10-14	18:30	18	162
180	POWERGRID	UPPTCL	LINE	SARANGPUR (400KV)-PHULPUR (220KV)	DAILY	For Insulator cleaning	2019-10-15	09:30	2019-10-15	18:30	9	152
181	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-JAIPUR South (400KV)I	DAILY	For Insulator cleaning	2019-10-21	09:30	2019-10-22	18:30	18	152
182	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-JAIPUR South (400KV)II	DAILY	For Insulator cleaning	2019-10-23	09:30	2019-10-24	18:30	18	155
183	POWERGRID	POWERGRID	LINE	FATEHPUR -PG (400KV)-MAINPURI-PG (400KV)I	DAILY	For Insulator cleaning	2019-10-15	09:30	2019-10-16	18:30	18	152
184	POWERGRID	POWERGRID	LINE	FATEHPUR -PG (400KV)-MAINPURI-PG (400KV)II	DAILY	For Insulator cleaning	2019-10-16	09:30	2019-10-16	18:30	9	-

185	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-AGRA-PG (400KV)	DAILY	For Insulator cleaning	2019-10-17	09:30	2019-10-18	18:30	18	162
186	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-AURAIYA GPS (400KV)I	DAILY	For Insulator cleaning	2019-10-04	09:30	2019-10-04	18:30	9	151
187	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-UNCHAHAR (220KV)I	DAILY	For Insulator cleaning	2019-10-22	09:30	2019-10-23	18:30	18	156
188	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-UNCHAHAR (220KV)II	DAILY	For Insulator cleaning	2019-10-24	09:30	2019-10-25	18:30	18	156
189	POWERGRID	POWERGRID	LINE	UNCHAHAR (220KV)-KANPUR (400KV)III	DAILY	For Insulator cleaning	2019-10-26	09:30	2019-10-27	18:30	18	162
190	POWERGRID	POWERGRID	LINE	UNCHAHAR (220KV)-KANPUR (400KV)IV	DAILY	For Insulator cleaning	2019-10-20	09:30	2019-10-21	18:30	18	162
191	POWERGRID	POWERGRID	LINE	UNCHAHAR (220KV)-RAEBAREILLY (220KV)3	DAILY	For Insulator cleaning	2019-10-31	09:30	2019-10-31	18:30	9	154
192	POWERGRID	DTL	LINE	BAMNOLI (400KV)-JHATIKALA (400KV)2	DAILY	AMP of Line and switchyard equipments like Line isolator, CVT, Wavetrap etc.	2019-10-21	09:00	2019-10-21	19:00	10	162
193	POWERGRID	POWERGRID	LINE	Bhadla-BHADLA (400KV)1	DAILY	Line maintenance work eg. CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	2019-10-01	09:00	2019-10-07	19:00	70	-
194	POWERGRID	POWERGRID	LINE	Bhadla-BHADLA (400KV)2	DAILY	Line maintenance work eg. CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	2019-10-08	09:00	2019-10-15	19:00	80	-
195	POWERGRID	POWERGRID	LINE	MEERUT (400KV)-BAGHPAT (400KV)1	DAILY	Retrofitting, Testing & Commissioning of SEL421 Relay with Micom P444 Relay & AMP work	2019-10-23	09:00	2019-10-23	19:00	10	160
196	POWERGRID	POWERGRID	LINE	MEERUT (400KV)-BAGHPAT (400KV)2	DAILY	Retrofitting, Testing & Commissioning of SEL421 Relay with Micom P444 Relay & AMP work	2019-10-24	09:00	2019-10-24	18:00	9	160
197	POWERGRID	POWERGRID	LINE	BAGHPAT (400KV)-DEHRADUN (400KV)	DAILY	FOR AMP WORK	2019-10-01	10:00	2019-10-01	17:00	7	160
198	POWERGRID	POWERGRID	LINE	KAITHAL (400KV)-BAGHPAT (400KV)I	DAILY	FOR AMP WORK	2019-10-10	10:00	2019-10-10	17:00	7	160
199	POWERGRID	POWERGRID	LINE	KAITHAL (400KV)-BAGHPAT (400KV)II	DAILY	FOR AMP WORK	2019-10-11	10:00	2019-10-11	17:00	7	160
200	POWERGRID	UPPTCL	LINE	SHAMLI (220KV)-BAGHPAT (400KV)	DAILY	FOR AMP WORK	2019-10-16	10:00	2019-10-16	17:00	7	160
201	POWERGRID	UPRVUNL	LINE	BAGHPAT-UP (220KV)-BAGHPAT (400KV)	DAILY	FOR AMP WORK	2019-10-17	10:00	2019-10-17	17:00	7	160

202	POWERGRID	UPRVUNL	LINE	BARAUT-BAGHPAT (400KV)I	DAILY	FOR AMP WORK	2019-10-18	10:00	2019-10-18	17:00	7	-
203	POWERGRID	UPPTCL	LINE	BARAUT-BAGHPAT (400KV)II	DAILY	FOR AMP WORK	2019-10-19	10:00	2019-10-19	17:00	7	-
204	POWERGRID	POWERGRID	LINE	KOTESHWAR (400KV)-TEHRI (400KV)I	DAILY	Line maintenance work eg. CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	2019-10-08	09:00	2019-10-08	17:00	8	154
205	POWERGRID	POWERGRID	LINE	KOTESHWAR (400KV)-TEHRI (400KV)II	DAILY	Line maintenance work eg. CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	2019-10-09	09:00	2019-10-09	17:00	8	154
206	POWERGRID	POWERGRID	LINE	NEEMRANA (400KV)-SIKAR (400KV)II	DAILY	Line maintenance work eg. CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	2019-10-01	09:00	2019-10-02	17:00	16	160
207	POWERGRID	RRVUNL	LINE	JAIPUR SOUTH (220KV)-SEZ	DAILY	FOR AMP WORK	2019-10-22	09:00	2019-10-22	18:00	9	-
208	POWERGRID	RRVUNL	LINE	JAIPUR SOUTH (220KV)-Dhuni	DAILY	FOR AMP WORK	2019-10-24	09:00	2019-10-24	18:00	9	-
209	POWERGRID	POWERGRID	LINE	BABAI GSS-NEEMRANA (400KV)	DAILY	Line maintenance work eg. CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	2019-10-03	08:00	2019-10-04	18:00	20	162
210	POWERGRID	POWERGRID	LINE	BHIWADI-PG (400KV)-NEEMRANA (400KV)I	DAILY	Line maintenance work eg. CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	2019-10-05	08:00	2019-10-05	18:00	10	159
211	POWERGRID	POWERGRID	LINE	BHIWADI-PG (400KV)-NEEMRANA (400KV)2	DAILY	Line maintenance work eg. CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	2019-10-06	08:00	2019-10-06	18:00	10	154
212	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-JAIPUR South (400KV)I	DAILY	POLLUTED INSULATOR REPLACEMENT WORK AT 7-8 Tower location.	2019-10-11	08:00	2019-10-20	18:00	100	152
213	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-JAIPUR South (400KV)II	DAILY	POLLUTED INSULATOR REPLACEMENT WORK AT 7-8 Tower location.	2019-10-21	08:30	2019-10-30	18:30	100	155
214	POWERGRID	POWERGRID	LINE	GURGAON (400KV)-MANESAR (400KV)I	DAILY	RTV COATING WORK in BPI at S/S	2019-10-14	09:00	2019-10-14	18:00	9	161
215	POWERGRID	POWERGRID	LINE	GURGAON (400KV)-MANESAR (400KV)II	DAILY	RTV COATING WORK in BPI at S/S	2019-10-15	09:00	2019-10-15	18:00	9	161
216	POWERGRID	POWERGRID	LINE	NEEMRANA (400KV)-MANESAR (400KV)1	DAILY	RTV COATING WORK in BPI at S/S	2019-10-16	09:00	2019-10-16	18:00	9	161
217	POWERGRID	POWERGRID	LINE	NEEMRANA (400KV)-MANESAR (400KV)2	DAILY	RTV COATING WORK in BPI at S/S	2019-10-17	09:00	2019-10-17	18:00	9	160
218	POWERGRID	POWERGRID	LINE	JALLANDHAR-PG (400KV)-HAMIRPUR-PG (400KV)	DAILY	SD is required for taking out LR for maintenance works.	2019-10-15	09:30	2019-10-15	09:40	0.17	161

219	POWERGRID	POWERGRID	LINE	DEHRADUN (400KV)-ABDULLAPUR (400KV)1	DAILY	Online replacement of communication card of line differential relay at both ends	2019-10-03	09:30	2019-10-04	16:30	14	159
220	POWERGRID	POWERGRID	LINE	DEHRADUN (400KV)-ABDULLAPUR (400KV)2	DAILY	Online replacement of communication card of line differential relay at both ends	2019-10-04	09:30	2019-10-04	16:30	7	159
221	POWERGRID	POWERGRID	LINE	SALAL (220KV)-KISHENPUR (220KV)III	DAILY	Attending of shutdown nature defects	2019-10-16	09:00	2019-10-17	18:00	18	161
222	POWERGRID	POWERGRID	LINE	SALAL (220KV)-KISHENPUR (220KV)IV	DAILY	Attending of shutdown nature defects	2019-10-18	09:00	2019-10-18	18:00	9	158
223	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BASSI (400KV)I	CONTINUOUS	Disconnection of Droppers from Line side conductor of isolator no. 406-89A (Line Side).	2019-10-09	09:00	2019-10-09	13:00	4	161
224	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BASSI (400KV)I	DAILY	Connection of Droppers with Line side conductor of isolator no. 406-89A after replacement of isolator.	2019-10-12	13:00	2019-10-12	17:00	4	161
225	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BASSI (400KV)I	CONTINUOUS	Replacement of 400kV RK-Make Isolator(406-89L) with new S&S-Make Isolator	2019-10-14	09:00	2019-10-18	17:30	104.5	161
226	POWERGRID	POWERGRID	LINE	BASSI (400KV)-BHIWADI-PG (400KV)	CONTINUOUS	Diconnection of Droppers from Line side conductor of isolator no. 405-89A (Line Side).	2019-10-19	09:30	2019-10-19	13:00	3.5	159
227	POWERGRID	POWERGRID	LINE	BASSI (400KV)-BHIWADI-PG (400KV)	CONTINUOUS	Connection of Droppers with Line side conductor of isolator no. 405-89A after replacement of isolator.	2019-10-24	13:00	2019-10-24	17:00	4	159
228	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BASSI (400KV)I	DAILY	Diconnection of Droppers from Line side conductor of isolator no. 405-89B (Line Side).	2019-10-25	09:30	2019-10-25	13:00	3.5	161
229	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BASSI (400KV)I	DAILY	Connection of Droppers with Line side conductor of isolator no. 405-89B after replacement of isolator.	2019-10-30	13:00	2019-10-30	17:00	4	161
230	PTCUL	PTCUL	LINE	SRINAGAR_UK (400KV)-Srinagar HEP-ALAKANANDA (400KV)1	DAILY	For pre-diwali maintenance line & T/f Bays along with 400 KV Main Bus-1st	2019-10-09	09:00	2019-10-09	13:00	4	162
231	PTCUL	PTCUL	LINE	SRINAGAR_UK (400KV)-Srinagar HEP-ALAKANANDA (400KV)2	DAILY	For Pre-Diwali maintenance of line & T/f Bays along with 400 KV Main Bus-2nd.	2019-10-10	09:00	2019-10-10	13:00	4	162
232	PSTCL	PSTCL	LINE	NALLAGARH (220KV)-MOHALI (220KV)1	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 160 to 173	2019-10-03	10:00	2019-10-03	17:00	7	156
233	PSTCL	PSTCL	LINE	NAKODAR (400KV)-MAKHU (400KV)1	DAILY	General Maintenance	2019-10-04	10:00	2019-10-04	16:00	6	156
234	PSTCL	PSTCL	LINE	NAKODAR (400KV)-MAKHU (400KV)2	DAILY	General Maintenance	2019-10-07	10:00	2019-10-07	16:00	6	156
235	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-NAKODAR (400KV)	DAILY	General Maintenance	2019-10-09	10:00	2019-10-10	16:00	12	156

236	PSTCL	PSTCL	LINE	KANGRA (132KV)-SHANAN (132KV)	DAILY	Disc cleaning & Jumper tightening and other mtc. to be done	2019-10-07	10:00	2019-10-07	16:00	6	156
237	PSTCL	PSTCL	LINE	KANGRA (132KV)-SHANAN (132KV)	DAILY	Disc cleaning & Jumper tightening and other mtc. to be done	2019-10-09	10:00	2019-10-09	16:00	6	156
238	PSTCL	PSTCL	LINE	NALLAGARH (220KV)-MOHALI (220KV)2	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 160 to 173	2019-10-09	10:00	2019-10-09	17:00	7	156
239	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MOGA (400KV)	DAILY	General maintenance, Jumper tightening and Tree Cutting	2019-10-01	09:00	2019-10-01	17:00	8	155
240	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MOGA (400KV)	DAILY	General maintenance, Jumper tightening and Tree Cutting	2019-10-04	09:00	2019-10-05	17:00	16	155
241	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MOGA (400KV)	DAILY	General maintenance, Jumper tightening and Tree Cutting	2019-10-23	09:00	2019-10-24	17:00	16	155
242	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-NAKODAR (400KV)	DAILY	General Maintenance	2019-10-12	10:00	2019-10-12	16:00	6	156
243	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-NAKODAR (400KV)	DAILY	General Maintenance	2019-10-25	10:00	2019-10-25	16:00	6	156
244	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-NAKODAR (400KV)	DAILY	General Maintenance	2019-10-18	10:00	2019-10-19	16:00	12	156
245	PSTCL	PSTCL	LINE	MAKHU (400KV)-AMRITSAR (400KV)II	DAILY	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	2019-10-09	09:00	2019-10-09	17:00	8	156
246	PSTCL	PSTCL	LINE	KANGRA (132KV)-SHANAN (132KV)	DAILY	Disc cleaning & Jumper tightening and other mtc. to be done	2019-10-10	10:00	2019-10-11	16:00	12	156
247	PSTCL	PSTCL	LINE	HAMIRPUR HSEB (132KV)-CHOHAL (132KV)	DAILY	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	2019-10-10	10:00	2019-10-10	16:00	6	156
248	PSTCL	PSTCL	LINE	MOGA (400KV)-NAKODAR (400KV)	DAILY	General Maintenance	2019-10-11	10:00	2019-10-11	16:00	6	156
249	PSTCL	PSTCL	LINE	KANGRA (132KV)-PATHANKOT (132KV)	DAILY	Disc cleaning & Jumper tightening and other mtc. to be done	2019-10-12	10:00	2019-10-12	16:00	6	156
250	PSTCL	PSTCL	LINE	RAJPURA TPS (400KV)-NAKODAR (400KV)1	DAILY	Tightening of nut bolts of jumpers, dampers setting, routine electrical/civil maintenance of tower	2019-10-14	10:00	2019-10-17	17:00	28	156
251	PSTCL	PSTCL	LINE	RAJPURA TPS (400KV)-NAKODAR (400KV)2	DAILY	Tightening of nut bolts of jumpers, dampers setting, routine electrical/civil maintenance of tower	2019-10-21	10:00	2019-10-24	17:00	28	156
252	PSTCL	PSTCL	LINE	RAJPURA (400KV)-DHURI (400KV)2	DAILY	Maintenance	2019-10-14	09:30	2019-10-15	17:00	15	156

253	PSTCL	PSTCL	LINE	RAJPURA (400KV)-DHURI (400KV)1	DAILY	Maintenance	2019-10-16	09:30	2019-10-17	17:00	15	156
254	PSTCL	PSTCL	LINE	PONG (220KV)-DASUYA (220KV)1	DAILY	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	2019-10-17	10:00	2019-10-17	17:00	7	153
255	PSTCL	PSTCL	LINE	MAKHU (400KV)-AMRITSAR (400KV)I	DAILY	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	2019-10-16	10:00	2019-10-16	17:00	7	156
256	PSTCL	PSTCL	LINE	MUKTSAR (400KV)-MAKHU (400KV)1	DAILY	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	2019-10-18	10:00	2019-10-18	17:00	7	156
257	PSTCL	PSTCL	LINE	KANGRA (132KV)-PATHANKOT (132KV)	DAILY	Disc cleaning & Jumper tightening and other mtc. to be done for CKT-1	2019-10-21	10:00	2019-10-23	16:00	18	156
258	PSTCL	PSTCL	LINE	KANGRA (132KV)-PATHANKOT (132KV)	DAILY	Disc cleaning & Jumper tightening and other mtc. to be done for CKT-2	2019-10-24	10:00	2019-10-26	16:00	18	156
259	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-DHURI (400KV)1	DAILY	Maintenance	2019-10-21	09:30	2019-10-22	17:00	15	156
260	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-DHURI (400KV)2	DAILY	Maintenance	2019-10-29	09:30	2019-10-30	17:00	15	156
261	PSTCL	PSTCL	LINE	NALLAGARH (220KV)-MOHALI (220KV)1	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 174 to 183 and s/s gantry	2019-10-24	10:00	2019-10-24	17:00	7	156
262	PSTCL	PSTCL	LINE	NALLAGARH (220KV)-MOHALI (220KV)2	DAILY	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 1 to 10	2019-10-29	10:00	2019-10-29	17:00	7	156
263	PSTCL	PSTCL	LINE	MAKHU (400KV)-AMRITSAR (400KV)I	DAILY	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	2019-10-25	10:00	2019-10-25	17:00	7	156
264	PSTCL	PSTCL	LINE	MAKHU (400KV)-AMRITSAR (400KV)II	DAILY	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	2019-10-29	10:00	2019-10-29	17:00	7	156
265	PSTCL	PSTCL	LINE	MUKTSAR (400KV)-MAKHU (400KV)2	DAILY	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	2019-10-30	10:00	2019-10-30	17:00	7	156
266	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MOGA (400KV)	DAILY	General maintenance, Jumper tightening and Tree Cutting	2019-10-07	09:00	2019-10-07	17:00	8	155
267	PSTCL	PSTCL	LINE	TALWANDI SABOO TPS (400KV)-MUKTSAR (400KV)2	DAILY	To attend hot point on Common T Clamp B/W bay 404 & 405 : B-Phase	2019-10-03	10:00	2019-10-03	13:00	3	158
268	RRVPN	RRVPN	LINE	MODAK (220KV)-BHANPURA MPSEB-WR (220KV)+MPSE	DAILY	QUARTERLY MAINTENANCE WORK AT 220KV GSS MORAK	2019-10-04	09:30	2019-10-04	16:00	6.5	153
269	RRVPN	POWERGRID	LINE	BHIWANI-PG (765 KV)-PHAGI (765KV)1	DAILY	1. Maintenance of CB & Reactors. 2. Maintenance of line bay equipments. 3. To attend the defects of B Phase of (702-89AB) Isolator.	2019-10-10	09:00	2019-10-10	18:00	9	162



270	RRVPN	RRVPN	LINE	RAPP A (220KV)-KOTA(220KV)1	CONTINUOUS	For stringing work of ACSR Zebra Conductor & Disc replacement & QUARTERLY Bay MAINTENANCE & testing WORK	2019-10-09	08:00	2019-10-13	18:00	106	160
271	RRVPN	RRVPN	LINE	RAPS B (220KV)-SAKATPURA-KOTA (220KV)	CONTINUOUS	For Disc replacement & QUARTERLY Bay MAINTENANCE & testing WORK	2019-10-14	08:00	2019-10-19	18:00	130	159
272	RRVPN	RRVPN	LINE	RAPP A (220KV)-KOTA(220KV)III	CONTINUOUS	For Disc replacement & QUARTERLY Bay MAINTENANCE & testing WORK	2019-10-21	08:00	2019-10-26	18:00	130	159
273	RRVPN	RRVPN	LINE	ANTA GPS (220KV)-KOTA(220KV)	CONTINUOUS	Defective CVT Replacement work along with QUARTERLY Bay MAINTENANCE & testing WORK	2019-10-09	08:00	2019-10-10	18:00	34	158
274	RRVPN	RRVPN	LINE	CHHABRA (400KV)-KAWAI SCTPS (400KV)	DAILY	Annual Maintenance of Line isolators and Bay Equipments.	2019-10-04	09:30	2019-10-04	19:30	10	152
275	RRVPN	RRVUNL	LINE	BHILWARA (400KV)-AJMER (400KV)I	DAILY	HALF YEARLY MAINTENANCE WORK OF BAY & EQUIPMENTS	2019-10-03	09:00	2019-10-03	18:00	9	162
276	RRVPN	RRVPN	LINE	BHILWARA (400KV)-AJMER (400KV)II	DAILY	HALF YEARLY MAINTENANCE WORK OF BAY & EQUIPMENTS	2019-10-04	09:00	2019-10-04	18:00	9	162
277	RRVPN	RRVPN	LINE	ANTA(400KV)-KALISINDH (400KV)2	DAILY	FOR Half yearly Maintenance work (Tightening of Nuts & Bolts of Clamp, Fixtures & Jumpers).	2019-10-01	09:00	2019-10-01	18:00	9	158
278	RRVPN	RRVPN	LINE	ANTA(400KV)-CHHABRA (400KV)1	DAILY	FOR Half yearly Maintenance work (Tightening of Nuts & Bolts of Clamp, Fixtures & Jumpers).	2019-10-03	09:00	2019-10-03	18:00	9	158
279	RRVPN	RRVPN	LINE	ANTA(400KV)-KAWAI (400KV)1	DAILY	FOR Half yearly Maintenance work (Tightening of Nuts & Bolts of Clamp, Fixtures & Jumpers).	2019-10-04	09:00	2019-10-04	18:00	9	161
280	RRVPN	RRVPN	LINE	ANTA(400KV)-CHHABRA (400KV)2	DAILY	FOR Half yearly Maintenance work (Tightening of Nuts & Bolts of Clamp, Fixtures & Jumpers).	2019-10-09	09:00	2019-10-09	18:00	9	159
281	RRVPN	RRVPN	LINE	ANTA(400KV)-KAWAI (400KV)2	DAILY	FOR Half yearly Maintenance work (Tightening of Nuts & Bolts of Clamp, Fixtures & Jumpers).	2019-10-10	09:00	2019-10-10	19:00	10	160
282	RRVPN	RRVPN	LINE	HISSAR BBMB (220KV)-CHIRAWA (220KV)	DAILY	For replacement of missing and broken earth wire b/w tower loc no 46 to 50	2019-10-16	08:00	2019-10-18	19:00	33	161
283	RRVPN	POWERGRID	LINE	ANTA GPS (220KV)-BHILWARA (220KV)1	DAILY	Half Yearly Maintenance	2019-10-10	08:00	2019-10-10	17:00	9	162
284	RRVPN	POWERGRID	LINE	ANTA GPS (220KV)-BHILWARA (220KV)2	DAILY	Half Yearly Maintenance	2019-10-11	08:00	2019-10-11	17:00	9	162
285	RRVPN	RRVPN	LINE	SIKAR (400KV)-BIKANER (400KV)1	DAILY	Routine Bay Maintenance	2019-10-03	10:00	2019-10-03	13:00	3	160
286	RRVPN	RRVPN	LINE	SIKAR (400KV)-BIKANER (400KV)2	DAILY	Routine Bay Maintenance	2019-10-04	10:00	2019-10-04	13:00	3	160

287	RRVPN	RRVPN	LINE	BIKANER (400KV)-MERTA (400KV)	DAILY	Routine Bay Maintenance	2019-10-11	10:00	2019-10-11	17:00	7	161
288	RRVPN	APL	LINE	ALWAR (400KV)-HINDAUN (400KV)	DAILY	Quarterly /Half yearly Maintenance work	2019-10-04	09:00	2019-10-04	16:00	7	152
289	RRVPN	RRVPN	LINE	Kankani 400 KV-MERTA (400KV)	DAILY	Quarterly maintenance work of bay & equipments	2019-10-04	10:00	2019-10-04	17:00	7	162
290	RRVPN	POWERGRID	LINE	KOTA (400KV)-MERTA (400KV)I	DAILY	quarterly maintenance work of bay & equipments	2019-10-10	10:00	2019-10-10	17:00	7	162
291	RRVPN	RRVPN	LINE	BHADLA (400KV)-MERTA (400KV)	DAILY	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-10-03	10:00	2019-10-03	17:00	7	162
292	RRVPN	RRVPN	LINE	SIKAR-PG (220KV)- RATANGARH(220KV)I(PG)	DAILY	Maintenance work of bay equipments	2019-10-17	09:30	2019-10-17	18:00	8.5	159
293	RRVPN	RRVPN	LINE	SIKAR-PG (220KV)- RATANGARH(220KV)II(PG)	DAILY	Maintenance work of bay equipments	2019-10-18	09:30	2019-10-18	18:00	8.5	159
294	RRVPN	POWERGRID	LINE	SHREE CEMENTS (400KV)-MERTA (400KV)	DAILY	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-10-05	10:00	2019-10-05	17:00	7	161
295	RRVPN	RRVPN	LINE	SURATGARH (400KV)-RATANGARH (400KV)1	DAILY	For overhead crossing of under construction line (765KV D/C BIKANER -MOGA Transmission line of PGCIL , TL. No. 122-124	2019-10-03	08:00	2019-10-05	18:00	30	160
296	RRVPN	RRVPN	LINE	SURATGARH (400KV)-RATANGARH (400KV)2	DAILY	For overhead crossing of under construction line (765KV D/C BIKANER -MOGA Transmission line of PGCIL , TL. No. 122-124	2019-10-03	08:00	2019-10-05	18:00	30	160
297	RRVPN	RRVPN	LINE	MERTA (400KV)-HEERAPURA (400KV)	DAILY	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-10-17	10:00	2019-10-17	17:00	7	162
298	RRVPN	RRVPN	LINE	Kankani 400 KV-RAJWEST (400KV)	DAILY	Quarterly maintenance Work	2019-10-04	09:00	2019-10-04	18:00	9	161
299	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-Kankani 400 KVII	DAILY	Quarterly maintenance Work	2019-10-24	09:00	2019-10-24	18:00	9	162
300	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-Kankani 400 KVI	DAILY	Quarterly maintenance Work	2019-10-31	09:00	2019-10-31	18:00	9	162
301	SJVNL	POWERGRID	LINE	NATHPA-JHAKRI (NJPC) (400KV)- RAMPUR HEP (400KV)II	DAILY	Annual Maintenance and attending minor leakages in lines	2019-10-03	08:30	2019-10-03	17:00	8.5	156
302	SJVNL	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)II	DAILY	Annual Maintenance and attending minor leakages in the lines	2019-10-04	08:30	2019-10-04	17:00	8.5	157
303	SJVNL	POWERGRID	LINE	RAMPUR HEP (400KV)-NALLAGARH (400KV)I	DAILY	Annual Maintenance and attending minor leakages in the lines	2019-10-05	08:30	2019-10-05	17:00	8.5	158

304	NRSS-XXIX	NRSS-XXIX	LINE	SAMBA (400KV)-AMARGARH (400KV)I	DAILY	A/R in non Auto mode, for the installation of OPGW in place of earth wire.	2019-10-01	07:30	2019-10-31	19:30	372	162
305	NRSS-XXIX	NRSS-XXIX	LINE	SAMBA (400KV)-AMARGARH (400KV)II	DAILY	A/R in non Auto mode, for the installation of OPGW in place of earth wire.	2019-10-01	07:30	2019-10-31	19:00	356.5	162
306	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-ANPARA-D (400KV)1	CONTINUOUS	For annual testing of Line Protection relays/system and Circuit Breaker, disconnecter etc.	2019-10-14	10:00	2019-10-14	17:00	7	161
307	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-ANPARA-D (400KV)2	CONTINUOUS	For annual testing of Line Protection relays/system and Circuit Breaker, disconnecter etc.	2019-10-16	10:00	2019-10-16	17:00	7	161
308	UPPTCL	POWERGRID	LINE	BAREILY-PG (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	DAILY	Routine Protection Testing and General Maintenance of Line Bay	2019-10-16	09:00	2019-10-16	17:00	8	160
309	UPPTCL	UPPTCL	LINE	OBRA (400KV)-SULTANPUR (400KV)	DAILY	for routine bay maintenance works	2019-10-14	10:00	2019-10-14	18:00	8	162
310	UPPTCL	UPPTCL	LINE	SULTANPUR (400KV)-TANDA	DAILY	for routine bay maintenance works	2019-10-16	10:00	2019-10-16	18:00	8	162
311	UPPTCL	UPPTCL	LINE	LUCKNOW-Kursi Road (400KV) PG-SULTANPUR (400KV)	DAILY	for routine bay maintenance works	2019-10-18	10:00	2019-10-18	18:00	8	162
312	UPPTCL	UPPTCL	LINE	TANDA (220KV)-SULTANPUR (400KV)	DAILY	for routine bay maintenance works	2019-10-04	10:00	2019-10-04	18:00	8	161
313	UPPTCL	UPPTCL	LINE	AZAMGARH (400KV)-TANDA	CONTINUOUS	for rerouting/diversion of this line in ROW of UPEIDA	2019-10-05	08:00	2019-10-12	18:00	178	162
314	UPPTCL	UPPTCL	LINE	GREATER NOIDA(765 KV)-GREATER NOIDA (400KV)II	CONTINUOUS	For general maintenance	2019-10-18	10:00	2019-10-18	16:00	6	161
315	UPPTCL	POWERGRID	LINE	DADRI-THERMAL (400KV)-GREATER NOIDA (400KV)	CONTINUOUS	For general maintenance and routine testing	2019-10-23	09:00	2019-10-23	14:00	5	161
316	UPPTCL	UPPTCL	LINE	MURADNAGAR (400KV)-ALIGARH (400KV)	DAILY	For carrying out height raising work for construction of Delhi Meerut Express way	2019-10-21	08:00	2019-10-26	18:00	60	162
317	UPPTCL	UPPTCL	LINE	SIMBHOLI (220KV)-MATORE (400KV)	CONTINUOUS	for Attending Problem of bus isolator of Simbhaoli- Mator Line	2019-10-17	08:00	2019-10-17	10:00	2	159
318	UPPTCL	UPPTCL	LINE	SARASAWA-KHADORI	DAILY	for looping, chopping of trees in line corridor, & maintenance work of bay	2019-10-17	10:00	2019-10-22	17:00	42	-
319	UPPTCL	UPPTCL	LINE	SARASAWA-KHODRI (220KV)	DAILY	for looping, chopping of trees in line corridor, & maintenance work of bay	2019-10-10	10:00	2019-10-15	17:00	42	152
320	UPPTCL	UPPTCL	LINE	NANAUTA (220KV)-SAHARANPUR-PG (220KV)	DAILY	Lopping, Chopping of the trees, Tightening & checking of the nut bolts, jumpers & insulator string and also all other associated work	2019-10-11	10:00	2019-10-12	18:00	16	158

321	UPPTCL	UPPTCL	LINE	Srinagar HEP- ALAKANANDA (400KV)- VISHNUPRAYAG (400KV)	DAILY	For Energy Meter calibration	2019-10-10	09:00	2019-10-10	18:00	9	156
322	UPPTCL	UPPTCL	LINE	ALIGARH (400KV)-SIKANDRABAD (400KV)1	DAILY	Cleaning of Disc Insulator, Tightning of Jumper, Hardware Fitting	2019-10-10	08:00	2019-10-14	18:00	50	159
323	UPPTCL	UPPTCL	LINE	ALIGARH (400KV)-SIKANDRABAD (400KV)2	DAILY	Cleaning of Disc Insulator, Tightning of Jumper, Hardware Fitting	2019-10-15	08:00	2019-10-19	18:00	50	159
324	UPPTCL	UPPTCL	LINE	FATEHBAD_AGRA(765KV)-MATHURA (400KV)II	DAILY	Maintenance work of line & jumper tightening	2019-10-01	08:00	2019-10-04	18:00	40	161
325	UPPTCL	UPPTCL	LINE	AGRA-UP (400KV)- FATEHBAD_AGRA(765KV)I	DAILY	Maintenance work of line & jumper tightening	2019-10-15	08:00	2019-10-18	18:00	40	161
326	UPPTCL	UPPTCL	LINE	FATEHBAD_AGRA(765KV)-AGRA SOUTH		Jumper Tightening,CRM	2019-10-15	09:00	2019-10-18	18:00	81	161
327	UPPTCL	UPPTCL	LINE	MURADNAGAR II (400KV)-MATHURA (400KV)	DAILY	Jumper Tightening of Line	2019-10-17	08:00	2019-10-18	19:00	22	161
328	UPPTCL	UPPTCL	LINE	ORAI (400KV)-MAINPURI-UP (765KV)	DAILY	Routine maintenance & testing of bay	2019-10-10	09:30	2019-10-10	18:00	8.5	161
329	UPPTCL	UPPTCL	LINE	ORAI (400KV)-BANDA (400KV)1		Routine maintenance & testing of bay	2019-10-11	09:30	2019-10-11	18:00	8.5	162
330	UPPTCL	UPPTCL	LINE	SAHUPURI (220KV)-PUSAULI BSEB-ER (220KV)+BSEB	CONTINUOUS	For maintenance work	2019-10-09	10:00	2019-10-09	16:00	6	161
331	UPPTCL	UPPTCL	LINE	SAHUPURI (132KV)-KARMNASA BSEB-ER (132KV)	CONTINUOUS	For maintenance work	2019-10-10	10:00	2019-10-10	16:00	6	162
332	UPPTCL	UPPTCL	LINE	CHANDOLI (132KV)-KARMNASA BSEB- ER (132KV)+MPSE	CONTINUOUS	For maintenance work	2019-10-11	10:00	2019-10-11	16:00	6	162
333	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-ANPARA-D (400KV)1	DAILY	Stringing of conductor for overhead power line crossing of under construction 765KV Anpara'D'-Jhunsi T/L	2019-10-11	07:00	2019-10-12	17:00	20	161
334	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-ANPARA-D (400KV)2	DAILY	Stringing of conductor for overhead power line crossing of under construction 765KV Anpara'D'-Jhunsi T/L	2019-10-11	07:00	2019-10-12	17:00	20	161
335	UPPTCL	POWERGRID	LINE	ANPARA-B (400KV)-SARNATH (400KV)2	DAILY	Stringing of conductor for overhead power line crossing of under construction 765KV Anpara'D'-Jhunsi T/L	2019-10-18	07:00	2019-10-19	17:00	20	161
336	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-MAU (400KV)	DAILY	Stringing of conductor for overhead power line crossing of under construction 765KV Anpara'D'-Jhunsi T/L	2019-10-18	07:00	2019-10-19	17:00	20	161
337	UPPTCL	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ANPARA-B (400KV)	DAILY	Stringing of conductor for overhead power line crossing of under construction 765KV Anpara'D'-Jhunsi T/L	2019-10-22	07:00	2019-10-23	17:00	20	162

338	UPPTCL	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)II	DAILY	Stringing of conductor for overhead power line crossing of under construction 765KV Anpara'D'-Jhunsi T/L	2019-10-22	07:00	2019-10-23	17:00	20	162
339	UPPTCL	UPPTCL	LINE	AZAMGARH (400KV)-TANDA	DAILY	Prefestival Maintenance & Routine Testing	2019-10-10	09:00	2019-10-10	18:00	9	162
340	UPPTCL	UPPTCL	LINE	GORAKHPUR-UP (400KV)-AZAMGARH (400KV)	DAILY	Prefestival Maintenance & Routine Testing	2019-10-11	09:00	2019-10-11	18:00	9	161
341	UPPTCL	UPPTCL	LINE	MAU (400KV)-AZAMGARH (400KV)	DAILY	Prefestival Maintenance	2019-10-15	09:00	2019-10-15	18:00	9	159
342	UPPTCL	UPPTCL	LINE	AZAMGARH (400KV)-SARNATH (400KV)	DAILY	Prefestival Maintenance	2019-10-13	09:00	2019-10-13	18:00	9	162
343	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-OBRA (400KV)	CONTINUOUS	Diversion of 400 KV Obra-Anpara L-2 Line from the proposed coal handling area of 2 x 660 MW of Obra C	2019-10-07	08:00	2019-10-19	18:00	298	162
344	UPPTCL	POWERGRID	LINE	ANPARA-B (400KV)-SARNATH (400KV)1	CONTINUOUS	Diversion of 400 KV Obra-Sarnath L-3 Line for the proposed DFCC corridor	2019-10-21	08:00	2019-10-30	18:00	226	161
345	UPPTCL	POWERGRID	LINE	BALIA(400KV)-MAU (400KV)I	DAILY	For Tightening of complete bay and testing of relay, CT, PT, C.B.	2019-10-15	09:00	2019-10-15	18:00	9	157
346	UPPTCL	POWERGRID	LINE	BALIA(400KV)-MAU (400KV)II	DAILY	For Tightening of complete bay and testing of relay, CT, PT, C.B.	2019-10-16	09:00	2019-10-16	18:00	9	157
347	UPPTCL	UPPTCL	LINE	OBRA (400KV)-REWA ROAD (400KV)	DAILY	For foundation of pile type tower for providing start up power to Obra C	2019-10-03	08:00	2019-10-04	18:00	20	149
348	UPPTCL	UPPTCL	LINE	GREATER NOIDA(765 KV)-HAPUR	CONTINUOUS	For replenishment of tower part	2019-10-15	08:00	2019-10-15	18:00	10	161
349	UPPTCL	UPPTCL	LINE	ALIGARH (400KV)-MAINPURI-UP (765KV)I	DAILY	Maintenance and Testing	2019-10-24	09:00	2019-10-24	18:00	9	160
350	UPPTCL	UPPTCL	LINE	ALIGARH (400KV)-MAINPURI-UP (765KV)II	DAILY	Maintenance and Testing	2019-10-25	09:00	2019-10-25	18:00	9	157
351	DTL	DTL	BAY	MAIN CB NO 152(BUS-I) CONTROLLING 400kV MUNDKA CKT-I AT BAWANA	DAILY	TESTING OF BREAKER TIMING & DCRM, BAY MTC. AS PER PMS SCHEDULE OF DTL.	2019-10-21	10:00	2019-10-21	14:00	4	-
352	DTL	DTL	BAY	400KV CB-252 AT BAWANA CONTROLLING 400KV TIKRI KALAN (MUNDKA) CKT.1 BUS-2	DAILY	TESTING OF BREAKER TIMING & DCRM, BAY MTC. AS PER PMS SCHEDULE OF DTL.	2019-10-22	10:00	2019-10-22	14:00	4	154
353	DTL	DTL	BAY	400KV CB-352 AT BAWANA CONTROLLING 400KV TIKRI KALAN (MUNDKA) CKT. 2 BUS-1	DAILY	TESTING OF BREAKER TIMING & DCRM, BAY MTC. AS PER PMS SCHEDULE OF DTL.	2019-10-23	10:00	2019-10-23	14:00	4	154
354	DTL	DTL	BAY	400KV CB-452 AT BAWANA CONTROLLING 400KV TIKRI KALAN (MUNDKA) CKT.2 BUS-2	DAILY	TESTING OF BREAKER TIMING & DCRM, BAY MTC. AS PER PMS SCHEDULE OF DTL.	2019-10-24	10:00	2019-10-24	14:00	4	154

355	DTL	DTL	BAY	BAY NO 40152 (MAIN CB WITH BUS-1)OF MUNDKA-JHATIKARANA-1	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-03	10:00	2019-10-03	13:00	3	162
356	DTL	DTL	BAY	BAY NO 40252 (MAIN CB WITH BUS-2) FOR MUNDKA - JHATIKALAN-I	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-03	14:00	2019-10-03	17:00	3	162
357	DTL	DTL	BAY	BAY NO 40352 (MAIN CB WITH BUS-1) FOR MUNDKA - JHATIKALAN-II	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-04	10:00	2019-10-04	13:00	3	162
358	DTL	DTL	BAY	BAY NO 40452 (MAIN CB WITH BUS-2) FOR MUNDKA- JHATIKALAN-II	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-04	14:00	2019-10-04	17:00	3	162
359	DTL	DTL	BAY	BAY NO 40952 (TIE CB) FOR 315MVA ICT-2	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-14	10:00	2019-10-14	13:00	3	162
360	DTL	DTL	BAY	BAY NO 41052 (MAIN CB) FOR 315MVA ICT-2	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-14	14:00	2019-10-14	17:00	3	162
361	DTL	DTL	BAY	BAY NO 41152 (MAIN CB WITH BUS-1) FOR MUNDKA - JHAJJAR-2	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-15	10:00	2019-10-15	13:00	3	162
362	DTL	DTL	BAY	BAY NO 41452 (MAIN CB WITH BUS-1) FOR MUNDKA - JHAJJAR-1	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-15	14:00	2019-10-15	17:00	3	162
363	DTL	DTL	BAY	BAY NO 41252 (TIE CB) FOR 315MVA ICT-3	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-18	10:00	2019-10-18	13:00	3	162
364	DTL	DTL	BAY	BAY NO 41352 (MAIN CB) FOR 315MVA ICT-3	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-18	14:00	2019-10-18	17:00	3	162
365	DTL	DTL	BAY	BAY NO 41552 (TIE CB) FOR 315MVA ICT-4	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-19	10:00	2019-10-19	13:00	3	162
366	DTL	DTL	BAY	BAY NO 41652 (MAIN CB) 315MVA ICT-4	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-19	14:00	2019-10-19	17:00	3	162
367	DTL	DTL	BAY	BAY NO 41752 (MAIN CB WITH BUS-1) FOR MUNDKA - BAWANA -2	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-21	10:00	2019-10-21	13:00	3	162
368	DTL	DTL	BAY	BAY NO 41852 (MAIN CB WITH BUS-2) FOR MUNDKA - BAWANA -2	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-21	14:00	2019-10-21	17:00	3	162
369	DTL	DTL	BAY	BAY NO 41952 (MAIN CB WITH BUS-1) FOR MUNDKA - BAWANA -1	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-22	10:00	2019-10-22	13:00	3	162
370	DTL	DTL	BAY	BAY NO 42052 (MAIN CB WITH BUS-2) FOR MUNDKA - BAWANA -1	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-22	14:00	2019-10-22	17:00	3	162
371	DTL	DTL	BAY	CB No. 40652	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-23	10:00	2019-10-23	13:00	3	162

372	DTL	DTL	BAY	CB NO 40752(SPARE BAY) AT MUNDKA	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-23	14:00	2019-10-23	17:00	3	162
373	DTL	DTL	BAY	CB NO 1652 CONTROLLING JHATIKALAN CKT- 02 AT BAMNAULI(BUS-02)	CONTINUOUS	For Replacement of BHEL CB with AREVA CB by OEM M/s GE T&D India Ltd.	2019-10-04	06:00	2019-10-12	17:30	203.5	154
374	DTL	DTL	BAY	CB NO 1852 CONTROLLING JHATIKARA CKT-I AT 400kV BAMNOLI	CONTINUOUS	For Replacement of BHEL CB with AREVA CB by OEM M/s GE T&D India Ltd.	2019-10-14	06:00	2019-10-22	17:30	203.5	-
375	HVPNL	HVPNL	BAY	Nawada TIE-2	DAILY	For three yearly mtc by M&P and general mtc.	2019-09-25	10:00	2019-09-25	19:00	9	160
376	HVPNL	HVPNL	BAY	NAWADA TIE-1	DAILY	For three yearly mtc by M&P and general mtc.	2019-10-03	10:00	2019-10-03	19:00	9	160
377	POWERGRID	POWERGRID	BAY	765 KV ICT-1 Main Bay 703, at Agra HVDC	DAILY	AMP OF BAY EQUIPMENT at Agra S/S	2019-10-04	09:30	2019-10-04	18:30	9	162
378	POWERGRID	POWERGRID	BAY	765 KV ICT 2 Main Bay 706 , at Agra HVDC	DAILY	AMP OF BAY EQUIPMENT at Agra S/S	2019-10-05	09:30	2019-10-05	18:30	9	161
379	POWERGRID	POWERGRID	BAY	713- Main Bay-(Gwalior-I) at AGRA	DAILY	AMP OF BAY EQUIPMENT at Agra S/S	2019-10-07	09:00	2019-10-07	18:00	9	161
380	POWERGRID	POWERGRID	BAY	714 Tie Bay of Gwalior-1, at Agra HVDC	DAILY	AMP OF BAY EQUIPMENT at Agra S/S	2019-10-09	09:00	2019-10-09	18:00	9	161
381	POWERGRID	POWERGRID	BAY	710R-SWITCHEABLE REACTOR BAY AT AGRA	DAILY	AMP OF BAY EQUIPMENT at Agra S/S	2019-10-10	09:00	2019-10-10	18:00	9	161
382	POWERGRID	POWERGRID	BAY	716 MAIN BAY-JHATIKALA LINE AT AGRA	DAILY	AMP OF BAY EQUIPMENT at Agra S/S	2019-10-11	09:00	2019-10-11	18:00	9	161
383	POWERGRID	POWERGRID	BAY	717 Tie Bay of Jhatikara, at Agra HVDC	DAILY	AMP OF BAY EQUIPMENT at Agra S/S	2019-10-12	09:00	2019-10-12	18:00	9	161
384	POWERGRID	POWERGRID	BAY	702 Bay at Ballia (765kV BR-1 Tie Bay)	DAILY	For AMP & CB Pole Interconnection replacement at Ballia S/S	2019-10-01	09:00	2019-10-02	18:00	18	160
385	POWERGRID	POWERGRID	BAY	705 Bay at Ballia (765kV BR-2 Tie Bay)	DAILY	For AMP & CB Pole Interconnection replacement at ballia S/S	2019-10-04	09:00	2019-10-05	18:00	18	160
386	POWERGRID	POWERGRID	BAY	765KV ICT-II tie Bay(Bay No.708) , at Ballia	DAILY	For AMP & CB Pole Interconnection replacement at ballia S/S	2019-10-07	09:00	2019-10-08	18:00	18	160
387	POWERGRID	POWERGRID	BAY	765KV Ballia-Varanasi tie Bay(Bay No.711) , at Ballia	DAILY	For AMP & CB Pole Interconnection replacement at ballia S/S	2019-10-09	09:00	2019-10-10	18:00	18	160
388	POWERGRID	POWERGRID	BAY	704 Bay at Ballia (765kV Lukcnw Line Main Bay)	DAILY	For AMP & CB Pole Interconnection replacement at ballia S/S	2019-10-21	09:00	2019-10-22	18:00	18	160

389	POWERGRID	POWERGRID	BAY	707 Bay at Ballia (765kV Gaya Line Main Bay)	DAILY	For AMP & CB Pole Interconnection replacement at ballia S/S	2019-10-23	09:00	2019-10-24	18:00	18	160
390	POWERGRID	POWERGRID	BAY	765 KV 709 Bay (ICT-2 Main Bay),at Balia	DAILY	For AMP & CB Pole Interconnection replacement at ballia S/S	2019-10-25	09:00	2019-10-26	18:00	18	156
391	POWERGRID	POWERGRID	BAY	765 kv 712 Bay (ICT-1 Main Bay),at Balia	DAILY	For AMP & CB Pole Interconnection replacement at ballia S/S	2019-10-28	09:00	2019-10-29	18:00	18	160
392	POWERGRID	POWERGRID	BAY	701 BAY (Main bay of 765 KV Fatehpur Varanasi Line), at Fatehpur	DAILY	AMP & Tightening Work at Fatehpur S/S	2019-10-03	09:00	2019-10-03	18:00	9	156
393	POWERGRID	POWERGRID	BAY	702- 765kV Balia Line Tie Bay , at Lucknow	DAILY	For AMP Work at 765kV lucknow S/S	2019-10-01	09:00	2019-10-02	18:00	18	159
394	POWERGRID	POWERGRID	BAY	765kV Bareilly Line Reactor Bay at Lucknow	DAILY	For AMP Work at 765kV lucknow S/S	2019-10-03	09:00	2019-10-04	18:00	18	158
395	POWERGRID	POWERGRID	BAY	710 Main Bay of Fatehpur Line At Agra	DAILY	AMP OF BAY EQUIPMENT at Agra S/S	2019-10-03	09:00	2019-10-03	18:00	9	-
396	POWERGRID	POWERGRID	BAY	765KV ICT-3 & FUTURE T/BAY 714 JHATIKRA	DAILY	AMP work	2019-10-10	09:00	2019-10-10	19:00	10	160
397	POWERGRID	POWERGRID	BAY	765KV B/R-II M/BAY 703 JHATIKRA	DAILY	AMP work	2019-10-18	09:00	2019-10-18	19:00	10	155
398	POWERGRID	POWERGRID	BAY	765KV ICT-I-M/ BAY 703 AT MEERUT	DAILY	AMP work	2019-10-03	09:00	2019-10-03	18:00	9	151
399	POWERGRID	POWERGRID	BAY	765KV G.NOIDA L/R BAY 715 AT MEERUT	DAILY	AMP work	2019-10-12	09:30	2019-10-12	18:30	9	151
400	POWERGRID	POWERGRID	BAY	765KV G.NOIDA M/ BAY 715 AT MEERUT	DAILY	AMP work	2019-10-14	09:00	2019-10-14	18:00	9	151
401	POWERGRID	POWERGRID	BAY	765KV ICT-I M/BAY 706 CHITOTGARH	DAILY	AMP of bay Equipment	2019-10-14	09:00	2019-10-15	18:00	18	159
402	POWERGRID	POWERGRID	BAY	765KV ICT-II M/BAY 709 CHITORGARH	DAILY	AMP of bay Equipment	2019-10-16	09:00	2019-10-17	18:00	18	159
403	POWERGRID	POWERGRID	BAY	765 KV 240MVAR B/R-I M/BAY CB 712 CHITORGARH	DAILY	AMP of bay Equipment	2019-10-18	09:00	2019-10-19	18:00	18	160
404	POWERGRID	POWERGRID	BAY	765kKV AJMER-I /MAIN BAY 713 CHITORGARH	DAILY	AMP of bay Equipment	2019-10-21	09:00	2019-10-22	18:00	18	161
405	POWERGRID	POWERGRID	BAY	765kKV AJMER-II /MAIN BAY 710 CHITORGARH	DAILY	AMP of bay Equipment	2019-10-23	09:00	2019-10-24	18:00	18	161



406	POWERGRID	POWERGRID	BAY	765KV Ajmer-II T/Bay 711 at Chitorgarh	DAILY	AMP of bay Equipment	2019-10-09	09:00	2019-10-09	18:00	9	158
407	POWERGRID	POWERGRID	BAY	765KV Banaskantha -1 T/bay 708 at chitorgarh	DAILY	AMP of bay Equipment	2019-10-10	09:00	2019-10-10	18:00	9	158
408	POWERGRID	POWERGRID	BAY	765KV Banaskantha -2 T/bay 705 at chitorgarh	DAILY	AMP of bay Equipment	2019-10-11	09:00	2019-10-11	18:00	9	158
409	POWERGRID	POWERGRID	BAY	765KV Future bay 715 at chitorgarh	DAILY	AMP of bay Equipment	2019-10-12	09:00	2019-10-12	18:00	9	158
410	POWERGRID	POWERGRID	BAY	765KV AJMER -I T/ BAY 714 CHITORGARH	DAILY	AMP of bay Equipment	2019-10-12	09:00	2019-10-12	18:00	9	152
411	POWERGRID	POWERGRID	BAY	765KV ICT-II M/BAY 704 AJMER	DAILY	Bay AMP work	2019-10-10	09:00	2019-10-10	17:00	8	159
412	POWERGRID	POWERGRID	BAY	765KV ICT-I & CHITORGRH LINE T/BAY 702 AJMER	DAILY	Bay AMP work	2019-10-11	09:30	2019-10-11	17:30	8	154
413	POWERGRID	POWERGRID	BAY	765KV B/R M/BAY 707 AJMER	DAILY	Bay AMP work	2019-10-01	09:30	2019-10-01	17:30	8	154
414	POWERGRID	POWERGRID	BAY	765KV ICT-I M/BAY 701 AJMER	DAILY	Bay AMP work	2019-10-04	09:00	2019-10-04	17:00	8	159
415	POWERGRID	POWERGRID	BAY	765 KV MOGA M/BAY 713 AT BHIWANI	DAILY	Bay AMP work	2019-10-01	09:30	2019-10-02	18:30	18	151
416	POWERGRID	POWERGRID	BAY	765KV MOGA/BUS REACTOR -I T/BAY 714 AT BHIWANI	DAILY	Bay AMP work	2019-10-03	09:00	2019-10-04	18:00	18	153
417	POWERGRID	POWERGRID	BAY	765KV BUS REACTOR -I M/BAY 715 AT BHIWANI	DAILY	Bay AMP work	2019-10-07	09:00	2019-10-08	18:00	18	151
418	POWERGRID	POWERGRID	BAY	765KV PHAGI-I M/BAY 716 BHIWANI	DAILY	Phase. SD is being clubbed with Phagi-Bhiwani I Line SD as the Line SD is also required considering safe working area of	2019-10-14	09:00	2019-10-15	18:00	18	162
419	POWERGRID	POWERGRID	BAY	765 KV B/R-II T/BAY 717 BHIWANI	DAILY	Bay AMP work	2019-10-11	09:00	2019-10-12	18:00	18	155
420	POWERGRID	POWERGRID	BAY	765 KV B/R-II M/BAY 718 BHIWANI	DAILY	Bay AMP work	2019-10-14	09:00	2019-10-15	18:00	18	155
421	POWERGRID	POWERGRID	BAY	765 KV PHAGI-II M/BAY 719 BHIWANI	DAILY	Bay AMP work	2019-10-16	09:00	2019-10-17	18:00	18	155
422	POWERGRID	POWERGRID	BAY	765 KV PHAGI-II T/BAY 720 BHIWANI	DAILY	Bay AMP work	2019-10-18	09:00	2019-10-19	18:00	18	155

423	POWERGRID	POWERGRID	BAY	765KV ICT-1 T/bay 708 at Bikaner	DAILY	AMP work	2019-10-05	09:00	2019-10-05	19:00	10	-
424	POWERGRID	POWERGRID	BAY	765KV ICT-III T/bay 714 at Jhatikra	DAILY	AMP work	2019-10-10	09:00	2019-10-10	19:00	10	-
425	POWERGRID	POWERGRID	BAY	765KV Bus/Reactor-II T/bay 702 at Jhatikra	DAILY	AMP work	2019-10-18	09:00	2019-10-18	18:00	9	-
426	POWERGRID	POWERGRID	BAY	765KV ICT-II M/bay 704 at Ajmer	DAILY	Bay AMP work	2019-10-10	09:00	2019-10-10	18:00	9	-
427	POWERGRID	POWERGRID	BAY	765KV ICT-I T/bay 702 at Ajmer	DAILY	Bay AMP work	2019-10-11	09:00	2019-10-11	18:00	9	-
428	POWERGRID	POWERGRID	BAY	765KV ICT-II & CHITORGARH-II T/BAY 705 AJMER	DAILY	Bay AMP work	2019-10-03	09:30	2019-10-03	18:30	9	152
429	POWERGRID	POWERGRID	BAY	(405) Tie Bay Agra-Auriya-1 , at Agra	CONTINUOUS	For repalcement of 40489 & 40589 (towards Bus-1 side) isolators under Ad Cap. at Agra S/S	2019-10-09	12:00	2019-10-15	18:00	150	158
430	POWERGRID	POWERGRID	BAY	407 Agra Kanpur Main Bay at Agra	CONTINUOUS	For repalcement of 40789A (towards Bus-1 side) isolators under Ad Cap. at Agra S/S	2019-10-15	14:00	2019-10-19	17:00	99	158
431	POWERGRID	POWERGRID	BAY	765 kV ICT-2 Main Bay 712 at Moga	DAILY	For AMP works.	2019-10-18	09:30	2019-10-18	17:30	8	158
432	POWERGRID	POWERGRID	BAY	765 kV Bhiwani & ICT-2 Tie Bay 711 at Moga	DAILY	For AMP works.	2019-10-21	09:30	2019-10-21	17:30	8	156
433	POWERGRID	POWERGRID	BAY	410 Agra Ballabgarh Main Bay at Agra	CONTINUOUS	For repalcement of 41089A (towards Bus-1 side) isolators under Ad Cap. at Agra S/S	2019-10-19	09:00	2019-10-23	17:00	104	158
434	POWERGRID	POWERGRID	BAY	765 kV Bhiwani Main Bay 710 at Moga	DAILY	For AMP works.	2019-10-22	09:30	2019-10-22	17:30	8	158
435	POWERGRID	POWERGRID	BAY	765kV Bus Reactor-II Tie Bay at Moga	DAILY	For oil sampling of newly installed CTs.	2019-10-04	10:30	2019-10-04	16:30	6	159
436	POWERGRID	POWERGRID	BAY	Tie Bay of W1.W1.Q2 ICT-1 , at Agra HVDC	DAILY	AMP of Bay Equipment i.e. CB , CT etc at Agra S/S	2019-10-12	09:00	2019-10-12	18:00	9	-
437	POWERGRID	POWERGRID	BAY	ICT-1 BAY, at Kanpur	CONTINUOUS	Isolator (42689 ) replacement work under add cap. at 400 KV Kanpur S/S	2019-10-13	09:00	2019-10-17	18:00	105	160
438	POWERGRID	POWERGRID	BAY	SVC-1 Main Bay at Kanpur	CONTINUOUS	Isolator (42389 ) replacement work under add cap. at 400 KV Kanpur S/S	2019-10-13	09:00	2019-10-17	18:00	105	-
439	POWERGRID	POWERGRID	BAY	SVC-2 MAIN BAY, at Kanpur	CONTINUOUS	Isolator 42489 & 42489A retrofitment work under add cap. at 400 KV Kanpur S/S	2019-10-18	09:00	2019-10-30	18:00	297	160

440	POWERGRID	POWERGRID	BAY	(421 bay) SVC-1 future Bay at kanpur	CONTINUOUS	Isolator 42189 & 42289B retrofitment work under add cap. at 400 KV Kanpur S/S	2019-10-18	09:00	2019-11-01	18:00	345	-
441	POWERGRID	POWERGRID	BAY	ALLAHABAD TIE BAY , at Kanpur	DAILY	Problem rectification in Siemens CB at 400 KV Kanpur S/S	2019-10-10	09:00	2019-10-12	18:00	27	151
442	POWERGRID	POWERGRID	BAY	ALLAHABAD MAIN BAY , at Kanpur	DAILY	Problem rectification in Siemens CB at 400 KV Kanpur S/S	2019-10-07	09:00	2019-10-09	18:00	27	162
443	POWERGRID	POWERGRID	BAY	418 Bay- Auraiya-1 Main Bay at 400kV Kanpur S/S	CONTINUOUS	CB Overhauling work at 400 KV Kanpur S/S	2019-10-01	09:00	2019-10-06	18:00	129	-
444	POWERGRID	POWERGRID	BAY	400KV SVC Filter 1 Bay at kankroli	CONTINUOUS	Barbed Wire Fencing Work	2019-10-01	09:00	2019-10-03	18:00	57	161
445	POWERGRID	POWERGRID	BAY	400KV SVC Filter bay and Aux bay at Kankroli	CONTINUOUS	Barbed Wire Fencing Work SVC shall remain charged except Filter 2 and AVR bay	2019-10-07	09:00	2019-10-09	21:00	60	161
446	POWERGRID	POWERGRID	BAY	400kv SVC TCR3 & TSC2 BAY AT KANKROLI	CONTINUOUS	Barbed Wire Fencing Work.SVC shall remain charged except TSC2 and TCR2 bay	2019-10-17	09:00	2019-10-19	18:00	57	-
447	POWERGRID	POWERGRID	BAY	400KV SVC TCR2 BAY AT KANKROLI	CONTINUOUS	Barbed Wire Fencing Work SVC shall remain charged except TCR2 bay	2019-10-14	09:00	2019-10-16	18:00	57	-
448	POWERGRID	POWERGRID	BAY	400KV TSC1 and TCR 1 bay of SVC at Kankroli	CONTINUOUS	Barbed Wire Fencing Work SVC shall remain charged except TSC1 and TCR1 bay	2019-10-10	09:00	2019-10-12	18:00	57	-
449	POWERGRID	POWERGRID	BAY	400KV AGRA M/BAY 406 AT BASSI	CONTINUOUS	Replacement of 400kV RK-Make Isolator (No. 406-89, Bus Side) with new S&S-Make Isolator	2019-10-01	09:00	2019-10-07	18:00	153	146
450	POWERGRID	POWERGRID	BAY	400KV AGRA M/BAY 406 AT BASSI	CONTINUOUS	Replacement of 400kV RK-Make Isolator(406-89A) with new S&S-Make Isolator	2019-10-09	09:00	2019-10-12	18:00	81	146
451	POWERGRID	POWERGRID	BAY	400KV Agar-Bhiwadi T/Bay 405 at Bassi	CONTINUOUS	Replacement of 400kV RK-Make Isolator(405-89A) with new S&S-Make Isolator	2019-10-19	09:30	2019-10-24	18:30	129	-
452	POWERGRID	POWERGRID	BAY	400KV Agra/Bhiwadi T/Bay 405 at Bassi	CONTINUOUS	Replacement of 400kV RK-Make Isolator(405-89B) with new S&S-Make Isolator	2019-10-25	09:00	2019-10-30	18:00	129	-
453	POWERGRID	POWERGRID	BAY	400KV ICT-I M/bay 401 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-10-01	09:30	2019-10-04	18:30	81	-
454	POWERGRID	POWERGRID	BAY	400KV ICT-I & Bhiwani -I T/bay 402 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-10-05	09:00	2019-10-08	18:00	81	-
455	POWERGRID	POWERGRID	BAY	400KV Bhiwani PG-I M/Bay 403 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-10-09	09:00	2019-10-12	18:00	81	-
456	POWERGRID	POWERGRID	BAY	400KV Moga-I M/bay 407 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-10-13	09:00	2019-10-16	18:00	81	-

457	POWERGRID	POWERGRID	BAY	400KV Bhiwani BBMB & Fatehbd T/Bay 411 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-10-17	09:00	2019-10-20	18:00	81	-
458	POWERGRID	POWERGRID	BAY	400KV Fatehabad M/Bay 412 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-10-21	09:00	2019-10-24	18:00	81	-
459	RRVPN	RRVPN	BAY	800kv CB (702-52A) for 765kV Phagi-Bhiwani-I line at 765kV GSS Phagi	DAILY	1. Maintenance of CB & Reactors. 2. Maintenance of line bay equipments. 3. To attend the defects of B Phase of (702-89AB) Isolator.	2019-10-10	09:00	2019-10-10	18:00	9	162
460	RRVPN	RRVPN	BAY	706-52T tie CB for 765kV ANTA-1 & GWALIOR-1 LINES AT 765KV PHAGI	DAILY	1. Measurements of operation timings of CB. 2. Measurement of Tan-delta of Current Transformers 3. Tightening of clamps & connectors.	2019-10-15	09:00	2019-10-15	18:00	9	155
461	RRVPN	RRVUNL	BAY	707-52T Tie CB of 765KV ANTA-II / GWALIOR-II AT 765 kv Phagi	DAILY	1. Measurements of operation timings of CB. 2. Measurement of Tan-delta of Current Transformers 3. Tightening of clamps & connectors.	2019-10-22	09:00	2019-10-22	18:00	9	-
462	UPPTCL	UPPTCL	BAY	400kv Unnao line bay at 400kv s/s panki	DAILY	routine relay testing and bay maintenance.	2019-10-23	08:00	2019-10-23	17:00	9	-
463	UPPTCL	UPPTCL	BAY	400KV Sarnath-Anpara A (L3) Line BAY	CONTINUOUS	Replacement of old & outlived 0.5 accuracy 400KV CTs & CVTs by New 0.2 accuracy 400KV CTs & CVTs along with strengthening of 400KV Main Bus-I & Transfer Bus	2019-10-14	08:00	2019-10-15	18:00	34	-
464	BBMB	BBMB	BUS	400KV Bus-1 at Panipat	DAILY	Yearly mtc	2019-10-24	08:00	2019-10-24	17:00	9	156
465	BBMB	BBMB	BUS	400 KV Bus-2 at Panipat	DAILY	Yearly mtc	2019-10-30	08:00	2019-10-30	17:00	9	156
466	DTL	DTL	BUS	400KV BUS-1 AT BAWANA-DTL (400KV)	CONTINUOUS	of DTL , tan Delta testing of CVT, CB & CT and also major Overhauling work of Isolator 189, 389,589,889,1189, 1389, 1589, 1789.	2019-10-06	07:00	2019-10-07	17:00	34	156
467	DTL	DTL	BUS	400KV BUS-2 AT BAWANA	CONTINUOUS	Tightning of all clamps , connectors of Bus as PMS schedule of DTL,tan Delta testing of CVT, CB & CT and also major Overhauling work of Isolator 289,789, 1289,1489.	2019-10-12	08:00	2019-10-13	17:00	33	153
468	HVPNL	HVPNL	BUS	400kv Bus-2 D/Bad	DAILY	To attend hot points on bus isolators observed during thermo vision scanning (ICT-2 will remain off during the download of 400 KV Bus-2 due to the absence of tie CB)	2019-09-25	10:29	2019-09-25	10:29	0	156
469	HVPNL	HVPNL	BUS	Nawada Bus-2	DAILY	For three yearly mtc by M&P and general mtc.	2019-09-25	10:00	2019-09-25	19:00	9	160
470	HVPNL	HVPNL	BUS	Nawada Bus-2	DAILY	For three yearly mtc by M&P and general mtc.	2019-10-03	10:00	2019-10-03	19:00	9	160
471	NTPC	NTPC	BUS	SINGRAULI 400KV BUS - I	DAILY	Replacement of CVT MB for integration with new SAS panel.	2019-10-03	08:30	2019-10-03	17:30	9	162
472	NTPC	NTPC	BUS	SINGRAULI 400KV BUS - II	DAILY	Replacement of CVT MB for integration with new SAS panel.	2019-10-04	08:30	2019-10-04	17:30	9	-
473	NTPC	NTPC	BUS	400KV Bus-3	DAILY	400KV bus-3 shutdown is required for maintenance work in 400KV Bus isolator 1889 as Unit-6 is under shutdown for overhauling.	2019-09-25	07:00	2019-09-25	18:00	11	-

474	POWERGRID	POWERGRID	BUS	765kV Bus-1 at Ballia Substation	DAILY	FOR AMP & INSULATOR REPLACEMENT at ballia S/S	2019-10-03	09:00	2019-10-03	18:00	9	160
475	POWERGRID	POWERGRID	BUS	765kV Bus-2 at Ballia Substation	DAILY	FOR AMP & INSULATOR REPLACEMENT at ballia S/S	2019-10-10	09:00	2019-10-10	18:00	9	160
476	POWERGRID	POWERGRID	BUS	Bus-2, at Fatehpur (PG)	DAILY	AMP & Tightening Work at Fatehpur S/S	2019-10-01	09:00	2019-10-01	18:00	9	154
477	POWERGRID	POWERGRID	BUS	765KV BUS -I JHATIKRA	DAILY	AMP work + Counter weight installation	2019-10-15	09:00	2019-10-15	19:00	10	162
478	POWERGRID	POWERGRID	BUS	765kV BUS-I at ALIGARH	DAILY	For carrying out Impulse test and HV Test on Bus at Aligarh	2019-09-29	08:00	2019-10-04	18:00	60	-
479	POWERGRID	POWERGRID	BUS	765kV BUS-I at ALIGARH	CONTINUOUS	For final connection of Bus-I at Aligarh S/S	2019-10-05	08:00	2019-10-07	18:00	58	-
480	POWERGRID	POWERGRID	BUS	765kV Bus-II at Aligarh	CONTINUOUS	For final connection of Bus-2 at Aligarh substation with existing system	2019-10-10	08:00	2019-10-12	18:00	58	-
481	POWERGRID	POWERGRID	BUS	765kV Bus-II at Aligarh	DAILY	HV test, Impulse Test of Bus at Aligarh S/S	2019-09-28	08:00	2019-10-03	18:00	60	-
482	POWERGRID	POWERGRID	BUS	765kV Bus-II at Aligarh	CONTINUOUS	For Inter connection of Existing system with new system at Aligarh Substation	2019-09-25	08:00	2019-09-27	18:00	58	-
483	POWERGRID	POWERGRID	BUS	400KV WCB Bus-1A/1B Sectionaliser, at Agra HVDC	DAILY	AMP of Bay Equipment i.e. CB , CT etc at Agra S/S	2019-10-01	09:00	2019-10-01	18:00	9	-
484	POWERGRID	POWERGRID	BUS	400KV WCB Bus-2A/2B Sectionaliser, at Agra HVD	DAILY	AMP of Bay Equipment i.e. CB , CT etc at Agra S/S	2019-10-03	09:00	2019-10-03	18:00	9	-
485	POWERGRID	POWERGRID	BUS	Bus-1B , at Agra	DAILY	Point to point testing of Bus Bar Protection M1 / M2, REB 500 at Agra HVDC,	2019-10-04	09:00	2019-10-05	18:00	18	155
486	POWERGRID	POWERGRID	BUS	400 KV WCA Bus-1/1A sectionaliser, at Agra HVDC	DAILY	AMP of Bay Equipment i.e. CB , CT etc at Agra S/S	2019-10-07	09:00	2019-10-07	18:00	9	157
487	POWERGRID	POWERGRID	BUS	Bus-1, at Agra HVDC	DAILY	For 03 hrs to remove bus dropper from Bus-1 to 40489 isolator in order to retrofit this isolator under Ad Cap. at Agra S/S	2019-10-09	09:00	2019-10-09	12:00	3	160
488	POWERGRID	POWERGRID	BUS	Bus-1, at Agra HVDC	DAILY	isolator in order to take 405 & 404 bay in service, and to remove bus dropper from Bus-1 to 40789A isolator in order to retrofit this isolator under Ad Cap. at Agra S/S	2019-10-15	09:00	2019-10-15	14:00	5	160
489	POWERGRID	POWERGRID	BUS	Bus-1, at Agra HVDC	DAILY	isolator in order to take 407 bay in service, and to remove bus dropper from Bus-1 to 41089A isolator in order to retrofit this isolator under Ad Cap. at Agra S/S	2019-10-19	09:00	2019-10-19	14:00	5	160
490	POWERGRID	POWERGRID	BUS	Bus-1, at Agra HVDC	DAILY	For 03 hrs to reconnect Bus dropper from Bus-1 to 41089 isolator in order to take 410 bay in service. at Agra S/S	2019-10-23	09:00	2019-10-23	12:00	3	160

491	POWERGRID	POWERGRID	BUS	400 KV WCA Bus-2/2A sectionaliser, at Agra HVDC	DAILY	AMP of Bay Equipment i.e. CB , CT etc at Agra S/S	2019-10-09	09:00	2019-10-09	18:00	9	-
492	POWERGRID	POWERGRID	BUS	Bus-2B, at Agra	DAILY	Point to point testing of Bus Bar Protection M1 / M2, REB 500 at Agra HVDC at Agra S/S	2019-10-10	09:00	2019-10-11	18:00	18	155
493	POWERGRID	POWERGRID	BUS	400 KV WCA Bus-1/1A sectionaliser, at Agra HVDC	CONTINUOUS	Repalcement of Bus sectionaliser CT of three phases with 4000/1A CT under retrofit of Bus bar Protection at Agra S/S	2019-10-14	09:00	2019-10-15	18:00	33	157
494	POWERGRID	POWERGRID	BUS	Bus 1A, at Agra	DAILY	Stablity test between new replaced CT and existing CT for correct summation in Bus Bar Prot at Agra S/S	2019-10-15	13:00	2019-10-15	17:00	4	152
495	POWERGRID	POWERGRID	BUS	400 KV WCA Bus-2/2A sectionaliser, at Agra HVDC	DAILY	Repalcement of Bus sectionaliser CT of three phases with 4000/1A CT under retrofit of Bus bar Protection at Agra S/S	2019-10-16	09:00	2019-10-17	13:00	8	-
496	POWERGRID	POWERGRID	BUS	Bus-2A , at Agra	DAILY	Stablity test between new replaced CT and existing CT for correct summation in Bus Bar Prot.	2019-10-17	13:00	2019-10-17	17:00	4	152
497	POWERGRID	POWERGRID	BUS	400 KV BUS-II at Jalandhar	DAILY	For AMP works.	2019-10-15	09:30	2019-10-15	17:30	8	154
498	POWERGRID	POWERGRID	BUS	220 KV BUS-I at Jalandhar	DAILY	For AMP works.	2019-10-16	09:30	2019-10-16	17:30	8	161
499	POWERGRID	POWERGRID	BUS	220KV BUS-1 at Amritsar	DAILY	For Changing the Bus Coupler 3-89 A Isolator R-Ph Terminal Pad .	2019-10-03	10:30	2019-10-03	17:30	7	156
500	POWERGRID	POWERGRID	BUS	400KV BUS-1 , at Allahabad	DAILY	AMP WORK of BUS-I at Allahabad S/S	2019-10-17	08:00	2019-10-17	18:00	10	160
501	POWERGRID	POWERGRID	BUS	400KV BUS-2 , at Allahabad	DAILY	AMP WORK of BUS-II at Allahabad S/S	2019-10-22	08:00	2019-10-22	18:00	10	160
502	POWERGRID	POWERGRID	BUS	BUS-2,at Kanpur	DAILY	For jumper opening work for Isolator replacement at 400 KV Kanpur S/S	2019-10-13	11:23	2019-10-13	11:23	0	160
503	POWERGRID	POWERGRID	BUS	BUS-2,at Kanpur	DAILY	For Jumper connection work. at 400 KV Kanpur S/S	2019-10-17	09:00	2019-10-17	18:00	9	160
504	POWERGRID	POWERGRID	BUS	BUS-1 at Kanpur	DAILY	For jumper opening work for Isolator replacement at 400 KV Kanpur S/S	2019-10-18	09:00	2019-10-18	18:00	9	160
505	POWERGRID	POWERGRID	BUS	BUS-1 at Kanpur	DAILY	For Jumper connection work. at 400 KV Kanpur S/S	2019-10-22	09:00	2019-10-22	18:00	9	160
506	POWERGRID	POWERGRID	BUS	Bus -1, at Mainpuri	DAILY	AMP WORK at 400kV Mainpuri S/S	2019-10-14	09:00	2019-10-14	18:00	9	151
507	POWERGRID	POWERGRID	BUS	Bus -2, at Mainpuri	DAILY	AMP WORK at 400kV Mainpuri S/S	2019-10-16	09:00	2019-10-16	18:00	9	151

508	POWERGRID	POWERGRID	BUS	220KV Bus -1, at Mainpuri S/S (PG)	DAILY	AMP WORK at 400kV Mainpuri S/S	2019-10-18	09:00	2019-10-18	18:00	9	155
509	POWERGRID	POWERGRID	BUS	220KV Bus -2 at Mainpuri S/S	DAILY	AMP WORK at 400kV Mainpuri S/S	2019-10-19	09:00	2019-10-19	18:00	9	155
510	POWERGRID	POWERGRID	BUS	Transfer bus at Mainpuri S/S	DAILY	AMP WORK at 400kV Mainpuri S/S	2019-10-21	09:00	2019-10-21	18:00	9	152
511	POWERGRID	POWERGRID	BUS	220kV Bus-I at Kurukshetra	DAILY	For attending SF6 gas leakage in G-9 compartment. The compartment is common for both buses, hence bus-2 SD is also required for same period.	2019-10-22	09:30	2019-10-22	17:30	8	160
512	POWERGRID	POWERGRID	BUS	220kV Bus-II at Kurukshetra	DAILY	For attending SF6 gas leakage in G-9 compartment. The compartment is common for both buses, hence bus-1 SD is also required for same period.	2019-10-22	09:30	2019-10-22	17:30	8	160
513	POWERGRID	POWERGRID	BUS	400KV BUS-I JIND	DAILY	For AMP work	2019-10-15	09:00	2019-10-15	18:00	9	146
514	POWERGRID	POWERGRID	BUS	220 KV Bus-I at Abdullapur	DAILY	For retrofitting of bus-1 isolator of DCRTTP bay 202	2019-10-10	09:00	2019-10-15	18:00	54	159
515	POWERGRID	POWERGRID	BUS	400KV BUS-II JIND	DAILY	For AMP work	2019-10-17	09:00	2019-10-17	18:00	9	146
516	POWERGRID	POWERGRID	BUS	220 KV Bus-II at Abdullapur	DAILY	For retrofitting of bus-2 isolator of DCRTTP bay 202	2019-10-16	09:00	2019-10-21	18:00	54	159
517	POWERGRID	POWERGRID	BUS	400KV BUS-I CHIOTRGARH PG	DAILY	AMP of bus & associated equipment .All line & equipment will remain in service through 765kV Bus # 2	2019-10-25	09:00	2019-10-26	18:00	18	155
518	POWERGRID	POWERGRID	BUS	400KV BUS-II CHIOTRGARH PG	DAILY	AMP of bus & associated equipment .All line & equipment will remain in service through 765kV Bus # 1	2019-10-30	09:00	2019-10-31	18:00	18	155
519	POWERGRID	POWERGRID	BUS	400KV BUS-I SONIPAT	DAILY	AMP work	2019-10-15	09:00	2019-10-15	18:00	9	151
520	POWERGRID	POWERGRID	BUS	400KV BUS-II SONIPAT	DAILY	AMP work	2019-10-16	09:00	2019-10-16	18:00	9	151
521	POWERGRID	POWERGRID	BUS	220 KV Bus 1 Mandola	DAILY	AMP work	2019-10-04	08:00	2019-10-04	18:00	10	156
522	POWERGRID	POWERGRID	BUS	220KV BUS-I at JIND	DAILY	AMP work	2019-10-22	09:00	2019-10-22	18:00	9	-
523	POWERGRID	POWERGRID	BUS	220KV BUS-2 at JIND	DAILY	AMP work	2019-10-24	09:00	2019-10-24	18:00	9	-
524	POWERGRID	POWERGRID	BUS	BUS-I JAIPUR(SOUTH) 400KV	DAILY	AMP work	2019-10-15	09:00	2019-10-15	18:00	9	158

525	POWERGRID	POWERGRID	BUS	BUS-II JAIPUR (SOUTH) 400KV	DAILY	AMP work	2019-10-17	09:00	2019-10-17	18:00	9	157
526	POWERGRID	POWERGRID	BUS	400KV BUS-I Bikaner	DAILY	Equipment erection by Renew Power for bay Extension	2019-10-01	09:00	2019-10-01	19:00	10	-
527	POWERGRID	POWERGRID	BUS	400KV BUS-I Bikaner	DAILY	Jumpering Work by Renew Power for bay Extension	2019-10-03	09:30	2019-10-03	18:30	9	-
528	POWERGRID	POWERGRID	BUS	400KV BUS-I Bikaner	DAILY	Balance Work by Renew Power for bay Extension	2019-10-05	09:00	2019-10-05	19:00	10	-
529	POWERGRID	POWERGRID	BUS	400KV BUS-2 Bikaner	DAILY	Equipment erection by Renew Power for bay Extension	2019-10-02	09:00	2019-10-02	18:00	9	-
530	POWERGRID	POWERGRID	BUS	400KV BUS-2 Bikaner	DAILY	Jumpering Work by Renew Power for bay Extension	2019-10-04	09:00	2019-10-04	18:00	9	-
531	POWERGRID	POWERGRID	BUS	400KV BUS-2 Bikaner	DAILY	Balance Work by Renew Power for bay Extension	2019-10-06	09:00	2019-10-06	18:00	9	-
532	POWERGRID	POWERGRID	BUS	400KV BUS-II BASSI	DAILY	Disconnection of Droppers from 400kV Bus-2 of isolator no. 406-89 (Bus Side).	2019-10-01	09:30	2019-10-01	13:30	4	156
533	POWERGRID	POWERGRID	BUS	400KV BUS-II BASSI	DAILY	Connection of Droppers with 400 kV Bus-2 of isolator no. 406-89 after replacement of isolator.	2019-10-07	09:00	2019-10-07	12:00	3	156
534	PSTCL	PSTCL	BUS	DHURI - BUS BAR 2	DAILY	General Maintenance	2019-10-03	09:00	2019-10-04	17:00	16	153
535	PSTCL	PSTCL	BUS	DHURI - BUS BAR 2	DAILY	General Maintenance	2019-10-07	09:00	2019-10-07	17:00	8	153
536	PSTCL	PSTCL	BUS	NAKODAR - BUS BAR 1	DAILY	Periodic Maintenance	2019-10-21	09:00	2019-10-21	17:00	8	-
537	PSTCL	PSTCL	BUS	RAJPURA - BUS BAR 1	DAILY	Annual Maintenance and Testing	2019-10-21	09:00	2019-10-22	16:00	14	156
538	PSTCL	PSTCL	BUS	RAJPURA - BUS BAR 2	DAILY	Annual Maintenance and Testing	2019-10-23	09:00	2019-10-24	16:00	14	156
539	PSTCL	PSTCL	BUS	DHURI - BUS BAR 1	DAILY	General Maintenance	2019-10-22	09:00	2019-10-24	17:00	24	153
540	PSTCL	PSTCL	BUS	MAKHU - BUS BAR 1	DAILY	Periodical/routine Maintenance	2019-10-30	09:00	2019-10-30	17:00	8	155
541	RRVPN	RRVPN	BUS	400KV BUS-I AKAL JAISALMER (400KV)	DAILY	Quarterly Maintenance	2019-10-23	08:00	2019-10-23	16:00	8	158



542	RRVPN	RRVPN	BUS	400KV MAIN BUS-I BARMER	DAILY	Quarterly Maintenance	2019-10-18	10:00	2019-10-18	18:00	8	161
543	RRVPN	RRVPN	BUS	400KV MAIN BUS-II BARMER	DAILY	Quarterly Maintenance	2019-10-19	10:00	2019-10-19	18:00	8	161
544	RRVPN	RRVPN	BUS	MAIN BUS-B RATANGARH	DAILY	Maintenance work of bay equipment	2019-10-15	09:30	2019-10-15	18:00	8.5	160
545	RRVPN	RRVPN	BUS	400kV Bus-I at 400kV GSS Kankani	DAILY	Quarterly maintenance Work	2019-10-18	08:59	2019-10-18	18:01	9.03	161
546	UPPTCL	UPPTCL	BUS	BUS SECTION-I(Between 400KV A&B TPS Switchyard)	CONTINUOUS	For replacement of old 400KV HITACHI make Gas circuit breaker to new GE T&D make Gas circuit breaker.	2019-10-01	08:00	2019-10-14	15:00	319	-
547	UPPTCL	UPPTCL	BUS	BUS SECTION-II(Between 400KV A &B TPS Switchyard)	CONTINUOUS	For replacement of old 400KV HITACHI make Gas circuit breaker to new GE T&D make Gas circuit breaker	2019-10-17	08:00	2019-10-30	15:00	319	-
548	UPPTCL	UPPTCL	BUS	400 kV Bus 2 Greater Noida	CONTINUOUS	For Overhauling R-Phase B-Bus PG isolator of 500MVA ICT-III	2019-10-16	10:00	2019-10-16	17:00	7	159
549	UPPTCL	UPPTCL	BUS	400 KV Main Bus-B at 400 KV Moradabad	DAILY	Repairing of damaged Moose conductor of Bus	2019-10-10	09:00	2019-10-10	17:00	8	-
550	UPPTCL	UPPTCL	BUS	BUS A MURADNAGAR	DAILY	Replacement of defective pantograph bus isolator of ICT-III	2019-10-10	08:00	2019-10-13	18:00	40	145
551	UPPTCL	UPPTCL	BUS	BUS B MURADNAGAR	DAILY	Replacement of defective pantograph bus isolator of ICT-III	2019-10-14	08:00	2019-10-17	18:00	40	145
552	UPPTCL	UPPTCL	BUS	BUS B-PANKI	CONTINUOUS	for replacement of TBC B bus PG Isolator	2019-10-10	08:00	2019-10-15	17:00	129	161
553	UPPTCL	UPPTCL	BUS	BUS-2 Agra South		Routine Testing ,CRM& Regular Maintenance and Tightening ,	2019-10-15	09:00	2019-10-15	17:00	8	161
554	UPPTCL	UPPTCL	BUS	bus 1 SARNATH	CONTINUOUS	Repairing & strengthening of Main Bus-I	2019-10-14	08:00	2019-10-18	18:00	106	155
555	UPPTCL	UPPTCL	BUS	400kV Bus-1 at Dasna	CONTINUOUS	For conducting HV test to confirm healthiness of equipments.	2019-10-25	15:00	2019-10-25	17:00	2	-
556	UPPTCL	UPPTCL	BUS	400kV Bus-2 at Dasna	CONTINUOUS	For conducting HV test to confirm healthiness of equipments.	2019-10-25	15:00	2019-10-25	17:00	2	-
557	DTL	DTL	ICT	ICT03 MUNDKA (400KV)(DTL)/315	DAILY	MAINTENANCE AS PER PMS SCHEDULE OF DTL. THE SHUTDOWN WAS APPROVED IN 162 OCC BUT COULD NOT BE AVAILED BECAUSE OF	2019-10-16	06:00	2019-10-16	17:30	11.5	162
558	HVPNL	HVPNL	ICT	ICT01 DAULTABAD (400KV)(HVPNL)/315	DAILY	For general maintenance and Nut Bolt Tightening of isolators & CTs	2019-10-14	10:00	2019-10-14	14:00	4	158

559	HVPNL	HVPNL	ICT	ICT03 DAULTABAD (400KV)(HVPNL)/315	DAILY	For general maintenance and Nut Bolt Tightening of isolators & CTs	2019-10-16	10:00	2019-10-16	14:00	4	160
560	HVPNL	HVPNL	ICT	ICT04/315	DAILY	To attend oil leakage	2019-09-27	10:00	2019-09-27	14:00	4	162
561	HVPNL	HVPNL	ICT	ICT02 NAWADA (400KV)(HVPNL)/250	DAILY	For three yearly mtc by M&P and gen mtc.	2019-09-25	10:00	2019-09-25	19:00	9	156
562	HVPNL	HVPNL	ICT	ICT01 NAWADA (400KV)(HVPNL)/315	DAILY	For three yearly mtc by M&P and general mtc.	2019-10-03	10:00	2019-10-03	19:00	9	160
563	POWERGRID	POWERGRID	ICT	ICT -I AGRA-PG (765KV)(POWERGRID)/1500	DAILY	For commissioning of back up impedance relays at Agra S/S	2019-10-14	09:00	2019-10-14	18:00	9	160
564	POWERGRID	POWERGRID	ICT	ICT-II AGRA-PG (765KV)(POWERGRID)/1500	DAILY	For commissioning of back up impedance relays at Agra S/S	2019-10-15	09:00	2019-10-15	18:00	9	160
565	POWERGRID	POWERGRID	ICT	ICT02 KANPUR GIS (765KV)(POWERGRID)/1500	DAILY	FOR AMP of ICT at 765 kV kanpur GIS S/S	2019-10-16	09:00	2019-10-16	18:00	9	151
566	POWERGRID	POWERGRID	ICT	ICT01 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For RTV coating in ICT-1 in 400KV Interconnection.In 400KV ICT-1,Interconnection, Conductor of ICT-2 is running over head	2019-10-01	09:00	2019-10-01	10:00	1	162
567	POWERGRID	POWERGRID	ICT	ICT02 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For RTV coating in ICT-1 in 400KV Interconnection In 400KV ICT-1,Interconnection, Conductor of ICT-2 is running over head	2019-10-01	09:00	2019-10-01	19:00	10	162
568	POWERGRID	POWERGRID	ICT	ICT02 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For RTV coating in ICT-2 in 400KV Interconnection. In 400KV ICT-2 Interconnection, Conductor of ICT-3 is running over head	2019-10-03	09:00	2019-10-03	19:00	10	162
569	POWERGRID	POWERGRID	ICT	ICT03 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For RTV coating in ICT-2 in 400KV Interconnection. In 400KV ICT-2 Interconnection, Conductor of ICT-3 is running over head	2019-10-03	09:00	2019-10-03	19:00	10	162
570	POWERGRID	POWERGRID	ICT	ICT01 BHIWANI-PG (765 KV)(POWERGRID)/1000	DAILY	For AMP Work	2019-10-25	09:30	2019-10-25	18:30	9	152
571	POWERGRID	POWERGRID	ICT	ICT02 BHIWANI-PG (765 KV)(POWERGRID)/1000	DAILY	For AMP Work	2019-10-26	09:00	2019-10-26	18:00	9	162
572	POWERGRID	POWERGRID	ICT	765KV 1500MVA ICT-I AJMER/1500	DAILY	AMP & CSD fine tuning work	2019-10-16	09:00	2019-10-16	18:00	9	162
573	POWERGRID	POWERGRID	ICT	765KV 1500MVA ICT-II AJMER/1500	DAILY	AMP & CSD fine tuning work	2019-10-17	09:00	2019-10-17	18:00	9	160
574	POWERGRID	POWERGRID	ICT	ICT AGRA-PG (400KV)(POWERGRID)/315	DAILY	commissioning of B/U impedance relay of 315MVA 400/220kV ICT-1 at Agra S/S	2019-10-31	08:00	2019-10-31	18:00	10	-
575	POWERGRID	POWERGRID	ICT	ICT-2, 315 MVA , at Agra HVDC/315 MVA	CONTINUOUS	Replacement of CT terminal plate on B-phase HV bushing turret, commissioning of B/U impedance relay at Agra S/S	2019-10-29	08:00	2019-10-30	18:00	34	160

576	POWERGRID	POWERGRID	ICT	ICT01 HAMIRPUR-PG (400KV)(POWERGRID)/315	DAILY	For AMP works.	2019-10-01	09:00	2019-10-01	17:30	8.5	157
577	POWERGRID	POWERGRID	ICT	ICT02 PATIALA (400KV)(POWERGRID)/315	DAILY	For replacement of Oil Surge Relay (leakage observed).	2019-10-08	10:30	2019-10-08	13:30	3	158
578	POWERGRID	POWERGRID	ICT	ICT02 FATEHABAD PG (400KV)(POWERGRID)/315	DAILY	For AMP works.	2019-10-15	09:30	2019-10-15	17:30	8	150
579	POWERGRID	POWERGRID	ICT	ICT03 RAEBAREILLY (220KV)(POWERGRID)/100	DAILY	AMP WORK at Raibareilly S/S	2019-10-24	09:00	2019-10-24	18:00	9	157
580	POWERGRID	POWERGRID	ICT	ICT02 SOHAWAL (400KV)(POWERGRID)/315	DAILY	AMP WORK at Sohawal S/S S/S	2019-10-15	09:00	2019-10-15	18:00	9	149
581	POWERGRID	POWERGRID	ICT	ICT03 kaithal/315	DAILY	For AMP works.	2019-10-17	09:30	2019-10-17	17:30	8	156
582	POWERGRID	POWERGRID	ICT	ICT03 SAMBA (400KV)(POWERGRID)/315	DAILY	For AMP works.	2019-10-03	09:30	2019-10-03	17:30	8	158
583	POWERGRID	POWERGRID	ICT	ICT-II/500 MVA	CONTINUOUS	For arresting SF6 gas leakage in Gas Insulated Bus (GIB) duct which is installed in outside switchyard.	2019-10-14	09:30	2019-10-18	17:30	104	-
584	POWERGRID	POWERGRID	ICT	315 MVA ICT-II AT MEERUT/315	CONTINUOUS	Replacement of PRD Relay due to Oil Leakages form the PRD.Oil drain ,filtration & refilling of PRD relay.	2019-10-15	09:00	2019-10-19	18:00	105	160
585	POWERGRID	POWERGRID	ICT	315 MVA ICT-III AT MEERUT/315	DAILY	AMP Maintenance Work of the ICT.	2019-10-21	10:00	2019-10-21	18:00	8	-
586	POWERGRID	POWERGRID	ICT	ICT01 SONIPAT (400KV)(POWERGRID)/315	DAILY	AMP work	2019-10-10	10:00	2019-10-10	18:00	8	156
587	POWERGRID	POWERGRID	ICT	ICT02 SONIPAT (400KV)(POWERGRID)/315	DAILY	AMP work	2019-10-11	10:00	2019-10-11	18:00	8	156
588	POWERGRID	POWERGRID	ICT	ICT02 KANKROLI (400KV)(POWERGRID)/315	DAILY	AMP work	2019-10-18	09:00	2019-10-18	17:00	8	160
589	POWERGRID	POWERGRID	ICT	ICT03 KANKROLI (400KV)(POWERGRID)/315	DAILY	AMP work	2019-10-20	09:00	2019-10-20	17:00	8	160
590	POWERGRID	BBMB	ICT	ICT DEHAR (400KV)(BBMB)/315	DAILY	For AMP works of ICT & Bay equipment. Spare unit has also to be taken into service. Two days are needed to complete all this work.	2019-10-17	09:30	2019-10-18	17:30	16	161
591	POWERGRID	POWERGRID	ICT	ICT01 GURGAON (400KV)(POWERGRID)/315	CONTINUOUS	value and along with its associated 400 kV & 220 kV bays (401 & 206) at Gurgaon	2019-10-01	09:30	2019-10-20	18:30	465	161
592	POWERGRID	POWERGRID	ICT	ICT02 GURGAON (400KV)(POWERGRID)/315	CONTINUOUS	bays and along with its associated 400 kV & 220 kV bays (405 & 207) at Gurgaon	2019-10-21	09:00	2019-10-23	18:00	57	161

593	POWERGRID	POWERGRID	ICT	ICT03 GURGAON/500	CONTINUOUS	For Owing to high ppm of oil in OLTC chamber and sd along with its associated 400 kV & 220 kV bays (410 & 210) at Gurgaon	2019-10-24	09:00	2019-10-30	18:00	153	161
594	POWERGRID	POWERGRID	ICT	ICT02 ROORKEE (400KV)(POWERGRID)/315	DAILY	FOR AMP WORK	2019-10-07	09:00	2019-10-07	18:00	9	161
595	POWERGRID	POWERGRID	ICT	ICT02 JAIPUR South (400KV)(POWERGRID)/500	DAILY	FOR AMP WORK	2019-10-04	09:00	2019-10-04	18:00	9	152
596	POWERGRID	POWERGRID	ICT	ICT01 BAHADURGARH (400KV)(POWERGRID)/315	DAILY	For AMP work of ICTs & Retrofitment of diff. relay	2019-10-15	09:30	2019-10-15	18:30	9	157
597	POWERGRID	POWERGRID	ICT	ICT02 BAHADURGARH (400KV)(POWERGRID)/500	DAILY	For AMP work .	2019-10-16	09:00	2019-10-16	18:00	9	157
598	POWERGRID	POWERGRID	ICT	ICT01 HISSAR-PG (400KV)(POWERGRID)/315	DAILY	AMP works	2019-10-14	09:30	2019-10-14	18:30	9	152
599	POWERGRID	POWERGRID	ICT	ICT02 HISSAR-PG (400KV)(POWERGRID)/315	DAILY	AMP works	2019-10-16	09:00	2019-10-16	18:00	9	152
600	POWERGRID	POWERGRID	ICT	ICT03 HISSAR-PG (400KV)(POWERGRID)/315	DAILY	AMP works	2019-10-18	09:00	2019-10-18	18:00	9	152
601	PTCUL	PTCUL	ICT	ICT01 SRINAGAR_UK (400KV)(PTCUL)/315	DAILY	For Pre-Diwali Maintenance line & T/F Bays along with 400KV Main Bus-1st	2019-10-09	13:30	2019-10-09	18:30	5	162
602	PSTCL	PSTCL	ICT	ICT02 MUKTSAR (400KV)(PSTCL)/315	DAILY	To attend the hot point on Bush clamp Y-Phase and To attend hot point on Common T Clamp B/W bay 411 & 412 : R-Phase	2019-10-01	10:00	2019-10-01	13:00	3	156
603	PSTCL	PSTCL	ICT	ICT02 NAKODAR (400KV)(PSTCL)/315	DAILY	Periodic Maintenance	2019-10-01	09:00	2019-10-01	17:00	8	156
604	PSTCL	PSTCL	ICT	ICT01 MAKHU (400KV)(PSTCL)/315	DAILY	Periodical/routine Maintenance	2019-10-09	09:00	2019-10-09	17:00	8	155
605	PSTCL	PSTCL	ICT	ICT02 MAKHU (400KV)(PSTCL)/315	DAILY	Periodical/routine Maintenance	2019-10-14	09:00	2019-10-14	17:00	8	156
606	PSTCL	PSTCL	ICT	ICT02 DHURI (400KV)(PSTCL)/500	DAILY	General Maintenance	2019-10-18	09:00	2019-10-18	17:00	8	-
607	PSTCL	PSTCL	ICT	ICT04 RAJPURA (400KV)(PSTCL)/500	DAILY	Annual Maintenance and Testing	2019-10-29	09:00	2019-10-31	16:00	21	153
608	PSTCL	PSTCL	ICT	ICT02 DHURI (400KV)(PSTCL)/500	DAILY	General Maintenance	2019-10-21	09:00	2019-10-21	17:00	8	-
609	RRVFN	RRVFN	ICT	ICT01 PHAGI (765KV)(RRVFN)/1500	DAILY	1.For the measurement of Tan-delta of Bushings . 2. Tightening of clamps & connectors. 3. To check the tripping of CBs through auxiliary protection.	2019-10-03	09:00	2019-10-03	18:00	9	-

610	RRVPN	ADANIRJ	ICT	Station Transformer - 2/80	DAILY	needed. 2 Annual Maintenance of Station Transformer. 3 Bay equipment maintenance and testing work.	2019-10-15	09:30	2019-10-16	19:30	20	160
611	RRVPN	RRVPN	ICT	ICT01 AJMER (400KV)(RRVUNL)/315	DAILY	HALF YEARLY MAINTENANCE WORK OF 400/220 KV 315 MVA ICT-I	2019-10-05	09:00	2019-10-05	18:00	9	160
612	RRVPN	RRVPN	ICT	ICT01 AKAL JAISALMER (400KV)(RRVPN)/315	DAILY	Quarterly Maintenance	2019-10-03	08:00	2019-10-03	15:00	7	158
613	RRVPN	RRVPN	ICT	ICT02 AKAL JAISALMER (400KV)(RRVPN)/315	DAILY	Quarterly Maintenance	2019-10-10	08:00	2019-10-10	16:00	8	159
614	RRVPN	RRVPN	ICT	ICT03 AKAL JAISALMER (400KV)(RRVPN)/315	DAILY	Quarterly Maintenance	2019-10-11	08:00	2019-10-11	16:00	8	158
615	RRVPN	RRVPN	ICT	ICT04 AKAL JAISALMER (400KV)(RRVPN)/500	DAILY	Quarterly Maintenance	2019-10-15	08:00	2019-10-15	16:00	8	147
616	RRVPN	RRVPN	ICT	ICT02 BHADLA (400KV)(RRVPN)/500	DAILY	Quarterly Maintenance work	2019-10-04	17:00	2019-10-04	21:00	4	158
617	RRVPN	RRVPN	ICT	ICT01 BHADLA (400KV)(RRVPN)/500	DAILY	Quarterly Maintenance work	2019-10-09	17:00	2019-10-09	21:00	4	157
618	RRVPN	RRVPN	ICT	ICT03 BHADLA (400KV)(RRVPN)/500	DAILY	Quarterly Maintenance work	2019-10-14	17:00	2019-10-14	21:00	4	162
619	RRVPN	RRVPN	ICT	ICT02 BHILWARA (400KV)(RRVPN)/315	DAILY	Routine maintenane of 400 KV ICT-2 bay WITH 315 MVA TR.-2 (4252A)& ASSOCIATED EQUIPMENTS	2019-10-10	09:00	2019-10-10	17:00	8	161
620	RRVPN	RRVPN	ICT	ICT01 BIKANER (400KV)(RRVPN)/315	DAILY	Routine Bay Maintenance	2019-10-10	10:00	2019-10-10	17:00	7	161
621	RRVPN	RRVPN	ICT	ICT01 HINDAUN (400KV)(RRVPN)/315	DAILY	Quarterly /Half yearly Maintance work	2019-10-09	09:00	2019-10-09	16:00	7	160
622	RRVPN	RRVPN	ICT	ICT02 HINDAUN (400KV)(RRVPN)/315	DAILY	Quarterly /Half yearly Maintance work	2019-10-16	09:00	2019-10-16	16:00	7	160
623	RRVPN	RRVPN	ICT	ICT01 MERTA (400KV)(RRVPN)/315	DAILY	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-10-18	10:00	2019-10-18	17:00	7	160
624	RRVPN	RRVPN	ICT	ICT02 RATANGARH (400KV)(RRVPN)/315	DAILY	Maintenance work of bay equipment	2019-10-16	09:30	2019-10-16	18:00	8.5	160
625	RRVPN	RRVPN	ICT	400/220kV 500MVA ICT-II at 400kV GSS Kankani/500	DAILY	Quarterly maintenance Work	2019-10-11	09:00	2019-10-11	18:00	9	161
626	UPPTCL	UPPTCL	ICT	ICT03 UNNAO (765KV)(UPPTCL)/1000	DAILY	Routine protection testing, Annual maintenance of ICT Bay and attending pending punch points by M/s TBEA	2019-10-15	09:00	2019-10-16	18:00	18	156

627	UPPTCL	UPPTCL	ICT	ICT02 UNNAO (400KV)(UPPTCL)/315	DAILY	Routine Protection Testing and General Maintenance of Transformer and Bay at 400 KV Sub-Station Unnao	2019-10-18	09:00	2019-10-18	17:00	8	155
628	UPPTCL	UPPTCL	ICT	ICT03 Unnao/315 MVA	DAILY	General Maintenance of Transformer and Bay at 400 KV Sub-Station Unnao.	2019-10-21	09:00	2019-10-21	17:00	8	-
629	UPPTCL	UPPTCL	ICT	500 MVA ICT02 LUCKNOW (Sarojini Nagar) 400-UP/500 MVA	DAILY	Routine Protection Testing and General Maintenance of Transformer Bay	2019-10-15	09:00	2019-10-15	17:00	8	159
630	UPPTCL	UPPTCL	ICT	ICT02 UNNAO (765KV)(UPPTCL)/1000	DAILY	Routine protection testing and Annual maintenance of ICT Bay	2019-10-18	09:00	2019-10-19	18:00	18	151
631	UPPTCL	UPPTCL	ICT	ICT01 UNNAO (765KV)(UPPTCL)/1000	DAILY	Routine protection testing and Annual maintenance of ICT Bay	2019-10-22	09:00	2019-10-23	18:00	18	151
632	UPPTCL	UPPTCL	ICT	ICT03 SULTANPUR (400KV)(UPPTCL)/315	DAILY	for routine bay maintenance works	2019-10-03	10:00	2019-10-03	18:00	8	162
633	UPPTCL	UPPTCL	ICT	ICT01 SULTANPUR (400KV)(UPPTCL)/240	DAILY	for routine testing and bay maintenance works	2019-10-10	10:00	2019-10-10	18:00	8	162
634	UPPTCL	UPPTCL	ICT	ICT02 SULTANPUR (400KV)(UPPTCL)/240	DAILY	for routine bay maintenance works	2019-10-21	10:00	2019-10-21	18:00	8	162
635	UPPTCL	UPPTCL	ICT	ICT03 GREATER NOIDA (400KV)(UPPTCL)/500	CONTINUOUS	For general maintenance and routine testine	2019-10-10	10:00	2019-10-10	16:00	6	162
636	UPPTCL	UPPTCL	ICT	ICT-II Agra South/200 MVA		Routine Testing, CRM & Regular Maintenance and Tightening	2019-10-15	09:00	2019-10-15	17:00	8	162
637	UPPTCL	UPPTCL	ICT	ICT III AGRA SOUTH/200 MVA		Routine Testing & Regular Maintenance and Tightening	2019-10-16	09:00	2019-10-17	17:00	32	161
638	UPPTCL	UPPTCL	ICT	ICT-II MATHURA/315	DAILY	Routine Testing and Regular Maintenance of Bay & Tightening	2019-10-15	08:00	2019-10-16	19:00	22	161
639	UPPTCL	UPPTCL	ICT	ICT03 SARNATH (400KV)(UPPTCL)/315	CONTINUOUS	Replacement of old & outlived 0.5 accuracy 220 CTs by New 0.2 accuracy CTs	2019-10-16	08:00	2019-10-17	18:00	34	155
640	UPPTCL	UPPTCL	ICT	500 MVA ICT - II at 400kV sarnath/500 MVA	CONTINUOUS	Complete Bay tightening, Isolator maintenance & strengthening of 400KV Main Bus-I	2019-10-18	08:00	2019-10-18	18:00	10	-
641	UPPTCL	UPPTCL	ICT	500 MVA ICT01 AZAMGARH/500MVA	DAILY	Prefestival Maintenance	2019-10-17	09:00	2019-10-17	18:00	9	159
642	UPPTCL	UPPTCL	ICT	ICT02 AZAMGARH (400KV)(UPPTCL)/500	DAILY	Prefestival Maintenance	2019-10-19	09:00	2019-10-19	18:00	9	158
643	UPPTCL	UPPTCL	ICT	ICT-I Indrapuram/500 MVA	CONTINUOUS	For CB pole replacement in IV side of ICT	2019-10-03	09:00	2019-10-04	17:00	32	159

644	UPPTCL	UPPTCL	ICT	1500 MVA ICT-2 at Hapur S/s/1500 MVA	DAILY	Annual Maintenance of 765kV 500MVA 1-phase ICT-2 (R-phase)	2019-10-03	09:00	2019-10-03	17:00	8	162
645	UPPTCL	UPPTCL	ICT	1500 MVA ICT-2 at Gr. Noida S/s/1500 MVA	DAILY	Annual Maintenance of 765kV 500MVA 1-phase ICT-2 (B-phase)	2019-10-10	09:00	2019-10-10	10:00	1	-
646	POWERGRID	POWERGRID	REACTOR	765 kV Bus-reactor at Fatehpur/330.00	DAILY	AMP & Tightening Work at Fatehpur S/S	2019-10-28	09:00	2019-10-28	18:00	9	158
647	POWERGRID	POWERGRID	REACTOR	330MVAR Kanpur LR at Aligarh GIS Substation/330.00	DAILY	For AMP Works of LR at Aligarh Substation	2019-10-20	08:00	2019-10-20	18:00	10	162
648	POWERGRID	POWERGRID	REACTOR	Bus Reactor-1 at Aligarh GIS Substation/330.00	DAILY	For AMP Works of BR at Aligarh Substation	2019-10-21	08:00	2019-10-21	18:00	10	162
649	POWERGRID	POWERGRID	REACTOR	240MVAR B/Reactor AJMER-765/240.00	DAILY	CSD fine tuning work	2019-10-18	10:00	2019-10-18	14:00	4	162
650	POWERGRID	POWERGRID	REACTOR	240MVAR S/R 765 KV Chitorgarh-1 at Ajmer/240.00	DAILY	CSD Checking & fine tuning During Shutdown Line will remain in service & line recator switching to be done after CSD fine tuning work	2019-10-14	10:00	2019-10-14	14:00	4	162
651	POWERGRID	POWERGRID	REACTOR	240MVAR S/R 765 KV Chitorgarh-2 at Ajmer/240.00	DAILY	CSD Checking & fine tuning During Shutdown Line will remain in service & line recator switching to be done after CSD fine tuning work	2019-10-15	10:00	2019-10-15	14:00	4	162
652	POWERGRID	POWERGRID	REACTOR	Bus Reactor-2 at Aligarh GIS Substation/330.00	DAILY	Construction of 765 kV GIS Exten. Interference of Voltage injected during HV Test with System Voltage	2019-10-01	09:00	2019-10-01	18:00	9	162
653	POWERGRID	POWERGRID	REACTOR	Bus Reactor-2 at Aligarh GIS Substation/330.00	DAILY	Construction of 765 kV GIS Exten. Interference of Voltage injected during HV Test with System Voltage	2019-10-04	09:00	2019-10-04	18:00	9	162
654	POWERGRID	POWERGRID	REACTOR	765KV Bikaner-1 240MVAR L/R at Ajmer/240.00	DAILY	Bay AMP work	2019-10-06	09:30	2019-10-06	17:30	8	-
655	POWERGRID	POWERGRID	REACTOR	765KV Bikaner-2 240MVAR L/R -II at Ajmer/240.00	DAILY	Bay AMP work	2019-10-07	09:00	2019-10-07	17:00	8	-
656	POWERGRID	POWERGRID	REACTOR	REACTOR AGRA-PG (400KV)/50.00	CONTINUOUS	For replacement of 03 nos. BHEL make HV bushings of 400kV 125MVAR B/R#2 on test result violation at Agra S/S	2019-10-01	08:00	2019-10-20	18:00	466	149
657	POWERGRID	BBMB	REACTOR	REACTOR-I DEHAR (400KV)/63.00	DAILY	For AMP and CSD relay commissioning.	2019-10-04	09:00	2019-10-04	17:30	8.5	151
658	POWERGRID	BBMB	REACTOR	REACTOR-2 DEHAR (400KV)/63.00	DAILY	For AMP and CSD relay commissioning. Both reactors are on single CB.	2019-10-04	09:00	2019-10-04	17:30	8.5	151
659	POWERGRID	POWERGRID	REACTOR	80 MVAR Singrauli Line Reactor , at Fatehpur/80.00	CONTINUOUS	Modification in HV Bushing ,CC-CL plate replacement work internal Inspection Work etc. at fatehpur S/S	2019-10-16	08:00	2019-10-23	18:00	178	159
660	POWERGRID	POWERGRID	REACTOR	Bus Reactor-1, at Sohawal/80.00	DAILY	AMP WORK at Sohawal S/S	2019-10-24	09:00	2019-10-24	18:00	9	149

661	POWERGRID	POWERGRID	REACTOR	REACTORII VINDHYACHAL (400KV)/93.00	CONTINUOUS	HVDC S/S is needed for Retrofitment of 03 nos. Circuit Breaker under ADD-CAP at Vindhyachal HVDC S/S	2019-10-01	09:00	2019-10-31	18:00	729	162
662	POWERGRID	POWERGRID	REACTOR	REACTOR KURUKSHETRA-PG (400KV)/125.00	DAILY	For AMP works of 125 MVAr B/R.	2019-10-17	09:30	2019-10-17	17:30	8	145
663	POWERGRID	POWERGRID	REACTOR	REACTOR II JAIPUR South (400KV)/125.00	CONTINUOUS	AMP work	2019-10-29	09:00	2019-10-29	18:00	9	145
664	POWERGRID	POWERGRID	REACTOR	REACTOR I(S) JAIPUR South (400KV)/125.00	DAILY	AMP work	2019-10-07	09:00	2019-10-07	18:00	9	158
665	POWERGRID	POWERGRID	REACTOR	400KV MERTA 50MVAR L/R at KOTA/50.00	DAILY	AMP work.400kv KOTA -Merta line will be also in sd 10-15 minutes for taking out/in of Line Reactor.	2019-10-04	09:30	2019-10-04	18:30	9	-
666	POWERGRID	POWERGRID	REACTOR	400KV Beawar 50MVAR L/R at KOTA/50.00	DAILY	AMP work.400kv KOTA -Beawar line will be also in sd 10-15 minutes for taking out/in of Line Reactor.	2019-10-09	09:00	2019-10-09	18:00	9	-
667	POWERGRID	POWERGRID	REACTOR	125MVAR BUS REACTOR -1 AT SONIPAT/125.00	DAILY	AMP work.	2019-10-12	09:00	2019-10-12	18:00	9	-
668	POWERGRID	POWERGRID	REACTOR	125MVAR BUS REACTOR -2 AT SONIPAT/125.00	DAILY	AMP work.	2019-10-14	09:00	2019-10-14	18:00	9	-
669	POWERGRID	POWERGRID	REACTOR	400KV Bus series reactor at Mandola/333.00	DAILY	Shutdown for rectification in GIS equipments by M/S GE along with 400kv bus 3 & 4 s/d is required for 10 minutes during s/d and charging of Bus series reactor.	2019-10-01	10:00	2019-10-01	19:00	9	159
670	POWERGRID	POWERGRID	REACTOR	REACTOR BAGHPAT (400KV)/125.00	DAILY	AMP work	2019-10-04	10:00	2019-10-04	17:00	7	-
671	POWERGRID	POWERGRID	REACTOR	REACTOR I KANKROLI (400KV)/50.00	DAILY	Yearly AMP and Relay Testing	2019-10-21	09:00	2019-10-21	16:00	7	152
672	POWERGRID	POWERGRID	REACTOR	REACTOR II KANKROLI (400KV)/125.00	DAILY	Yearly AMP and Relay Testing	2019-10-22	09:00	2019-10-22	16:00	7	152
673	RRVFN	RRVFN	REACTOR	REACTOR AKAL JAISALMER (400KV)/50.00	DAILY	Quarterly Maintenance	2019-10-16	08:00	2019-10-16	16:00	8	159
674	RRVFN	RRVFN	REACTOR	REACTOR BARMER (400KV)/50.00	DAILY	Quarterly Maintenance	2019-10-17	10:00	2019-10-17	18:00	8	160
675	RRVFN	RRVFN	REACTOR	Series Reactor 5 BHADLA (400KV)/125.00	DAILY	Quarterly Maintenance work	2019-10-04	10:00	2019-10-04	14:00	4	158
676	RRVFN	RRVFN	REACTOR	50MVAR Reactor Kota line/50.00	DAILY	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-10-10	10:00	2019-10-10	17:00	7	162
677	RRVFN	RRVFN	REACTOR	REACTOR MERTA (400KV)/50.00	DAILY	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-10-12	10:00	2019-10-12	17:00	7	162



678	RRVPN	RRVPN	REACTOR	50MVAR REACTOR AKAL JAISALMER/50.00	DAILY	Quarterly Maintenance	2019-10-22	08:00	2019-10-22	16:00	8	159
679	RRVPN	RRVPN	REACTOR	REACTOR BIKANER (400KV)/50.00	DAILY	Routine Bay Maintenance	2019-10-18	10:00	2019-10-18	17:00	7	-
680	RRVPN	RRVPN	REACTOR	BIKANER/50.00	DAILY	Routine Bay Maintenance	2019-10-24	10:00	2019-10-24	17:00	7	160
681	RRVPN	RRVPN	REACTOR	Line reactor - MERTA (400KV)/400.00	DAILY	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-10-11	10:00	2019-10-11	17:00	7	160
682	UPPTCL	UPPTCL	REACTOR	50 MVAR Line Reactor I at 400 KV Bareilly - Unnao ckt II/50.00	CONTINUOUS	Preventive Maintenance and Spray Painting	2019-10-09	08:00	2019-10-11	17:00	57	-
683	UPPTCL	UPPTCL	REACTOR	REACTOR MATHURA (400KV)/80.00	DAILY	Routine Testing and Regular Maintenance of Bay & Tightening	2019-10-10	08:00	2019-10-11	19:00	22	153
684	UPPTCL	UPPTCL	REACTOR	REACTOR MAINPURI-UP (765KV)/330.00	DAILY	Maintenance and Testing	2019-10-18	09:00	2019-10-19	18:00	18	161
685	UPPTCL	UPPTCL	REACTOR	REACTOR MAINPURI-UP (765KV)/330.00	DAILY	Maintenance and Testing	2019-10-21	09:00	2019-10-22	18:00	18	161
686	POWERGRID	POWERGRID	SVC	400 MVAR STATCOM Nalagarh	DAILY	For rectification works which were identified during comprehensive maintenance but could not be carried out due to non-availability of some material.	2019-10-04	09:30	2019-10-04	17:30	8	162
687	POWERGRID	POWERGRID	SVC	SVC-1, at Kanpur	DAILY	For jumper opening work for Isolator replacement at 400 KV Kanpur S/S	2019-10-24	09:00	2019-10-24	18:00	9	160
688	POWERGRID	POWERGRID	SVC	SVC-1, at Kanpur	DAILY	For Jumper connection work. at 400 KV Kanpur S/S	2019-10-30	09:00	2019-10-30	18:00	9	160
689	POWERGRID	POWERGRID	SVC	SVC at Ludhiana	DAILY	For AMP and jumper tightening works.	2019-10-03	09:30	2019-10-03	17:30	8	161