

Sr No	OCC Number	Name of Requesting Agency	Element Type	Element Name	Owner	Daily/Continuous	Reason	Requested From Date	Requested From Time	Requested To Date	Requested To Time	Requester Remarks	Rpc Remarks
1	OCC_166	adhydro_sd	GENERATING UNIT	96 MW AD HYDRO - UNIT 2	ADHPL	C	Annual maintenance of Unit & its auxiliaries.	02-Jan-2020	09:00	26-Jan-2020	18:00	.	
2	OCC_166	rampur_sd	GENERATING UNIT	68.67 MW RAMPUR HEP - UNIT 3	SJVNL	C	Annual Maintenance of Unit	02-Feb-2020	09:00	09-Feb-2020	18:00		
3	OCC_166	rampur_sd	GENERATING UNIT	68.67 MW RAMPUR HEP - UNIT 2	SJVNL	C	Annual Maintenance of Unit	24-Jan-2020	09:00	31-Jan-2020	18:00		
4	OCC_166	rampur_sd	GENERATING UNIT	68.67 MW RAMPUR HEP - UNIT 1	SJVNL	C	Annual Maintenance of Unit	15-Jan-2020	09:00	22-Jan-2020	18:00		
5	OCC_166	rappc_sd	GENERATING UNIT	220 MW RAPS-C - UNIT 2	NPCIL	C	Biennial shutdown of RAPS-C (Unit-6)	15-Jan-2020	00:00	24-Feb-2020	23:59		
6	OCC_166	ntpcncr_sd	GENERATING UNIT	200 MW KOLDAM HPS - UNIT 3	NTPC	C	Annual maintenance	04-Feb-2020	08:00	08-Feb-2020	18:00	Approved in LGBR	
7	OCC_166	ntpcncr_sd	GENERATING UNIT	200 MW KOLDAM HPS - UNIT 2	NTPC	C	Annual maintenance	07-Jan-2020	08:00	11-Jan-2020	18:00	Approved in LGBR	
8	OCC_166	ntpcos_sd	GENERATING UNIT	200 MW SINGRAULI STPS - UNIT 4	NTPC	C	annual maintenance	04-Jan-2020	00:00	05-Feb-2020	23:59	s/d is 35 days upto 08.02.20	
9	OCC_166	ntpcncr_sd	GENERATING UNIT	200 MW KOLDAM HPS - UNIT 1	NTPC	C	Annual maintenance	24-Dec-2019	08:00	28-Dec-2019	18:00	it is approved in LGBR & shut date start from 17th Dec.'2019 to 21st Dec.'2019	
10	OCC_166	ntpcncr_sd	GENERATING UNIT	130.19 MW DADRI GPS - UNIT 2	NTPC	C	8000 EOH Inspection	08-Jan-2020	08:00	14-Jan-2020	18:00		
11	OCC_166	ntpcncr_sd	GENERATING UNIT	130.19 MW DADRI GPS - UNIT 1	NTPC	C	Boiler license renewal	06-Jan-2020	08:00	07-Jan-2020	18:00	GT-1 available for open cycle operation modee	
12	OCC_166	ntpcncr_sd	GENERATING UNIT	130.19 MW DADRI GPS - UNIT 3	NTPC	C	Boiler license renewal	06-Jan-2020	08:00	07-Jan-2020	18:00	GT-3 available for open cycle operation	
13	OCC_166	cpcc3_sd	HVDC LINE CIRCUIT	800 KV HVDC AGRA-BISHWANATH CHARIALI (PG) CKT-1		C	15 DAY SD REQUIRED SHIFTING OF LINE TO ERS TO RECTIFY VULNERABLE LOCATION 1619, 1618 WHOSE LEGS /MAIN BRACING HAVE BEEN CUT BY MISCREANTS. DATES TENTATIVE AND SHALL BE CONFIRMED BASED ON SITE CONDITION. Requested by ER1.	05-Jan-2020	08:00	19-Jan-2020	18:00		
14	OCC_166	cpcc3_sd	HVDC LINE CIRCUIT	800 KV HVDC AGRA-BISHWANATH CHARIALI (PG) CKT-2		C	15 DAY SD REQUIRED SHIFTING OF LINE TO ERS TO RECTIFY VULNERABLE LOCATION 1619, 1618 WHOSE LEGS /MAIN BRACING HAVE BEEN CUT BY MISCREANTS. DATES TENTATIVE AND SHALL BE CONFIRMED BASED ON SITE CONDITION. Requested by ER1.	05-Jan-2020	08:00	19-Jan-2020	18:00		
15	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI-GAYA (PG) CKT-2	POWERGRID	D	765 KV Tower Strengthening works. Requested by ER1.	24-Jan-2020	08:00	30-Jan-2020	18:00		

16	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHPUR-SASARAM (PG) CKT-1	POWERGRI D	C	"1. For tower rectification Work at location no. 326 2. For Power line Crossing of under construction 765 kV D/C vindhyachal-Varanasi transmission line (under TBCB) 3. For AMP and Tightning work of Line Side Equipments and 110 X3 MVAR Line Reactor at Fatehpur"	16-Jan-2020	08:00	17-Jan-2020	18:00		
17	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BALIA-GAYA (PG) CKT-1	POWERGRI D	D	765 KV Tower Strengthening works. Requested by ER1.	13-Jan-2020	08:00	20-Jan-2020	18:00		
18	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-JABALPUR (PG) CKT-1	POWERGRI D	D	For insulator cleaning & line Maintenance work. Dia to be kept opened at both end and 765KV-JABALPUR- ORAI-2 to be kept in Non Auto mode. Requested by WR2	09-Jan-2020	08:00	09-Jan-2020	18:00		
19	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-JABALPUR (PG) CKT-2	POWERGRI D	D	For insulator cleaning & line Maintenance work. Dia to be kept opened at both end and 765KV-JABALPUR- ORAI-1 to be kept in Non Auto mode. Requested by WR2	08-Jan-2020	08:00	08-Jan-2020	18:00		
20	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-GWALIOR (PG) CKT-1	POWERGRI D	D	For insulator cleaning & line Maintenance work (attending s/d nature defects) and For alignment of isolator and rectification of interlock problem in isolator. A/R OFF of 765kV Gwalior-Satna, Dia to be kept open at both ends. Requested by WR2	07-Jan-2020	08:00	07-Jan-2020	18:00		
21	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-GWALIOR(PG) (PG) CKT-2	POWERGRI D	D	"For insulator cleaning & line Maintenance work (attending s/d nature defects) and For alignment of isolator and rectification of interlock problem in isolator. Dia to be kept open at both ends."	05-Jan-2020	08:00	06-Jan-2020	18:00	sd request by wr2	
22	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI-GAYA (PG) CKT-1	POWERGRI D	D	765 KV Tower Strengthening works. Requested by ER1.	03-Jan-2020	08:00	10-Jan-2020	18:00		
23	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-GWALIOR(PG) (PG) CKT-1	POWERGRI D	D	For insulator cleaning & line Maintenance work (attending s/d nature defects). Dia to be kept open at both ends.	03-Jan-2020	08:00	04-Jan-2020	18:00	sd request by wr2	
24	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BALIA-GAYA (PG) CKT-1	POWERGRI D	C	For Diversion Work due to construction of purvanchal Expway by UPEIDA	26-Dec-2019	08:00	29-Dec-2019	18:00		
25	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-PATNA (PG) CKT-4	POWERGRI D	D	Replacement of porcelain insulator by polmer A/R OF OTHER CKT TO BE PUT INTO NON AUTO MODE. Requested by ER1.	09-Jan-2020	08:00	09-Jan-2020	18:00		
26	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-BIHARSHARIFF (PG) CKT-2	POWERGRI D	D	Liquidation of all pending line defects (spacer cap, conductor cut, A/R OF OTHER CKT TO BE PUT INTO NON AUTO MODE) Requested by ER1.	09-Jan-2020	08:00	10-Jan-2020	18:00		
27	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-PATNA (PG) CKT-3	POWERGRI D	D	Replacement of porcelain insulator by polmer A/R OF OTHER CKT TO BE PUT INTO NON AUTO MODE. Requested by ER1.	08-Jan-2020	08:00	08-Jan-2020	18:00		

28	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-BIHARSHARIFF (PG) CKT-1	POWERGRID	D	For the replacement of Reactor Neutral Bushing	08-Jan-2020	08:00	08-Jan-2020	18:00		
29	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-SASARAM (PG) CKT-1	POWERGRID	D	For Insulator cleaning and defect rectification work	07-Jan-2020	08:00	08-Jan-2020	18:00	For Insulator cleaning and S/D nature defect rectification work	
30	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA-BIHARSHARIFF (PG) CKT-1	POWERGRID	D	Liquidation of all pending line defects (spacer cap, conductor cut, A/R OF OTHER CKT TO BE PUT INTO NON AUTO MODE) Requested by ER1.	07-Jan-2020	08:00	08-Jan-2020	18:00		
31	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-SASARAM (PG) CKT-1	POWERGRID	D	Replacement of insulators at Road/Rail/River/Power Line Crossings and Relay Retrofitting A/R OF OTHER CKT TO BE PUT INTO NON AUTO MODE Requested by ER1.	06-Jan-2020	08:00	11-Jan-2020	18:00		
32	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)-MUZAFFARPUR(PG) (POWERLINK) CKT-2	POWERLINK	D	AMP of Line Bay equipments at PGCIL Gorakhpur S/s	25-Dec-2019	08:00	25-Dec-2019	18:00		
33	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)-MUZAFFARPUR(PG) (POWERLINK) CKT-1	POWERLINK	D	AMP of Line Bay equipments & Relay Testing at PGCIL Gorakhpur S/s	24-Dec-2019	08:00	24-Dec-2019	18:00		
34	OCC_166	cpcc2_sd	HVDC POLE	800 KV HVDC KURUKSHETRA(PG) POLE-2	POWERGRID	C	Pole-4 Commissioning works and Integration of Bipole-2 (P3 & P4) with Bipole-1 (P1 & P2)	23-Jan-2020	08:00	29-Jan-2020	18:00	Construction activity	
35	OCC_166	cpcc2_sd	HVDC POLE	800 KV HVDC KURUKSHETRA(PG) POLE-1	POWERGRID	C	Pole-4 Commissioning works and Integration of Bipole-2 (P3 & P4) with Bipole-1 (P1 & P2)	23-Jan-2020	08:00	29-Jan-2020	18:00	Construction activity	
36	OCC_166	cpcc2_sd	HVDC POLE	800 KV HVDC KURUKSHETRA(PG) POLE-03	POWERGRID	C	Pole-4 Commissioning works and Integration of Bipole-2 (P3 & P4) with Bipole-1 (P1 & P2)	16-Jan-2020	08:00	29-Jan-2020	20:00	Construction activity	
37	OCC_166	cpcc2_sd	HVDC POLE	800 KV HVDC KURUKSHETRA(PG) POLE-2	POWERGRID	C	Pole-4 Commissioning works and Integration of Bipole-2 (P3 & P4) with Bipole-1 (P1 & P2)	08-Jan-2020	08:00	15-Jan-2020	20:00	Construction activity	
38	OCC_166	cpcc2_sd	HVDC POLE	800 KV HVDC KURUKSHETRA(PG) POLE-1	POWERGRID	C	Pole-4 Commissioning works and Integration of Bipole-2 (P3 & P4) with Bipole-1 (P1 & P2)	08-Jan-2020	08:00	15-Jan-2020	20:00	Construction activity	
39	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER-AJMER (PG) CKT-2	POWERGRID	D	AMP work of line terminal equipments & fixing bracket replacementt work in Line Isolator & Line maintenance work	23-Jan-2020	09:00	23-Jan-2020	18:00		
40	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER-AJMER (PG) CKT-1	POWERGRID	D	AMP work of line terminal equipments & fixing bracket replacementt work in Line Isolator & Line maintenance work	22-Jan-2020	09:00	22-Jan-2020	18:00		
41	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-FATEHPUR (PG) CKT-1	POWERGRID	D	For taking line Reactor into the Service After line reactor protection testing and AMP of line reactor at Agra Substation	13-Jan-2020	17:00	13-Jan-2020	18:00		
42	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI-BALIA (PG) CKT-1	POWERGRID	C	For Diversion Work due to construction of purvanchal Expway by UPEIDA	13-Jan-2020	08:00	16-Jan-2020	18:00		
43	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-FATEHPUR (PG) CKT-1	POWERGRID	D	For taking line Reactor out of Service for line reactor protection testing and AMP of line reactor at Agra Substation	13-Jan-2020	08:00	13-Jan-2020	09:00		

44	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-FATEHPUR (PG) CKT-2	POWERGRID	D	Line protection testing at Agra substation	11-Jan-2020	08:00	11-Jan-2020	18:00		
45	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI-KANPUR_GIS (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
46	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-ALIGARH (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
47	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BAREILLY_2-LUCKNOW_2 (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
48	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-ALIGARH (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
49	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV GR.NOIDA_2(UPC)-ALIGARH(PG) (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
50	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV GR.NOIDA_2(UPC)-MEERUT(PG) (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
51	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ANPARA_C(LAN)-UNNAO(UP) (UP) CKT-1	UPPTCL	D	POWER LINE CROSSING of under construction 765 kV D/C vindhyachal-Varanasi transmission line (under TBCB)	23-Jan-2020	08:00	24-Jan-2020	18:00		
52	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	765 KV GR.NOIDA_2(UPC)-MAINPURI (UP) CKT-1	UPPTCL	D	For Annual Maintenance work , Jumper & hardware tightness	14-Jan-2020	08:00	15-Jan-2020	18:00		
53	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ANPARA_C(LAN)-UNNAO(UP) (UP) CKT-1	UPPTCL	D	For disc cleaning between loc 290 to 310, from 610 to 630	02-Jan-2020	09:00	05-Jan-2020	17:00		
54	OCC_166	stuup_sd	BUS	765 KV GR.NOIDA_2(UPC) - BUS 2	UPPTCL	D	For the New765kv feeder Bay-712 Erection work as per the request of Ghatampur Transmission Limited	29-Jan-2020	08:00	30-Jan-2020	18:00		
55	OCC_166	stuup_sd	BUS	765KV BUS 2 AT HAPUR(UP)	UPPTCL	C	For Annual Maintenance work	04-Jan-2020	09:00	04-Jan-2020	18:00		
56	OCC_166	stuup_sd	BUS	765 KV GR.NOIDA_2(UPC) - BUS 2	UPPTCL	C	For the New765kv feeder Bay-712 Erection work as per the request of Ghatampur Transmission Limited	04-Jan-2020	08:00	04-Jan-2020	18:00		
57	OCC_166	cpcc1_sd	BUS	765KV BUS 2 AT MEERUT(PG)	POWERGRID	D	SS Const. - Erection & Testing of 01 No. Isolator & Jumper Connection	15-Jan-2020	08:00	17-Jan-2020	18:00		
58	OCC_166	cpcc2_sd	BUS	765KV BUS 2 AT MOGA(PG)	POWERGRID	D	Commissioning work of Bikaner Line -I&II bays under construction.	13-Jan-2020	09:30	14-Jan-2020	17:30		
59	OCC_166	cpcc1_sd	BUS	765KV BUS 2 AT AJMER(PG)	POWERGRID	D	FOR AMP WORK	10-Jan-2020	08:00	10-Jan-2020	18:00		
60	OCC_166	cpcc1_sd	BUS	765KV BUS 1 AT AJMER(PG)	POWERGRID	D	FOR AMP WORK	09-Jan-2020	08:00	09-Jan-2020	18:00		
61	OCC_166	cpcc2_sd	BUS	765KV BUS 1 AT MOGA(PG)	POWERGRID	D	Commissioning work of Bikaner Line -I&II bays under construction.	08-Jan-2020	09:30	09-Jan-2020	17:30		

62	OCC_166	cpcc1_sd	BR/BSR/MSR/MSR	240 MVAR BUS REACTOR NO 2 AT 765KV JHATIKARA(PG)	POWERGRID	D	installation of silicon jacket on isolators and LA	16-Jan-2020	10:00	16-Jan-2020	14:00		
63	OCC_166	cpcc1_sd	BR/BSR/MSR/MSR	240 MVAR BUS REACTOR NO 1 AT 765KV JHATIKARA(PG)	POWERGRID	D	installation of silicon jacket on isolators and LA	15-Jan-2020	10:00	15-Jan-2020	14:00		
64	OCC_166	cpcc3_sd	BR/BSR/MSR/MSR	240 MVAR BUS REACTOR NO 2 AT 765KV AGRA(PG)	POWERGRID	D	For protection testing & AMP work of reactor at Agra Substation	10-Jan-2020	08:00	10-Jan-2020	18:00		
65	OCC_166	cpcc3_sd	BR/BSR/MSR/MSR	240 MVAR BUS REACTOR NO 1 AT 765KV AGRA(PG)	POWERGRID	D	For protection testing & AMP work of reactor at Agra Substation	09-Jan-2020	08:00	09-Jan-2020	18:00		
66	OCC_166	cpcc1_sd	LINE REACTOR	240 MVAR LR ON 765 KV BHADLA-BIKANER (PG) CKT-2 @BIKANER(PG)	POWERGRID	D	Scheme Checking for healthines of protecyion of spare Reactor CB and spare switching	21-Jan-2020	11:00	21-Jan-2020	17:00		Bhadla-2 Line Reactor outage
67	OCC_166	cpcc1_sd	LINE REACTOR	330 MVAR LR ON 765 KV BIKANER-AJMER (PG) CKT-1 @BIKANER(PG)	POWERGRID	D	Scheme Checking for healthines of protecyion of spare Reactor CB and spare switching	21-Jan-2020	11:00	21-Jan-2020	17:00		Ajmer-1 Line Reactor Outage
68	OCC_166	cpcc1_sd	LINE REACTOR	240 MVAR LR ON 765 KV BHADLA-BIKANER (PG) CKT-2 @BIKANER(PG)	POWERGRID	D	Scheme Checking for healthines of protecyion of spare Reactor CB and spare switching	18-Jan-2020	11:00	18-Jan-2020	17:00		
69	OCC_166	cpcc1_sd	LINE REACTOR	240 MVAR LR ON 765 KV BHADLA-BIKANER (PG) CKT-1 @BIKANER(PG)	POWERGRID	D	Scheme Checking for healthines of protection of spare Reactor CB and spare switching	17-Jan-2020	11:00	17-Jan-2020	17:00		Bhadla-1 Line Reactor outage
70	OCC_166	cpcc1_sd	LINE REACTOR	240 MVAR LR ON 765 KV BHADLA-BIKANER (PG) CKT-1 @BIKANER(PG)	POWERGRID	D	Scheme Checking for healthines of protecyion of spare Reactor CB and spare switching	16-Jan-2020	11:00	16-Jan-2020	17:00		Bhadla-1 Line Reactor outage
71	OCC_166	stuup_sd	LINE REACTOR	330 MVAR LR ON BARA-MAINPURI (UP) CKT-1 @MAINPURI(UP)	UPPTCL	C	Line reactor Maintenance and testing	06-Jan-2020	09:00	07-Jan-2020	18:00		
72	OCC_166	cpcc3_sd	BAY	707 MAIN BAY - 765KV LUCKNOW_2-BAREILLY (PG) CKT-1 AT LUCKNOW_2(PG)	POWERGRID	D	For AMP Work at lucknow S/S	28-Jan-2020	08:00	29-Jan-2020	18:00		
73	OCC_166	cpcc1_sd	BAY	711 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT JHATIKARA(PG) AND FUTURE AT 765 KV JHATIKARA(PG)	POWERGRID	D	FOR AMP WORK	24-Jan-2020	08:00	24-Jan-2020	18:00		
74	OCC_166	cpcc3_sd	BAY	703 MAIN BAY - 240 MVAR BUS REACTOR NO 1 AT 765KV BALIA(PG)	POWERGRID	D	For AMP Activities & Jumper Tightening works at Ballia S/S.	23-Jan-2020	08:00	24-Jan-2020	18:00		
75	OCC_166	cpcc1_sd	BAY	709 MAIN BAY - 765/400KV 1500 MVA ICT 1 AT JHATIKARA(PG)	POWERGRID	D	FOR AMP WORK	22-Jan-2020	08:00	22-Jan-2020	18:00		
76	OCC_166	cpcc1_sd	BAY	708 TIE BAY - 765KV JHATIKARA-BHIWANI (PG) CKT-1 AND 765/400KV 1500 MVA ICT 1 AT JHATIKARA(PG)	POWERGRID	D	FOR AMP WORK	20-Jan-2020	08:00	20-Jan-2020	18:00		
77	OCC_166	cpcc1_sd	BAY	703 MAIN BAY - 240 MVAR BUS REACTOR NO 2 AT 765KV JHATIKARA(PG)	POWERGRID	D	FOR AMP WORK	18-Jan-2020	08:00	18-Jan-2020	18:00		

78	OCC_166	cpcc1_sd	BAY	702 TIE BAY - 765 KV BIKANER-AJMER (PG) CKT-1 AND 765/400 KV 1500 MVA ICT 1 AT AJMER(PG)	POWERGRID	D	Amp work (CB timing & DCRM and Capacitance tandelta etc)	17-Jan-2020	08:00	17-Jan-2020	18:00		
79	OCC_166	cpcc1_sd	BAY	701 MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT AJMER(PG)	POWERGRID	D	Amp work (CB timing & DCRM and Capacitance tandelta etc)	16-Jan-2020	08:00	16-Jan-2020	18:00		
80	OCC_166	cpcc1_sd	BAY	712 MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT BIKANER(PG)	POWERGRID	D	FOR AMP WORK	15-Jan-2020	08:00	15-Jan-2020	18:00		
81	OCC_166	cpcc1_sd	BAY	711 TIE BAY - 765 KV BIKANER-MOGA (PG) CKT-1 AND 765/400 KV 1500 MVA ICT 2 AT BIKANER(PG) AT 765 KV BIKANER(PG)	POWERGRID	D	FOR AMP WORK	14-Jan-2020	08:00	14-Jan-2020	18:00		
82	OCC_166	cpcc3_sd	BAY	702 TIE BAY - 765 KV BALIA-LUCKNOW_2 (PG) CKT-1 AND 765/400 KV 1500 MVA ICT 1 AT LUCKNOW_2(PG)	POWERGRID	D	For AMP Work at lucknow S/S	13-Jan-2020	08:00	14-Jan-2020	18:00		
83	OCC_166	cpcc1_sd	BAY	710 MAIN BAY - 765 KV BIKANER-MOGA (PG) CKT-1	POWERGRID	D	FOR AMP WORK	13-Jan-2020	08:00	13-Jan-2020	18:00		
84	OCC_166	cpcc1_sd	BAY	709 MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT BIKANER(PG)	POWERGRID	D	FOR AMP WORK	11-Jan-2020	08:00	11-Jan-2020	18:00		
85	OCC_166	cpcc3_sd	BAY	706 MAIN BAY - 240 MVAR BUS REACTOR NO 2 AT 765KV BALIA(PG)	POWERGRID	D	For AMP Activities & Jumper Tightening works at Ballia S/S.	10-Jan-2020	08:00	11-Jan-2020	18:00		
86	OCC_166	cpcc1_sd	BAY	708 TIE BAY - 765/400 KV 1500 MVA ICT 1 AT BIKANER(PG) AND 765 KV BIKANER-AJMER (PG) CKT-2	POWERGRID	D	FOR AMP WORK	10-Jan-2020	08:00	10-Jan-2020	18:00		
87	OCC_166	cpcc1_sd	BAY	704 MAIN BAY - 765 KV CHITTORGARH-BANASKANTHA (PG) CKT-2 AT CHITTORGARH(PG)	POWERGRID	D	FOR AMP WORK	09-Jan-2020	08:00	11-Jan-2020	18:00		
88	OCC_166	cpcc1_sd	BAY	707 MAIN BAY - 330 MVAR LR ON 765 KV BIKANER-AJMER (PG) CKT-2 @BIKANER(PG) AND 765 KV BIKANER(PG) - BUS 1 AT BIKANER(PG)	POWERGRID	D	FOR AMP WORK	09-Jan-2020	08:00	09-Jan-2020	18:00		
89	OCC_166	cpcc1_sd	BAY	706 MAIN BAY - 330 MVAR BUS REACTOR NO 1 AT 765 KV BIKANER(PG)	POWERGRID	D	FOR AMP WORK	08-Jan-2020	08:00	08-Jan-2020	18:00		
90	OCC_166	cpcc3_sd	BAY	717 TIE BAY - 765KV AGRA-JHATIKARA (PG) CKT-1 AND 240 MVAR BUS REACTOR NO 2 AT 765KV AGRA(PG)	POWERGRID	D	AMP OF BAY EQUIPMENT at Agra S/S	07-Jan-2020	08:00	07-Jan-2020	18:00		

91	OCC_166	cpcc1_sd	BAY	705 TIE BAY - 765 KV BIKANER-AJMER (PG) CKT-1 AND 330 MVAR BUS REACTOR NO 1 AT 765 KV BIKANER(PG) AT 765 KV BIKANER(PG)	POWERGRID	D	FOR AMP WORK	07-Jan-2020	08:00	07-Jan-2020	18:00		
92	OCC_166	cpcc2_sd	BAY	705 TIE BAY - 240 MVAR BUS REACTOR NO 2 AT 765KV MOGA(PG) AND FUTURE	POWERGRID	D	For AMP works.	06-Jan-2020	09:30	07-Jan-2020	17:30		
93	OCC_166	cpcc3_sd	BAY	718 MAIN BAY - 240 MVAR BUS REACTOR NO 2 AT 765KV AGRA(PG) AND 765KV BUS 2 AT AGRA(PG)	POWERGRID	D	AMP OF BAY EQUIPMENT at Agra S/S	06-Jan-2020	08:00	06-Jan-2020	18:00		
94	OCC_166	cpcc1_sd	BAY	707 MAIN BAY - 765 KV CHITTORGARH-BANASKANTHA (PG) CKT-1 AT CHITTORGARH(PG)	POWERGRID	D	FOR AMP WORK	06-Jan-2020	08:00	08-Jan-2020	18:00		
95	OCC_166	cpcc1_sd	BAY	704 MAIN BAY - 765 KV BIKANER(PG) - BUS 1 AND 330 MVAR LR ON 765 KV BIKANER-AJMER (PG) CKT-1 @BIKANER(PG) AT BIKANER(PG)	POWERGRID	D	FOR AMP WORK	06-Jan-2020	08:00	06-Jan-2020	18:00		
96	OCC_166	cpcc3_sd	BAY	714 TIE BAY - 765KV AGRA(PG)-GWALIOR(PG) (UNDEF) CKT-1 AND 240 MVAR BUS REACTOR NO 1 AT 765KV AGRA(PG)	POWERGRID	D	AMP OF BAY EQUIPMENT at Agra S/S	03-Jan-2020	08:00	03-Jan-2020	18:00		
97	OCC_166	cpcc3_sd	BAY	715 MAIN BAY - 240 MVAR BUS REACTOR NO 1 AT 765KV AGRA(PG) AND 765KV BUS 2 AT AGRA(PG)	POWERGRID	D	AMP OF BAY EQUIPMENT at Agra S/S	02-Jan-2020	08:00	02-Jan-2020	18:00		
98	OCC_166	sldcrs_sd	BAY	70752B MAIN BAY - 765KV ANTA-PHAGI (RS) CKT-2 AT PHAGI(RS)	RRVNL	D	1.Maintenance of CB & CTs. Measurement of Tan-delta of CTs. 2. Tightening of clamps & connectors.	22-Jan-2020	09:00	22-Jan-2020	18:00		
99	OCC_166	sldcrs_sd	BAY	70652B MAIN BAY - 765KV ANTA-PHAGI (RS) CKT-1 AT PHAGI(RS)	RRVNL	D	1.Maintenance of CB & CTs. Measurement of Tan-delta of CTs. 2. Tightening of clamps & connectors.	17-Jan-2020	09:00	17-Jan-2020	18:00		
100	OCC_166	stuup_sd	BAY	707 MAIN BAY - 765/400KV 1500 MVA ICT 1 AT HAPUR(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Tie Bay)	13-Jan-2020	09:00	13-Jan-2020	13:00		
101	OCC_166	stuup_sd	BAY	706 MAIN BAY - 240 MVAR BUS REACTOR NO 1 AT 765KV HAPUR(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Tie Bay)	10-Jan-2020	14:00	10-Jan-2020	18:00		
102	OCC_166	stuup_sd	BAY	710 MAIN BAY - 765/400KV 1500 MVA ICT 2 AT HAPUR(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Tie Bay)	10-Jan-2020	09:00	10-Jan-2020	13:00		

103	OCC_166	stuup_sd	BAY	702 TIE BAY - 240 MVAR BUS REACTOR NO 1 AT 765KV AGRA FATEHBAD(UP) AND FUTURE	UPPTCL	C	Stringing over 63MVAR Line Reactor (Future 765KV Ghatampur- Agra line), 701Bay CT, CB and Isolator erection, Dismantling of Guy arrangement in Bay 701	03-Jan-2020	08:00	10-Jan-2020	18:00		
104	OCC_166	rampur_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NATHPA JHAKRI(SJ)-RAMPUR HEP(SJ) (PG) CKT-1	POWERGRID	D	Annual Maintenance of GIS Bay and PHY	01-Feb-2020	09:00	06-Feb-2020	18:00		
105	OCC_166	rampur_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NATHPA JHAKRI(SJ)-RAMPUR HEP(SJ) (PG) CKT-2	POWERGRID	D	Annual Maintenance of GIS Bay and PHY	01-Feb-2020	09:00	06-Feb-2020	18:00		
106	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RIHAND(NT)-ALLAHABAD(PG) (PG) CKT-1	POWERGRID	C	For Overhead crossing of this line by under construction 765 kV Vindhyachal (PS) Varanasi D/C line (MP part).	30-Jan-2020	08:00	31-Jan-2020	18:00		
107	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RIHAND(NT)-ALLAHABAD(PG) (PG) CKT-2	POWERGRID	C	For Overhead crossing of this line by under construction 765 kV Vindhyachal (PS) Varanasi D/C line (MP part).	30-Jan-2020	08:00	31-Jan-2020	18:00		
108	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-FATEHPUR(PG) (PG) CKT-1	POWERGRID	C	For Overhead crossing of this line by under construction 765 kV Vindhyachal (PS) Varanasi D/C line (MP part).	30-Jan-2020	08:00	31-Jan-2020	18:00		
109	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-ALLAHABAD(PG) (PG) CKT-2	POWERGRID	C	S/D required for overhead crossing of D/C Vindhyachal-varanasi ckt. S/D by WR1	30-Jan-2020	08:00	31-Jan-2020	18:00		
110	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-ALLAHABAD(PG) (PG) CKT-3	POWERGRID	C	S/D required for overhead crossing of D/C Vindhyachal-varanasi ckt. S/D by WR1	30-Jan-2020	08:00	31-Jan-2020	18:00		
111	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-LUCKNOW(UP) (PG) CKT-1	POWERGRID	C	S/D required for overhead crossing of D/C Vindhyachal-varanasi ckt. S/D by WR1	30-Jan-2020	08:00	31-Jan-2020	18:00		
112	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEHRADUN-ABDULLAPUR (PG) CKT-2	POWERGRID	C	For Tree lopping works of forest regrowth trees.	30-Jan-2020	08:00	31-Jan-2020	18:00		
113	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR-KANPUR (PG) CKT-2	POWERGRID	D	For AMP and Tightning work of Line Side Equipments at Fatehpur S/S	28-Jan-2020	08:00	28-Jan-2020	18:00		
114	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEHRADUN-ABDULLAPUR (PG) CKT-1	POWERGRID	C	For Tree lopping works of forest regrowth trees.	28-Jan-2020	08:00	29-Jan-2020	18:00		
115	OCC_166	chamera2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-KISHENPUR(PG) (PG) CKT-1	POWERGRID	D	Diagnostic Testing of EHV equipment of 400KV GIS for condition monitoring by OEM.	25-Jan-2020	08:00	25-Jan-2020	18:00	Actual shutdown required from 20/12/2019 (09:00 hrs.) to 21/12/2019 (17:30 hrs.)	
116	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1(PG)-UNNAO(UP) (PG) CKT-2	POWERGRID	D	General Maintenance of Bay at 400 KV Sub-Station Unnao	24-Jan-2020	09:00	24-Jan-2020	17:00		

117	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)-BAWANA(DV) (PG) CKT-1	POWERGRID	D	Non Auto mode for live line installation of Bird Guard on Tower between Loc. 367 to 436 (Between LILO Point to Bawana).	22-Jan-2020	09:00	30-Jan-2020	17:00	Non shutdown activity
118	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEEPALPUR(JHKT)-BAWANA(DV) (PG) CKT-1	POWERGRID	D	Non Auto mode for live line installation of Bird Guard on Tower between Loc. 367 to 436 (Between LILO Point to Bawana).	22-Jan-2020	09:00	30-Jan-2020	17:00	Non shutdown activity
119	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR-JALANDHAR (PG) CKT-2	POWERGRID	D	For AMP works.	22-Jan-2020	09:00	22-Jan-2020	18:00	
120	OCC_166	sterlite_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GURGAON-MANESAR (PG) CKT-1	POWERGRID	C	LILO of D/C Gurgaon-Manesar Line(PGCIL) at Sohna Road SS of GTPL,	19-Jan-2020	08:00	08-Feb-2020	18:00	
121	OCC_166	sterlite_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GURGAON-MANESAR (PG) CKT-2	POWERGRID	C	LILO of D/C Gurgaon-Manesar Line(PGCIL) at Sohna Road SS of GTPL,	19-Jan-2020	08:00	08-Feb-2020	18:00	
122	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-BASSI (PG) CKT-1	POWERGRID	D	Connection of Droppers with liine side conductor of isolator No.405-89B After replacement of isolator.	18-Jan-2020	13:00	18-Jan-2020	17:00	
123	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KAITHAL-MALERKOTLA (PG) CKT-1	POWERGRID	C	For replacement of Line Isolators	17-Jan-2020	09:00	18-Jan-2020	18:00	
124	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-NEWWANPOH (PG) CKT-4	POWERGRID	D	Non Auto mode required for Live line installation of OPGW under ULDC scheme.	17-Jan-2020	08:00	31-Jan-2020	18:00	Non shutdown activity
125	OCC_166	singrauli_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-ALLAHABAD(PG) (PG) CKT-2	POWERGRID	C	for Integration in New SAS System	16-Jan-2020	08:00	20-Jan-2020	18:00	Switchyard Sub station Automation system
126	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AURAIYA(NT)-AGRA(PG) (PG) CKT-1	POWERGRID	D	For taking line reactor into the service after AMP of line reactor at agra Substation	15-Jan-2020	17:00	15-Jan-2020	18:00	
127	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AURAIYA(NT)-AGRA(PG) (PG) CKT-1	POWERGRID	D	for taking line reactor out of service for AMP of line reactor at agra Substation	15-Jan-2020	08:00	15-Jan-2020	09:00	
128	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-BASSI (PG) CKT-1	POWERGRID	D	AMP of line reactor and Changing of daigram in reactor conservator at agra Substation	14-Jan-2020	08:00	14-Jan-2020	18:00	
129	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-NEWWANPOH (PG) CKT-2	POWERGRID	D	For AMP Works with K'pur N Wanpoh ckt-I in Non Auto mode.	14-Jan-2020	08:00	14-Jan-2020	17:00	
130	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-BASSI (PG) CKT-1	POWERGRID	D	Dis-connection of Droppers with liine side conductor of isolator No.405-89B before replacement of isolator.	13-Jan-2020	09:00	13-Jan-2020	13:00	
131	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)-BAWANA(DV) (PG) CKT-1	POWERGRID	D	Non Auto mode for live line installation of Bird Guard on Tower between Loc. 315 to 367 (upto LILO point)	13-Jan-2020	09:00	21-Jan-2020	17:00	Non shutdown activity

132	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)-DEEPALPUR(JHKT) (PG) CKT-1	POWERGRID	D	Non Auto mode for live line installation of Bird Guard on Tower between Loc. 315 to 367 (upto LILO point)	13-Jan-2020	09:00	21-Jan-2020	17:00	Non shutdown activity	
133	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-FATEHPUR(PG) (PG) CKT-1	POWERGRID	D	Pre winter preparedness and line AMP work	13-Jan-2020	08:00	14-Jan-2020	18:00		
134	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)-GORAKHPUR(UP) (PG) CKT-2	POWERGRID	D	AMP of Line Bay equipments at PGCIL Gorakhpur S/s	13-Jan-2020	08:00	13-Jan-2020	18:00		
135	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-BHIWADI (PG) CKT-2	POWERGRID	D	Connection of Droppers with liine side conductor of isolator No.405-89A After replacement of isolator.	11-Jan-2020	13:00	11-Jan-2020	17:00		
136	OCC_166	singrauli_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-LUCKNOW(UP) (PG) CKT-1	POWERGRID	C	for Integration in New SAS System	11-Jan-2020	08:00	15-Jan-2020	18:00	Switchyard Sub station Automation system	
137	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTESHWAR-MEERUT (PG) CKT-1	POWERGRID	C	Erection of 765 kV line terminal equipments and SF6 to Air Bushings. HV Test of GIS Equipments of 765 kV Meerut-1 Line, ICT-3 & 4 (765 kV Side) and final testing and commissioning.	11-Jan-2020	08:00	17-Feb-2020	18:00		
138	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)-GORAKHPUR(UP) (PG) CKT-1	POWERGRID	D	AMP of Line Bay equipments at PGCIL Gorakhpur S/s	10-Jan-2020	08:00	10-Jan-2020	18:00		
139	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-NEWWANPOH (PG) CKT-1	POWERGRID	D	For AMP Works with K'pur N Wanpoh ckt-II in Non Auto mode.	10-Jan-2020	08:00	10-Jan-2020	17:00		
140	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS)-KANKROLI(PG) (PG) CKT-1	POWERGRID	D	For Pre-winter maintenance work eg.Insulator cleaning , CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	10-Jan-2020	08:00	10-Jan-2020	18:00		
141	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-PANIPAT(BB) (PG) CKT-2	POWERGRID	D	SD for testing of main-2 relay after replacement.	09-Jan-2020	15:00	09-Jan-2020	17:00		
142	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTA(PG)-MERTA(RS) (PG) CKT-1	POWERGRID	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	09-Jan-2020	10:00	09-Jan-2020	17:00		
143	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-MURADNAGAR_2(UP) (PG) CKT-1	POWERGRID	D	For preventive maintenance and tightiningg of 400 KV Towers for Meerut-Bulandshahar Expressway and Meerut-Delhi Expressway	09-Jan-2020	09:00	09-Jan-2020	17:00		
144	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2-BAREILLY (PG) CKT-2	POWERGRID	D	Routine testing /preventive maintenance	09-Jan-2020	09:00	09-Jan-2020	15:00		
145	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA-SONIPAT (PG) CKT-2	POWERGRID	D	For AMP and fixation of spacers.	09-Jan-2020	09:00	10-Jan-2020	17:00		
146	OCC_166	koteshwar_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTESWAR(TH)-KOTESHWAR(PG) (PG) CKT-2	POWERGRID	D	For testing and condition monitoring of 400 kV line -II Circuit Breaker of KHEP by CPRI	09-Jan-2020	09:00	09-Jan-2020	17:00		

147	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD-VARANASI (PG) CKT-1	POWERGRID	D	Pre winter preparedness and line AMP work	09-Jan-2020	08:00	10-Jan-2020	18:00		
148	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAGHPAT-SAHARANPUR (PG) CKT-1	POWERGRID	D	Clearing of Porcelain insulators & other maintenance work in the line	09-Jan-2020	08:00	10-Jan-2020	18:00		
149	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1(PG)-UNNAO(UP) (PG) CKT-2	POWERGRID	D	Main-1 Distance relay Replacement work at Unnao s/s	09-Jan-2020	08:00	09-Jan-2020	18:00		
150	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)-KANKROLI(PG) (PG) CKT-1	POWERGRID	D	For Pre-winter maintenance work eg. Insulator cleaning , CC Ring, Spacer, VD, Bird Guard & Jumper tightening.	09-Jan-2020	08:00	09-Jan-2020	18:00		
151	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(RS)-BHADLA(PG) (PG) CKT-1	POWERGRID	D	Quarterly Maintenance work	08-Jan-2020	09:00	08-Jan-2020	17:00		
152	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(RS)-BHADLA(PG) (PG) CKT-2	POWERGRID	D	Quarterly Maintenance work	08-Jan-2020	09:00	08-Jan-2020	17:00		
153	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA-HISSAR (PG) CKT-2	POWERGRID	D	For AMP works.	08-Jan-2020	09:00	08-Jan-2020	18:00		
154	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2-BAREILLY (PG) CKT-1	POWERGRID	D	Routine testing /preventive maintenance	08-Jan-2020	09:00	08-Jan-2020	15:00		
155	OCC_166	koteshwar_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTESWAR(TH)-KOTESHWAR(PG) (PG) CKT-1	POWERGRID	D	For testing and condition monitoring of 400 kV line -I Circuit Breaker of KHEP by CPRI	08-Jan-2020	09:00	08-Jan-2020	17:00		
156	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-KISHENPUR(PG) (PG) CKT-1	POWERGRID	D	For AMP Work.	08-Jan-2020	08:00	08-Jan-2020	17:00		
157	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RIHAND(NT)-ALLAHABAD(PG) (PG) CKT-1	POWERGRID	D	POWER LINE CROSSING of under construction 765 kV D/C vindhyachal-Varanasi transmission line (under TBCB)	08-Jan-2020	08:00	09-Jan-2020	18:00		
158	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SHREE CEMENT(SCL)-MERTA(RS) (PG) CKT-2	POWERGRID	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	07-Jan-2020	10:00	07-Jan-2020	17:00		
159	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-PANIPAT(BB) (PG) CKT-2	POWERGRID	D	Online replacement of Main-2 distance relay.	07-Jan-2020	10:00	08-Jan-2020	18:00		
160	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA-SONIPAT (PG) CKT-1	POWERGRID	D	For AMP and fixation of spacers.	07-Jan-2020	09:00	08-Jan-2020	17:00		
161	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ROORKEE-DEHRADUN (PG) CKT-1	POWERGRID	D	Clearing of Porcelain insulators & other maintenance work in the line	07-Jan-2020	08:00	08-Jan-2020	18:00		

162	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTESWAR(TH)-KOTESHWAR(PG) (PG) CKT-2	POWERGRID	C	Extension of 400 kV Bus-2. Line shutdown is required as evacuation of SF6 Gas of Bus-2 during extension work shall also result in evacuation of gas of common gas compartment between Bus-1 & 2 isolator.	07-Jan-2020	08:00	10-Jan-2020	18:00		
163	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHINMAL-KANKROLI (PG) CKT-1	POWERGRID	D	For Pre-winter maintenance work eg. Insulator cleaning , CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	07-Jan-2020	08:00	07-Jan-2020	18:00		
164	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-BHIWADI (PG) CKT-2	POWERGRID	D	Dis-connection of Droppers with line side conductor of isolator No.405-89A before replacement of isolator.	06-Jan-2020	09:00	06-Jan-2020	13:00		
165	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-LUCKNOW(UP) (PG) CKT-1	POWERGRID	D	Pre winter preparedness and line AMP work	06-Jan-2020	08:00	06-Jan-2020	18:00		
166	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1(PG)-UNNAO(UP) (PG) CKT-1	POWERGRID	D	Main-1 Distance relay Replacement work at Unnao s/s	06-Jan-2020	08:00	06-Jan-2020	18:00		
167	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTESWAR(TH)-KOTESHWAR(PG) (PG) CKT-2	POWERGRID	C	Extension of 400 kV Bus-1. Line shutdown is required as evacuation of SF6 Gas of Bus-1 during extension work shall also result in evacuation of gas of common gas compartment between Bus-1 & 2 isolator.	03-Jan-2020	08:00	06-Jan-2020	18:00		
168	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI-BHIWADI (PG) CKT-2	POWERGRID	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
169	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI-HISSAR (PG) CKT-1	POWERGRID	D	"Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works (195 Kms out of 212 Kms completed)- work very slow /some times stopped due to severe ROW/Rain issues)"	01-Jan-2020	08:00	31-Jan-2020	18:00		
170	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SIKAR(PG)-BABAI(RS) (PG) CKT-1	POWERGRID	D	"Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works (155 Kms out of 178 kms OPGW laying Completed-work very slow /some times stopped due to severe ROW/Rain issues)"	01-Jan-2020	08:00	31-Jan-2020	18:00		
171	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALLABHGARH-GURGAON (PG) CKT-1	POWERGRID	D	"Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works (OPGW works completed, minor rectification, if required)"	01-Jan-2020	08:00	31-Jan-2020	18:00		
172	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALLABHGARH-MAHARANIBAGH (PG) CKT-1	POWERGRID	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
173	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI-GURGAON (PG) CKT-1	POWERGRID	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		

174	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GR.NOIDA(UPC)-NAWADA(HV) (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works under Relabile Communication scheme	01-Jan-2020	08:00	31-Jan-2020	18:00		
175	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALLABHGARH(PG)-NAWADA(HV) (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works under Relabile Communication scheme	01-Jan-2020	08:00	31-Jan-2020	18:00		
176	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI(BB)-HISSAR(PG) (PG) CKT-1	POWERGRID	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
177	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI-BALLABHGARH (PG) CKT-2	POWERGRID	D	"Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works (236 kms out of 236 Kms completed), Jointing WIP"	01-Jan-2020	08:00	31-Jan-2020	18:00		
178	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AURAIYA(NT)-AGRA(PG) (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
179	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR(UP)-MORADABAD(UP) (PG) CKT-1	POWERGRID	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off) - Completed	01-Jan-2020	08:00	31-Jan-2020	18:00		
180	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR(UP)-MURADNAGAR_1(UP) (PG) CKT-1	POWERGRID	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off) - Completed	01-Jan-2020	08:00	31-Jan-2020	18:00		
181	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-MANDOLA(PG) (PG) CKT-2	POWERGRID	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
182	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-PANIPAT(BB) (PG) CKT-2	POWERGRID	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
183	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)-MAHARANIBAGH(PG) (PG) CKT-1	POWERGRID	D	"Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works (OPGW works completed, minor rectification, if required)"	01-Jan-2020	08:00	31-Jan-2020	18:00		
184	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-BALLABHGARH (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
185	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-BASSI (PG) CKT-1	POWERGRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
186	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMBA-JALANDHAR (PG) CKT-1	POWERGRID	D	LIVE LINE OPGW INSTALLATION WORK (Relay setting for TX line must be in NON AUTO MODE during OPGW installation work)	01-Jan-2020	08:00	31-Jan-2020	18:00		
187	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMBA-JALANDHAR (PG) CKT-2	POWERGRID	D	LIVE LINE OPGW INSTALLATION WORK (Relay setting for TX line must be in NON AUTO MODE during OPGW installation work)	01-Jan-2020	08:00	31-Jan-2020	18:00		

188	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR-MOGA (PG) CKT-2	POWERGRID	D	LIVE LINE OPGW INSTALLATION WORK (Relay setting for TX line must be in NON AUTO MODE during OPGW installation work)	01-Jan-2020	08:00	31-Jan-2020	18:00		
189	OCC_166	singrauli_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)-ALLAHABAD(PG) (PG) CKT-1	POWERGRID	D	For routine bay maintenance works	28-Dec-2019	08:00	28-Jan-2020	18:00		
190	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PANCHKULA-ABDULLAPUR (PG) CKT-2	POWERGRID	D	Testing for conversion of fixed LR to switched LR.	27-Dec-2019	10:00	27-Dec-2019	14:00	Construction activity	
191	OCC_166	chamera2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-CHAMERA_1(NH) (PG) CKT-1	POWERGRID	D	Diagnostic Testing of EHV equipment of 400KV GIS for condition monitoring by OEM.	27-Dec-2019	08:00	27-Dec-2019	18:00		
192	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2(PG)-KASHIPUR(UK) (PG) CKT-2	POWERGRID	D	Pre winter preparedness and line AMP work	27-Dec-2019	08:00	28-Dec-2019	18:00		
193	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTPUTLI-BHIWADI (PG) CKT-1	POWERGRID	D	For Pre-winter maintenance work eg. Insulator cleaning , CC Ring, Spacer,VD, Bird Guard & Jumper tightening.	27-Dec-2019	08:00	28-Dec-2019	18:00		
194	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PANCHKULA-ABDULLAPUR (PG) CKT-1	POWERGRID	D	Testing for conversion of fixed LR to switched LR.	26-Dec-2019	10:00	26-Dec-2019	14:00	Construction activity	
195	OCC_166	chamera2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-KISHENPUR(PG) (PG) CKT-1	POWERGRID	D	Diagnostic Testing of EHV equipment of 400KV GIS for condition monitoring by OEM.	26-Dec-2019	09:00	26-Dec-2019	18:00		
196	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KAITHAL-HISSAR (PG) CKT-2	POWERGRID	D	Replacement of Defective R-Ph Wave Trap of the 400kV Hisar-Kaithal Line-2	26-Dec-2019	08:00	26-Dec-2019	16:00		
197	OCC_166	chamera2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-CHAMBA(PG) (PG) CKT-1	POWERGRID	D	Diagnostic Testing of EHV equipment of 400KV GIS for condition monitoring by OEM.	25-Dec-2019	08:00	25-Dec-2019	18:00	Actual shutdown required from 19/12/2019 (13:00 hrs.) to 19/12/2019 (17:00 hrs.).	
198	OCC_166	chamera2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-CHAMERA_1(NH) (PG) CKT-1	POWERGRID	D	Diagnostic Testing of EHV equipment of 400KV GIS for condition monitoring by OEM.	25-Dec-2019	08:00	26-Dec-2019	18:00	Actual shutdown required from 22/12/2019 (9:00 hrs.) to 23/12/2019 (18:00 hrs.)	
199	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2(PG)-KASHIPUR(UK) (PG) CKT-1	POWERGRID	D	Pre winter preparedness and line AMP work	25-Dec-2019	08:00	26-Dec-2019	18:00		
200	OCC_166	chamera2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-KISHENPUR(PG) (PG) CKT-1	POWERGRID	D	Diagnostic Testing of EHV equipment of 400KV GIS for condition monitoring by OEM.	25-Dec-2019	08:00	25-Dec-2019	18:00	Actual shutdown required from 19/12/2019 (13:00 hrs.) to 19/12/2019 (17:00 hrs.).	

201	OCC_166	chamera2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)-CHAMERA_1(NH) (PG) CKT-1	POWERGRID	D	Diagnostic Testing of EHV equipment of 400KV GIS for condition monitoring by OEM.	24-Dec-2019	08:00	25-Dec-2019	18:00	Actual shutdown of line required from 19/12/2019 (13:00 hrs.) to 19/12/2019 (17:00 hrs.).
202	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR-DASNA (UP) CKT-2	UPPTCL	C	For Annual Maintenance work	30-Jan-2020	08:00	30-Jan-2020	14:00	
203	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR-DASNA (UP) CKT-1	UPPTCL	C	For Annual Maintenance work	29-Jan-2020	08:00	29-Jan-2020	18:00	
204	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ORAI-PARICHA (UP) CKT-2	UPPTCL	C	For routine testing and maintenance	22-Jan-2020	09:00	22-Jan-2020	18:30	
205	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SULTANPUR(UP)-LUCKNOW_1(PG) (UP) CKT-1	UPPTCL	C	For routine bay maintenance & Isolator replacement works	21-Jan-2020	10:00	23-Jan-2020	18:00	
206	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TANDA(NT)-SULTANPUR(UP) (UP) CKT-1	UPPTCL	D	For routine bay maintenance works	20-Jan-2020	10:00	20-Jan-2020	18:00	
207	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ORAI-PARICHA (UP) CKT-1	UPPTCL	C	For routine testing and maintenance	20-Jan-2020	09:00	20-Jan-2020	18:30	
208	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA-SARNATH (UP) CKT-1	UPPTCL	C	Diversion of 400 KV Anpara-Sarnath L-3 line for proposed DFCC Corridor	20-Jan-2020	08:00	30-Jan-2020	18:00	
209	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV OBRA_B-SULTANPUR (UP) CKT-1	UPPTCL	C	Diversion of 400 KV Obra-Sultanpur line for construction of start up power line for Obra-C	20-Jan-2020	08:00	27-Jan-2020	18:00	
210	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUZAFFARNAGAR-ATAUR (UP) CKT-1	UPPTCL	D	For lopping chopping of trees and jumper tightening	16-Jan-2020	10:00	17-Jan-2020	18:00	
211	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA_B(UPUN)-SARNATH(UP) (UP) CKT-2	UPPTCL	D	Shut Down required for replacement of old & outlived 0.5 accuracy CTs to 0.2 accuracy CTs.	16-Jan-2020	09:00	18-Jan-2020	17:00	
212	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MURADNAGAR_2-MATHURA (UP) CKT-1	UPPTCL	C	Height Raising of 400KV S/C Manth (Mathura)-Muradnagar Line at Location no.477-480 for Construction of Delhi-Meerut Expressway by N.H.A.I.	16-Jan-2020	08:00	23-Jan-2020	19:00	
213	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PANKI-ALIGARH (UP) CKT-1	UPPTCL	C	Centrifuging of oil of 50 MVAR Line Reactor.	15-Jan-2020	08:00	18-Jan-2020	17:00	
214	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA FATEHBAD-MATHURA (UP) CKT-2	UPPTCL	D	For replacement of damaged jumper and polymer	14-Jan-2020	09:00	16-Jan-2020	18:00	

215	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA_B(UPUN)-MAU(UP) (UP) CKT-1	UPPTCL	D	For replacement of disc insulator by polymer insulator	13-Jan-2020	08:00	23-Jan-2020	18:00		
216	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALIGARH-SIKANDRABAD (UP) CKT-1	UPPTCL	D	Providing of Bird Guard, Disc Cleaning and other Maintenance work.	11-Jan-2020	08:00	15-Jan-2020	18:00		
217	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TANDA(NT)-AZAMGARH(UP) (UP) CKT-1	UPPTCL	C	For Re-routing of Express way	08-Jan-2020	10:00	16-Jan-2020	18:00		
218	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA_B(UPUN)-MAU(UP) (UP) CKT-1	UPPTCL	D	Tightening of complete bay, testing of relay panel and other maintenance work.	07-Jan-2020	10:00	07-Jan-2020	18:00		
219	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY-UNNAO (UP) CKT-2	UPPTCL	D	Routine testing /preventive maintenance	07-Jan-2020	09:00	07-Jan-2020	15:00		
220	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV OBRA_B-SULTANPUR (UP) CKT-1	UPPTCL	C	For CT replacement & Bay maintenance Work	06-Jan-2020	10:00	08-Jan-2020	18:00		
221	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY-UNNAO (UP) CKT-1	UPPTCL	D	Routine testing /preventive maintenance	06-Jan-2020	09:00	06-Jan-2020	15:00		
222	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALIGARH-SIKANDRABAD (UP) CKT-2	UPPTCL	D	Providing of Bird Guard, Disc Cleaning and other Maintenance work.	06-Jan-2020	08:00	10-Jan-2020	18:00		
223	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALIGARH-MURADNAGAR_1 (UP) CKT-1	UPPTCL	C	For carrying out the wrok of hight raising of 400 KV Towers for Meerut-Bulandshahar Expressway and Meerut-Delhi Expressway	05-Jan-2020	09:00	25-Jan-2020	17:00		
224	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BANDA-ORAI (UP) CKT-2	UPPTCL	D	For Annual Routine Testing, Jumper Tightening and Bay maintenance work at 400 KV S/S Banda	05-Jan-2020	08:00	05-Jan-2020	17:00		
225	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV OBRA_B-REWA ROAD (UP) CKT-1	UPPTCL	C	Diversion of 400 KV Obra-Rewa Road line for construction of start up power line for Obra-C	05-Jan-2020	08:00	18-Jan-2020	18:00		
226	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BANDA-ORAI (UP) CKT-1	UPPTCL	D	For Annual Routine Testing, Jumper Tightening and Bay maintenance work at 400 KV S/S Banda	04-Jan-2020	08:00	04-Jan-2020	17:00		
227	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA_B(UPUN)-SARNATH(UP) (UP) CKT-2	UPPTCL	D	For replacement of disc insulator by polymer insulator	02-Jan-2020	08:00	12-Jan-2020	18:00		
228	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SARNATH-AZAMGARH (UP) CKT-1	UPPTCL	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
229	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEHAR(BB)-RAJPURA(PS) (BB) CKT-1	BBMB	C	Shifting of Tower at ACC cement limited	30-Jan-2020	08:00	01-Feb-2020	18:00		Shifting of tower at ACC cement limited
230	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUKTSAR-MAKHU (PS) CKT-2	PSTCL	D	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	30-Jan-2020	08:00	30-Jan-2020	18:00		

231	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR(PG)-MAKHU(PSTCL) CKT-2	PSTCL	D	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	28-Jan-2020	08:00	28-Jan-2020	18:00		
232	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUKTSAR-MAKHU (PS) CKT-1	PSTCL	D	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	24-Jan-2020	08:00	24-Jan-2020	18:00		
233	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR(PG)-MAKHU(PSTCL) CKT-1	PSTCL	D	Tightening/checking of jumpers and cleaning of disc insulators in polluted area	23-Jan-2020	08:00	23-Jan-2020	18:00		
234	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJPURA TPS(PSG)-NAKODAR(PSG) (PS) CKT-2	PSTCL	D	General Maintenance	17-Jan-2020	08:00	17-Jan-2020	18:00		
235	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJPURA-DHURI (PS) CKT-2	PSTCL	D	Jumper Tightening	16-Jan-2020	08:00	17-Jan-2020	18:00		
236	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NAKODAR(PSG)-MAKHU(PS) (PS) CKT-2	PSTCL	D	General Maintenance	14-Jan-2020	08:00	14-Jan-2020	18:00		
237	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NAKODAR(PSG)-MAKHU(PS) (PS) CKT-1	PSTCL	D	General Maintenance	13-Jan-2020	08:00	13-Jan-2020	18:00		
238	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJPURA TPS(PSG)-NAKODAR(PSG) (PS) CKT-1	PSTCL	D	General Maintenance	10-Jan-2020	08:00	10-Jan-2020	18:00		
239	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJPURA-DHURI (PS) CKT-1	PSTCL	D	Jumper Tightening	09-Jan-2020	08:00	09-Jan-2020	18:00		
240	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NAKODAR(PSG)-MOGA(PG) (PS) CKT-1	PSTCL	D	General Maintenance	08-Jan-2020	08:00	08-Jan-2020	18:00		
241	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TALWANDI SABOO(PSG)-DHURI(PS) (PS) CKT-1	PSTCL	D	Jumper Tightening	07-Jan-2020	08:00	08-Jan-2020	18:00		
242	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TALWANDI SABOO(PSG)-NAKODAR(PSG) (PS) CKT-1	PSTCL	D	General Maintenance	06-Jan-2020	08:00	06-Jan-2020	18:00		
243	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR(PG)-MAKHU(PSTCL) CKT-2	PSTCL	D	General Maintenance	06-Jan-2020	08:00	06-Jan-2020	18:00		
244	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NAKODAR(PSG)-MAKHU(PS) (PS) CKT-2	PSTCL	D	General Maintenance	03-Jan-2020	08:00	03-Jan-2020	18:00		
245	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR(PG)-MAKHU(PSTCL) CKT-1	PSTCL	D	General Maintenance	02-Jan-2020	08:00	02-Jan-2020	18:00		
246	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NAKODAR(PSG)-MAKHU(PS) (PS) CKT-1	PSTCL	D	General Maintenance	01-Jan-2020	08:00	01-Jan-2020	18:00		

247	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-AGRA FATEHBAD (UP) CKT-1	POWERGR D,UPPTCL	D	For replacement of damaged jumper and polymer	28-Jan-2020	09:00	30-Jan-2020	18:00		
248	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT(PG)-MANDOLA(PG) (PL) CKT-4	POWERLIN K	D	Stringing of 765KV Koteshwar-Meerut-II line for Diversion work of span -1B-2B.Existing line charged at 400KV level.Also rearrangement of existing diamond crossing of earthwire between Meerut - Moga TL & Meerut-Mandola-III & IV to be carried out.	27-Jan-2020	08:00	28-Jan-2020	18:00		
249	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT(PG)-MANDOLA(PG) (PL) CKT-3	POWERLIN K	D	Stringing of 765KV Koteshwar-Meerut-II line for Diversion work of span -1B-2B.Existing line charged at 400KV level.Also rearrangement of existing diamond crossing of earthwire between Meerut - Moga TL & Meerut-Mandola-III & IV to be carried out.	27-Jan-2020	08:00	28-Jan-2020	18:00		
250	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JODHPUR-KANKANI (RS) CKT- 2	RRVPNL	D	Preventive maintenance Work	24-Jan-2020	09:00	24-Jan-2020	18:00		
251	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BARMER(RS)-RAJWEST(RW) (RS) CKT-1	RRVPNL	D	Planned maintenance	18-Jan-2020	08:00	18-Jan-2020	18:00		
252	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHILWARA-CHITTORGARH (RS) CKT-2	RRVPNL	D	Maintenance work	17-Jan-2020	09:00	17-Jan-2020	17:00		
253	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJWEST(RW)-JODHPUR(RS) (RS) CKT-2	RRVPNL	D	Planned maintenance	17-Jan-2020	08:00	17-Jan-2020	18:00		
254	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHILWARA-CHITTORGARH (RS) CKT-1	RRVPNL	D	Maintenance work	16-Jan-2020	09:00	16-Jan-2020	17:00		
255	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA-MERTA (RS) CKT-1	RRVPNL	D	To isolate line reactor for maintenance work.	16-Jan-2020	09:00	16-Jan-2020	10:00		
256	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJWEST(RW)-KANKANI (RS) CKT-1	RRVPNL	D	Planned maintenance	16-Jan-2020	08:00	16-Jan-2020	18:00		
257	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER-BHADLA (RS) CKT-2	RRVPNL	D	To isolate line reactor for maintenance work.	15-Jan-2020	09:00	15-Jan-2020	10:00		
258	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL-BARMER (RS) CKT-1	RRVPNL	D	Quarterly Maintenance	15-Jan-2020	08:00	15-Jan-2020	18:00		
259	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER(RS)-SIKAR(PG) (RS) CKT-2	RRVPNL	D	AMP TESTING OF 400 kV Line Reactor of 400kV Bikaner ckt-2 line at 400 kV Sikar S/s	09-Jan-2020	08:00	09-Jan-2020	18:00		
260	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER-MERTA (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	08-Jan-2020	10:00	08-Jan-2020	17:00		

261	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER(RS)-SIKAR(PG) (RS) CKT-1	RRVPNL	D	AMP TESTING OF 400 kV Line Reactor of 400kV Bikaner ckt-1 line at 400 kV Sikar S/s	08-Jan-2020	08:00	08-Jan-2020	18:00		
262	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA-JODHPUR (RS) CKT- 1	RRVPNL	D	Quarterly Maintenance work	07-Jan-2020	09:00	07-Jan-2020	17:00		
263	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA-MERTA (RS) CKT-1	RRVPNL	D	Quarterly Maintenance work	07-Jan-2020	09:00	07-Jan-2020	17:00		
264	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AJMER-BHILWARA (RS) CKT- 2	RRVPNL	D	Yearly Maintenane of 400 KV AJMER-BHILWARA CKT- 1 LINE&BAY(4352B)& ASSOCIATED EQUIPMENTS	07-Jan-2020	09:00	07-Jan-2020	18:00		
265	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA-KANKANI (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	06-Jan-2020	10:00	06-Jan-2020	17:00		
266	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AJMER-BHILWARA (RS) CKT- 1	RRVPNL	D	Yearly Maintenane of 400 KV AJMER-BHILWARA CKT- 1 LINE&BAY(4352B)& ASSOCIATED EQUIPMENTS	06-Jan-2020	09:00	06-Jan-2020	18:00		
267	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER-BHADLA (RS) CKT-2	RRVPNL	D	Quarterly Maintenance work	06-Jan-2020	09:00	06-Jan-2020	17:00		
268	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHILWARA-CHITTORGARH (RS) CKT-1	RRVPNL	D	OPGW laying shall be started in this line under Reliable Comunication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
269	OCC_166	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KHEDAR(HPG)- NUHIAWALI(HV) (HV) CKT-1	HVPNL	D	For relay testing and testing of bay equipment	24-Jan-2020	09:00	24-Jan-2020	18:00		
270	OCC_166	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KHEDAR(HPG)-KIRORI(HV) (HV) CKT-2	HVPNL	D	For relay testing and testing of bay equipment	23-Jan-2020	09:00	23-Jan-2020	18:00		
271	OCC_166	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KHEDAR(HPG)-KIRORI(HV) (HV) CKT-1	HVPNL	D	For relay testing and testing of bay equipment	22-Jan-2020	09:00	22-Feb-2020	18:00		
272	OCC_166	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KHEDAR(HPG)- FATEHABAD(PG) (HV) CKT-1	HVPNL	D	For relay testing and testing of bay equipment	21-Jan-2020	09:00	21-Feb-2020	18:00		
273	OCC_166	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-1	HVPNL	D	For gen mtc of bay isolators	16-Jan-2020	09:00	16-Jan-2020	15:00		
274	OCC_166	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-2	HVPNL	D	For general mtc and nut bolts tightening and isolator alignment	10-Jan-2020	10:00	10-Jan-2020	17:00		
275	OCC_166	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA-DAULATABAD (HV) CKT-1	HVPNL	D	For general mtc and nut bolts tightening and isolator alignment	04-Jan-2020	10:00	04-Jan-2020	17:00		

276	OCC_166	sldchp_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASPA(JP)-KARCHAM WANGTOO(JSW) (HBPCL) CKT-2	JSW,JPL,HB PCL	C	Planned Maintenance of GIS bay of line.	18-Jan-2020	08:00	22-Jan-2020	20:00	Ckt. 1 shall be available for evacuation of power during Shutdown on Ckt.2.
277	OCC_166	sldchp_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASPA(JP)-KARCHAM WANGTOO(JSW) (HBPCL) CKT-1	JSW,JPL,HB PCL	C	Planned Maintenance of GIS bay of line.	13-Jan-2020	08:00	17-Jan-2020	20:00	Ckt.2 shall be available for evacuation of power during Shutdown on Ckt.1
278	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER(PG)-BHADLA(RS) (PG) CKT-1	POWERGRI D,RRVPL	D	To isolate line reactor for maintenance work.	14-Jan-2020	09:00	14-Jan-2020	10:00	
279	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER(PG)-BHADLA(RS) (PG) CKT-1	POWERGRI D,RRVPL	D	Quarterly Maintenance work	06-Jan-2020	09:00	06-Jan-2020	17:00	
280	OCC_166	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAWANA-MUNDKA (DV) CKT- 2	DTL	D	Capacitance & Tan delta testing.	10-Jan-2020	14:00	10-Jan-2020	17:30	Load shall be shared by alternate feeder
281	OCC_166	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-1	DTL	D	Capacitance & Tan delta testing	10-Jan-2020	09:00	10-Jan-2020	13:00	Load shall be shared by alternate feeder
282	OCC_166	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-2	DTL	D	Line maintenance and broken spacer change	09-Jan-2020	09:00	09-Jan-2020	17:30	Load shall be shared by alternate feeder
283	OCC_166	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-2	DTL	D	Line maintenance and broken spacer change	08-Jan-2020	09:00	08-Jan-2020	17:30	Load shall be shared by alternate feeder
284	OCC_166	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-1	DTL	D	Line maintenance and broken spacer change	07-Jan-2020	09:00	07-Jan-2020	17:30	Load shall be shared by alternate feeder
285	OCC_166	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-1	DTL	D	Line maintenance and broken spacer change	06-Jan-2020	09:00	06-Jan-2020	17:30	Load shall be shared by alternate feeder
286	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)-KALA AMB(PKTL) (JPL) CKT-2	JPVL,PKATL ,JPL	D	Non auto of auto reclosure for OPGW works	06-Jan-2020	08:00	31-Jan-2020	18:00	
287	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)-KALA AMB(PKTL) (JPVL) CKT-1	JPVL,PKATL	D	Non auto of auto reclosure for OPGW works	06-Jan-2020	08:00	31-Jan-2020	18:00	
288	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_3(NH)-PARBATI POOLING BANALA(PG) (PKTCL) CKT- 2	PKTCL,PSTC L	D	Shut Down required for Installation of OPGW under ULDC Scheme due to steep slopes and working difficulty.	01-Jan-2020	09:00	31-Jan-2020	17:00	
289	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_3(NH)-SAINJ(HR) (PKTCL) CKT-1	PKTCL,PSTC L	D	Non-Auto reclose required during installation work of OPGW on 400 kV Banala – Parbati III HEP TL.	01-Jan-2020	09:00	31-Jan-2020	17:00	Non shutdown activity

290	OCC_166	sterlite_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1	NRSS XXIX	D	A/R in non Auto mode, for the installation of OPGW in place of earth wire.	01-Jan-2020	08:00	31-Jan-2020	18:00		
291	OCC_166	sterlite_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2	NRSS XXIX	D	A/R in non Auto mode, for the installation of OPGW in place of earth wire.	01-Jan-2020	08:00	31-Jan-2020	18:00		
292	OCC_166	sterlite_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1	NRSS XXIX	D	A/R in non Auto mode, for the installation of OPGW in place of earth wire.	01-Jan-2020	08:00	31-Jan-2020	18:00		
293	OCC_166	sterlite_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2	NRSS XXIX	D	A/R in non Auto mode, for the installation of OPGW in place of earth wire.	01-Jan-2020	08:00	31-Jan-2020	18:00		
294	OCC_166	sterlite_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1	NRSS XXIX	D	Peak has been bent due to heavy snow and wind shutdown required for rectification work	24-Dec-2019	08:00	25-Dec-2019	18:00	Consider this outage under Force Majeure, because it was beyond the control of NRSS-XXIX.	
295	OCC_166	sterlite_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2	NRSS XXIX	D	Peak has been bent due to heavy snow and wind shutdown required for rectification work	24-Dec-2019	08:00	25-Dec-2019	18:00	Consider this outage under Force Majeure, because it was beyond the control of NRSS-XXIX.	
296	OCC_166	renew_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER(PG)-BIKANER RENEW SOLAR(RENEW) (RENEW POWER) CKT-1	RENEW POWER	C	For placing of missing conductor hardware in 400kv line	25-Dec-2019	18:30	29-Dec-2019	05:00	Line shutdown will be take evening and again line will be charged for the next day morning.	
297	OCC_166	sldcrs_sd	BUS	400KV BUS 1KANKANI(RS)	RRVPLN	D	Preventive maintenance Work	31-Jan-2020	09:00	31-Jan-2020	18:00		
298	OCC_166	sldcrs_sd	BUS	400KV BUS 1 AT BHADLA(RS)	RRVPLN	D	Quarterly Maintenance work	06-Jan-2020	09:00	08-Jan-2020	17:00		
299	OCC_166	cpcc2_sd	BUS	400KV BUS 1 AT PANCHKULA(PG)	POWERGRID	D	For AMP works.	30-Jan-2020	09:00	30-Jan-2020	18:00		
300	OCC_166	cpcc2_sd	BUS	400KV BUS 2 AT FATEHABAD(PG)	POWERGRID	D	For Amp works	29-Jan-2020	10:00	29-Jan-2020	18:00		
301	OCC_166	cpcc2_sd	BUS	400KV BUS 1 AT KISHENPUR(PG)	POWERGRID	D	For AMP Work and bus isolator maintenance.	29-Jan-2020	09:00	30-Jan-2020	17:00		
302	OCC_166	cpcc2_sd	BUS	400KV BUS 1 AT FATEHABAD(PG)	POWERGRID	D	For Amp works	28-Jan-2020	10:00	28-Jan-2020	18:00		
303	OCC_166	cpcc3_sd	BUS	400KV BUS 1 AT KANPUR(PG)	POWERGRID	D	For Jumper closing of Iso 40189 and 40489 at Kanpur S/S	28-Jan-2020	08:00	28-Jan-2020	18:00		
304	OCC_166	cpcc1_sd	BUS	400KV BUS 2 AT GURGAON(PG)	POWERGRID	D	FOR AMP WORK	28-Jan-2020	08:00	28-Jan-2020	18:00		

305	OCC_166	cpcc1_sd	BUS	400KV BUS 1 AT GURGAON(PG)	POWERGRID	D	FOR AMP WORK	27-Jan-2020	08:00	27-Jan-2020	18:00		
306	OCC_166	cpcc1_sd	BUS	400KV BUS 2 AT BASSI(PG)	POWERGRID	D	Connection of Droppers with Bus side conductor of Isolator No.406-89 After replacement of isolator.	25-Jan-2020	13:00	25-Jan-2020	17:00		
307	OCC_166	cpcc3_sd	BUS	400KV BUS 1 AT KANPUR(PG)	POWERGRID	D	For Jumper Opening of Iso 40189 and 40489 at Kanpur S/S	20-Jan-2020	08:00	20-Jan-2020	18:00		
308	OCC_166	cpcc1_sd	BUS	400KV BUS 2 AT BASSI(PG)	POWERGRID	D	Dis-connection of Droppers with Bus side conductor of isolator No.406-89 before replacement of isolator.	20-Jan-2020	08:00	20-Jan-2020	18:00		
309	OCC_166	cpcc1_sd	BUS	400KV BUS 2 AT MEERUT(PG)	POWERGRID	D	SS Const. - Jumper Connection in Bay 414	09-Jan-2020	08:00	11-Jan-2020	18:00		
310	OCC_166	cpcc1_sd	BUS	400KV BUS 2 AT MEERUT(PG)	POWERGRID	D	Testing of Newly retrofitted Centralized Bus Bar Protection Scheme.	08-Jan-2020	08:00	09-Jan-2020	18:00		
311	OCC_166	cpcc1_sd	BUS	KOTESHWAR(PG) - 400KV - BUS 2	POWERGRID	C	Construction work eg. Extension of 400 kV Bus-2.	07-Jan-2020	08:00	10-Jan-2020	18:00		
312	OCC_166	cpcc1_sd	BUS	400KV BUS 1 AT MEERUT(PG)	POWERGRID	D	Testing of Newly retrofitted Centralized Bus Bar Protection Scheme.	06-Jan-2020	08:00	07-Jan-2020	18:00		
313	OCC_166	cpcc1_sd	BUS	400KV BUS 2 AT AJMER(PG)	POWERGRID	D	FOR AMP WORK	04-Jan-2020	08:00	04-Jan-2020	18:00		
314	OCC_166	cpcc1_sd	BUS	400KV BUS 1 AT AJMER(PG)	POWERGRID	D	FOR AMP WORK	03-Jan-2020	08:00	03-Jan-2020	18:00		
315	OCC_166	cpcc1_sd	BUS	KOTESHWAR(PG) - 400KV - BUS 1	POWERGRID	C	Construction work eg. Extension of 400 kV Bus-1.	03-Jan-2020	08:00	06-Jan-2020	18:00		
316	OCC_166	stuup_sd	BUS	400KV BUS 2 AT SARNATH(UP)	UPPTCL	C	Shut Down required for Jumpering of extension of 400KV Main Bus-II for newly 315 MVA-IV.	29-Jan-2020	09:00	30-Jan-2020	17:00		
317	OCC_166	stuup_sd	BUS	400KV BUS 1 AT SARNATH(UP)	UPPTCL	C	Shut Down required for Jumpering of extension of 400KV Main Bus-I for newly 315 MVA-IV.	27-Jan-2020	09:00	28-Jan-2020	17:00		
318	OCC_166	stuup_sd	BUS	400KV BUS 2 AT ORAI(UP)	UPPTCL	C	For routine testing and maintenance	24-Jan-2020	09:00	24-Jan-2020	18:30		
319	OCC_166	sldchr_sd	BUS	400KV BUS 2 AT DAULATABAD(HV)	HVPNL	D	For general maintenance and nut bolts tightening of CTs and isolators	28-Jan-2020	10:00	28-Jan-2020	17:00		
320	OCC_166	sldchr_sd	BUS	400KV BUS 1 AT DAULATABAD(HV)	HVPNL	D	For general maintenance and nut bolts tightening of CTs and isolators	23-Jan-2020	10:00	23-Jan-2020	17:00		
321	OCC_166	sldchr_sd	BUS	400KV BUS 2 AT DAULATABAD(HV)	HVPNL	D	For general maintenance and nut bolts tightening of CTs and isolators	20-Jan-2020	10:00	20-Jan-2020	17:00		
322	OCC_166	sldchr_sd	BUS	400KV BUS 1 AT DAULATABAD(HV)	HVPNL	D	For general maintenance and nut bolts tightening of CTs and isolators	16-Jan-2020	10:00	16-Jan-2020	17:00		
323	OCC_166	sldcps_sd	BUS	400KV BUS 2 AT MAKHU(PS)	PSTCL	D	General Maintenance	23-Jan-2020	08:00	23-Jan-2020	18:00		
324	OCC_166	sldcps_sd	BUS	400KV BUS 2 AT MUKTSAR(PS)	PSTCL	D	General Maintenance	20-Jan-2020	08:00	20-Jan-2020	18:00		
325	OCC_166	sldcps_sd	BUS	400KV BUS 1 AT MUKTSAR(PS)	PSTCL	D	General Maintenance	13-Jan-2020	08:00	13-Jan-2020	18:00		
326	OCC_166	sldcps_sd	BUS	400KV BUS 1 AT MAKHU(PS)	PSTCL	D	General Maintenance	07-Jan-2020	08:00	07-Jan-2020	18:00		

327	OCC_166	bbmb_sd	BUS	400KV BUS 1 AT PANIPAT(BB)	BBMB	D	Yearly Maintenance	15-Jan-2020	08:00	15-Jan-2020	18:00		
328	OCC_166	sldcps_sd	BUS	400KV BUS 2 AT NAKODAR(PSG)	PSPCL	D	General Maintenance	14-Jan-2020	08:00	14-Jan-2020	18:00		
329	OCC_166	sldcps_sd	BUS	400KV BUS 1 AT NAKODAR(PSG)	PSPCL	D	General Maintenance	07-Jan-2020	08:00	07-Jan-2020	18:00		
330	OCC_166	sldcuk_sd	BUS	400KV BUS 2 AT SRINAGAR(UK)	PTCUL	D	For maintenance of buses and bays	08-Jan-2020	10:00	08-Jan-2020	17:00		
331	OCC_166	sldcuk_sd	BUS	400KV BUS 1 AT SRINAGAR(UK)	PTCUL	D	For maintenance of buses and bays	07-Jan-2020	10:00	07-Jan-2020	17:00		
332	OCC_166	sldcuk_sd	BUS	400KV BUS 3 AT SRINAGAR(UK)	PTCUL	D	For maintenance of buses and bays	06-Jan-2020	10:00	06-Jan-2020	17:00		
333	OCC_166	sterlite_sd	BUS	400KV BUS 2 AT AMARGARH(NRSS XXIX)	NRSS XXIX	C	Bay 415 CB replacement	06-Jan-2020	08:00	09-Jan-2020	18:00		
334	OCC_166	sldcdv_sd	BUS	400KV BUS 2 AT BAWANA(DV)	DTL	D	Tan Delta Testing of CB no. 252,452,1052,1252,1452,1652,1852 as per OS Manual	04-Jan-2020	10:30	04-Jan-2020	17:00		Load of the line will be managed through BUS-I.
335	OCC_166	sldcdv_sd	BUS	400KV BUS 1 AT BAWANA(DV)	DTL	D	Tan Delta Testing of CB no. 152,352,952,1152,1352,1552,1752 as per OS Manual.	03-Jan-2020	10:30	03-Jan-2020	17:00		Load of the line will be managed through BUS-II.
336	OCC_166	chamera2_sd	BUS	400KV BUS 1 AT CHAMERA_2(NH)	NHPC	D	Diagnostic Testing of EHV equipment of 400KV GIS for condition monitoring by OEM.	26-Dec-2019	08:00	27-Dec-2019	18:00		Actually approval for opening of Bus coupler is required from 24/12/2019 (09:00 hrs.) to 25/12/2019 (18:00 hrs.) and again on 28/12/2019 (09:00 hrs.) to 28/12/2019 (18:00 hrs.). Since the description of Bus coupler is not available so it is inserted in bus shutdown. Bus s/d is not required. Both the bus will be charged.
337	OCC_166	cpcc3_sd	LINE REACTOR	50 MVAR LR ON GORAKHPUR-LUCKNOW_1 (PG) CKT-2 @GORAKHPUR(PG)	POWERGRID	D	AMP WORK at Gorakhpur Substation	27-Jan-2020	08:00	27-Jan-2020	18:00		this is actually gorakhpur-Lucknow#4
338	OCC_166	cpcc3_sd	LINE REACTOR	50 MVAR LR ON GORAKHPUR-LUCKNOW_1 (PG) CKT-1 @GORAKHPUR(PG)	POWERGRID	D	AMP WORK at Gorakhpur Substation	26-Jan-2020	08:00	26-Jan-2020	18:00		this is actually gorakhpur-Lucknow#3

339	OCC_166	sldcrs_sd	LINE REACTOR	50 MVAR LR ON KOTA(PG)-MERTA(RS) (PG) CKT-1 @MERTA(RS)	POWERGRID	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	09-Jan-2020	10:00	09-Jan-2020	17:00		
340	OCC_166	cpcc1_sd	LINE REACTOR	50 MVAR LR ON BHIWADI-HISSAR (PG) CKT-1 @HISSAR(PG)	POWERGRID	D	AMP works of the Bhiwadi-1 L/R	06-Jan-2020	08:00	06-Jan-2020	18:00		
341	OCC_166	stuup_sd	LINE REACTOR	50 MVAR LR ON SRINAGAR(UK)-VISHNUPRAYAG(JP) (UP) CKT-1 @VISHNUPRAYAG(JP)	UPPTCL	C	For centrifuging of transformer oil.	24-Jan-2020	09:00	29-Jan-2020	18:00		
342	OCC_166	stuup_sd	LINE REACTOR	50 MVAR LR ON MUZAFFARNAGAR(UP)-VISHNUPRAYAG(JP) (UP) CKT-1 @MUZAFFARNAGAR(UP)	UPPTCL	C	For replacement of gasket.	13-Jan-2020	09:00	22-Jan-2020	18:00		
343	OCC_166	sldcrs_sd	LINE REACTOR	50 MVAR LR ON 400 KV BHADLA-MERTA (RS) CKT-1 @BHADLA(RS)	RRVPNL	D	Quarterly Maintenance work	16-Jan-2020	10:00	16-Jan-2020	17:00		
344	OCC_166	sldcrs_sd	LINE REACTOR	50 MVAR LR ON BIKANER-BHADLA (RS) CKT-2 @BHADLA(RS)	RRVPNL	D	Quarterly Maintenance work	15-Jan-2020	10:00	15-Jan-2020	17:00		
345	OCC_166	sldcrs_sd	LINE REACTOR	50 MVAR LR ON 400 KV BIKANER(PG)-BHADLA(RS) (PG) CKT-1 @BHADLA(RS)	RRVPNL	D	Quarterly Maintenance work	14-Jan-2020	10:00	14-Jan-2020	17:00		
346	OCC_166	sldcrs_sd	LINE REACTOR	50 MVAR LR ON BIKANER-MERTA (RS) CKT-1 @MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	08-Jan-2020	10:00	08-Jan-2020	17:00		
347	OCC_166	stuup_sd	BR/BSR/MSC/MSR	50 MVAR BUS REACTOR NO 1 AT 400KV PANKI(UP)	UPPTCL	C	Centrifuging of oil of 3x16.67 MVAR Bus Reactor.	21-Jan-2020	08:00	25-Jan-2020	17:00		
348	OCC_166	stuup_sd	BR/BSR/MSC/MSR	80 MVAR BUS REACTOR NO 1 AT 400KV MATHURA(UP)	UPPTCL	D	Routine Testing and Regular Maintenance /Tightening of Bay	08-Jan-2020	08:00	09-Jan-2020	19:00		
349	OCC_166	stuup_sd	BR/BSR/MSC/MSR	125 MVAR BUS REACTOR NO 1 AT 400KV SIKANDRABAD(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Tie Bay)	07-Jan-2020	09:00	07-Jan-2020	13:00		
350	OCC_166	sldcrs_sd	BR/BSR/MSC/MSR	125 MVAR BUS REACTOR NO 1 AT 400KV MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	20-Jan-2020	10:00	20-Jan-2020	17:00		
351	OCC_166	sldcrs_sd	BR/BSR/MSC/MSR	50 MVAR BUS REACTOR NO 1 AT 400KV BIKANER(RS)	RRVPNL	D	Routine Bay Maintenance Work	10-Jan-2020	10:00	10-Jan-2020	17:00		
352	OCC_166	sldcrs_sd	BR/BSR/MSC/MSR	80 MVAR BUS REACTOR NO 1 AT 400KV CHITTORGARH(RS)	RRVPNL	D	FOR MAINTENANCE WORK	10-Jan-2020	09:00	10-Jan-2020	17:00		
353	OCC_166	sldcrs_sd	BR/BSR/MSC/MSR	125 MVAR BUS REACTOR NO 2 AT 400KV BIKANER(RS)	RRVPNL	D	Routine Bay Maintenance Work	07-Jan-2020	10:00	07-Jan-2020	17:00		
354	OCC_166	sldcrs_sd	BR/BSR/MSC/MSR	63 MVAR BUS REACTOR NO 1 AT 400 KV KAWAI SCTPS(APR)	RRVPNL,APRL	D	Bay equipment maintenance and testing work.	20-Jan-2020	09:30	20-Jan-2020	19:30	Bus Reactor 2 will be available	
355	OCC_166	stuup_sd	BR/BSR/MSC/MSR	80 MVAR BUS REACTOR NO 1 AT 400KV FATEHABAD(PG)	POWERGRID	D	For AMP of 125MVAR Bus Reactor, Testing of Bushing, IR and WRM test of unit, relay test	20-Jan-2020	08:00	20-Jan-2020	18:00		
356	OCC_166	cpcc1_sd	BR/BSR/MSC/MSR	80 MVAR BUS REACTOR NO 1 AT 400KV SIKAR(PG)	POWERGRID	D	AMP tesing of 80 MVAR, 400 kV Bus Reactor at 400 KV Sikar S/s	15-Jan-2020	08:00	15-Jan-2020	18:00		
357	OCC_166	cpcc1_sd	BR/BSR/MSC/MSR	125 MVAR BUS REACTOR NO 2 AT 400KV JAIPUR SOUTH(PG)	POWERGRID	D	FOR AMP WORK	03-Jan-2020	08:00	03-Jan-2020	18:00		

358	OCC_166	sldcuk_sd	BR/BSR/MSR/MSR	80 MVAR BUS REACTOR NO 1 AT 400 KV SRINAGAR(UK)	PTCUL	D	For Maintenance of Buses & Bays	09-Jan-2020	10:00	09-Jan-2020	16:00		
359	OCC_166	sterlite_sd	BR/BSR/MSR/MSR	63 MVAR BUS REACTOR NO 1 AT 400 KV AMARGARH(NRSS XXIX)	NRSS XXIX	C	Bay 415 CB replacement	06-Jan-2020	08:00	09-Jan-2020	18:00		
360	OCC_166	sterlite_sd	BR/BSR/MSR/MSR	63 MVAR BUS REACTOR NO 2 AT 400 KV AMARGARH(NRSS XXIX)	STPL	C	Bay 415 CB replacement	06-Jan-2020	08:00	09-Jan-2020	18:00		
361	OCC_166	bbmb_sd	BAY	404 MAIN BAY - 400 KV DADRI(NT)- PANIPAT(BB) (PG) CKT-1 AT PANIPAT(BB)	POWERGRI D	D	yearly mtc	30-Jan-2020	08:00	30-Jan-2020	18:00		
362	OCC_166	bbmb_sd	BAY	408 MAIN BAY - 400 KV DADRI(NT)- PANIPAT(BB) (PG) CKT-2 AT PANIPAT(BB)	POWERGRI D	D	Yearly Maintenance	28-Jan-2020	08:00	28-Jan-2020	18:00		
363	OCC_166	cpcc2_sd	BAY	406 MAIN BAY - 400/220KV 315 MVA ICT 1 AT PATIALA(PG)	POWERGRI D	C	For overhauling of 400 KV BHEL make Circuit Breakers which are ten years old.	27-Jan-2020	09:00	31-Jan-2020	17:00		
364	OCC_166	cpcc1_sd	BAY	493 MAIN BAY - 400 KV HAPUR- MURADNAGAR_1 (UP) CKT-1	POWERGRI D	C	Shutdown for 400 KV ABB CB Overhauling	25-Jan-2020	08:00	02-Feb-2020	18:00		
365	OCC_166	cpcc2_sd	BAY	405 TIE BAY - 400KV NALLAGARH- PATIALA (PG) CKT-1 AND 400/220KV 315 MVA ICT 1 AT PATIALA(PG)	POWERGRI D	C	For overhauling of 400 KV BHEL make Circuit Breakers which are ten years old.	20-Jan-2020	09:00	24-Jan-2020	17:00		
366	OCC_166	cpcc3_sd	BAY	401 MAIN BAY - 400KV ALLAHABAD- KANPUR (PG) CKT-1 AT KANPUR(PG)	POWERGRI D	C	For Iso 40189 replacement work under CERC Add Cap at Kanpur S/S	20-Jan-2020	08:00	28-Jan-2020	18:00		
367	OCC_166	cpcc3_sd	BAY	404 MAIN BAY - 400KV FATEHPUR- KANPUR (PG) CKT-2 AT KANPUR(PG)	POWERGRI D	C	For Iso 40489 replacement work under CERC Add Cap at Kanpur S/S	20-Jan-2020	08:00	28-Jan-2020	18:00		
368	OCC_166	cpcc1_sd	BAY	406 MAIN BAY - 400 KV AGRA-BASSI (PG) CKT-1 AT BASSI(PG)	POWERGRI D	C	RK-make Isolator (406-89) Replacement work with S&S Make-Isolator, material has been supplied.	20-Jan-2020	08:00	25-Jan-2020	18:00		
369	OCC_166	bbmb_sd	BAY	403 TIE BAY - 400/220 KV 450 MVA ICT 2 AT PANIPAT(BB) AND 400 KV DADRI(NT)-PANIPAT(BB) (PG) CKT-1	POWERGRI D	D	Yearly Maintenance	17-Jan-2020	08:00	17-Jan-2020	18:00		
370	OCC_166	bbmb_sd	BAY	402 MAIN BAY - 400/220 KV 450 MVA ICT 2 AT PANIPAT(BB)	POWERGRI D	D	Yearly Maintenance	16-Jan-2020	08:00	16-Jan-2020	18:00		
371	OCC_166	sterlite_sd	BAY	401 MAIN BAY - 400KV AMARGARH(NRSS XXIX)-SAMBA(PG) (UNDEF) CKT-1 AT AMARGARH(NRSS XXIX)	POWERGRI D	D	RPH3 commisioning activities	15-Jan-2020	08:00	15-Jan-2020	18:00		
372	OCC_166	cpcc1_sd	BAY	407 MAIN BAY - 400KV MANDOLA(PG)-BAWANA(DV) (DV) CKT-2 AT MANDOLA(PG)	POWERGRI D	C	BHEL CB Overhauling	15-Jan-2020	08:00	23-Jan-2020	18:00		
373	OCC_166	cpcc2_sd	BAY	402 TIE BAY - 400KV PATIALA(PG)- PATRAN(PATR) (PG) CKT-1 AND 400KV MALERKOTLA-PATIALA (PG) CKT-1 AT PATIALA(PG)	POWERGRI D	C	For overhauling of 400 KV BHEL make Circuit Breakers which are ten years old.	14-Jan-2020	09:00	18-Jan-2020	17:00		

374	OCC_166	sterlite_sd	BAY	404 MAIN BAY - 400KV AMARGARH(NRSS XXIX)-SAMBA(PG) (UNDEF) CKT-2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	RPH3 commisioning activities	14-Jan-2020	08:00	14-Jan-2020	18:00		
375	OCC_166	sterlite_sd	BAY	402 TIE BAY - 400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1 AND 400/220 KV 315 MVA ICT 1 AT AMARGARH(NRSS XXIX)	POWERGRID	D	RPH3 commisioning activities	13-Jan-2020	08:00	13-Jan-2020	18:00		
376	OCC_166	cpcc1_sd	BAY	405 TIE BAY - 400 KV BASSI-BHIWADI (PG) CKT-2 AND 400 KV AGRA-BASSI (PG) CKT-1 AT BASSI(PG)	POWERGRID	C	RK-make Isolator (405-89B) Replacement work with S&S Make-Isolator, material has been supplied.	13-Jan-2020	08:00	18-Jan-2020	18:00		
377	OCC_166	sterlite_sd	BAY	403 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT AMARGARH(NRSS XXIX) AND 400KV BUS 2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	RPH3 commisioning activities	12-Jan-2020	08:00	12-Jan-2020	18:00		
378	OCC_166	sterlite_sd	BAY	405 TIE BAY - 400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2 AND 400/220 KV 315 MVA ICT 2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	RPH3 commisioning activities	11-Jan-2020	08:00	11-Jan-2020	18:00		
379	OCC_166	sterlite_sd	BAY	406 MAIN BAY - 400/220 KV 315 MVA ICT 2 AT AMARGARH(NRSS XXIX) AND 400KV BUS 2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	RPH3 commisioning activities	10-Jan-2020	08:00	10-Jan-2020	18:00		
380	OCC_166	cpcc2_sd	BAY	401 MAIN BAY - 400KV PATIALA(PG)-PATRAN(PATR) (PG) CKT-1 AT PATIALA(PG)	POWERGRID	C	For overhauling of 400 KV BHEL make Circuit Breakers which are ten years old.	08-Jan-2020	09:00	13-Jan-2020	17:00		
381	OCC_166	cpcc1_sd	BAY	406 MAIN BAY - 400KV MANDOLA(PG)-BAWANA(DV) (DV) CKT-1 AT MANDOLA(PG)	POWERGRID	C	BHEL CB Overhauling	06-Jan-2020	08:00	14-Jan-2020	18:00		
382	OCC_166	cpcc1_sd	BAY	405 TIE BAY - 400 KV BASSI-BHIWADI (PG) CKT-2 AND 400 KV AGRA-BASSI (PG) CKT-1 AT BASSI(PG)	POWERGRID	C	RK-make Isolator (405-89A) Replacement work with S&S Make-Isolator, material has been supplied.	06-Jan-2020	08:00	11-Jan-2020	18:00		
383	OCC_166	sterlite_sd	BAY	406 MAIN BAY - 400/220 KV 315 MVA ICT 2 AT AMARGARH(NRSS XXIX) AND 400KV BUS 2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	04-Jan-2020	12:00	04-Jan-2020	14:00		
384	OCC_166	sterlite_sd	BAY	403 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT AMARGARH(NRSS XXIX) AND 400KV BUS 2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	04-Jan-2020	09:00	04-Jan-2020	11:00		
385	OCC_166	cpcc3_sd	BAY	W5BS1 BUS SECTIONALIZER BAY - 400KV AGRA(PG) - BUS 7 AND 400KV AGRA(PG) - BUS 3 AT AGRA(PG)	POWERGRID	D	AMP of CBs (WCB Bus-1B Sectioniser) and CTs at Agra Substation	02-Jan-2020	08:00	02-Jan-2020	18:00	WCB Bus-1B Sectioniser(It sectionalises Bus 1A- and 1B)	

386	OCC_166	cpcc3_sd	BAY	W6BS2 BUS SECTIONALIZER BAY - 400KV AGRA(PG) - BUS 4 AND 400KV AGRA(PG) - BUS 8 AT AGRA(PG)	POWERGRID	D	AMP of CBs (WCB Bus-2B Sectioniser) and CTs at Agra Substation	01-Jan-2020	08:00	01-Jan-2020	18:00	WCB Bus-1B Sectioniser(It sectionalises Bus 2A- and 2B)
387	OCC_166	sterlite_sd	BAY	412 MAIN BAY - 400KV AMARGARH(NRSS XXIX)- WAGOORA(PG) (PG) CKT-2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	28-Dec-2019	12:00	28-Dec-2019	14:00	
388	OCC_166	sterlite_sd	BAY	411 TIE BAY - 400KV URI_1(NH)- AMARGARH(NRSS XXIX) (PG) CKT-1 AND 400KV AMARGARH(NRSS XXIX)- WAGOORA(PG) (PG) CKT-2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	28-Dec-2019	09:00	28-Dec-2019	11:00	
389	OCC_166	cpcc1_sd	BAY	404 MAIN BAY - 400KV MANDOLA(PG)-BAWANA(DV) (DV) CKT-1 AT MANDOLA(PG)	POWERGRID	C	BHEL CB Overhauling	28-Dec-2019	08:00	05-Jan-2020	18:00	
390	OCC_166	sterlite_sd	BAY	410 MAIN BAY - 400KV URI_1(NH)- AMARGARH(NRSS XXIX) (PG) CKT-1 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	27-Dec-2019	12:00	27-Dec-2019	14:00	
391	OCC_166	cpcc2_sd	BAY	412 MAIN BAY - 400/220KV 315 MVA ICT 2 AT LUDHIANA(PG)	POWERGRID	C	For Drive Mechanism Overhauling.	27-Dec-2019	09:00	29-Dec-2019	18:00	
392	OCC_166	sterlite_sd	BAY	409 MAIN BAY - 400KV AMARGARH(NRSS XXIX)- WAGOORA(PG) (PG) CKT-1 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	27-Dec-2019	09:00	27-Dec-2019	11:00	
393	OCC_166	sterlite_sd	BAY	408 TIE BAY - 400KV URI_1(NH)- AMARGARH(NRSS XXIX) (PG) CKT-2 AND 400KV AMARGARH(NRSS XXIX)- WAGOORA(PG) (PG) CKT-1 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	26-Dec-2019	12:00	26-Dec-2019	14:00	
394	OCC_166	sterlite_sd	BAY	407 MAIN BAY - 400KV URI_1(NH)- AMARGARH(NRSS XXIX) (PG) CKT-2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	26-Dec-2019	09:00	26-Dec-2019	11:00	
395	OCC_166	sterlite_sd	BAY	405 TIE BAY - 400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2 AND 400/220 KV 315 MVA ICT 2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	25-Dec-2019	12:00	25-Dec-2019	14:00	
396	OCC_166	sterlite_sd	BAY	404 MAIN BAY - 400KV AMARGARH(NRSS XXIX)-SAMBA(PG) (UNDEF) CKT-2 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	25-Dec-2019	09:00	25-Dec-2019	11:00	

397	OCC_166	sterlite_sd	BAY	402 TIE BAY - 400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1 AND 400/220 KV 315 MVA ICT 1 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	24-Dec-2019	12:00	24-Dec-2019	14:00		
398	OCC_166	sterlite_sd	BAY	401 MAIN BAY - 400KV AMARGARH(NRSS XXIX)-SAMBA(PG) (UNDEF) CKT-1 AT AMARGARH(NRSS XXIX)	POWERGRID	D	For Signal testing from Remote Control Centre	24-Dec-2019	09:00	24-Dec-2019	11:00		
399	OCC_166	cpcc2_sd	BAY	411 TIE BAY - 400KV LUDHIANA-MALERKOTLA (PG) CKT-1 AND 400/220KV 315 MVA ICT 2 AT LUDHIANA(PG)	POWERGRID	C	For Drive Mechanism Overhauling.	24-Dec-2019	09:00	26-Dec-2019	18:00		
400	OCC_166	stuup_sd	BAY	407 BUS COUPLER BAY - 400KV BUS 1 AT MAU(UP) AND 400KV BUS 2 AT MAU(UP)	UPPTCL	C	Replacement of old CTs (R,Y,B phase) of Bus coupler bay	29-Jan-2020	10:00	31-Jan-2020	18:00		
401	OCC_166	stuup_sd	BAY	401 MAIN BAY - 400KV UNNAO-PANKI (UP) CKT-1 AT PANKI(UP)	UPPTCL	C	Replacement of 400 KV Line Isolator.	21-Jan-2020	08:00	25-Jan-2020	17:00		
402	OCC_166	stuup_sd	BAY	401 MAIN BAY - 400/220KV 500 MVA ICT 1 AT SIKANDRABAD(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Tie Bay)	13-Jan-2020	09:00	13-Jan-2020	13:00		
403	OCC_166	stuup_sd	BAY	405 TIE BAY - 400KV RISHIKESH(UK)-NEHTAUR(UP) (UK) CKT-1 AND 125 MVAR BUS REACTOR NO 1 AT 400KV NEHTAUR(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Main Bay)	13-Jan-2020	09:00	13-Jan-2020	13:00		
404	OCC_166	stuup_sd	BAY	402 TIE BAY - 400/220KV 500 MVA ICT 1 AT SIKANDRABAD(UP) AND 400KV ALIGARH-SIKANDRABAD (UP) CKT-2	UPPTCL	D	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Main Bay)	10-Jan-2020	14:00	10-Jan-2020	18:00		
405	OCC_166	stuup_sd	BAY	403 MAIN BAY - 400KV ALIGARH-SIKANDRABAD (UP) CKT-2 AT SIKANDRABAD(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Tie Bay)	10-Jan-2020	09:00	10-Jan-2020	13:00		
406	OCC_166	cpcc3_sd	BAY	409 MAIN BAY - 400KV KANPUR(PG)-PANKI(UP) (PG) CKT-2 AT PANKI(UP)	UPPTCL	C	For Line Isolator replacement work under CERC add Cap at Panki end	10-Jan-2020	08:00	18-Jan-2020	18:00		
407	OCC_166	stuup_sd	BAY	404 MAIN BAY - 125 MVAR BUS REACTOR NO 1 AT 400KV SIKANDRABAD(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Tie Bay)	07-Jan-2020	14:00	07-Jan-2020	18:00		
408	OCC_166	stuup_sd	BAY	405 TIE BAY - 125 MVAR BUS REACTOR NO 1 AT 400KV SIKANDRABAD(UP) AND 400KV ALIGARH-SIKANDRABAD (UP) CKT-1	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Main Bay)	07-Jan-2020	09:00	07-Jan-2020	13:00		
409	OCC_166	stuup_sd	BAY	406 MAIN BAY - 400KV ALIGARH-SIKANDRABAD (UP) CKT-1 AT SIKANDRABAD(UP)	UPPTCL	C	For Annual Maintenance work , There will be no interruption on loads and element will be charge through Tie Bay)	06-Jan-2020	14:00	06-Jan-2020	18:00		

410	OCC_166	sldcrs_sd	BAY	411 TIE BAY - 400KV ANTA(RS)-CHHABRA(RVUN) (RS) CKT-1 AND 765/400KV 1500 MVA ICT 1 AT ANTA(RS)	RRVPNL	D	FOR 1st Quarter maintenance	29-Jan-2020	09:00	29-Jan-2020	18:00		
411	OCC_166	sldcrs_sd	BAY	405 TIE BAY - 400KV ANTA-KALISINDH (RS) CKT-1 AND FUTURE AT ANTA(RS)	RRVPNL	D	FOR 1st Quarter maintenance	28-Jan-2020	09:00	28-Jan-2020	18:00		
412	OCC_166	sldcrs_sd	BAY	408 TIE BAY - 400KV ANTA-KALISINDH (RS) CKT-2 AND FUTURE AT ANTA(RS)	RRVPNL	D	FOR 1st Quarter maintenance	23-Jan-2020	09:00	23-Jan-2020	18:00		
413	OCC_166	sldcrs_sd	BAY	411-52 D MAIN BAY - 400KV BUS 2 AT ANTA(RS) AND FUTURE AT 400 KV ANTA(RS)	RRVPNL	D	QUARTERLY MAINTENANCE	22-Jan-2020	09:00	22-Jan-2020	18:00		
414	OCC_166	sldcrs_sd	BAY	411-52T TIE BAY - 765/400 KV 1500 MVA ICT 3 AT ANTA(RS) AND FUTURE AT 400 KV ANTA(RS)	RRVPNL	D	QUARTERLY MAINTENANCE	22-Jan-2020	09:00	22-Jan-2020	18:00		
415	OCC_166	sldcrs_sd	BAY	418 MAIN BAY - 400KV ANTA(RS)-KAWAI SCTPS(APR) (RS) CKT-2 AT ANTA(RS)	RRVPNL	D	FOR 1st Quarter maintenance	21-Jan-2020	09:00	21-Jan-2020	18:00		
416	OCC_166	sldcrs_sd	BAY	405 TIE BAY - 400KV AJMER(RS)-DEEDWANA(MTS) (MTS) CKT-1 AND 400KV AJMER-BHILWARA (RS) CKT-2 AT AJMER(RS)	RRVPNL	D	HALF YEARLY MAINTENANCE WORK	20-Jan-2020	10:00	20-Jan-2020	15:00		
417	OCC_166	sldcrs_sd	BAY	402 TIE BAY - 400KV AJMER-BHILWARA (RS) CKT-1 AND FUTURE AT AJMER(RS)	RRVPNL	D	HALF YEARLY MAINTENANCE WORK	16-Jan-2020	10:00	16-Jan-2020	15:00		
418	OCC_166	sldcrs_sd	BAY	415 MAIN BAY - 400KV ANTA(RS)-KAWAI SCTPS(APR) (RS) CKT-1 AT ANTA(RS)	RRVPNL	D	FOR 1st Quarter maintenance	16-Jan-2020	09:00	16-Jan-2020	18:00		
419	OCC_166	sldcrs_sd	BAY	412 MAIN BAY - 400KV ANTA(RS)-CHHABRA(RVUN) (RS) CKT-1 AT ANTA(RS)	RRVPNL	D	FOR 1st Quarter maintenance	09-Jan-2020	09:00	09-Jan-2020	18:00		
420	OCC_166	sldcrs_sd	BAY	406 MAIN BAY - 400KV ANTA-KALISINDH (RS) CKT-1 AT ANTA(RS)	RRVPNL	D	FOR 1st Quarter maintenance	08-Jan-2020	09:00	08-Jan-2020	18:00		
421	OCC_166	sldcrs_sd	BAY	409 MAIN BAY - 400KV ANTA-KALISINDH (RS) CKT-2 AT ANTA(RS)	RRVPNL	D	FOR 1st Quarter maintenance	07-Jan-2020	09:00	07-Jan-2020	18:00		
422	OCC_166	bbmb_sd	BAY	407 TIE BAY - 400KV PANCHKULA(PG)-PANIPAT(BB) (BB) CKT-1 AND 400KV DADRI(NT)-PANIPAT(BB) (PG) CKT-2 AT PANIPAT(BB)	BBMB	D	Yearly mtc.	24-Jan-2020	08:00	24-Jan-2020	18:00		

423	OCC_166	bbmb_sd	BAY	406 MAIN BAY - 400/220 KV 450 MVA ICT 1 AT PANIPAT(BB) AND 400KV BUS 1 AT PANIPAT(BB) AT 400 KV PANIPAT(BB)	BBMB	D	Yearly mtc.	23-Jan-2020	08:00	23-Jan-2020	18:00		
424	OCC_166	bbmb_sd	BAY	405 MAIN BAY - 400/220KV 450 MVA ICT 1 AT PANIPAT(BB)	BBMB	D	Yearly Maintenance	21-Jan-2020	08:00	21-Jan-2020	18:00		
425	OCC_166	sldcrs_sd	BAY	402 TIE BAY - 400 KV ANTA(RS)-KAWAI SCTPS(APR) (RS) CKT-1 AND 63 MVAR BUS REACTOR NO 1 AT 400 KV KAWAI SCTPS(APR) AT 400 KV KAWAI SCTPS(APR)	APRL	D	Bay equipment maintenance and testing work. Bay equipment maintenance and testing work. Bay equipment maintenance and testing work. Bay equipment maintenance and testing work.	20-Jan-2020	09:30	20-Jan-2020	19:30		
426	OCC_166	sldcdv_sd	BAY	418 MAIN BAY - 400 KV BAWANA-MUNDKA (DV) CKT-1 AND 400KV BUS 2 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	18-Jan-2020	14:00	18-Jan-2020	17:00		
427	OCC_166	sldcdv_sd	BAY	417 MAIN BAY - 400 KV BAWANA-MUNDKA (DV) CKT-1 AND 400KV BUS 1 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	18-Jan-2020	10:00	18-Jan-2020	13:00		
428	OCC_166	sldcdv_sd	BAY	420 MAIN BAY - 400 KV BAWANA-MUNDKA (DV) CKT-2 AND 400KV BUS 2 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	17-Jan-2020	14:00	17-Jan-2020	17:00		
429	OCC_166	sldcdv_sd	BAY	419 MAIN BAY - 400 KV BAWANA-MUNDKA (DV) CKT-2 AND 400KV BUS 1 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	17-Jan-2020	10:00	17-Jan-2020	13:00		
430	OCC_166	sldcdv_sd	BAY	416 MAIN BAY - 400/220 KV 315 MVA ICT 4 AT MUNDKA(DV) AND 400KV BUS 2 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	16-Jan-2020	14:00	16-Jan-2020	17:00		
431	OCC_166	sldcdv_sd	BAY	415 TIE BAY - 400 KV JHAJJAR(APCL)-MUNDKA(DV) (APCL) CKT-1 AND 400/220 KV 315 MVA ICT 4 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	16-Jan-2020	10:00	16-Jan-2020	13:00		
432	OCC_166	sldcdv_sd	BAY	413 MAIN BAY - 400/220 KV 315 MVA ICT 3 AT MUNDKA(DV) AND 400KV BUS 2 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	15-Jan-2020	14:00	15-Jan-2020	17:00		
433	OCC_166	sldcdv_sd	BAY	412 TIE BAY - 400 KV JHAJJAR(APCL)-MUNDKA(DV) (APCL) CKT-2 AND 400/220 KV 315 MVA ICT 3 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	15-Jan-2020	10:00	15-Jan-2020	13:00		

434	OCC_166	sldcdv_sd	BAY	414 MAIN BAY - 400 KV JHAJJAR(APCL)-MUNDKA(DV) (APCL) CKT-1 AND 400KV BUS 1 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	14-Jan-2020	14:00	14-Jan-2020	17:00		
435	OCC_166	sldcdv_sd	BAY	411 MAIN BAY - 400 KV JHAJJAR(APCL)-MUNDKA(DV) (APCL) CKT-2 AND 400KV BUS 1 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	14-Jan-2020	10:00	14-Jan-2020	13:00		
436	OCC_166	sldcdv_sd	BAY	404 MAIN BAY - 400 KV JHATIKARA(PG)-MUNDKA(DV) (DV) CKT-2 AND 400KV BUS 2 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	13-Jan-2020	14:00	13-Jan-2020	17:00		
437	OCC_166	sldcdv_sd	BAY	403 MAIN BAY - 400 KV JHATIKARA(PG)-MUNDKA(DV) (DV) CKT-2 AND 400KV BUS 1 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	13-Jan-2020	10:00	13-Jan-2020	13:00		
438	OCC_166	sldcdv_sd	BAY	402 MAIN BAY - 400 KV JHATIKARA(PG)-MUNDKA(DV) (DV) CKT-1 AND 400KV BUS 2 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	11-Jan-2020	14:00	11-Jan-2020	17:00		
439	OCC_166	sldcdv_sd	BAY	401 MAIN BAY - 400 KV JHATIKARA(PG)-MUNDKA(DV) (DV) CKT-1 AND 400KV BUS 1 AT MUNDKA(DV)	DTL	D	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	11-Jan-2020	10:00	11-Jan-2020	13:00		
440	OCC_166	sldcdv_sd	BAY	425 TIE BAY - 400 KV MANDOLA(PG)- BAWANA(DV) (DV) CKT-2 AND 400KV BUS 2 AT BAWANA(DV)	DTL	D	General Maintenace of the bay equipments and CB testing as per maintenance Mannual	09-Jan-2020	10:30	09-Jan-2020	16:00	Load of the line will be run through CB(Bus-1)	
441	OCC_166	sldcdv_sd	BAY	424 MAIN BAY - 400KV MANDOLA(PG)-BAWANA(DV) (DV) CKT-2 AT BAWANA(DV)	DTL	D	General Maintenace of the bay equipments and CB testing as per maintenance Mannual	08-Jan-2020	10:30	08-Jan-2020	16:00	Load of the line will be run through CB(CB Bus-2)	
442	OCC_166	sldcdv_sd	BAY	422 MAIN BAY - 400 KV MANDOLA(PG)-BAWANA(DV) (DV) CKT-1 AND 400KV BUS 2 AT BAWANA(DV)	DTL	D	General Maintenace of the bay equipments and CB testing as per maintenance Mannual	07-Jan-2020	10:30	07-Jan-2020	16:00	Load of the line will be run through CB(Bus-1)	
443	OCC_166	sldcdv_sd	BAY	421 MAIN BAY - 400KV MANDOLA(PG)-BAWANA(DV) (DV) CKT-1 AT BAWANA(DV)	DTL	D	General Maintenace of the bay equipments and CB testing as per maintenance Mannual	06-Jan-2020	10:30	06-Jan-2020	16:00	Load of the line will be run through CB(Bus-2)	
444	OCC_166	sldcrs_sd	BAY	414 TIE BAY - 400KV CHHABRA(RVUN)-KAWAI SCTPS(APR) (RS) CKT-1 AND FUTURE AT KAWAI SCTPS(APR)	APL	D	Bay equipment maintenance and testing work. Bay equipment maintenance and testing work. Bay equipment maintenance and testing work. Bay equipment maintenance and testing work.	13-Jan-2020	09:30	13-Jan-2020	19:30		

445	OCC_166	sldcrs_sd	BAY	413 MAIN BAY - 400KV CHHABRA(RVUN)-KAWAI SCTPS(APR) (RS) CKT-1 AT KAWAI SCTPS(APR)	APL	D	Bay equipment maintenance and testing work. Bay equipment maintenance and testing work. Bay equipment maintenance and testing work. Bay equipment maintenance and testing work.	06-Jan-2020	09:30	06-Jan-2020	19:30		
446	OCC_166	singrauli_sd	BAY	413 BUS SECTIONALIZER BAY - 400KV BUS 1 AT SINGRAULI(NT) AND 400KV BUS 3 AT SINGRAULI(NT) AT 400 KV SINGRAULI(NT)	NTPC	C	for replacement of CTMB and routine PM	09-Jan-2020	08:00	11-Jan-2020	18:00		
447	OCC_166	singrauli_sd	BAY	424-BS BUS SECTIONALIZER BAY - 400KV BUS 2 AT SINGRAULI(NT) AND 400KV BUS 4 AT SINGRAULI(NT) AT 400 KV SINGRAULI(NT)	NTPC	C	for replacement of CTMB and routine PM	06-Jan-2020	08:00	08-Jan-2020	18:00		
448	OCC_166	singrauli_sd	BAY	418 BUS COUPLER BAY - 400KV BUS 1 AT SINGRAULI(NT) AND 400KV BUS 3 AT SINGRAULI(NT)	NTPC	D	For Routine Bay PM	30-Dec-2019	08:00	30-Dec-2019	18:00		
449	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NALLAGARH(PG)- MOHALI(PS) (PS) CKT-2	PSTCL	D	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 31 to 40	30-Jan-2020	08:00	30-Jan-2020	18:00		
450	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PATIALA(PG)-ABLOWAL(PS) (PSTCL) CKT-2	PSTCL	D	Disc cleaning, cheacking & Tightening jumpers nut bolts and routine electrical maintenance	30-Jan-2020	08:00	31-Jan-2020	18:00		
451	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NALLAGARH(PG)- MOHALI(PS) (PS) CKT-1	PSTCL	D	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 31 to 40	28-Jan-2020	08:00	28-Jan-2020	18:00		
452	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(BB)- ALAWALPUR(PS) (PSTCL) CKT-1	PSTCL	D	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	28-Jan-2020	08:00	28-Jan-2020	18:00		
453	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PATIALA(PG)-ABLOWAL(PS) (PSTCL) CKT-1	PSTCL	D	Disc cleaning, cheacking & Tightening jumpers nut bolts and routine electrical maintenance	27-Jan-2020	08:00	28-Jan-2020	18:00		
454	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL(BB)- MOHALI(PS) (PSTCL) CKT-2	PSTCL	D	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 21 to 30	25-Jan-2020	08:00	25-Jan-2020	18:00		
455	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV LUDHIANA(PG)- SAHNEWAL(PS) (PSTCL) CKT-1	PSTCL	D	Schedule Maint. Like Tree cutting, tightening of nuts and bolts etc.	21-Jan-2020	08:00	22-Jan-2020	18:00		
456	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV LUDHIANA(PG)-DORAHA(PS) (PSTCL) CKT-1	PSTCL	D	Schedule Maint. Like Tree cutting, tightening of nuts and bolts etc.	20-Jan-2020	08:00	20-Jan-2020	18:00		
457	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AMRITSAR(PG)-KHASA(PS) (PSTCL) CKT-1	PSTCL	D	Tree Cutting and ground maintenance	20-Jan-2020	08:00	20-Jan-2020	18:00		

458	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MOGA(PG)-BADNI KALAN(PS) (PSTCL) CKT-1	PSTCL	D	General Maintenance	17-Jan-2020	08:00	17-Jan-2020	18:00		
459	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV LUDHIANA(PG)-DORAHA(PS) (PSTCL) CKT-1	PSTCL	D	Schedule Maint. Like Tree cutting, tightening of nuts and bolts etc.	16-Jan-2020	08:00	17-Jan-2020	18:00		
460	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL(BB)-MAJRA(PS) (PS) CKT-1	PSTCL	D	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 11 to 20	16-Jan-2020	08:00	16-Jan-2020	18:00		
461	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL(BB)- MOHALI(PS) (PSTCL) CKT-2	PSTCL	D	General Maintenance	13-Jan-2020	08:00	13-Jan-2020	18:00		
462	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(PG)-KANJAL(PS) (PSTCL) CKT-2	PSTCL	D	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	13-Jan-2020	08:00	13-Jan-2020	18:00		
463	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(PG)-KANJAL(PS) (PSTCL) CKT-1	PSTCL	D	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	10-Jan-2020	08:00	10-Jan-2020	18:00		
464	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(BB)- ALAWALPUR(PS) (PSTCL) CKT-1	PSTCL	D	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	08-Jan-2020	08:00	08-Jan-2020	18:00		
465	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MOGA(PG)-MOGAN(PS) (PSTCL) CKT-3	PSTCL	D	General Maintenance	08-Jan-2020	08:00	08-Jan-2020	18:00		
466	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MOGA(PG)-MOGAN(PS) (PSTCL) CKT-1	PSTCL	D	General Maintenance	07-Jan-2020	08:00	07-Jan-2020	18:00		
467	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PATIALA(PG)-NABHA(PS) (PSTCL) CKT-2	PSTCL	D	Cleaning of breaker mechanism, insulator terminals, lubrication of moving parts of breaker.	06-Jan-2020	08:00	06-Jan-2020	18:00		
468	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NALLAGARH(PG)- MOHALI(PS) (PS) CKT-2	PSTCL	D	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 31 to 40	06-Jan-2020	08:00	06-Jan-2020	18:00		
469	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PATIALA(PG)-RAJPURA(PS) (PSTCL) CKT-1	PSTCL	D	Disc cleaning, cheacking & Tightening jumpers nut bolts and routine electrical maintenance	03-Jan-2020	08:00	04-Jan-2020	18:00		
470	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PAKHOWAL(PS)- LUDHIANA(PG) (PSTCL) CKT-1	PSTCL	D	Schedule Maint. Like Tree cutting, tightening of nuts and bolts etc.	02-Jan-2020	08:00	02-Jan-2020	18:00		
471	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PATIALA(PG)-NABHA(PS) (PSTCL) CKT-1	PSTCL	D	Cleaning of breaker mechanism, insulator terminals, lubrication of moving parts of breaker.	02-Jan-2020	08:00	02-Jan-2020	18:00		
472	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NALLAGARH(PG)- MOHALI(PS) (PS) CKT-1	PSTCL	D	Tightening of nut bolts of jumpers, dampers , suspension clamps and cleaning of Disc insulators of Tower No 31 to 40	02-Jan-2020	08:00	02-Jan-2020	18:00		
473	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAHADURGARH(PS)- PATIALA(PG) (PSTCL) CKT-1	PSTCL	D	Disc cleaning, cheacking & Tightening jumpers nut bolts and routine electrical maintenance	01-Jan-2020	08:00	01-Jan-2020	18:00		

474	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL-JAMALPUR (BB) CKT-1	BBMB	D	Schedule Maint. Like Tree cutting, tightening of nuts and bolts etc.	29-Jan-2020	08:00	31-Jan-2020	18:00		
475	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BALLABHGARH-CHARKHI DADRI (BB) CKT-1	BBMB	C	For completion of work of T.No 541-542 by NHAI	25-Jan-2020	08:00	31-Jan-2020	18:00		
476	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI-SAMAYPUR (BB) CKT-1	BBMB	C	For completion of work of T.No 541-542 by NHAI	25-Jan-2020	08:00	31-Jan-2020	18:00		
477	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BALLABHGARH-SAMAYPUR (BB) CKT-3	BBMB	D	Repair of earth wire	23-Jan-2020	08:00	24-Jan-2020	18:00		
478	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT-KURUKSHETRA (BB) CKT-1	BBMB	D	Yearly Maintenance	22-Jan-2020	08:00	22-Jan-2020	18:00		
479	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PONG(BB)-DASUYA(PS) (BBMB) CKT-1	BBMB	D	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	22-Jan-2020	08:00	22-Jan-2020	18:00		
480	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR-SANGRUR (BB) CKT-2	BBMB	D	Half Yearly Maintenance	20-Jan-2020	08:00	20-Jan-2020	18:00		
481	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT-DHULKOTE (BB) CKT-1	BBMB	D	Mtc of line during foggy session	20-Jan-2020	08:00	20-Jan-2020	18:00		
482	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT-DHULKOTE (BB) CKT-2	BBMB	D	Yearly Maintenance	18-Jan-2020	08:00	18-Jan-2020	18:00	Yearly mtc	
483	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR-SANGRUR (BB) CKT-2	BBMB	D	Half yearly mtc	18-Jan-2020	08:00	18-Jan-2020	18:00		
484	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(BB)-CHIRAWA(RS) (BB) CKT-1	BBMB	D	For routine maintenance of 220 KV chirawa-Hissar line	17-Jan-2020	08:00	17-Jan-2020	19:00		
485	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR-PONG (BB) CKT-2	BBMB	D	Yearly mtc. .	17-Jan-2020	08:00	17-Jan-2020	18:00		
486	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR-PONG (BB) CKT-1	BBMB	D	Yearly mtc.	16-Jan-2020	08:00	16-Jan-2020	18:00		
487	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR-SANGRUR (BB) CKT-1	BBMB	D	Half Yearly Maintenance	14-Jan-2020	08:00	15-Jan-2020	18:00		
488	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWANI-HISSAR (BB) CKT-1	BBMB	D	Aerial mtc and disc cleaning	13-Jan-2020	08:00	13-Jan-2020	18:00		
489	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWANI-HISSAR (BB) CKT-2	BBMB	D	Aerial mtc and disc cleaning	11-Jan-2020	08:00	11-Jan-2020	18:00	Aerial Mtc. & disc cleaning.	

490	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT(BB)-NARELA(DV) (BBMB) CKT-3	BBMB	D	Yearly mtc.	11-Jan-2020	08:00	11-Jan-2020	18:00		
491	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT(BB)-NARELA(DV) (BBMB) CKT-2	BBMB	D	Yearly mtc.	10-Jan-2020	08:00	10-Jan-2020	18:00		
492	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHAKRA_L-GANGUWAL (BB) CKT-2	BBMB	D	annual mtc of substation equipments	09-Jan-2020	08:00	10-Jan-2020	18:00		
493	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT(BB)-NARELA(DV) (BBMB) CKT-1	BBMB	D	Yearly mtc	09-Jan-2020	08:00	09-Jan-2020	18:00		
494	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(BB)- JAMSHER(PS) (BB) CKT-2	BBMB	D	Disc cleaning, cheacking & Tightening jumpers nut bolts and routine electrical maintenance	06-Jan-2020	08:00	06-Jan-2020	18:00		
495	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL-JAGADHARI (BB) CKT-1	BBMB	D	Yearly mtc. of the substation equipment/ lines .	06-Jan-2020	08:00	07-Jan-2020	18:00		
496	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAMALPUR(BB)- SANGRUR(PS) (BB) CKT-1	BBMB	C	Replacement of HBB Ckt. Breaker with New CGL make Ckt. Breaker at Jamalpur.	06-Jan-2020	08:00	10-Jan-2020	18:00		
497	OCC_166	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BALLABHGARH(BB)- BADARPUR(NT) (BB) CKT-2	BBMB	D	General maintenance & Painting on isolator connecting rods, circuit breaker drive boxes, junction boxes.	05-Jan-2020	09:30	05-Jan-2020	17:00	Load can be managed through BTPS-Balabgharh-I Ckt	
498	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(BB)- JAMSHER(PS) (BB) CKT-1	BBMB	D	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	03-Jan-2020	08:00	03-Jan-2020	18:00		
499	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BALLABHGARH(BB)- BADARPUR(NT) (BB) CKT-1	BBMB	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW rectification works	01-Jan-2020	08:00	31-Jan-2020	18:00		
500	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT-DHULKOTE (BB) CKT-2	BBMB	D	OPGW laying shall be started in this line under Reliable Comunication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
501	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT-DHULKOTE (BB) CKT-1	BBMB	D	OPGW laying shall be started in this line under Reliable Comunication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
502	OCC_166	rappc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_C(NP)-ANTA(NT) (PG) CKT-1	POWERGRI D	D	Preventive maintenance of circuit breaker, disconnecting switches, earth swith, current transformers (3 nos), capacitor VTs (3 nos), protection relays, metring circuits, tan delta testing of CT & CVT.	29-Jan-2020	08:00	29-Jan-2020	20:00		
503	OCC_166	rappc_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_C(NP)-RAPS_B(NP) (PG) CKT-1	POWERGRI D	D	Preventive maintenance of circuit breaker, disconnecting switches, earth swith, current transformers (3 nos), capacitor VTs (3 nos), protection relays, metring circuits, tan delta testing of CT & CVT.	28-Jan-2020	08:00	28-Jan-2020	20:00		

504	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)-SARNA(PS) (PG) CKT-2	POWERGRID	D	For AMP Work.	24-Jan-2020	08:00	24-Jan-2020	17:00		
505	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)-BHILWARA(RS) (PG) CKT-2	POWERGRID	D	Yearly Maintenance	23-Jan-2020	08:00	24-Jan-2020	17:00		
506	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)-SARNA(PS) (PG) CKT-1	POWERGRID	D	For AMP Work.	22-Jan-2020	08:00	22-Jan-2020	17:00		
507	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PITHORAGARH(PG)-BAREILLY(UP) (PG) CKT-1	POWERGRID	D	Routine testing /preventive maintenance	21-Jan-2020	09:00	21-Jan-2020	15:00		
508	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(PG)-HISSAR IA(HV) (PG) CKT-1	POWERGRID	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		
509	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(PG)-HISSAR IA(HV) (PG) CKT-2	POWERGRID	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		
510	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DHAULIGANGA(NH)-BAREILLY(UP) (PG) CKT-1	POWERGRID	D	To take the Reactor in service after Dry Out of the Reactor	20-Jan-2020	10:00	20-Jan-2020	11:00		
511	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AGRA(PG)-BHARATPUR(RS) (PG) CKT-1	POWERGRID	C	For replacement of earthwire and maintenance of line and bay at 220KV GSS RVPN, Bharatpur	20-Jan-2020	09:00	25-Jan-2020	18:00		
512	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DHAULIGANGA(NH)-BAREILLY(UP) (PG) CKT-1	POWERGRID	D	Routine testing /preventive maintenance	20-Jan-2020	09:00	20-Jan-2020	15:00		
513	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)-SALAL(NH) (PG) CKT-1	POWERGRID	D	For AMP Works with K'pur Sala-II in Non-Auto mode.	16-Jan-2020	10:00	16-Jan-2020	17:00	Non-Auto mode of K'pur-Salal-2 is required	
514	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)-BHILWARA(RS) (PG) CKT-1	POWERGRID	D	Yearly Maintenance	16-Jan-2020	08:00	17-Jan-2020	17:00		
515	OCC_166	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SARNA(PS)-DASUYA(PS) (PG) CKT-2	POWERGRID	D	Line & bay equipment AMP at PSTCL Dasua S/s	13-Jan-2020	09:00	13-Jan-2020	18:00		
516	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ALLAHABAD(PG)-ALLAHABADREWAROAD(UP) (PG) CKT-2	POWERGRID	C	For diversion work due to DFCC	12-Jan-2020	08:00	16-Jan-2020	18:00		
517	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JESSORE(HP)-PONG(BB) (PG) CKT-1	POWERGRID	D	Yearly mtc	09-Jan-2020	08:00	09-Jan-2020	18:00		

518	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SIKAR(PG)-SIKAR(RS) (PG) CKT-2	POWERGRID	D	AMP & TESTING OF Line Bay equipments at Sikar	07-Jan-2020	08:00	07-Jan-2020	18:00		
519	OCC_166	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAIRASIUL(NH)-PONG(BB) (PG) CKT-1	POWERGRID	D	Yearly mtc.	07-Jan-2020	08:00	07-Jan-2020	18:00		
520	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ALLAHABAD(PG)-ALLAHABADREWAROAD(UP) (PG) CKT-1	POWERGRID	C	For diversion work due to DFCC	06-Jan-2020	08:00	10-Jan-2020	18:00		
521	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DHAULIGANGA(NH)-BAREILLY(UP) (PG) CKT-1	POWERGRID	D	To take the 25 MVAR Line Reactor out of service for Dry Out of the reactor	05-Jan-2020	10:00	05-Jan-2020	11:00		
522	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PITHORAGARH(PG)-BAREILLY(UP) (PG) CKT-1	POWERGRID	D	Diversion work of 400kV D/C Dhauliganga-Bareilly(PG) : for Tower Erection at Tapping point	24-Dec-2019	08:00	25-Dec-2019	18:00		
523	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV UNCHAHAR(NT)-FATEHPUR(UP) (UP) CKT-2	UPPTCL	D	For AMP and Tightning work of Line Side Equipments at Fatehpur S/S	27-Jan-2020	08:00	27-Jan-2020	18:00		
524	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV UNCHAHAR(NT)-FATEHPUR(UP) (UP) CKT-1	UPPTCL	D	For AMP and Tightning work of Line Side Equipments at Fatehpur S/S	24-Jan-2020	08:00	24-Jan-2020	18:00		
525	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANTNAGAR(UK)-BAREILLY(UP) (UP) CKT-2	UPPTCL	D	Routine testing /preventive maintenance	22-Jan-2020	09:00	22-Jan-2020	15:00		
526	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SARSAWAN(UP)-KHODRI(UK) (UP) CKT-1	UPPTCL	D	For lopping chopping of trees and jumper tightening	21-Jan-2020	10:00	25-Jan-2020	17:00		
527	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AGRA(PG)-SHAMSHABAD(UP) (UP) CKT-1	UPPTCL	D	AMP of line side equipments at Agra Substation	13-Jan-2020	08:00	13-Jan-2020	18:00		
528	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MAINPURI(PG)-MAINPURI(UP) (UP) CKT-1	UPPTCL	D	Annual maintenance	08-Jan-2020	10:00	08-Jan-2020	17:00		
529	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NARA(UP)-ROORKEE(UK) (UP) CKT-1	UPPTCL	D	Replacement of damaged Polymer and Jumper tightening.	07-Jan-2020	10:00	08-Jan-2020	18:00		
530	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAHARANPUR(UP)-KHODRI(UK) (UP) CKT-1	UPPTCL	D	For lopping chopping of trees and jumper tightening	07-Jan-2020	10:00	11-Jan-2020	17:00		
531	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NAPP(NP)-ATRAULI(UP) (UP) CKT-1	UPPTCL	D	Annual Testing, maintenance and Disc cleaning	06-Jan-2020	10:00	07-Jan-2020	17:00		
532	OCC_166	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SULTANPUR(UP)-TANDA(NT) (UP) CKT-2	UPPTCL	D	For routine bay maintenance works	03-Jan-2020	10:00	03-Jan-2020	18:00		
533	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CBGANJ-MORADABAD (UP) CKT-1	UPPTCL	D	OPGW laying shall be started in this line under Reliable Comunication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		

534	OCC_166	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MAINPURI(PG)- MAINPURI(UP) (UP) CKT-1	UPPTCL	D	CVT Replacement work in R phase of line at Mainpuri PG S/S.	27-Dec-2019	08:00	27-Dec-2019	18:00		
535	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)-SAKATPURA(RS) (RS) CKT-1	RRVPNL	D	QUARTERLY Bay MAINTENANCE & testing WORK	24-Jan-2020	08:00	24-Jan-2020	17:00		
536	OCC_166	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_A(NP)-SAKATPURA(RS) (RS) CKT-1	RRVPNL	D	QUARTERLY Bay MAINTENANCE & testing WORK	23-Jan-2020	08:00	23-Jan-2020	17:00		
537	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAIPUR SOUTH(PG)- CHAKSU(RS) (RS) CKT-1	RRVPNL	D	AMP work	20-Jan-2020	08:00	20-Jan-2020	18:00	ckt 2 is not in software.kindly allow for ckt 2	
538	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAIPUR SOUTH(PG)- SEZJAIPUR(RS) (RS) CKT-1	RRVPNL	D	AMP work	16-Jan-2020	08:00	16-Jan-2020	18:00		
539	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAIPUR SOUTH(PG)- GONER(RS) (RS) CKT-1	RRVPNL	D	AMP work	10-Jan-2020	08:00	10-Jan-2020	18:00		
540	OCC_166	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BADARPUR(NT)-ALWAR MIA(RS) (RS) CKT-1	RRVPNL	D	General maintenance & Painting on isolator connecting rods, circuit breaker drive boxes, junction boxes.	08-Jan-2020	09:30	08-Jan-2020	17:00	Presently on no load.	
541	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHITTORGARH-DEBARI (RS) CKT-1	RRVPNL	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
542	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(PG)-SAGWAN(HV) (HVPNL) CKT-1	HVPNL	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		
543	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(PG)-SAGWAN(HV) (HVPNL) CKT-2	HVPNL	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		
544	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(PG)-FATEHABAD(HV) (HVPNL) CKT-1	HVPNL	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		
545	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(PG)-FATEHABAD(HV) (HVPNL) CKT-2	HVPNL	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		

546	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GURGAON(PG)-GURGAONSEC33(HV) (HVPNL) CKT-1	HVPNL	D	AMP work	15-Jan-2020	08:00	15-Jan-2020	18:00		
547	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DEHRADUN(PG)-JHAJRA(UK) (PTCUL) CKT-2	PTCUL	D	FOR AMP WORK	04-Jan-2020	08:00	04-Jan-2020	18:00		
548	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DEHRADUN(PG)-JHAJRA(UK) (PTCUL) CKT-1	PTCUL	D	FOR AMP WORK	03-Jan-2020	08:00	03-Jan-2020	18:00		
549	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MAHARANIBAGH(PG)-LODHIROAD(DV) (DTL) CKT-1	DTL	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
550	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BADARPUR(NT)-SARITA VIHAR(DV) (DTL) CKT-1	DTL	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
551	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MAHARANIBAGH(PG)-SARITA VIHAR(DV) (DTL) CKT-1	DTL	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
552	OCC_166	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BADARPUR(NT)-OKHLA(DV) (DTL) CKT-1	DTL	D	OPGW laying shall be started in this line under Reliable Communication package (Auto Reclose off)	01-Jan-2020	08:00	31-Jan-2020	18:00		
553	OCC_166	aptfl_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHADLA(PG)-AZURE POWER 34 SOLAR(APTFL) (APTFL) CKT-1	APTFL	C	Due to line differential work And Auto re-closer work	26-Dec-2019	17:30	27-Dec-2019	06:00	We required this shutdown after generation hours 26/12/2019 17:30 to 27/12/2019 06:00	
554	OCC_166	aptfl_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHADLA(PG)-AZURE POWER 34 SOLAR(APTFL) (APTFL) CKT-1	APTFL	C	Due to Line differential work & auto re-closer work	25-Dec-2019	17:30	26-Dec-2019	06:00	We required this shutdown after generation hour 25/12/2019 17:30 to 26/12/2019 06:00	
555	OCC_166	aptfl_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHADLA(PG)-AZURE POWER 34 SOLAR(APTFL) (APTFL) CKT-1	APTFL	C	Due to Line differential work & auto re-closer work	24-Dec-2019	17:30	25-Dec-2019	06:00	we require this shutdown after generation hours 24/12/2019 17:30 to 25/12/2019 06:00	
556	OCC_166	cpcc2_sd	BUS	220KV BUS 2 AT FATEHABAD(PG)	POWERGRID	D	For AMP works.	31-Jan-2020	10:00	31-Jan-2020	18:00		
557	OCC_166	cpcc2_sd	BUS	220KV BUS 1 AT FATEHABAD(PG)	POWERGRID	D	For AMP works.	30-Jan-2020	10:00	30-Jan-2020	18:00		
558	OCC_166	cpcc2_sd	BUS	220KV BUS 1 AT PANCHKULA(PG)	POWERGRID	D	For AMP works.	28-Jan-2020	09:00	28-Jan-2020	18:00		
559	OCC_166	cpcc2_sd	BUS	220KV BUS 2 AT LUDHIANA(PG)	POWERGRID	D	For AMP works.	17-Jan-2020	09:00	17-Jan-2020	18:00		

560	OCC_166	cpcc2_sd	BUS	220KV BUS 1 AT LUDHIANA(PG)	POWERGRID	D	For AMP works.	14-Jan-2020	09:00	14-Jan-2020	18:00		
561	OCC_166	cpcc3_sd	BUS	220KV BUS 2 AT ALLAHABAD(PG)	POWERGRID	D	AMP Works of 220kV Bus-2 at Allahabad SS	10-Jan-2020	08:00	10-Jan-2020	18:00		
562	OCC_166	cpcc1_sd	BUS	220KV BUS 2 AT JAIPUR SOUTH(PG)	POWERGRID	D	FOR AMP WORK	08-Jan-2020	08:00	08-Jan-2020	18:00		
563	OCC_166	cpcc3_sd	BUS	220KV BUS 1 AT ALLAHABAD(PG)	POWERGRID	D	AMP Works of 220kV Bus-1 at Allahabad SS	08-Jan-2020	08:00	08-Jan-2020	18:00		
564	OCC_166	cpcc1_sd	BUS	220KV BUS 1 AT JAIPUR SOUTH(PG)	POWERGRID	D	FOR AMP WORK	07-Jan-2020	08:00	07-Jan-2020	18:00		
565	OCC_166	cpcc1_sd	BUS	220KV BUS 4 AT MANDOLA(PG)	POWERGRID	D	AMP work	06-Jan-2020	08:00	06-Jan-2020	18:00		
566	OCC_166	cpcc1_sd	BUS	220KV BUS 3 AT MANDOLA(PG)	POWERGRID	D	AMP work	05-Jan-2020	08:00	05-Jan-2020	18:00		
567	OCC_166	cpcc1_sd	BUS	220KV BUS 2 AT MANDOLA(PG)	POWERGRID	D	AMP work	04-Jan-2020	08:00	04-Jan-2020	18:00		
568	OCC_166	cpcc1_sd	BUS	220KV BUS 1 AT MANDOLA(PG)	POWERGRID	D	AMP work	03-Jan-2020	08:00	03-Jan-2020	18:00		
569	OCC_166	bbmb_sd	BUS	220KV BUS 4 AT SAMAYPUR(BB)	BBMB	D	To replace the clamps with C-Wedge	06-Jan-2020	08:00	08-Jan-2020	18:00		
570	OCC_166	bbmb_sd	BUS	220KV BUS 3 AT SAMAYPUR(BB)	BBMB	D	To replace the clamps with C-Wedge	02-Jan-2020	08:00	04-Jan-2020	18:00		
571	OCC_166	dadri_sd	BUS	220KV BUS 2DADRITH(NT)	NTPC	D	verhauling of 220KV Bus isolator (1289B) Unit-4 Bay	26-Dec-2019	08:00	26-Dec-2019	18:00	Shutdown may please be allowed on 20/12/2019 in view of the ongoing overhauling of Unit-4	
572	OCC_166	dadri_sd	BUS	220KV BUS 1DADRITH(NT)	NTPC	D	Overhauling of 220KV Bus isolator (1289A) Unit-4 Bay	24-Dec-2019	08:00	24-Dec-2019	18:00	Shutdown may be please be allowed on 18/12/2019 in view of the ongoing overhauling of Unit-4	
573	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV KANGRA (HP)-PATHANKOT (PS) (PSTCL) CKT-1	PSTCL	D	Jumper tightening, ground mtc.,checking of tower accessories,checking of muffs,off shoots and stubs,tree cutting, checking of ground wire.	17-Jan-2020	08:00	17-Jan-2020	18:00		
574	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV HAMIRPUR(HP)-CHOHAL (PS) (PSTCL) CKT-1	PSTCL	D	Tightening of Jumpers of Deadend Towers, Disc Cleaning & Tree Cutting	15-Jan-2020	08:00	15-Jan-2020	18:00		

575	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV KANGRA (HP)-SHANAN (PS) (PSTCL) CKT-1	PSTCL	D	Jumper tightening, ground mtc.,checking of tower accessories,checking of muffs,off shoots and stubs,tree cutting, checking of ground wire.	13-Jan-2020	08:00	16-Jan-2020	18:00		
576	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV KANGRA (HP)-PATHANKOT (PS) (PSTCL) CKT-1	PSTCL	D	Jumper tightening, ground mtc.,checking of tower accessories,checking of muffs,off shoots and stubs,tree cutting, checking of ground wire.	06-Jan-2020	08:00	07-Jan-2020	18:00		
577	OCC_166	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV KANGRA (HP)-PATHANKOT (PS) (PSTCL) CKT-1	PSTCL	D	Jumper tightening, ground mtc.,checking of tower accessories,checking of muffs,off shoots and stubs,tree cutting, checking of ground wire.	02-Jan-2020	08:00	04-Jan-2020	18:00		
578	OCC_166	sewa2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV HIRANAGAR(PDD)- SEWA_2(NH) (PG) CKT-1	POWERGRI D	D	Annual Maintenance of Switchyard and Tan delta testings of CT, CVT.	10-Jan-2020	09:00	12-Jan-2020	18:00		
579	OCC_166	sewa2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV HIRANAGAR(PDD)- SEWA_2(NH) (PG) CKT-2	POWERGRI D	D	Annual Maintenance of Switchyard and Tan delta testings of CT, CVT.	10-Jan-2020	09:00	12-Jan-2020	18:00		
580	OCC_166	sewa2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV SEWA_2(NH)-KATHUA(JK) (PG) CKT-1	POWERGRI D	D	Annual Maintenance of Switchyard and Tan delta testings of CT, CVT.	10-Jan-2020	09:00	12-Jan-2020	18:00		
581	OCC_166	sewa2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV SEWA_2(NH)- MAHANPUR(PDD) (PG) CKT-1	POWERGRI D	D	Annual Maintenance of Switchyard and Tan delta testings of CT, CVT.	10-Jan-2020	09:00	12-Jan-2020	18:00		
582	OCC_166	sterlite_sd	BAY	208 MAIN BAY - 220KV BUS 1 AT AMARGARH(NRSS XXIX) AND FUTURE	NRSS XXIX	D	For Signal testing from Remote Control Centre	02-Jan-2020	09:00	02-Jan-2020	11:00		
583	OCC_166	sterlite_sd	BAY	207 MAIN BAY - 220KV BUS 1 AT AMARGARH(NRSS XXIX) AND FUTURE	NRSS XXIX	D	For Signal testing from Remote Control Centre	01-Jan-2020	12:00	01-Jan-2020	14:00		
584	OCC_166	sterlite_sd	BAY	205 MAIN BAY - 220KV BUS 1 AT AMARGARH(NRSS XXIX) AND 220 KV AMARGARH(NRSS XXIX)- DELINA(PDD) (PDD JK) CKT-1	NRSS XXIX	D	For Signal testing from Remote Control Centre	01-Jan-2020	09:00	01-Jan-2020	11:00		
585	OCC_166	sterlite_sd	BAY	204 MAIN BAY - 220KV BUS 1 AT AMARGARH(NRSS XXIX) AND FUTURE	NRSS XXIX	D	For Signal testing from Remote Control Centre	31-Dec-2019	12:00	31-Dec-2019	16:00		
586	OCC_166	sterlite_sd	BAY	206 MAIN BAY - 220 KV AMARGARH(NRSS XXIX)- DELINA(PDD) (PDD JK) CKT-1	NRSS XXIX	D	For Signal testing from Remote Control Centre	31-Dec-2019	09:00	31-Dec-2019	11:00		
587	OCC_166	sterlite_sd	BAY	202 MAIN BAY - 220 KV AMARGARH(NRSS XXIX)- ZIANKOTE(JK) (PDD JK) CKT-1 AND 220KV BUS 1 AT AMARGARH(NRSS XXIX) AT 220 KV AMARGARH(NRSS XXIX)	NRSS XXIX	D	For Signal testing from Remote Control Centre	30-Dec-2019	12:00	30-Dec-2019	16:00		

588	OCC_166	sterlite_sd	BAY	201 BUS COUPLER BAY - 220KV BUS 1 AT AMARGARH(NRSS XXIX) AND 220KV BUS 2 AT AMARGARH(NRSS XXIX) AT 220 KV AMARGARH(NRSS XXIX)	NRSS XXIX	D	For Signal testing from Remote Control Centre	30-Dec-2019	09:00	30-Dec-2019	11:00		
589	OCC_166	cpcc3_sd	TRANSFORMER	220/132 KV 100 MVA ICT 1 AT RAEBAREILLY(PG)	POWERGRID	D	for Amp work at Raibareilly S/S	17-Jan-2020	08:00	17-Jan-2020	18:00		
590	OCC_166	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT BALIA(PG)	POWERGRID	D	For AMP Activities & Maintenance of ICT Switching Isolators, Earthing switches etc. at Ballia S/S.	29-Jan-2020	08:00	30-Jan-2020	18:00		
591	OCC_166	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT BALIA(PG)	POWERGRID	D	For AMP Activities & Maintenance of ICT Switching Isolators, Earthing switches etc. at Ballia S/S.	27-Jan-2020	08:00	28-Jan-2020	18:00		
592	OCC_166	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT JHATIKARA(PG)	POWERGRID	D	Wrapping of insulation sleeve on tertiary IPS tube	13-Jan-2020	08:00	13-Jan-2020	18:00		
593	OCC_166	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT JHATIKARA(PG)	POWERGRID	D	For GE make CSD Tuning and require 05times swiching of ICT (No load switching)	10-Jan-2020	08:00	10-Jan-2020	18:00	For GE-CSD Tuning and require 05times swiching of ICT (No load switching)	
594	OCC_166	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT AGRA(PG)	POWERGRID	D	For extension of tertiary bay for connection of new tertiary equipment bay at Agra Substation	08-Jan-2020	08:00	08-Jan-2020	18:00		
595	OCC_166	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT JHATIKARA(PG)	POWERGRID	D	For GE make CSD Tuning and require 05times swiching of ICT (No load switching)	08-Jan-2020	08:00	08-Jan-2020	18:00	For GE-CSD Tuning and require 05times swiching of ICT (No load switching)	
596	OCC_166	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT AJMER(PG)	POWERGRID	D	CSD fine tuning work	07-Jan-2020	08:00	07-Jan-2020	18:00		
597	OCC_166	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT AJMER(PG)	POWERGRID	D	FOR AMP WORK	06-Jan-2020	08:00	06-Jan-2020	18:00		
598	OCC_166	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT JHATIKARA(PG)	POWERGRID	D	For GE make CSD Tuning and require 05times swiching of ICT (No load switching)	06-Jan-2020	08:00	06-Jan-2020	18:00	For GE-CSD Tuning and require 05times swiching of ICT (No load switching)	
599	OCC_166	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT HAPUR(UP)	UPPTCL	D	For Annual Maintenance work of B -Phase , and Normalizing the ICT	24-Jan-2020	09:00	25-Jan-2020	10:00		
600	OCC_166	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT HAPUR(UP)	UPPTCL	C	For Annual Maintenance work of Y -Phase ,	22-Jan-2020	09:00	22-Jan-2020	10:00		
601	OCC_166	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT HAPUR(UP)	UPPTCL	C	For Annual Maintenance work of R -Phase ,	20-Jan-2020	09:00	20-Jan-2020	10:00		
602	OCC_166	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT HAPUR(UP)	UPPTCL	C	For Annual Maintenance work of Y -Phase ,	19-Jan-2020	09:00	19-Jan-2020	10:00		

603	OCC_166	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT HAPUR(UP)	UPPTCL	C	For Annual Maintenance work of B -Phase ,	17-Jan-2020	09:00	17-Jan-2020	10:00		
604	OCC_166	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT HAPUR(UP)	UPPTCL	C	For Annual Maintenance work of R -Phase ,	15-Jan-2020	09:00	15-Jan-2020	10:00		
605	OCC_166	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT GR.NOIDA_2(UPC)	UPPTCL	C	For Normalize the B-Phase of ICT-1 with Spare ICT	09-Jan-2020	09:00	09-Jan-2020	10:00		
606	OCC_166	sldcrs_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT PHAGI(RS)	RRVPNL	D	1. To replace the single moose conductor with double moose conductor for connecting neutral bushing of Transformers to 3" IPS Al. tube 2. Testing and maintenance of Transformers. 3. Tightening of clamps and connectors	08-Jan-2020	09:00	08-Jan-2020	20:00	There will be no interruption during shut-down period as the ICT-2 will be remained energized to evacuate the power.	
607	OCC_166	sldcrs_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT PHAGI(RS)	RRVPNL	D	1. To replace the single moose conductor with double moose conductor for connecting neutral bushing of Transformers to 3" IPS Al. tube 2. Testing and maintenance of Transformers. 3. Tightening of clamps and connectors	03-Jan-2020	09:00	03-Jan-2020	20:00	There will be no interruption during shut-down period as the ICT-1 will be remained energized to evacuate the power.	
608	OCC_166	sldcrs_sd	TRANSFORMER	765/400 KV 500 MVA SPARE ICT 1 AT PHAGI(RS)	RRVPNL	D	1. To replace the single moose conductor with double moose conductor for connecting neutral bushing of Transformers to 3" IPS Al. tube 2. Testing and maintenance of Transformers. 3. Tightening of clamps and connectors	02-Jan-2020	09:00	02-Jan-2020	18:00		
609	OCC_166	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT NAKODAR(PSG)	PSTCL	D	Periodic Maintenance	29-Jan-2020	08:00	29-Jan-2020	18:00		
610	OCC_166	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MAKHU(PS)	PSTCL	D	General Maintenance	21-Jan-2020	08:00	21-Jan-2020	18:00		
611	OCC_166	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT MAKHU(PS)	PSTCL	D	General Maintenance	20-Jan-2020	08:00	20-Jan-2020	18:00		
612	OCC_166	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT MUKTSAR(PS)	PSTCL	D	HV & IV Side Bays General Maintenance	08-Jan-2020	08:00	09-Jan-2020	18:00		
613	OCC_166	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT MUKTSAR(PS)	PSTCL	D	For testing of parallel operation of OLTC for Tap Position Changing in Master-Follower mode.	06-Jan-2020	08:00	06-Jan-2020	18:00		
614	OCC_166	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MUKTSAR(PS)	PSTCL	D	For testing of parallel operation of OLTC for Tap Position Changing in Master-Follower mode.	06-Jan-2020	08:00	06-Jan-2020	18:00		
615	OCC_166	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MUKTSAR(PS)	PSTCL	D	For testing of parallel operation of OLTC for Tap Position Changing in Master-Follower mode.	06-Jan-2020	08:00	06-Jan-2020	18:00		

616	OCC_166	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MUKTSAR(PS)	PSTCL	D	HV & IV Side Bays General Maintenance + Periodical Testing	03-Jan-2020	08:00	04-Jan-2020	18:00		
617	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT AMRITSAR(PG)	POWERGRID	D	For Amp works	28-Jan-2020	10:00	28-Jan-2020	17:00		
618	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT CHAMBA(PG)	POWERGRID	D	To attend oil leakage problem R-phase	25-Jan-2020	09:00	25-Jan-2020	18:00		
619	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT CHAMBA(PG)	POWERGRID	D	For replacement of defective Aircell and to attend oil leakage problem in Y-phase	23-Jan-2020	09:00	24-Jan-2020	18:00		
620	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT PANCHKULA(PG)	POWERGRID	D	For AMP works.	23-Jan-2020	09:00	23-Jan-2020	18:00		
621	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT KOTPUTLI(PG)	POWERGRID	D	FOR AMP WORK	22-Jan-2020	08:00	22-Jan-2020	18:00		
622	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BAHADURGARH(PG)	POWERGRID	D	For RELAY retrofitment work of ICT relays.	21-Jan-2020	10:00	21-Jan-2020	15:00		
623	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT PANCHKULA(PG)	POWERGRID	D	For AMP works.	21-Jan-2020	09:00	21-Jan-2020	18:00		
624	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT HISSAR(PG)	POWERGRID	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		
625	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT HISSAR(PG)	POWERGRID	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		
626	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT HISSAR(PG)	POWERGRID	D	For replacement of damaged conductors of 220kV Bus Coupler, Jumpers and other conductors (as per attached LOA) shutdown of complete 220KV system(Bus-1 & Bus-2 along with connected elements) of Hisar s/s is required.	21-Jan-2020	07:00	21-Jan-2020	19:00		
627	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT BAHADURGARH(PG)	POWERGRID	D	For RELAY retrofitment work of ICT relays.	20-Jan-2020	10:00	20-Jan-2020	15:00		
628	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT GURGAON(PG)	POWERGRID	C	For rectify high ppm(moisture) in cable box	20-Jan-2020	08:00	23-Jan-2020	18:00		
629	OCC_166	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT KANPUR(PG)	POWERGRID	C	For Isolator 43089T replacement work under CERC Add Cap at Kanpur S/S	20-Jan-2020	08:00	24-Jan-2020	18:00		
630	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KOTPUTLI(PG)	POWERGRID	D	FOR AMP WORK	20-Jan-2020	08:00	20-Jan-2020	18:00		
631	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT SAMBA(PG)	POWERGRID	D	For AMP works.	18-Jan-2020	09:00	18-Jan-2020	17:30		
632	OCC_166	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT AGRA(PG)	POWERGRID	D	Repeat VFTD on violation of paramters in HV bushings at Agra Substation	18-Jan-2020	08:00	18-Jan-2020	18:00		
633	OCC_166	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT AGRA(PG)	POWERGRID	D	Repeat VFTD on violation of paramters in HV bushings at Agra Substation	17-Jan-2020	08:00	17-Jan-2020	18:00		

634	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT GURGAON(PG)	POWERGRID	D	AMP of ICT and its associated 400 kv & 220 kv bays	17-Jan-2020	08:00	18-Jan-2020	18:00		
635	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BHADLA(PG)	POWERGRID	D	FOR AMP WORK	17-Jan-2020	08:00	17-Jan-2020	18:00		
636	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT SIKAR(PG)	POWERGRID	C	To attend oil leakage from bottom portion of Bell tank of 500 MVA ICT-3 (Make-T&R) at 400 KV Sikar S/S	17-Jan-2020	08:00	31-Jan-2020	18:00		
637	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BHADLA(PG)	POWERGRID	D	FOR AMP WORK	16-Jan-2020	08:00	16-Jan-2020	18:00		
638	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BHADLA(PG)	POWERGRID	D	FOR AMP WORK	15-Jan-2020	08:00	15-Jan-2020	18:00		
639	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT SIKAR(PG)	POWERGRID	D	Digital RTCC Tesing from SAS for 315 MVA, 400/220 kv ICT-2 at 400 KV Sikar S/s	14-Jan-2020	08:00	14-Jan-2020	18:00		
640	OCC_166	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KANPUR(PG)	POWERGRID	C	For Isolator 42689T replacement work under CERC Add Cap at Kanpur S/S	13-Jan-2020	08:00	16-Jan-2020	18:00		
641	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT SIKAR(PG)	POWERGRID	D	AMP tesing of 315 MVA, 400/220 kv ICT-1 at 400 KV Sikar S/s	13-Jan-2020	08:00	13-Jan-2020	18:00		
642	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MALERKOTLA(PG)	POWERGRID	C	For replacement of 400KV & 220KV side T- Isolators	10-Jan-2020	09:00	12-Jan-2020	18:00		
643	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT SAMBA(PG)	POWERGRID	D	For AMP works.	10-Jan-2020	09:00	10-Jan-2020	17:30		
644	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BHINMAL(PG)	POWERGRID	D	FOR AMP WORK	09-Jan-2020	08:00	09-Jan-2020	18:00		
645	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT BHINMAL(PG)	POWERGRID	D	FOR AMP WORK	07-Jan-2020	08:00	07-Jan-2020	18:00		
646	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT LUDHIANA(PG)	POWERGRID	C	Replacement of 1 no. 400KV Bushing. AMP	06-Jan-2020	09:00	10-Jan-2020	18:00		
647	OCC_166	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT MALERKOTLA(PG)	POWERGRID	C	For replacement of 220KV side T- Isolators	06-Jan-2020	09:00	08-Jan-2020	18:00		
648	OCC_166	cpcc3_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT LUCKNOW_1(PG)	POWERGRID	D	Tertiary cable connection with ICT at 400kv lucknow S/S	26-Dec-2019	08:00	26-Dec-2019	18:00		
649	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BASSI(PG)	POWERGRID	D	FOR AMP WORK	25-Dec-2019	08:00	25-Dec-2019	18:00		
650	OCC_166	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BASSI(PG)	POWERGRID	D	FOR AMP WORK	24-Dec-2019	08:00	24-Dec-2019	18:00		
651	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT GR.NOIDA_2(UPC)	UPPTCL	C	For Annual Maintenance work	28-Jan-2020	09:00	28-Jan-2020	14:00		
652	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT LUCKNOW(UP)	UPPTCL	D	For annual protection testing and bay maintenance works.	28-Jan-2020	09:00	28-Jan-2020	17:00		
653	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 240 MVA ICT 3 AT MURADNAGAR_2(UP)	UPPTCL	D	For preventive maintenance and tightning	23-Jan-2020	10:00	23-Jan-2020	17:00		
654	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT BAREILLY(UP)	UPPTCL	D	Routine testing /preventive maintenance	23-Jan-2020	09:00	23-Jan-2020	15:00		
655	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT SARNATH(UP)	UPPTCL	C	Shut down required for replacement of old retrofitted panel to new Numeric relay panel	21-Jan-2020	08:00	23-Jan-2020	18:00		
656	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT SARNATH(UP)	UPPTCL	D	Shut Down required for general maintenance and tightening of bay.	20-Jan-2020	09:00	20-Jan-2020	17:00		

657	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 240 MVA ICT 2 AT SULTANPUR(UP)	UPPTCL	D	For routine bay maintenance works	17-Jan-2020	10:00	17-Jan-2020	18:00		
658	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT SULTANPUR(UP)	UPPTCL	D	For routine bay maintenance works	13-Jan-2020	10:00	13-Jan-2020	18:00		
659	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT ATAUR(UP)	UPPTCL	C	For Annual Maintenance work	13-Jan-2020	09:00	13-Jan-2020	18:00		
660	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT MURADNAGAR_1(UP)	UPPTCL	C	For replacement of emulsifier system and painting work	10-Jan-2020	09:00	25-Jan-2020	18:00		
661	OCC_166	stuup_sd	TRANSFORMER	400/220 KV 240 MVA ICT 1 AT MURADNAGAR_2(UP)	UPPTCL	D	For preventive maintenance and tightning	03-Jan-2020	09:00	03-Jan-2020	17:00		For replacement of OSR Relay and painting work
662	OCC_166	singrauli_sd	TRANSFORMER	400/132 KV 100 MVA ICT 2 AT SINGRAULI(NT)	NTPC	C	for transformer maintenance and CT replacement	27-Jan-2020	08:00	31-Jan-2020	18:00		
663	OCC_166	singrauli_sd	TRANSFORMER	400/132 KV 100 MVA ICT 1 AT SINGRAULI(NT)	NTPC	C	for transformer maintenance and CT replacement	21-Jan-2020	08:00	25-Jan-2020	18:00		
664	OCC_166	dadri_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT DADRI(NT)	NTPC	C	Annual Overhauling & testing.	06-Jan-2020	09:00	18-Jan-2020	18:00		
665	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT CHITTORGARH(RS)	RRVPNL	D	FOR MAINTENANCE WORK	23-Jan-2020	09:00	23-Jan-2020	17:00		400kv ICT-2 will remain off and load will be shifted to 400kv ICT-1 during this period
666	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	22-Jan-2020	10:00	22-Jan-2020	17:00		Supply maintained through OTHER 400/220/33 KV,315 MVA ILT-II. Hence No supply disturbance
667	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT AJMER(RS)	RRVPNL	D	HALF YEARLY MAINTENANCE WORK OF 400/220 KV 315 MVA ICT-I	22-Jan-2020	09:00	22-Jan-2020	18:00		During the shutdown the supply shall be fed by the ICT-III hence there will be no supply disturbance.
668	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BHADLA(RS)	RRVPNL	D	Yearly maintenance work	22-Jan-2020	09:00	22-Jan-2020	17:00		
669	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BHADLA(RS)	RRVPNL	D	Yearly maintenance work	20-Jan-2020	09:00	20-Jan-2020	17:00		
670	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BARMER(RS)	RRVPNL	D	Quarterly Maintenance	17-Jan-2020	10:00	17-Jan-2020	18:00		
671	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT BARMER(RS)	RRVPNL	D	Quarterly Maintenance	16-Jan-2020	10:00	16-Jan-2020	18:00		
672	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT KANKANI(RVUN)	RRVPNL	D	Preventive maintenance Work	10-Jan-2020	09:00	10-Jan-2020	18:00		

673	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BIKANER(RS)	RRVPNL	D	For Tan Delta Testing	09-Jan-2020	10:00	09-Jan-2020	17:00	
674	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT CHITTORGARH(RS)	RRVPNL	D	FOR MAINTENANCE WORK	09-Jan-2020	09:00	09-Jan-2020	17:00	400kv ICT-1 will remain off and load will be shifted to 400kv ICT-2 during this period
675	OCC_166	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BHILWARA(RS)	RRVPNL	D	Yearly maintenane of 315 MVA 400/220/33 KV ICT No.-2 & ASSOCIATED BAY EQUIPMENTS	08-Jan-2020	09:00	09-Jan-2020	18:00	
676	OCC_166	sldcdv_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT MUNDKA(DV)	DTL	D	Testing of Transformer as per PMS sechedule	19-Jan-2020	09:00	19-Jan-2020	17:30	Load shall be shared by alternate ICT 4
677	OCC_166	sldcdv_sd	TRANSFORMER	400/220 KV 315 MVA ICT 4 AT MUNDKA(DV)	DTL	D	Testing of Transformer as per PMS sechedule	12-Jan-2020	09:00	12-Jan-2020	17:30	Load shall be shared by alternate ICT 3
678	OCC_166	sldcdv_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BAMNOLI(DV)	DTL	D	For Tan delta Testing and Annual Maintenance as per PMS Schedule.	09-Jan-2020	08:30	09-Jan-2020	17:30	Load will be shared through ICT-1 315MVA, ICT-4 315MVA and ICT-2 500MVA.
679	OCC_166	sldcdv_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT BAMNOLI(DV)	DTL	D	For Tan delta Testing and Annual Maintenance as per PMS Schedule.	08-Jan-2020	08:30	08-Jan-2020	17:30	Load will be shared through ICT-2 500MVA, ICT-4 315MVA and ICT-3 500MVA.
680	OCC_166	sldcdv_sd	TRANSFORMER	400/220 KV 315 MVA ICT 6 AT BAWANA(DV)	DTL	D	Tan Delta Testing as per OS Manual	02-Jan-2020	10:30	02-Jan-2020	17:00	Load of the line will be run through ICT-1,2,3,4&5
681	OCC_166	sldcdv_sd	TRANSFORMER	400/220 KV 315 MVA ICT 5 AT BAWANA(DV)	DTL	D	Tan Delta Testing as per OS Manual	01-Jan-2020	10:30	01-Jan-2020	17:00	Load of the line will be run through ICT-1,2,3,4&6
682	OCC_166	cpcc3_sd	HVDC POLE	70 KV VINDHYACHAL(PG) POLE-1	POWERGRI D	C	Variation in Power Code of up to 550 MW for Harmonic Studies under ADD-CAP scheme	22-Jan-2020	08:00	28-Jan-2020	18:00	Both Block wil remain in service however Open code for Power Flow variation required
683	OCC_166	cpcc3_sd	HVDC POLE	70 KV VINDHYACHAL(PG) POLE-2	POWERGRI D	D	Power Code of 50 MW (totalling both block) for Harmonic Studies under ADD-CAP scheme	21-Jan-2020	09:00	21-Jan-2020	12:00	Both Block wil remain in service however Open code for Power Flowvariation required

684	OCC_166	cpcc3_sd	HVDC POLE	70 KV VINDHYACHAL(PG) POLE-2	POWERGRID	C	S/D of only HVDC Block#2 with Variation of Power Flow upto 275 MW for Harmonic Studies under ADD-CAP scheme	14-Jan-2020	08:00	20-Jan-2020	21:00	Block#1 wil remain in service however Open code for Power Flow variation required
685	OCC_166	cpcc3_sd	HVDC POLE	70 KV VINDHYACHAL(PG) POLE-1	POWERGRID	D	S/D of only HVDC Block#1 with station Power Flow of 25 MW for Harmonic Studies under ADD-CAP scheme	13-Jan-2020	15:30	13-Jan-2020	18:30	
686	OCC_166	cpcc3_sd	HVDC POLE	70 KV VINDHYACHAL(PG) POLE-2	POWERGRID	D	S/D of only HVDC Block#2 with station Power Flow of 25 MW for Harmonic Studies under ADD-CAP scheme	13-Jan-2020	09:00	13-Jan-2020	12:00	
687	OCC_166	cpcc3_sd	HVDC POLE	70 KV VINDHYACHAL(PG) POLE-1	POWERGRID	D	S/D of both HVDC Block#1 & 2 for Harmonic Studies under ADD-CAP scheme	11-Jan-2020	08:00	11-Jan-2020	18:00	
688	OCC_166	cpcc3_sd	HVDC POLE	70 KV VINDHYACHAL(PG) POLE-2	POWERGRID	D	S/D of both HVDC Block#1 & 2 for Harmonic Studies under ADD-CAP scheme	11-Jan-2020	08:00	11-Jan-2020	18:00	
689	OCC_166	cpcc3_sd	TCSC	TCSC OF 400 KV GORAKHPUR-MUZAFFARPUR (PG) CKT-2 AT GORAKHPUR(PG)	POWERGRID	D	AMP WORK at Gorakhpur Substation	16-Jan-2020	08:00	18-Jan-2020	18:00	
690	OCC_166	cpcc3_sd	TCSC	TCSC OF 400 KV GORAKHPUR-MUZAFFARPUR (PG) CKT-1 AT GORAKHPUR(PG)	POWERGRID	D	AMP WORK at Gorakhpur Substation	06-Jan-2020	08:00	08-Jan-2020	18:00	
691	OCC_166	cpcc3_sd	SVC/STATCOM	SVC No 2(-140/+140MVAR) at 400 KV Kanpur(PG)	POWERGRID	C	For ISO 42489T replacement work under CERC Add Cap at Kanpur S/S	06-Jan-2020	08:00	09-Jan-2020	18:00	
692	OCC_166	cpcc3_sd	SVC/STATCOM	SVC No 1(-140/+140MVAR) at 400 KV Kanpur(PG)	POWERGRID	C	For ISO 42389T replacement work under CERC Add Cap at Kanpur S/S	01-Jan-2020	08:00	04-Jan-2020	18:00	