

## भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power उत्तर क्षेत्रीय विद्युत समिति Northern Regional Power Committee

सं.:उ.क्षे.वि.स./प्रचालन/106/01/2023/6685-6726

दिनांक: 19.09.2023

विषय: उत्तर क्षेत्रीय विद्युत समिति की प्रचालन समन्वय उप- समिति की 211वी बैठक में स्वीकृत आऊटेज कार्यक्रम की सूची I

Subject: Outage programme approved in the 211th OCC Meeting.

विद्युत् उत्पादन कंपनियों व पारेषण लाइसेंस धारकों द्वारा उत्पादन इकाइयों व पारेषण तंत्र के प्रस्तावित आऊटेज कार्यक्रमों को दिनांक 18.09.2023 में आयोजित प्रचालन समन्वय उप- समिति की 211 वी बैठक में चर्चा करने के पश्चात आऊटेज कार्यक्रम की स्वीकृत सूची को उत्तर क्षेत्रीय विद्युत समिति के वेब पोर्टल पर उपलब्ध किया गया है। सभी आऊटेज कार्यक्रम संभावित हैं एवं वास्तविक काल में ग्रिड की स्तिथि के अनुरूप प्रभावी होंगे। किसी प्रकार की त्रुटि होने पर दो कार्य दिवसों के भीतर हमें सूचित करने का कष्ट करें।

The outage programme of Generating Units and Transmission Lines proposed by Generating Companies and Transmission Licensees were discussed in the 211<sup>th</sup> OCC meeting held on 18.09.2023 and the approved list of outages program has been uploaded on NRPC web portal. All outage programmes are approved tentatively subject to real time grid conditions. Discrepancy, if any may kindly be intimated within two working days.

(संतोष कुमार)

अधीक्षण अभियंता (प्रचालन)

सेवा में, प्रचालन समन्वय उप- समिति के सभी सदस्य I

## APPROVED OUTAGE PROGRAM OF 211th OCC

									APPROVE		ROGRAM OF 2									
Sr No	Reference Number	OCC Number	Name of Requesting Agency	Element Type	Element Name	Owner	Daily/ Continous	Reason	Requested From Date	Requested From Time	Requested To Date	Requested To Time	Requester Remarks	Request Type	Shutdown Status	Approved From Date	Approved From Time	Approved To Date	Approved To Time	OCC Remarks
1	RQ145628	OCC_211	ntpcos_sd	GENERATING UNIT	660 MW TANDA TPS - UNIT 5	NTPC	С	BOILER LICENSE RENEWAL & UNIT OVERHAULING	01/Oct/2023	00:00	09/Nov/2023	23:59		PLANNED	Approved	05-Oct-23	00:00	11-Oct-23	23:59	shutdown to be availed only for boiler license renewal
2	RQ145629	OCC_211	ntpcos_sd	GENERATING UNIT	490 MW DADRI-II TPS - UNIT 1	NTPC	С	Capital Overhauling	27/Oct/2023	00:00	10/Dec/2023	23:59		PLANNED	Conditionall y Approved	27-Oct-23	00:00	10-Dec-23	23:59	
3	RQ145631	OCC_211	ntpcos_sd	GENERATING UNIT	130.19 MW DADRI GPS - UNIT 4	NTPC	С	Turbine Inspection	05/Oct/2023	00:00	08/Oct/2023	23:59		PLANNED	Approved	05-Oct-23	00:00	08-Oct-23	23:59	
4	RQ145630	OCC_211	ntpcos_sd	GENERATING UNIT	111.19 MW AURAIYA GPS - UNIT 2	NTPC	С	GT#2 Turbine inspection	10/Oct/2023	00:00	25/Oct/2023	23:59		PLANNED	Approved	10-Oct-23	00:00	25-Oct-23	23:59	
5	RQ145347	OCC_211	napp_sd	GENERATING UNIT	220 MW NAPS - UNIT 2	NPCIL	С	Bienneal Shutdown of NAPS-2	28/Oct/2023	00:00	28/Dec/2023	18:00		PLANNED	Approved	19-Nov-23	00:00	18-Jan-24	18:00	mandatory overhauling - condensor tube replacement and rotor inspection
6	RQ145578	OCC_211	rappc_sd	GENERATING UNIT	220 MW RAPS-C - UNIT 2	NPCIL	С	Biennial shut down maintenance of RAPS 6	01/Oct/2023	00:00	09/Nov/2023	23:00	S/D was approved in Dec2023 in LGBR but due to some technical issues it is proposed to prepond the shut down from 1st October (30th Sept 2350 hrs.) Kindly approve	PLANNED	Approved	01-Oct-23	00:00	09-Nov-23	23:00	
7	RQ145894	OCC_211	cpcc3_sd	HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-2	POWER GRID	С	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	29/Oct/2023	08:00	30/Oct/2023	18:00		PLANNED	Approved	28-Oct-23	08:00	29-Oct-23	18:00	
8	RQ145893	OCC_211	cpcc3_sd	HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-1	POWER GRID	С	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	29/Oct/2023	08:00	30/Oct/2023	18:00	During S/D all 04 poles will be out	PLANNED	Approved	28-Oct-23	08:00	29-Oct-23	18:00	
9	RQ145895	OCC_211	cpcc3_sd	HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-3	POWER GRID	С	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	29/Oct/2023	08:00	30/Oct/2023	18:00		PLANNED	Approved	28-Oct-23	08:00	29-Oct-23	18:00	
10	RQ145896	OCC_211	cpcc3_sd	HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-4	POWER GRID	С	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	29/Oct/2023	08:00	30/Oct/2023	18:00		PLANNED	Approved	28-Oct-23	08:00	29-Oct-23	18:00	

11	RQ146397	OCC_211	cpcc1_sd	HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-2	С	DIVERSION OF LINES DUE INFRIGEMENT OF GANGA EXPRESSWAY OF M/S UPEIDA	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	15-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before chraging of Line. ATC Curtailment of 5800 MW in NR Import for all 4 pole shutdown. Subjected to WRPC approval
12	RQ146396	OCC_211	cpcc1_sd	HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-1	С	DIVERSION OF LINES DUE INFRIGEMENT OF GANGA EXPRESSWAY OF M/S UPEIDA	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	15-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before chraging of Line. ATC Curtailment of 5800 MW in NR Import for all 4 pole shutdown. Subjected to WRPC approval
		OCC_211		HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-3	С	DIVERSION OF LINES DUE INFRIGEMENT OF GANGA EXPRESSWAY OF M/S UPEIDA	01/Oct/2023		15/Oct/2023			PLANNED	Approved	01-Oct-23	08:00	15-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before chraging of Line. ATC Curtailment of 5800 MW in NR Import for all 4 pole shutdown. Subjected to WRPC approval
14	RQ146399	OCC_211	cpcc1_sd	HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-4	С	DIVERSION OF LINES DUE INFRIGEMENT OF GANGA EXPRESSWAY OF M/S UPEIDA	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	15-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before chraging of Line. ATC Curtailment of 5800 MW in NR Import for all 4 pole shutdown. Subjected to WRPC approval
15	RQ146140	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(P G)-BHADLA(PG) (FBTL) CKT-2	D	For AMP, Relay testing works, Line equipment AMP Works	28/Oct/2023	17:00	28/Oct/2023	23:30		PLANNED	Approved	28-Oct-23	17:00	28-Oct-23	23:30	
16	RQ146148	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KOTESHWAR- MEERUT (PG) CKT- 2	D	Shut down defect rectification works	26/Oct/2023	08:00	28/Oct/2023	20:00		PLANNED	Approved	26-Oct-23	08:00	28-Oct-23	20:00	
17	RQ146137	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(P G)-BHADLA(PG) (FBTL) CKT-1	D	For AMP, Relay testing works, Line equipment AMP Works	24/Oct/2023	17:00	25/Oct/2023	23:30		PLANNED	Approved	24-Oct-23	17:00	25-Oct-23	23:30	
18	RQ146172	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(P G)	D	765KV/400KV ICT 1 for AMP works	24/Oct/2023	17:00	28/Oct/2023	23:59		PLANNED	Approved	24-Oct-23	17:00	28-Oct-23	23:59	
19	RQ146478	OCC_211	cpcc1_sd	BAY	721 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-1 (POWERGRID)	D	For bay AMP Works	23/Oct/2023	17:00	24/Oct/2023	23:00	For Bay AMP works	PLANNED	Approved	23-Oct-23	17:00	24-Oct-23	23:00	
20	RQ146125	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-2	D	For AMP, Relay testing works, Line equipment AMP Works	23/Oct/2023	17:00	23/Oct/2023	23:30		PLANNED	Approved	23-Oct-23	17:00	23-Oct-23	23:30	
21	RQ146212	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT BHADLA_2 (PG)	D	BAY EXTENSION WORK (724)	23/Oct/2023	17:00	24/Oct/2023	23:59		PLANNED	Approved	23-Oct-23	17:00	24-Oct-23	23:59	

22	RQ146146	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KOTESHWAR- MEERUT (PG) CKT- 1	D	Shut down defect rectification works	23/Oct/2023	08:00	25/Oct/2023	20:00		PLANNED	Approved	23-Oct-23	08:00	25-Oct-23	20:00	
23	RQ146123	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-1	D	For AMP, Relay testing works, Line equipment AMP Works	22/Oct/2023	17:00	22/Oct/2023	23:30		PLANNED	Approved	22-Oct-23	17:00	22-Oct-23	23:30	
24	RQ146171	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G)	D	765KV/400KV ICT 2 for AMP works	22/Oct/2023	17:00	25/Oct/2023	23:59		PLANNED	Approved	22-Oct-23	17:00	25-Oct-23	23:59	
25	RQ146211	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT BHADLA_2 (PG)	D	FOR rectification WORK	22/Oct/2023	17:00	22/Oct/2023	23:59		PLANNED	Approved	22-Oct-23	17:00	22-Oct-23	23:59	
26	RQ146404	OCC_211	cpcc1_sd	BAY	718 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 (POWERGRID)	D	For bay AMP Works	21/Oct/2023	17:00	22/Oct/2023	23:00	For Bay AMP works	PLANNED	Approved	21-Oct-23	17:00	22-Oct-23	23:00	
27	RQ146139	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(P G)-BHADLA(PG) (FBTL) CKT-2	D	For ladder logic and interlock checking for spare reactor commissioning	20/Oct/2023	17:00	27/Oct/2023	23:30		PLANNED	Approved	20-Oct-23	17:00	27-Oct-23	23:30	
28	RQ146813	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(P G)	D	Ladder logic commissioning with spare reactor logic scheme checking	19/Oct/2023	17:00	25/Oct/2023	23:00		PLANNED	Approved	19-Oct-23	17:00	25-Oct-23	23:00	
29	RQ146169	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G)	D	765KV/400KV ICT 4 for AMP works	18/Oct/2023	17:00	21/Oct/2023	23:59		PLANNED	Approved	18-Oct-23	17:00	21-Oct-23	23:59	
30	RQ146170	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(P G)	D	765KV/400KV ICT 3 for AMP works	18/Oct/2023	17:00	21/Oct/2023	23:59		PLANNED	Approved	18-Oct-23	17:00	21-Oct-23	23:59	
31	RQ146229	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT BHADLA(PG)	D	For installation and testing of Backup Impedance relay in ICT	18/Oct/2023	17:00	18/Oct/2023	23:59		PLANNED	Approved	18-Oct-23	17:00	18-Oct-23	23:59	
32	RQ146203	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT AJMER(PG)	D	FOR AMP WORK	18/Oct/2023	09:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	09:00	18-Oct-23	18:00	
		OCC_211		TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT BHADLA(PG)	D	For installation and testing of Backup Impedance relay in ICT	17/Oct/2023		17/Oct/2023			PLANNED	Approved	17-Oct-23	17:00	17-Oct-23	23:59	
34	RQ146143	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV JHATIKARA- BHIWANI (PG) CKT-1	D	Liquidation of Shut Down nature defects and closing of notification & LINE BAY AMP	17/Oct/2023	09:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	

35	RQ146227	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT BHADLA(PG)	D	For installation and testing of Backup Impedance relay in ICT	16/Oct/2023	17:00	16/Oct/2023	23:59		PLANNED	Approved	16-Oct-23	17:00	16-Oct-23	23:59	
36	RQ146127	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA- BIKANER (PG) CKT- 2	D	Installation of Bird Diverter	16/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	17:00	31-Oct-23	23:00	May be availed from 17:00 hrs
37	RQ146129	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER- BHADLA_2 (PG) CKT-2	D	Installation of Bird Diverter	16/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry
38	RQ146133	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER- MOGA (PG) CKT-2	D	Installation of Bird Diverter	16/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Rejected					To be clubbed when s/d for diversion work is taken.
39	RQ146119	OCC_211	cpcc1_sd	AC	765 KV AJMER- BHADLA_2 (PG) CKT-2	D	Installation of Bird Diverter	16/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Rejected	16-Oct-23	17:00	31-Oct-23	23:00	May be availed from 17:00 hrs
40	RQ146141	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(P G)-BHADLA(PG) (FBTL) CKT-2	D	Installation of Bird Diverter	16/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	17:00	31-Oct-23	23:00	May be availed from 17:00 hrs
41	RQ146121	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- CHITTORGARH (PG) CKT-2	D	AMP / SHUTDOWN RELATED WORK & To configure Line Reactor Tripping on Single phase fault as per CC approval	16/Oct/2023	08:00	16/Oct/2023	18:00	765 KV AJMER- CHITTORGARH (PG) CKT-1 to be kept in non auto mode	PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	ATC Curtailment of 600 MW in NR Export. Subjected to WRPC Approval
42	RQ146812	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(P G)	D	Ladder logic commissioning with spare reactor logic scheme checking	15/Oct/2023	17:00	20/Oct/2023	23:00		PLANNED	Approved	15-Oct-23	17:00	20-Oct-23	23:00	
43	RQ146167	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G)	D	Commissioning of ICT with Spare ICT Bank & CSD Fine tuning works	15/Oct/2023	17:00	24/Oct/2023	23:59		PLANNED	Approved	15-Oct-23	17:00	24-Oct-23	23:59	
44	RQ146120	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- CHITTORGARH (PG) CKT-1	D	AMP / SHUTDOWN RELATED WORK & To configure Line Reactor Tripping on Single phase fault as per CC approval	14/Oct/2023	08:00	14/Oct/2023	18:00	765 KV AJMER- CHITTORGARH (PG) CKT-2 to be kept in non auto mode	PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	ATC Curtailment of 600 MW in NR Export. Subjected to WRPC Approval
45	RQ146136	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(P G)-BHADLA(PG) (FBTL) CKT-1	D	For ladder logic and interlock checking for spare reactor commissioning	13/Oct/2023	17:00	20/Oct/2023	23:30		PLANNED	Approved	13-Oct-23	17:00	20-Oct-23	23:30	ATC Curtailment of 200/1750 MW in NR Import/Export. Subjected to WRPC approval
46	RQ146135	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH- BANASKANTHA (PG) CKT-2	D	TO ATTEND CROSS PATROLLING DEFECTS & To configure Line Reactor Tripping on Single phase fault as per CC approval	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
47	RQ146134	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH- BANASKANTHA (PG) CKT-1	D	TO ATTEND CROSS PATROLLING DEFECTS & To configure Line Reactor Tripping on Single phase fault as per CC approval	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	ATC Curtailment of 200/1750 MW in NR Import/Export. Subjected to WRPC approval

	RQ146150			AC TRANSMISSION LINE CIRCUIT TRANSFORMER	765 KV PHAGI(RS)- BHIWANI(PG) (PG) CKT-1 765/400 KV 1500 MVA ICT 3 AT	D	Shut down maintenance work & FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK Commissioning of ICT with Spare ICT Bank	11/Oct/2023 10/Oct/2023		13/Oct/2023			PLANNED PLANNED	Approved  Approved	11-Oct-23	08:00 17:00	13-Oct-23	19:00	
					FATEHGARH_II(P G)		& CSD Fine tuning works												
	RQ146153			AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1	С	NHAI diversion work	10/Oct/2023		25/Oct/2023			PLANNED	Approved	10-Oct-23	08:00	25-Oct-23	19:00	All statuory clearences, FTC approval to be submitted before charging of line. ATC Curtailment of 500 MW in NR Import. Subjected to WRPC approval
51	RQ146811	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(P G)	D	For final testing of CSD Relay of 765kV Bus Reactor	08/Oct/2023	17:00	12/Oct/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown	PLANNED	Approved	08-Oct-23	17:00	12-Oct-23	23:00	
52	RQ146124	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-2	D	For ladder logic and interlock checking for spare reactor commissioning	08/Oct/2023	17:00	13/Oct/2023	23:30		PLANNED	Approved	08-Oct-23	17:00	13-Oct-23	23:30	
	RQ146810			MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(P G)	D	For final testing of CSD Relay of 765KV Bus Reactor	07/Oct/2023		10/Oct/2023		Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown		Approved	07-Oct-23	17:00	10-Oct-23	23:00	
54	RQ146168	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G)	D	For Erection works of SS-63 A1 package 765 kV ICT-5 B phase unit	07/Oct/2023	17:00	11/Oct/2023	23:59	For commissioning works of SS-63 A1 package 765 kV ICT-5	PLANNED	Approved	07-Oct-23	17:00	11-Oct-23	23:59	
55	RQ146154	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)- GWALIOR(PG) (PG) CKT-2	D	Tightening of Jumper & hardware fitting & fixing of missing Jumper N&B	06/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	07-Oct-23	18:00	ATC Curtailment of 500 MW in NR Import. Subjected to WRPC approval
56	RQ146165	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G)	D	Commissioning of ICT with Spare ICT Bank & CSD Fine tuning works	05/Oct/2023	17:00	13/Oct/2023	23:59		PLANNED	Approved	05-Oct-23	17:00	13-Oct-23	23:59	

57	RQ146453	OCC_211	cpcc1_sd	BAY	714 TIE BAY - 765 KV GR.NOIDA_2(UPC )-MEERUT(PG) (PG) CKT-1 AND	D	АМР	05/Oct/2023	09:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
					FUTURE AT														
58	RQ146201	OCC_211	cpcc1_sd	TRANSFORMER	MEERUT(PG) 765/400 KV 1500 MVA ICT 1 AT	D	FOR AMP WORK AND		8 08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
					CHITTORGARH(P G)		insulation on Tertien connector and conductor												
59	RQ146452	OCC_211	cpcc1_sd	ВАУ	705 TIE BAY - 765/400KV 1500 MVA ICT 2 AT MEERUT(PG) AND 240 MVAR BUS REACTOR NO 1 AT 765KV MEERUT(PG)	D	АМР	04/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	18:00	
60	RQ146151	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)-	D	Liquidation of Shut Down nature defects and closing of notification & FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK	04/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	18:00	ATC Curtailment of 500 MW in NR Import
61	RQ146152	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)- GWALIOR(PG) (PG) CKT-1	D	Tightening of Jumper & hardware fitting & fixing of missing Jumper N&B		8 08:00	05/Oct/2023	18:00		PLANNED	Approved					To be clubbed with sI 50
62	RQ146202	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT CHITTORGARH(P G)	D	For providing insulation on Tertien connector and conductor	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
63	RQ146451	OCC_211	cpcc1_sd	BAY	703 MAIN BAY - 765/400KV 1500 MVA ICT 1 AT MEERUT(PG)	D	AMP	03/Oct/2023		03/Oct/2023			PLANNED	Approved	03-Oct-23	09:00	03-Oct-23	18:00	
64	RQ146122	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-1	D	For ladder logic and interlock checking fo spare reactor commissioning	02/Oct/2023 r	17:00	07/Oct/2023	23:30		PLANNED	Approved	02-Oct-23	17:00	07-Oct-23	23:30	
65	RQ146117	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-1	D	overhead crossing by u/c 765kV Bhadla 2 - Sikar 2 TLC TW02	02/Oct/2023	09:00	03/Oct/2023	17:00	Shutdown may be availed in Sept-23.	PLANNED	Approved	02-Oct-23	17:00	03-Oct-23	23:00	ATC Curtailment of 200/1300 MW in NR Import/Export for D/C outage. May be availed from 17:00 hrs. Subjected to WRPC approval
66	RQ146118	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-2	D	overhead crossing by u/c 765kV Bhadla 2 - Sikar 2 TLC TW02	02/Oct/2023	09:00	03/Oct/2023	17:00	Shutdown may be availed in Sept-23.	PLANNED	Approved	02-Oct-23	17:00	03-Oct-23	23:00	ATC Curtailment of 200/1300 MW in NR Import/Export for D/C outage. May be availed from 17:00 hrs. Subjected to WRPC approval
67	RQ146164	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(P G)	D	Commissioning of IC with Spare ICT Bank & CSD Fine tuning works	01/Oct/2023	3 17:00	07/Oct/2023	23:59		PLANNED	Approved	01-Oct-23	17:00	07-Oct-23	23:59	

68	RQ146210	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1000 MVA ICT 2 AT BHIWANI(PG)		D	FOR AMP WORK	01/Oct/2023	09:00	01/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	09:00	01-Oct-23	18:00	
69	RQ146209	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT MEERUT(PG)		D	FOR AMP WORK	01/Oct/2023	09:00	01/Oct/2023	18:30		PLANNED	Approved	01-Oct-23	09:00	01-Oct-23	18:30	
		_	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA- BIKANER (PG) CKT 1		D	Installation of Bird Diverter	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	17:00	15-Oct-23	23:00	May be availed from 17:00 hrs
71	RQ146128	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER- BHADLA_2 (PG) CKT-1		D	Installation of Bird Diverter	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry
72	RQ146131	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER- MOGA (PG) CKT-1		D	Installation of Bird Diverter	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Rejected	01-Oct-23	08:00	15-Oct-23	18:00	To be clubbed when s/d for diversion work is taken.
73	RQ146138	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(P G)-BHADLA(PG) (FBTL) CKT-1		D	Installation of Bird Diverter	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Rejected	01-Oct-23	17:00	15-Oct-23	23:00	May be availed from 17:00 hrs
74	RQ146116	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-1		D	Installation of Bird Diverter	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	17:00	15-Oct-23	23:00	May be availed from 17:00 hrs
75	RQ146147	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KOTESHWAR- MEERUT (PG) CKT- 2		D	Auto Reclose off is required for OPGW INSTALLATION works under Northern Region Optical fibre Strengthening Scheme (NROSS)	01/Oct/2023	08:00	31/Oct/2023	18:00	Non-Auto, on daily basis	PLANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	
76	RQ146680	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI- JABALPUR (PG) CKT-2	POWER GRID	D	FOR AMP WORK OF LINE TERMINAL EQUIPMENT & FOR ATTENDING \$/D NATURE DEFECT IN LINE. FOR REACTOR AMP WORK & FOR SPARE ROTATION AT JABALPUR.DIA TO BE KEPT OPEN AT BOTH NON AUTO MODE I TO FACILITATE WORK IN 765KV JABALPUR ORAI # 2 BY WR2	26/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	ATC Curtailment of 900 MW in NR ilmport.
77	RQ146719	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI GAYA (PG) CKT-2		D	Replacemnt of Broken Insulators & Rectification of other Shutdown defects by ER1	16/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	17-Oct-23	18:00	
78	RQ146690	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI- GWALIOR (PG) CKT-1	POWER GRID	D	To take Spare LR in service(Spare Changeover) at Gwalior end. DIA TO BE KEPT OPEN AT BOTH ENDS by WR2	14/Oct/2023	08:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	

		OCC_211		AC TRANSMISSION LINE CIRCUIT	BANASKANTHA (PG) CKT-2	POWER GRID	D	TO ATTEND CROSS PATROLLING DEFECTS & To configure Line Reactor Tripping on Single phase fault as per CC approval. DIA TO BE KEPT OPEN AT BOTH ENDS.	13/Oct/2023		13/Oct/2023		S/D by WR-2	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	ATC Curtailment of 200/1750 MW in NR Import/Export.
		OCC_211		AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH- BANASKANTHA (PG) CKT-1	POWER GRID	D	A/R IN NON AUTO MODE REQUIRED AT BOTH ENDS FOR FACILITATING WORKS IN 765KV BANASKANTHA- CHITTORGARH # 2	13/Oct/2023		13/Oct/2023		only Non auto mode by WR-2		Approved	13-Oct-23	08:00	13-Oct-23	18:00	
81	RQ146802	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH- BANASKANTHA (PG) CKT-1	POWER GRID	D	TO ATTEND CROSS PATROLLING DEFECTS & To configure Line Reactor Tripping on Single phase fault as per CC approval. DIA TO BE KEPT OPEN AT BOTH ENDS.	12/Oct/2023	08:00	12/Oct/2023	18:00	S/D by WR-2	PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	ATC Curtailment of 200/1750 MW in NR Import/Export.
82	RQ146803	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH- BANASKANTHA (PG) CKT-2	POWER GRID	D	A/R IN NON AUTO MODE REQUIRED AT BOTH ENDS FOR FACILITATING WORKS IN 765KV BANASKANTHA- CHITTORGARH # 1	12/Oct/2023	08:00	12/Oct/2023	18:00	request by wr2	PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
83	RQ146806	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS) GWALIOR(PG) (PG) CKT-1	-POWER GRID	С	NHAI line Diverson work.DIA TO BE KEPT OPEN AT BOTH ENDS.	10/Oct/2023	08:00	25/Oct/2023	18:00	S/D by WR-2	PLANNED	Approved	10-Oct-23	08:00	25-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before charging of line. ATC Curtailment of 500 MW in NR Import
84	RQ146724	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BALIA- GAYA (PG) CKT-1	POWER GRID	D	Replacement of Porcelain Insulators with Polymer Insulators at major crossings by ER1	09/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	15-Oct-23	18:00	
85	RQ145957	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BALIA- GAYA (PG) CKT-1	POWER GRID	D	Replacement of connector and pilot insulator string	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved					To be clubbed with sl 84
86	RQ146666	OCC_211	cpcc3_sd	AC	765 KV ORAI- JABALPUR (PG) CKT-1	POWER GRID	D	FOR AMP WORK OF LINE TERMINAL EQUIPMENT & FOR ATTENDING S/D NATURE DEFECT IN LINE. FOR REACTOR AMP WORK & FOR SPARE ROTATION AT JABALPUR.DIA TO BE KEPT OPEN AT BOTH ENDS.CKT 2 -A/R IN NON AUTO MODE I TO FACILITATE WORK IN 765KV JABALPUR - ORAI # 1 BY WR2	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	ATC Curtailment of 900 MW in NR ilmport.

87	RO146718	OCC_211	cncc3 sd	AC	765 KV VARANASI	POWER	D	Replacement of	05/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	07-Oct-23	18:00	1
0,	NQ140710	000_211	cpcc3_3u		GAYA (PG) CKT-1			Porcelain Insulators	03/000/2023	00.00	07/000/2023	10.00		DANIVED	Аррготса	05 000 25	00.00	07 000 23	10.00	
				LINE CIRCUIT				with Polymer												
								Insulators at major												
								crossings by ER1												
88	RQ146681	OCC_211	cpcc3_sd	AC	765 KV ORAI-	POWER	D	For OPGW stringing	01/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	Subjected to WRPC approval
					JABALPUR (PG)	GRID		under live line												
				LINE CIRCUIT	CKT-1			condition. A/R IN NON AUTO MODE IS												
								REQUIRED AT BOTH												
								ENDS.												
89	RQ146395	OCC_211	cpcc1_sd	HVDC LINE	500 KV HVDC		С	AMP work	09/Oct/2023	09:00	11/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	09:00	11-Oct-23	18:00	
				CIRCUIT	BALIA-BHIWADI															
					(PG) CKT-2															
90	RQ145346	OCC_211	apl_sd	HVDC LINE	500 KV HVDC	POWER	D	OPGW	01/Oct/2023	08:00	31/Oct/2023	18:30	No outage	PLANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:30	Subjected to WRPC approval
				CIRCUIT	MAHINDERGARH(	GRID		REPLACEMENT					Required							
					APL)-ADANI MUNDRA(APL)			WORK (Replacement of old earthwire with												
					(ATIL) CKT-2			OPGW). No outage is												
					(ATIL) CKT-2			required. Work will												
								be carried out online.												
91	RQ146086	OCC_211	cpcc1_sd	AC	400 KV KANPUR-		D	For taking line	28/Oct/2023	18:00	28/Oct/2023	19:00		PLANNED	Approved	28-Oct-23	18:00	28-Oct-23	19:00	
					BALLABHGARH			reactor into service.												
- 00	00446400	000 244		LINE CIRCUIT	(PG) CKT-1			F	20/0 - /2022	47.00	20/0 - / /2022	22.50		DIANNED	A	20.0.1.22	47.00	20.0.1.22	22.50	Mar. 1
92	KQ146180	OCC_211	cpcc1_sa	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT		D	For pending construction related	28/Oct/2023	17:00	30/Oct/2023	23:59		PLANNED	Approved	28-Oct-23	17:00	30-Oct-23	23:59	May be given from 1700 Hrs
					FATEHGARH_II(P			works and LM												
					G)			erection Works												
93	RQ146049	OCC_211	cpcc1_sd	AC	400 KV BHINMAL-		D	TL CROSS	27/Oct/2023	08:00	29/Oct/2023	18:00	400 KV	PLANNED	Approved	27-Oct-23	08:00	29-Oct-23	18:00	
				TRANSMISSION	KANKROLI (PG)			PATROLLING					KANKROLI-							
				LINE CIRCUIT	CKT-1			DEFECTS ATTENDING					ZERDA (PG)							
								AND SHUTDOWN					CKT-1 to be							
								RELATED WORK &					kept in non							
								AMP / SHUTDOWN RELATED WORK					auto mode							
								KELATED WORK												
94	RQ146214	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500		D	AMP	26/Oct/2023	17:00	26/Oct/2023	23:59		PLANNED	Approved	26-Oct-23	17:00	26-Oct-23	23:59	May be given from 1700 Hrs
		_			MVA ICT 4 AT															
					BHADLA_2 (PG)															
95	RQ146085	OCC_211	cpcc1_sd	AC	400 KV KANPUR-		D	For taking line	26/Oct/2023	09:00	26/Oct/2023	10:00		PLANNED	Approved	26-Oct-23	09:00	26-Oct-23	10:00	
					BALLABHGARH			reactor out of												
00	DO14C442	000 311	1	LINE CIRCUIT	(PG) CKT-1		-	service.	20/0+/2022	00.00	20/0+/2022	10.00		DIANNED	A	20 0+ 22	00.00	20 0++ 22	10.00	
96	KQ146443	OCC_211	chcc1_sq	BAY	411 TIE BAY - 400KV		D	For bay AMP Works	26/Oct/2023	08:00	26/Oct/2023	19:00		PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
					ROORKEE(PG)-															
					KASHIPUR(UK)															
					(PG) CKT-2 AND															
					125 MVAR BUS															
					REACTOR NO 1															
		1	1		AT 400KV							1								
					ROORKEE(PG)				0.1/0.1/0		0.5 /0 . /0			B1 44115	ļ	24.0			22.50	
97	KQ146213	OCC_211	cpcc1_sd	IRANSFORMER	400/220 KV 500		D	TERTIARY	24/Oct/2023	1/:00	25/Oct/2023	23:59		PLANNED	Approved	24-Oct-23	17:00	25-Oct-23	23:59	May be given from 1700 Hrs
					MVA ICT 6 AT BHADLA_2 (PG)			TRANSFORMER ERECTION WORK												
98	RO146178	OCC_211	cncc1 sd	TRANSFORMER	400/220 KV 500	1	D	For testing and	23/Oct/2023	17:00	25/Oct/2023	23.59	+	PLANNED	Approved	23-Oct-23	17:00	25-Oct-23	23:59	May be given from 1700 Hrs
00		000_211	opeci_su		MVA ICT 3 AT		D	commissioning works	23,000,2023	17.00	25,000,2023	23.33		CANTILLE	, ipproved	23 000 23	17.00	25 000 25	23.33	, Se given nom 1700 ms
		1	1		FATEHGARH_II(P			with TBC Bay				1								
					G) _ `			1												
														_						

99	RQ146029	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAHADURGARH- SONIPAT (PG) CKT-	D	For AMP of Line Bay	23/Oct/2023	09:00	23/Oct/2023	18:00		PLANNED	Approved	23-Oct-23	09:00	23-Oct-23	18:00	
100	RQ146177	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT FATEHGARH_II(P G)	D	For testing and commissioning works with TBC Bay	21/Oct/2023	17:00	23/Oct/2023	23:59		PLANNED	Approved	21-Oct-23	17:00	23-Oct-23	23:59	May be given from 1700 Hrs
101	RQ146181	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT FATEHGARH_II(P G)	D	For erection works of 33 kV Auxiliary transformer of Statcom-1 and its commissioning	21/Oct/2023	17:00	27/Oct/2023	23:59		PLANNED	Approved	21-Oct-23	17:00	27-Oct-23	23:59	May be given from 1700 Hrs
102	RQ146186	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 6 AT FATEHGARH_II(P G)	D	ICT-6 CSD Relay final tuning and TBC testing of LV side bay	21/Oct/2023	17:00	29/Oct/2023	23:59		PLANNED	Approved	21-Oct-23	17:00	29-Oct-23	23:59	May be given from 1700 Hrs
103	RQ146437	OCC_211	cpcc1_sd	BAY	407 MAIN BAY - 400KV BAHADURGARH- SONIPAT (PG) CKT- 2 AT SONIPAT(PG)	D	For bay AMP Works	21/Oct/2023	09:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	09:00	21-Oct-23	18:00	
104	RQ146070	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS )-KANKROLI(PG) (PG) CKT-1	D	AMP / SHUTDOWN RELATED WORK	21/Oct/2023	08:00	21/Oct/2023	18:00	400 KV RAPS_C(NP)- KANKROLI(PG) (PG) CKT-1 to be kept non Auto mode	PLANNED	Approved	21-Oct-23	17:00	21-Oct-23	23:00	May be given from 1700 Hrs
105	RQ146208	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT BHADLA(PG)	D	FOR AMP WORK	20/Oct/2023	17:00	20/Oct/2023	23:59		PLANNED	Approved	20-Oct-23	17:00	20-Oct-23	23:59	May be given from 1700 Hrs
106	RQ146207	OCC_211	cpcc1_sd	TRANSFORMER		D	FOR AMP WORK	20/Oct/2023	10:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	10:00	20-Oct-23	18:00	
107	RQ146442	OCC_211	cpcc1_sd	ВАУ	410 MAIN BAY - 400KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-2 AT ROORKEE(PG)	D	For bay AMP Works	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
108	RQ146056	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI(PG)- KABULPUR(HV)	D	To attend Shutdown Nature Defects	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
109	RQ146176	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT FATEHGARH_II(P G)	D	For testing and commissioning works with TBC Bay	19/Oct/2023	17:00	21/Oct/2023	23:59		PLANNED	Approved	19-Oct-23	17:00	21-Oct-23	23:59	May be given from 1700 Hrs
110	RQ146429	OCC_211	cpcc1_sd	ВАУ	208 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT BHINMAL(PG) (POWERGRID)	D	For bay AMP Works	19/Oct/2023	09:00	19/Oct/2023	17:30		PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	17:30	
111	RQ146023	OCC_211	cpcc1_sd		400 KV AGRA- BALLABHGARH (PG) CKT-1	D	For AMP of Line Bay/ For taking line reactor in service.	19/Oct/2023	09:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	18:00	
112	RQ146050	OCC_211	cpcc1_sd	AC	400 KV BHINMAL- ZERDA (PG) CKT-1	D	TL CROSS PATROLLING DEFECTS ATTENDING AND SHUTDOWN RELATED WORK	19/Oct/2023	08:00	21/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	21-Oct-23	18:00	Subjected to WRPC approval

113 F	RQ146200	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BASSI(PG)	D	FOR AMP WORK	18/Oct/2023	10:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	10:00	18-Oct-23	18:00	
114 F	RQ146433	3 OCC_211	cpcc1_sd	ВАУ	405 TIE BAY - 400KV BAHADURGARH(P G)- KABULPUR(HV) (PG) CKT-1 AND 400/220KV 500 MVA ICT 2 AT BAHADURGARH(P G)	D	For bay AMP Works	18/Oct/2023	09:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	09:00	18-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_D(NP)- KOTA(PG) (PG) CKT-2		Additional glass disc insertion: LOA given	18/Oct/2023		19/Oct/2023		Non auto for 400 kV RAPPD- Jaipur South	PLANNED	Approved	18-Oct-23	17:00	19-Oct-23	23:00	May be given from 1700 Hrs
		OCC_211		ВАУ	440 TIE BAY - 400/220 KV 500 MVA ICT 1 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 400 KV BHADLA_2 (PG) (POWERGRID)		АМР	17/Oct/2023		17/Oct/2023			PLANNED		17-Oct-23	17:00	17-Oct-23	23:59	May be given from 1700 Hrs
117 F	RQ14620!	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT SIKAR(PG)	D	FOR AMP WORK	17/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
118 F	RQ146204	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT ROORKEE(PG)	D	FOR AMP WORK	17/Oct/2023	08:00	17/Oct/2023	20:00		PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	20:00	
119 F	RQ146449	OCC_211	cpcc1_sd	BAY	401 MAIN BAY - 400 KV BASSI(PG)- HEERAPURA(RS) (PG) CKT-1 AT HEERAPURA(RS)		BAY LBB RETROFITMENT WORK	16/Oct/2023	10:00	17/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	10:00	17-Oct-23	18:00	Element must remain in service via other bay.
120 F	RQ14643	2 OCC_211	cpcc1_sd	BAY	410 MAIN BAY - 400KV BAHADURGARH- SONIPAT (PG) CKT- 2 AT BAHADURGARH(P G)	D	For bay AMP Works	16/Oct/2023	09:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	
121 F	RQ146030	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAHADURGARH- SONIPAT (PG) CKT- 2	D	For AMP of Line Bay	16/Oct/2023	09:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	
		3 OCC_211		AC TRANSMISSION LINE CIRCUIT	JAIPUR SOUTH(PG) (PG) CKT-1		Additional glass disc insertion: LOA given	16/Oct/2023		17/Oct/2023		Non auto for 400 kV RAPPD- Kota	PLANNED		16-Oct-23	17:00	17-Oct-23	23:00	May be given from 1700 Hrs
123 F	RQ146048	3 OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(RS)- BHADLA(PG) (PG) CKT-2		Installation of Bird Diverter	16/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	17:00	31-Oct-23	23:59	May be given from 1700 Hrs
124 F	RQ14604!	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV		Installation of Bird Diverter	16/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	17:00	31-Oct-23	23:59	May be given from 1700 Hrs

125	RQ146081	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(P G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-2	D	Installation of Bird Diverter	16/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	17:00	31-Oct-23	23:59	May be given from 1700 Hrs
126	RQ146084	OCC_211	cpcc1_sd		400 KV KANKROLI- ZERDA (PG) CKT-1	D	AMP / SHUTDOWN RELATED WORK & TL DEFECTS ATTENDING AND SHUTDOWN RELATED WORK	16/Oct/2023	08:00	19/Oct/2023	18:00	400 KV BHINMAL- KANKROLI (PG) CKT-1 to kept in non-auto mode	PLANNED	Approved	16-Oct-23	08:00	19-Oct-23	18:00	ATC Curtailment of 1350 MW in NR Export. Subjected to WRPC approval
127	RQ146082	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR(UP)- MORADABAD(UP) (PG) CKT-1	С	DIVERSION WORK BETWEEN 171-174 & 226 & 228	16/Oct/2023	06:00	31/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	06:00	04-Nov-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/UP Consent required.
128	RQ146418	OCC_211	cpcc1_sd	BAY	436 MAIN BAY - 400KV KANPUR- BALLABHGARH (PG) CKT-2 AT BALLABHGARH(P	D	For bay AMP Works	15/Oct/2023	09:00	15/Oct/2023	18:00		PLANNED	Approved	15-Oct-23	09:00	15-Oct-23	18:00	
129	RQ146042	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAWANA CCGTB(DTL)- BHIWANI(PG) (PG)	D	To attend Shutdown Nature Defects	15/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	15-Oct-23	08:00	15-Oct-23	18:00	
130	RQ146184	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(P G)	D	LBB testing and TBC testing of ICT-7 with TBC Bay and Tertiary Bay erection and commissioning works	14/Oct/2023	17:00	20/Oct/2023	23:59		PLANNED	Approved	14-Oct-23	17:00	20-Oct-23	23:59	May be given from 1700 Hrs
131	RQ146101	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- HISSAR (PG) CKT- 3	D	Liquidation of Shut Down nature defects	14/Oct/2023	09:00	14/Oct/2023	19:00	A/R of 400 KV MOGA-HISSAR (PG) CKT-2 required to be on non-auto mode	PLANNED	Approved	14-Oct-23	09:00	14-Oct-23	19:00	
132	RQ146032	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALLABHGARH(P G)- TUGHLAKABAD(P G) (DTL) CKT-2	D	to attend SD nature defects	14/Oct/2023	08:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	
		OCC_211		LINE CIRCUIT	TUGHLAKABAD(P G) (DTL) CKT-1	D	to attend SD nature defects	14/Oct/2023		14/Oct/2023			PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	
134	RQ146040	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI- SIKAR (PG) CKT-2	D	FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK & Line Bay AMP work	14/Oct/2023	08:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	
135	RQ146405	OCC_211	cpcc1_sd	ВАУ	426 TIE BAY - 400/220 KV 500 MVA ICT 7 AT BHADLA(PG) (POWERGRID) AND FUTURE AT 400 KV BHADLA(PG) (POWERGRID)	D	FOR BAY AMP WORK	13/Oct/2023	17:00	13/Oct/2023	23:59		PLANNED	Approved	13-Oct-23	15:00	13-Oct-23	23:59	May be given from 1500 Hrs

136	RQ146226	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT BHADLA(PG)	D	For installation and testing of Backup Impedance relay in ICT	13/Oct/2023	17:00	13/Oct/2023	23:59		PLANNED	Approved	13-Oct-23	17:00	13-Oct-23	23:59	May be given from 1700 Hrs
137	RQ146448	OCC_211	cpcc1_sd	BAY	403 MAIN BAY - 400KV HEERAPURA- HINDAUN (RS) CKT-1 AT HEERAPURA(RS)	С	BAY LBB RETROFITMENT WORK	13/Oct/2023	10:00	14/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	10:00	14-Oct-23	18:00	Element must remain in service via other bay.
138	RQ146436	OCC_211	cpcc1_sd	BAY	404 MAIN BAY - 400KV BAHADURGARH(P G)- KABULPUR(HV) (PG) CKT-1 AT BAHADURGARH(P G)	D	For bay AMP Works	13/Oct/2023	09:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	09:00	13-Oct-23	18:00	
				ВАУ	409 MAIN BAY - 80 MVAR BUS REACTOR NO 1 AT 400KV SIKAR(PG)		AMP	13/Oct/2023		13/Oct/2023			PLANNED	Approved	13-Oct-23	09:00	13-Oct-23	18:00	
140	RQ146100	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- HISSAR (PG) CKT- 2	D	Liquidation of Shut Down nature defects	13/Oct/2023	09:00	13/Oct/2023	18:00	A/R of 400 KV MOGA-HISSAR (PG) CKT-2 required to be on non-auto mode	PLANNED	Approved	13-Oct-23	09:00	13-Oct-23	18:00	
141	RQ146441	OCC_211	cpcc1_sd	BAY	407 MAIN BAY - 400KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-1 AT ROORKEE(PG)	D	For bay AMP Works	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
142	RQ146106	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)- CHITTORGARH(RS ) (PG) CKT-1	D	Additional glass disc insertion: LOA given	13/Oct/2023	08:00	14/Oct/2023	18:00	Non auto for 400 kV RAPPC- Kankroli	PLANNED		13-Oct-23	17:00	14-Oct-23	23:00	May be given from 1700 Hrs
		OCC_211		LINE CIRCUIT	400 KV BASSI- SIKAR (PG) CKT-1	D	Porcelain insulator cleaning work & Line Bay AMP work / FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK	13/Oct/2023		13/Oct/2023			PLANNED		13-Oct-23	08:00	13-Oct-23	18:00	
144	RQ146225	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT BHADLA(PG)	D	For installation and testing of Backup Impedance relay in ICT	12/Oct/2023	17:00	12/Oct/2023	23:59		PLANNED	Approved	12-Oct-23	17:00	12-Oct-23	23:59	May be given from 1700 Hrs
145	RQ146419	OCC_211	cpcc1_sd	BAY	419 MAIN BAY - 400KV MAINPURI- BALLABHGARH (PG) CKT-2 AT BALLABHGARH(P G)	D	For bay AMP Works	12/Oct/2023	09:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	09:00	12-Oct-23	18:00	
146	RQ146435	OCC_211	cpcc1_sd	ВАУ	403 MAIN BAY - 400/220KV 315 MVA ICT 1 AT BAHADURGARH(P G)	D	For bay AMP Works	12/Oct/2023	09:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	09:00	12-Oct-23	18:00	

147	RQ146221	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MANDOLA(PG)	D	FOR AMP	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
148	RQ146028	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAHADURGARH(P G)- KABULPUR(HV) (PG) CKT-1	D	To attend Shutdown Nature Defects	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
149	RQ146027	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA- SIKAR (PG) CKT-2	D	FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
150	RQ146038	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI(PG)- PHAGI(RS) (PG) CKT-2	D	Porcelain insulator cleaning work	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
151	RQ146224	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BHADLA(PG)	D	For installation and testing of Backup Impedance relay in ICT	11/Oct/2023	17:00	11/Oct/2023	23:59		PLANNED	Approved	11-Oct-23	17:00	11-Oct-23	23:59	May be given from 1700 Hrs
152	RQ146447	OCC_211	cpcc1_sd	ВАУ	4402 TIE BAY - 400KV BASSI(PG)- HEERAPURA(RS) (PG) CKT-1 AND 400KV HEERAPURA- HINDAUN (RS) CKT-1 AT HEERAPURA(RS)	c	BAY LBB RETROFITMENT WORK	11/Oct/2023	10:00	12/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	10:00	12-Oct-23	18:00	Element must remain in service via other bay.
153	RQ146060	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI- JIND (PG) CKT-2	D	Liquidation of Shut Down nature defects and closing of notification	11/Oct/2023	09:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	09:00	11-Oct-23	18:00	
154	RQ146069	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS )- CHITTORGARH(P G) (PG) CKT-2	D	TO ATTEND SHUT DOWN NATURE DEFECTS	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	17:00	11-Oct-23	23:00	May be given from 1700 Hrs
155	RQ146026	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA- SIKAR (PG) CKT-1	D	FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
156	RQ146037	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI(PG)- PHAGI(RS) (PG) CKT-1	D	Porcelain insulator cleaning work	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
157	RQ146107	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)- KANKROLI(PG) (PG) CKT-1	D	Additional glass disc insertion: LOA given & AMP / SHUTDOWN RELATED WORK	11/Oct/2023	08:00	12/Oct/2023	18:00	Non auto for 400 kV RAPPC- Chittorgarh & 400 KV CHITTORGARH (RS)- KANKROLI(PG) (PG) CKT-1 to kept in Non - Auto Mode	PLANNED	Approved	11-Oct-23	17:00	12-Oct-23	23:00	May be given from 1700 Hrs
158	RQ146223	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BHADLA(PG)	D	For installation and testing of Backup Impedance relay in ICT	10/Oct/2023	17:00	10/Oct/2023	23:59		PLANNED	Approved	10-Oct-23	17:00	10-Oct-23	23:59	May be given from 1700 Hrs

159 F	RQ146818	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400KV KANKROLI(PG)	D	AMP work	10/Oct/2023	09:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	17:00	10-Oct-23	23:00	May be given from 1700 Hrs
160 F	RQ146434	OCC_211	cpcc1_sd	BAY	402 TIE BAY - 400 KV BAWANA CCGTB(DTL)- BAHADURGARH(P G) (PG) CKT-1 AND 400/220 KV 315 MVA ICT 1 AT BAHADURGARH(P G)	D	For bay AMP Works	10/Oct/2023	09:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	18:00	
161 F	RQ146059	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI- JIND (PG) CKT-1	D	Liquidation of Shut Down nature defects and closing of notification	10/Oct/2023	09:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	18:00	
162 F	RQ146094	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI- BALLABHGARH (PG) CKT-2	С	For shifting of line bay equipments for line reactor commissioning work.	10/Oct/2023	09:00	12/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	09:00	12-Oct-23	18:00	
163 F	RQ146440	OCC_211	cpcc1_sd	ВАУ	403 MAIN BAY - 400/220KV 315 MVA ICT 1 AT ROORKEE(PG)	D	For bay AMP Works	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
164 F	RQ146041	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAWANA CCGTB(DTL)- BAHADURGARH(P G) (PG) CKT-1	D	To attend Shutdown Nature Defects	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
165 F	RQ146052	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI- HISSAR (PG) CKT- 2	С	FOR NCRTC DIVERSION WORK	10/Oct/2023	08:00	30/Oct/2023	18:00	PLANNED	Approved	20/10/202	08:00	30-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Haryana consent required/Only two continuous shutdown would be given at a time
		OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI- HISSAR (PG) CKT- 3	С	FOR NCRTC DIVERSION WORK	10/Oct/2023		30/Oct/2023	18:00	PLANNED	Approved	20/10/202	08:00	30-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Haryana consent required/Only two continuous shutdown would be given at a time.
167 F	RQ146112	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SIKAR(PG)- BABAI(RS) (NRSS36) CKT-1	D	FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
168 F	RQ146068	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS )- CHITTORGARH(P G) (PG) CKT-1	D	TO SHUT DOWN DEFECT	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	17:00	10-Oct-23	23:00	May be given from 1700 Hrs
169 F	RQ146222	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BHADLA(PG)	D	For installation and testing of Backup Impedance relay in ICT	09/Oct/2023	17:00	09/Oct/2023	23:59	PLANNED	Approved	09-Oct-23	17:00	09-Oct-23	23:59	May be given from 1700 Hrs

170	RQ146817	OCC_211	cpcc1_sd		50 MVAR BUS	D	AMP work	09/Oct/2023	09:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	17:00	09-Oct-23	23:00	May be given from 1700 Hrs
				MSR	REACTOR NO 1														
					AT 400KV														
					KANKROLI(PG)												ļ		
171	RQ146814	OCC_211	cpcc1_sd	BR/BSR/MSC/	80 MVAR BUS	D	AMP work	09/Oct/2023	3 08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
				MSR	REACTOR NO 1														
					AT 400KV														
					NEEMRANA(PG)														
172	RQ146111	OCC_211	cpcc1_sd	AC	400 KV	D	Shut down defect	09/Oct/2023	08:00	14/Oct/2023	20:00	Non auto of	PLANNED	Approved	09-Oct-23	08:00	14-Oct-23	20:00	
				TRANSMISSION			rectification works					Ckt 1							
				LINE CIRCUIT	KASHIPUR(UK)														
					(PG) CKT-2														
173	RQ146105	OCC_211	cpcc1_sd	AC	400 KV	D	FOR CLEANING OF	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
				TRANSMISSION	NEEMRANA-		INSULATOR AND												
				LINE CIRCUIT	SIKAR (PG) CKT-2		SHUT DOWN												
							RELATED WORK & SD												
							nature defect												
							rectification work												
							i.e.IGR, Jumper Nut-												
							bolt Tightinning,CC												
							ring fixing etc.												
174	RQ146179	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	For pending	07/Oct/2023	17:00	17/Oct/2023	23:59		PLANNED	Approved	07-Oct-23	17:00	17-Oct-23	23:59	May be given from 1700 Hrs
					MVA ICT 4 AT		construction related												
					FATEHGARH_II(P		works and LM												
					G)		erection Works												
175	RQ146431	OCC_211	cpcc1_sd	BAY	411 TIE BAY -	D	For bay AMP Works	07/Oct/2023	3 09:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	09:00	07-Oct-23	18:00	
					400KV														
					BAHADURGARH-														
					SONIPAT (PG) CKT														
					2 AND FUTURE AT														
					BAHADURGARH(P														
					G)														
176	RQ146428	OCC_211	cpcc1_sd	BAY	411 TIE BAY - 400	D	For bay AMP Works	07/Oct/2023	09:00	07/Oct/2023	17:30		PLANNED	Approved	07-Oct-23	09:00	07-Oct-23	17:30	
					KV BHINMAL(PG)-														
					BARMER(RS) (RS)														
					CKT-2														
					(POWERGRID)														
					AND FUTURE AT														
					400 KV														
					BHINMAL(PG)														
					(POWERGRID)														
					1		1												
177	RQ146031	OCC_211	cpcc1_sd	AC	400 KV	D	to attend SD nature	07/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	08:00	07-Oct-23	18:00	
				TRANSMISSION	BALLABHGARH(P		defects												
				LINE CIRCUIT	G)-		1												
			1		TUGHLAKABAD(P	1 1	1												
					G) (DTL) CKT-1		1												
178	RQ146034	OCC_211	cpcc1_sd	AC	400 KV	D	to attend SD nature	07/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	08:00	07-Oct-23	18:00	
		-	_	TRANSMISSION			defects												
				LINE CIRCUIT	TUGHLAKABAD(P		1												
					G) (DTL) CKT-2		1												
179	RQ146220	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	С	BUS BAR	07/Oct/2023	08:00	08/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	08:00	08-Oct-23	18:00	May be given subject to real
				1	MVA ICT 4 AT		RETROFITTING						1		1	1			time grid conditions/One ICT
			1		MANDOLA(PG)	1 1	WORK												shutdwon at a time
180	RQ146430	OCC_211	cpcc1 sd	BAY	406 MAIN BAY -	D	For bay AMP Works	06/Oct/2023	3 09:00	06/Oct/2023	18:00	1	PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	18:00	
-50	0 .50			I	400/220KV 500			1., 200, 2020	1	22, 20, 2023							11 200 23		
					MVA ICT 2 AT		1												
					BAHADURGARH(P		1												
					G)		1												
$\bot$		l	L	1	· · /	1	1		1			1	<u> </u>		L		1		1

181	RQ146093	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI- BALLABHGARH (PG) CKT-1		For shifting of line bay equipments for line reactor commissioning work.	06/Oct/2023	09:00	08/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	09:00	08-Oct-23	18:00	
182	RQ146439	OCC_211	cpcc1_sd	BAY	416 MAIN BAY - 400KV ROORKEE- SAHARANPUR (PG) CKT-1 AT ROORKEE(PG)	D	For bay AMP Works	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
183	RQ146114	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SIKAR(PG)- RATANGARH(RS) (PG) CKT-2		FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK & Line Bay AMP work	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
184	RQ146183	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 8 AT FATEHGARH_II(P G)		ICT-9 CSD Relay final tuning and other pending construction works	05/Oct/2023	17:00	09/Oct/2023	23:59		PLANNED	Approved	05-Oct-23	17:00	09-Oct-23	23:59	May be given from 1700 Hrs
185	RQ146185	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(P G)		ICT-7 CSD Relay final tuning and other pending construction works	05/Oct/2023	17:00	11/Oct/2023	23:59		PLANNED	Approved	05-Oct-23	17:00	11-Oct-23	23:59	May be given from 1700 Hrs
186	RQ146413	OCC_211	cpcc1_sd	BAY	402 TIE BAY - 400KV KANKROLI(PG)- JODHPUR(RS) (PG) CKT-1 AND 125 MVAR BUS REACTOR NO 2 AT 400KV KANKROLI(PG)	D	For bay AMP Works	05/Oct/2023	09:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	15:00	05-Oct-23	23:00	May be given from 1500 Hrs
187	RQ146216	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT NEEMRANA(PG)	D	FOR AMP WORK	05/Oct/2023	08:00	05/Oct/2023	20:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	20:00	
188	RQ146095	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MANDOLA(PG)- MAHARANIBAGH( PG) (DTL) CKT-1		Auto Reclose off is required for OPGW INSTALLATION works under Northern Region Optical fibre Strengthening Scheme (NROSS)	05/Oct/2023	08:00	15/Oct/2023	18:00	Non-Auto, on daily basis; Shutdown may be availed in Sept-23.	PLANNED	Approved	05-Oct-23	08:00	15-Oct-23	18:00	
189	RQ146113	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SIKAR(PG)- RATANGARH(RS) (PG) CKT-1		FOR CLEANING OF INSULATOR AND SHUT DOWN RELATED WORK & Line Bay AMP work	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
190	RQ146066	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER_2 (PBTSL)-KHETRI (PKTSL) (PBTSL) CKT-4		For rectification work in transmission line	05/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	17:00	06-Oct-23	23:00	May be given from 1700 Hrs
191	RQ146065	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV		For rectification work in transmission line	05/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	17:00	06-Oct-23	23:00	May be given from 1700 Hrs
192	RQ146219	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MANDOLA(PG)		BUS BAR RETROFITTING WORK	05/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	06-Oct-23	18:00	May be given subject to real time grid conditions/One ICT shutdwon at a time

193	RQ14641	2 OCC_21	cpcc1_sd	ВАУ	401 MAIN BAY - 400KV KANKROLI(PG)-	D	For bay AMP Works	04/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	15:00	04-Oct-23	23:00	May be given from 1500 Hrs
194	RQ14643	8 OCC_21	L cpcc1_sd	BAY	JODHPUR(RS) (PG) CKT-1 AT KANKROLI(PG) 413 MAIN BAY -	D	For bay AMP Works	04/Oct/2023	8 08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
					400KV ROORKEE- DEHRADUN (PG) CKT-1 AT ROORKEE(PG)														
195	RQ14620	0 OCC_21	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT BALLABHGARH(P G)	D	For replacement of LBB relay of 220KV CB.	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
			L cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	PANIPAT(BB) (PG) CKT-1	D	DEFECT RECTIFICATION WORK IN MODEL TRANSMISSION LINE	04/Oct/2023		04/Oct/2023		be availed in Sept-23.	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	May be given subject to real time grid conditions and no other shutdown from Dadri end.
197	RQ14618	2 OCC_21	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 9 AT FATEHGARH_II(P G)	D	For commissioning works of 400 kV ICT- 6 under SS-63 package and ICT-9 CSD Relay final tuning, other pending construction works	03/Oct/2023	3 17:00	10/Oct/2023	23:59	for LBB testing of Bay 443 for commissioning check with ICT- 6 LV Bay(BaY 231)	PLANNED	Approved	03-Oct-23	17:00	10-Oct-23	23:59	May be given from 1700 Hrs
198	RQ14607	1 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)- BALLABHGARH(P G) (PG)	D	INSULATOR REPLACEMENT WORK AT TOWER NO. 33	03/Oct/2023	10:00	03/Oct/2023	16:00	Shutdown may be availed in Sept-23.	PLANNED	Approved	03-Oct-23	10:00	03-Oct-23	16:00	May be given subject to real time grid conditions and no other shutdown from Dadri end.
199	RQ14607	5 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	D	Shut down defect rectification works	03/Oct/2023	09:00	03/Oct/2023	17:00	Shutdown may be availed in Sept-23.	PLANNED	Approved	03-Oct-23	09:00	03-Oct-23	17:00	
200	RQ14607	6 OCC_21	Cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEHRADUN- ABDULLAPUR (PG) CKT-2	D	Shut down defect rectification works	03/Oct/2023	09:00	03/Oct/2023	17:00	Shutdown may be availed in Sept-23.	PLANNED	Approved	03-Oct-23	09:00	03-Oct-23	17:00	
			L cpcc1_sd		400/220 KV 500 MVA ICT 1 AT NEEMRANA(PG)	D	FOR AMP WORK	03/Oct/2023		03/Oct/2023			PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	20:00	
			L cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BALLABHGARH(P G)	D	For replacement of LBB relay of 220KV CB.	03/Oct/2023		03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
203	RQ14605	5 OCC_21	L cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI(PG)- BHIWANI(BB) (PG)	С	RETROFFITING OF LINE SIDE CVT AT BBMB BHIWANI END BY POWERGRID HISAR GROUP IN ADD CAP	03/Oct/2023	8 08:00	04/Oct/2023	18:00	SHUTDOWN IS IN ADD CAP BLOCK19-24	PLANNED	Approved	03-Oct-23	08:00	04-Oct-23	18:00	Subject to real time grid conditions and BBMB consent
204	RQ14606	4 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER_2 (PBTSL)-KHETRI (PKTSL) (PBTSL) CKT-2	D	For rectification work in transmission line	03/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	17:00	04-Oct-23	23:00	May be given from 1700 Hrs
205	RQ14606	3 OCC_21	L cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER_2 (PBTSL)-KHETRI (PKTSL) (PBTSL) CKT-1	D	For rectification work in transmission line	03/Oct/2023	8 08:00	04/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	17:00	04-Oct-23	23:00	May be given from 1700 Hrs

206	RQ14611	0 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-1	D	Shut down defect rectification works	03/Oct/2023	08:00	08/Oct/2023	20:00	Non auto of Ckt 2	PLANNED	Approved	03-Oct-23	08:00	08-Oct-23	20:00	
207	RQ14621	8 OCC_21	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT MANDOLA(PG)	С	BUS BAR RETROFITTING WORK	03/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	04-Oct-23	18:00	May be given subject to real time grid conditions/One ICT shutdwon at a time
208	RQ14618	8 OCC_21	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT DEHRADUN(PG)	D	AMP WORKS	02/Oct/2023	08:00	02/Oct/2023	18:00	Shutdown to be availed in Sept-23.	PLANNED	Approved	02-Oct-23	08:00	02-Oct-23	18:00	
		8 OCC_21		TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BALLABHGARH(P G)	D	For replacement of LBB relay of 220KV CB.	02/Oct/2023		02/Oct/2023			PLANNED	Approved	02-Oct-23	08:00	02-Oct-23	18:00	
210	RQ14607	8 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(P G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-1	D	For arching horn installation work in Line isolator/earth switch by agency M/s Linxon	01/Oct/2023	17:00	06/Oct/2023	23:30		PLANNED	Approved	01-Oct-23	17:00	06-Oct-23	23:30	May be given from 1700 Hrs
211	RQ14608	0 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(P G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-2	D	For arching horn installation work in Line isolator/earth switch by agency M/s Linxon	01/Oct/2023	17:00	06/Oct/2023	23:30		PLANNED	Approved	01-Oct-23	17:00	06-Oct-23	23:30	May be given from 1700 Hrs
212	RQ14617	5 OCC_21	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 6 AT FATEHGARH_II(P G)	D	FOR STRINGING WORKS OF 765/400 KV ICT-5 LV SIDE	01/Oct/2023	15:00	06/Oct/2023	23:59	REQUIRED FOR SS-63 A1 PACKAGE	PLANNED	Approved	01-Oct-23	17:00	06-Oct-23	23:59	May be given from 1700 Hrs
			cpcc1_sd	LINE CIRCUIT	400 KV BIKANER- MERTA (RS) CKT- 1		overhead crossing by u/c 765kV Bhadla 2 - Sikar 2 TLC TW02	01/Oct/2023		02/Oct/2023		Shutdown may be availed in Sept-23.		Approved	01-Oct-23	17:00	02-Oct-23	23:00	May be given from 1700 Hrs
214	RQ14618	7 OCC_21	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT DEHRADUN(PG)	D	AMP WORKS	01/Oct/2023	08:00	01/Oct/2023	18:00	Shutdown to be availed in Sept-23.	PLANNED	Approved	01-Oct-23	08:00	01-Oct-23	18:00	
215	RQ14604	7 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(RS)- BHADLA(PG) (PG) CKT-1	D	Installation of Bird Diverter	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	17:00	15-Oct-23	23:59	May be given from 1700 Hrs
216	RQ14604	4 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(PG)- BHADLA_2 (PG) (FBTL) CKT-1	D	Installation of Bird Diverter	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	17:00	15-Oct-23	23:59	May be given from 1700 Hrs
217	RQ146079	9 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(P G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-1	D	Installation of Bird Diverter	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	17:00	15-Oct-23	23:59	May be given from 1700 Hrs
218	RQ14619	7 OCC_21	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BALLABHGARH(P G)	D	For replacement of LBB relay of 220KV CB.	01/Oct/2023		01/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	01-Oct-23	18:00	
219	RQ14611	5 OCC_21	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TEHRI(THDC)- KOTESHWAR(PG) (PG) CKT-3	D	Auto Reclose off is required for OPGW INSTALLATION works under Northern Region Optical fibre Strengthening Scheme (NROSS)	01/Oct/2023	08:00	31/Oct/2023	18:00	Non-Auto, on daily basis	PLANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	Subject to tehri consent.

220	RQ146054	OCC_211	cpcc1_sd	AC TRANSMISSION	400 KV BHIWANI(BB)-		С	RETROFFITING OF LINE SIDE CVT AT	01/Oct/2023	08:00	02/Oct/2023	18:00	SHUTDOWN IS IN ADD CAP	PLANNED	Approved	01-Oct-23	08:00	02-Oct-23	18:00	Subject to real time grid conditions and BBMB consent
				LINE CIRCUIT	HISSAR(PG) (PG) CKT-1			BBMB BHIWANI END BY POWERGRID HISAR GROUP IN					BLOCK19-24							conditions and some consent
								ADD CAP												
221	RQ146083	OCC_211	cpcc1_sd	AC TRANSMISSION	400 KV KANKROLI(PG)-		С	RECONDUCTORING WORK	01/Oct/2023	08:00	31/Oct/2023	18:00	ANTI THEFT CHARGING	PLANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	ATC Curtailment of 400 MW in NR Export. Subjected to
				LINE CIRCUIT	JODHPUR(RS) (PG) CKT-1								MAY BE APPROVED							WRPC approval
222	RO146217	OCC_211	cpcc1_sd	TRANSFORMER		1	С	BUS BAR	01/Oct/2023	08:00	02/Oct/2023	18:00	APPROVED	PLANNED	Approved	01-Oct-23	08:00	02-Oct-23	18:00	May be given subject to real
					MVA ICT 1 AT MANDOLA(PG)			RETROFITTING WORK	,,		32, 33, 232				трртого					time grid conditions/One ICT shutdwon at a time
223	RQ146717	OCC_211	cpcc3_sd	AC	400 KV VARANASI		D	Insulator	28/Oct/2023	08:00	01/Nov/2023	18:00		PLANNED	Approved	28-Oct-23	08:00	01-Nov-23	18:00	
					BIHARSHARIFF	GRID		Replacement in Fog												
				LINE CIRCUIT	(PG) CKT-2			Affected Areas by												
								ER1. CKT 1 - A/R Off to facilitate S/D on												
								CKT 2												
224	RQ146716	OCC_211	cpcc3_sd	AC	400 KV VARANASI	I-POWER	D	Insulator	24/Oct/2023	08:00	28/Oct/2023	18:00		PLANNED	Approved	24-Oct-23	08:00	28-Oct-23	18:00	
					BIHARSHARIFF	GRID		Replacement in Fog												
				LINE CIRCUIT	(PG) CKT-1			Affected Areas by												
								ER1. CKT 2 - A/R Off												
								to facilitate S/D on CKT 1												
225	RQ145959	OCC 211	cpcc3_sd	AC	400 KV BALIA-	POWER	D	Insulator Cleaning	21/Oct/2023	08:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	08:00	21-Oct-23	18:00	Subjected to ERPC approval
		_	. –		BIHARSHARIFF	GRID		Work												
				LINE CIRCUIT	(PG) CKT-2															
226	RQ145958	OCC_211	cpcc3_sd	AC	400 KV BALIA- BIHARSHARIFF	POWER GRID	D	Insulator Cleaning	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	Subjected to ERPC approval
				LINE CIRCUIT	(PG) CKT-1	GKID		Work												
227	RQ145961	OCC 211	cpcc3_sd	AC	400 KV BALIA-	POWER	D	Insulator Cleaning	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved					To be clubbed with sl
			. –	TRANSMISSION LINE CIRCUIT	PATNA (PG) CKT- 2	GRID		Work												236/237
228	RQ145960	OCC_211	cpcc3_sd	AC	400 KV BALIA-	POWER	D	Insulator Cleaning	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved					To be clubbed with sl
				LINE CIRCUIT	PATNA (PG) CKT- 1			Work												236/237
229	RQ146729	OCC_211	cpcc3_sd	AC	400 KV	POWER	D	FLASHED INSULATOR REPLACEMENT	09/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	10-Oct-23	18:00	
				LINE CIRCUIT	GORAKHPUR(PG)- MOTIHARI(BS)	- GRID		WORK BY ER1. CKT 2 -												
				EINE CINCOTT	(PG) CKT-1			A/R off to facilitate												
					, -			S/D on Ckt 1												
									20/0 //2000		00/0 //000									
230	RQ146/31	OCC_211	cpcc3_sd	AC TRANSMISSION	400 KV BALIA- BIHARSHARIFF	POWER GRID	D	INSULATOR CLEANING FOR	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
				LINE CIRCUIT	(PG) CKT-2	GKID		WINTER												
				LINE CINCOTT	(1 0) 011 2			PREPAREDNESS BY												
								ER1. CKT -1 - A/R OFF												
								to facilitate S/D on												
								CKT 2	00/0 //0		00/0 //0		4						10.05	
231	KQ146721	OCC_211	cpcc3_sd	AC TRANSMISSION	400 KV BALIA- BIHARSHARIFF	POWER GRID	D	FOR TIE LBB RELAY RETROFITTING	09/Oct/2023	U8:U0	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
				LINE CIRCUIT	(PG) CKT-2	GKID		WORK by ER1. CKT 1 -												
				E.IVE CINCOII	1. 0, CK1-2			A/R off to facilitate												
					ĺ			S/D on Ckt 2												
232	RQ146687	OCC_211	cpcc3_sd	AC	400 KV	POWER	D	Line AMP works by	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Conditionall	06-Oct-23	08:00	06-Oct-23	18:00	Subjected to Unit outage at
				TRANSMISSION LINE CIRCUIT	VINDHYACHALPO	GRID		WR2, Dia to be Kept open at both							y Approved					Rihand 3 & WRPC approval
1				LINE CINCOTT	OL(PG) (PG) CKT-			ends.CKT 1 -A/R in												
					2			non auto mode .												

		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- BIHARSHARIFF (PG) CKT-1	POWER GRID	D	INSULATOR CLEANING FOR WINTER PREPAREDNESS BY ER1. CKT -2 - A/R OFF to facilitate S/D on CKT 1	05/Oct/2023		05/Oct/2023			PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
234	RQ146720	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- BIHARSHARIFF (PG) CKT-1	POWER GRID	D	FOR TIE LBB RELAY RETROFITTING WORK by ER1. CKT 2 - A/R off to facilitate S/D on Ckt 1	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
235	RQ146686	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RIHAND(NT)- VINDHYACHALPO OL(PG) (PG) CKT- 1	POWER GRID	D	Line AMP works by WR2, Dia to be Kept open at both ends.CKT 2 -A/R in non auto mode .	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Conditionall y Approved	04-Oct-23	08:00	04-Oct-23	18:00	Subjected to Unit outage at Rihand 3 & WRPC approval
236	RQ146722	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- PATNA (PG) CKT- 1	POWER GRID		DIVERSION WORK UNDER CONSULTANCY SERVICES TO RVNL by ER1	03/Oct/2023	08:00	23/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	23-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before charging of line
237	RQ146723	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- PATNA (PG) CKT- 2	POWER GRID	С	DIVERSION WORK UNDER CONSULTANCY SERVICES TO RVNL by ER1	03/Oct/2023	08:00	23/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	23-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before charging of line
238	RQ146610	OCC_211	indigrid_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_D(NP)- SHUJALPUR(PG) (RTCL) CKT-1	RTCL		Rajgarh Transmission Limited has submitted a shutdown request for the month of OCT23 to RTCL - IndiGrid, RTCL - IndiGrid, RTCL - IndiGrid on behalf of Rajgarh Transmission Limited, has incorporated this proposed shutdown for the Stringing Work of the 400 KV Pachora-Bhopal under construction Line, so that it can be under consideration for OCC Approval.	20/Oct/2023	09:00	20/Oct/2023	17:00	Stringing Work of U/C 400 KV Pachora- Bhopal Line	PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	17:00	ATC Curtailment of 500 MW in NR Export for D/C outage. Subjected to WRPC approval

239	RQ146612	OCC_211	indigrid_sd	AC TRANSMISSION	400 KV	RTCL	D	Rajgarh Transmission	20/Oct/2023	09:00	20/Oct/2023	17:00	Stringing Work	PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	17:00	ATC Curtailment of 500 MW
				LINE CIRCUIT	SHUJALPUR(PG) (RTCL) CKT-2			Limited has submitted a shutdown request					of U/C 400 KV Pachora- Bhopal Line							in NR Export for D/C outage. Subjected to WRPC approval
								for the month of OCT23 to RTCL - IndiGrid, RTCL -												
								IndiGrid on behalf of Rajgarh Transmission												
								Limited, has incorporated this												
								proposed shutdown for the Stringing												
								Work of the 400 KV Pachora-Bhopal												
								under construction Line, so that it can be												
								under consideration for OCC Approval.												
240	RQ146004	OCC_211	cpcc1_sd		220 KV FATEHGARH_II(P		D	For testing and commissioning works	20/Oct/2023	17:00	22/Oct/2023	23:30		PLANNED	Approved	20-Oct-23	19:00	22-Oct-23	23:30	May be given from 1900 Hrs
				LINE CIRCUIT	G)-AHEJOL PSS HB_FGRAH_PG (AHEJOL)			with TBC Bay												
241	RQ146018	OCC_211	cpcc1_sd	AC TRANSMISSION	(AHEJOL) CKT-2 220 KV		D	Additional glass disc	20/Oct/2023	08:00	21/Oct/2023	18:00	Timely	PLANNED	Approved	20-Oct-23	08:00	21-Oct-23	18:00	
				TRANSMISSION LINE CIRCUIT	ANTA(NT) (PG) CKT-1			insertion: LOA given					requirement of S/D							
242	RQ145999	OCC_211	cpcc1_sd	AC TRANSMISSION	220 KV BHILWARA(RS)-		D	AMP / SHUTDOWN RELATED WORK	18/Oct/2023	09:00	18/Oct/2023	13:30		PLANNED	Approved	18-Oct-23	15:00	18-Oct-23	23:00	May be given from 1500 Hrs
				LINE CIRCUIT	KANKROLI(PG) (RS) CKT-1															
243	RQ146017	OCC_211	cpcc1_sd	AC TRANSMISSION			D	TO ATTEND SHUT DOWN NATURE	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	17:00	18-Oct-23	23:00	May be given from 1700 Hrs
				LINE CIRCUIT	CHITTORGARH(RS ) (PG) CKT-2			DEFECTS												
244	RQ146016	OCC_211	cpcc1_sd	TRANSMISSION			D	TO ATTEND THE SHUT DOWN	17/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	17:00	17-Oct-23	23:00	May be given from 1700 Hrs
245	DO145003	000 311	1	LINE CIRCUIT	CHITTORGARH(RS ) (PG) CKT-1		D	DEFECTS	15/0+/2022	00.00	15/0+/2022	18.00	220 107	DIANNED	A	15.0+.22	08:00	15.0 -+ 22	18:00	
245	KQ145993	OCC_211	cpcc1_su	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT) BHILWARA(RS) (PG) CKT-2		D	AMP / SHUTDOWN RELATED WORK	15/Oct/2023	08:00	15/Oct/2023	18:00	220 KV ANTA(NT)- BHILWARA(RS)	PLANNED	Approved	15-Oct-23	08:00	15-Oct-23	18:00	
				LINE CIRCUIT	(PG) CK1-2								(PG) CKT-1 to be kept in non							
246	RO145991	OCC_211	cncc1 sd	AC	220 KV ANTA(NT)		D	AMP / SHUTDOWN	14/Oct/2023	08:00	14/Oct/2023	18:00	auto mode 220 KV	PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	
240	MQ145551	000_211	cpcc1_su		BHILWARA(RS) (PG) CKT-1			RELATED WORK	14,000,2023	00.00	14/000/2023	10.00	ANTA(NT)- BHILWARA(RS)	PANNED	Арргочеа	14 000 25	00.00	14 000 25	10.00	
					(. 2) 5.00 2								(PG) CKT-2 to be kept in non auto mode							
247	RQ146003	OCC_211	cpcc1_sd	AC TRANSMISSION	220 KV FATEHGARH_II(P		D	For testing and commissioning works	08/Oct/2023	17:00	10/Oct/2023	23:30	auto mode	PLANNED	Approved	08-Oct-23	19:00	10-Oct-23	23:30	May be given from 1900 Hrs
				LINE CIRCUIT	G)-AHEJOL PSS HB_FGRAH_PG			with TBC Bay												
					(AHEJOL) (AHEJOL) CKT-1															

248	RQ146022	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RENEW SUNBRIGHT SL_FGARH_PG (RSBPL)- FATEHGARH_II(P G) (RENEW SUN BRIGHT (RSBPL)) CKT-1		For testing and commissioning works with TBC Bay & LM Erection Works	07/Oct/2023	17:00	17/Oct/2023			PLANNED	Approved	07-Oct-23	19:00	17-Oct-23	23:30	May be given from 1900 Hrs
249	RQ146007	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(P G)- RENEW_JHARKHA ND 3 SL_FGARH_PG (RSEJ3PL) (RSEJ3PL) CKT-1		For testing and commissioning works with TBC Bay & LM Erection Works	07/Oct/2023	17:00	17/Oct/2023	23:30		PLANNED	Approved	07-Oct-23	19:00	17-Oct-23	23:30	May be given from 1900 Hrs
250	RQ146006	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(P G)-RENEW SUNWAVE SL_FGRAH_PG (RSWPL) (RENEW SUN WAVE (RSWPL)) CKT-1		For testing and commissioning works with TBC Bay & LM Erection Works	07/Oct/2023	17:00	17/Oct/2023	23:30		PLANNED	Approved	07-Oct-23	19:00	17-Oct-23	23:30	May be given from 1900 Hrs
251	RQ146414	OCC_211	cpcc1_sd	BAY	202 MAIN BAY - 220 KV KANKROLI(PG)- KANKROLI(RS) (RS) CKT-1 AT KANKROLI(PG)	D	For bay AMP Works	06/Oct/2023	09:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	15:00	06-Oct-23	23:00	May be given from 1500 Hrs
252	RQ145997	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAHADURGARH(P G)-NUNA MAJRA(HV) (HVPNL) CKT-1	D	For AMP of Line Bay	03/Oct/2023	09:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	09:00	03-Oct-23	18:00	
253	RQ146010	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANKROLI(PG)- KANKROLI(RS) (RS) CKT-2		AMP / SHUTDOWN RELATED WORK	03/Oct/2023	09:00	03/Oct/2023	13:00		PLANNED	Approved	03-Oct-23	15:00	03-Oct-23	23:00	May be given from 1500 Hrs
254	RQ145996	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)- SAWAIMADHOPU R(RS) (PG) CKT-1	С	NHAI diversion work	03/Oct/2023	08:00	09/Oct/2023	18:00	Timely requirement of S/D	PLANNED	Rejected					s/d already availed by powergrid from 14.09.2023
255	RQ145995	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)- LALSOTE(RS) (PG) CKT-1	С	NHAI diversion work	03/Oct/2023	08:00	09/Oct/2023	18:00	Timely requirement of S/D	PLANNED	Rejected					s/d already availed by powergrid from 14.09.2023
		OCC_211		AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(P G)-AHEJ2L PSS HB_FGRAH_PG (AHEJ2L) (AHEJ2L) CKT-1		For testing and commissioning works with TBC Bay	02/Oct/2023	17:00	07/Oct/2023	23:30		PLANNED	Approved	02-Oct-23	19:00	07-Oct-23	23:30	May be given from 1900 Hrs
257	RQ146002	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(P G)-AHEJ3L PSS HB_FGRAH_PG (AHEJ3L) (AHEJ3L) CKT-1		For testing and commissioning works with TBC Bay	02/Oct/2023	17:00	07/Oct/2023	23:30		PLANNED	Approved	02-Oct-23	19:00	07-Oct-23	23:30	May be given from 1900 Hrs

258	RQ146406	OCC_211	cpcc1_sd	ВАУ	A208 BUS COUPLER BAY - 220 KV FATEHGARH (PG) - BUS 1 (POWERGRID) AND 220 KV FATEHGARH (PG) - BUS 2 AT 220 KV FATEHGARH (PG) (POWERGRID)	D	FOR ConstructionWORKS OF PHASE-2	01/Oct/2023	18:00	05/Oct/2023	23:00		PLANNED	Approved	01-Oct-23	19:00	05-Oct-23	23:00	May be given from 1900 Hrs
259	RQ146021	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RENEW SOLARURJA SL_FGARH_PG (RSUPL)- FATEHGARH_II(P G) (RENEW SOLAR URJA (RSUPL)) CKT-1	D	For testing and commissioning works with TBC Bay	01/Oct/2023	17:00	06/Oct/2023	23:30		PLANNED	Approved	01-Oct-23	19:00	06-Oct-23	23:30	May be given from 1900 Hrs
260	RQ146005	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(P G)-EDEN SL_FGRAH_PG (ERCPL) (EDEN (ERCPL)) CKT-1	D	For testing and commissioning works with TBC Bay	01/Oct/2023	17:00	06/Oct/2023	23:30		PLANNED	Approved	01-Oct-23	19:00	06-Oct-23	23:30	May be given from 1900 Hrs
261	RQ146019	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_C(NP)- ANTA(NT) (PG) CKT-1	D	Auto Reclose off is required for OPGW INSTALLATION works under Northern Region Optical fibre Strengthening Scheme (NROSS)	01/Oct/2023	08:00	31/Oct/2023	18:00	Non-Auto, on daily basis	PLANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	
262	RQ145992	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)- BHILWARA(RS) (PG) CKT-1	D	Auto Reclose off is required for OPGW INSTALLATION works under Northern Region Optical fibre Strengthening Scheme (NROSS)	01/Oct/2023	08:00	31/Oct/2023	18:00	Non-Auto, on daily basis	PLANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	
263	RQ145994	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)- BHILWARA(RS) (PG) CKT-2	D	Auto Reclose off is required for OPGW INSTALLATION works under Northern Region Optical fibre Strengthening Scheme (NROSS)	01/Oct/2023	08:00	31/Oct/2023	18:00	Non-Auto, on daily basis	PLANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	
264	RQ146375	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-1 @FATEHGARH_II( PG)	D	Ladder logic commissioning with spare reactor logic scheme checking	26/Oct/2023	17:00	28/Oct/2023	23:00		PLANNED	Approved	26-Oct-23	17:00	28-Oct-23	23:00	

		OCC_211		LINE REACTOR	80 MVAR NON- SWITCHABLE LR ON KANPUR- BALLABHGARH (PG) CKT-1 @BALLABHGARH( PG)	С	For implementing NGR bypass scheme	26/Oct/2023		28/Oct/2023		PLANN			09:00	28-Oct-23	18:00	
266	RQ146379	OCC_211	cpcc1_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON AGRA-JAIPUR SOUTH (PG) CKT- 1 @AGRA(PG)	D	FOR AMP WORKS	24/Oct/2023	09:00	24/Oct/2023	17:30	PLANN	ED Approve	d 24-Oct-23	09:00	24-Oct-23	17:30	
267	RQ146335	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II- BHADLA (PG) CKT- 2 @FATEHGARH_II( PG)	D	Ladder logic commissioning with spare reactor logic scheme checking	23/Oct/2023	17:00	25/Oct/2023	23:00	PLANN	ED Approve	d 23-Oct-23	17:00	25-Oct-23	23:00	
268	RQ146351	OCC_211	cpcc1_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON AGRA-SIKAR (PG) CKT-1 @SIKAR(PG)	D	410R AMP WORK	23/Oct/2023	09:00	23/Oct/2023	18:00	PLANN	ED Approve	d 23-Oct-23	09:00	23-Oct-23	18:00	
269	RQ146334	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II(P G)-BHADLA(PG) (FBTL) CKT-1 @FATEHGARH_II( PG)	D	Ladder logic commissioning with spare reactor logic scheme checking	20/Oct/2023	17:00	22/Oct/2023	23:00	PLANN	ED Approve	d 20-Oct-23	17:00	22-Oct-23	23:00	
		OCC_211		LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-1 @FATEHGARH_II( PG)	D	For Erection works of Bhadla-2 circuit -4 line reactor.	20/Oct/2023		28/Oct/2023		PLANN			17:00	28-Oct-23	23:00	Shutdown may be facilitated subjected to real time grid conditions. If the line trips during the shutdown of L/R, then the line will be charged along with L/R only and availability of the line will be curtailed accordingly till line is charged.
271	RQ146341	OCC_211	cpcc1_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON AGRA- BALLABHGARH (PG) CKT-1 @BALLABHGARH( PG)	С	For implementing NGR bypass scheme	19/Oct/2023	09:00	21/Oct/2023	18:00	PLANN	ED Approve	d 19-Oct-23	09:00	21-Oct-23	18:00	
272	RQ146350	OCC_211	cpcc1_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON AGRA-SIKAR (PG) CKT-1 @SIKAR(PG)	С	410R CB OVERHAULING WORK	18/Oct/2023	09:00	21/Oct/2023	18:00	PLANN	ED Approve	d 18-Oct-23	09:00	21-Oct-23	18:00	

	RQ146376			LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 @FATEHGARH_II( PG) 240 MVAR SWITCHABLE LR	D	Ladder logic commissioning with spare reactor logic scheme checking For AMP Work-Line shall remain charged	13/Oct/2023 10/Oct/2023		15/Oct/2023			PLANNED	Approved Rejected	13-Oct-23	17:00	15-Oct-23	23:00	To be clubbed with Line outage/AMP work
					ON 765 KV GR.NOIDA_2(UPC )-MEERUT(PG) (PG) CKT-1 @MEERUT(PG)		Shaii remain chargeu												outage/Aivir work
275	RQ146333	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 @FATEHGARH_II( PG)	D	For final testing of CSD Relay of 765KV Line Reactor and AMP worls	06/Oct/2023	17:00	11/Oct/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAR Reactors shall be performed during shutdown	PLANNED	Approved	06-Oct-23	17:00	11-Oct-23	23:00	
276	RQ146346	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV AJMER- CHITTORGARH (PG) CKT-2 @CHITTORGARH( PG)	D	To configure Line Reactor Tripping on Single phase fault as per CC approval	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Rejected					To be clubbed with Line outage/AMP work
	RQ146371		cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-1 @FATEHGARH_II( PG)	D	For final testing of CSD Relay of 765KV Line Reactor and AMP worls	05/Oct/2023		10/Oct/2023		Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown		Approved	05-Oct-23	17:00	10-Oct-23	23:00	
278	RQ146345	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV AJMER- CHITTORGARH (PG) CKT-1 @CHITTORGARH( PG)	D	To configure Line Reactor Tripping on Single phase fault as per CC approval	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Rejected					To be clubbed with Line outage/AMP work

279	RQ146331	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II- BHADLA (PG) CKT- 2 @FATEHGARH_II( PG)	D	For final testing of CSD Relay of 765KV Line Reactor and AMP worls	04/Oct/2023	17:00	08/Oct/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown	PLANNED	Approved	04-Oct-23	17:00	08-Oct-23	23:00	
280	RQ146383	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV CHITTORGARH- BANASKANTHA (PG) CKT-2 @CHITTORGARH( PG)	D	To configure Line Reactor Tripping on Single phase fault as per CC approval	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Rejected					To be clubbed with Line outage/AMP work
281	RQ146369	OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II(P G)-BHADLA(PG) (FBTL) CKT-1 @FATEHGARH_II( PG)	D	For final testing of CSD Relay of 765KV Line Reactor and AMP worls	03/Oct/2023	17:00	06/Oct/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown	PLANNED	Rejected					To be clubbed with Line outage/AMP work
	RQ146343		cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV CHITTORGARH- BANASKANTHA (PG) CKT-1 @CHITTORGARH( PG)	D	To configure Line Reactor Tripping on Single phase fault as per CC approval	03/Oct/2023		03/Oct/2023			PLANNED	Rejected					To be clubbed with Line outage/AMP work
283	RQ145904	OCC_211	cpcc3_sd	HVDC LINE CIRCUIT	500 KV HVDC BALIA-BHIWADI (PG) CKT-2	D	Insulator Cleaning Work	14/Oct/2023	08:00	15/Oct/2023			PLANNED	Approved	14-Oct-23	08:00	15-Oct-23	18:00	
284	RQ145903	OCC_211	cpcc3_sd	HVDC LINE CIRCUIT	500 KV HVDC BALIA-BHIWADI (PG) CKT-1	D	Insulator Cleaning Work	12/Oct/2023		13/Oct/2023			PLANNED	Approved	12-Oct-23	08:00	13-Oct-23	18:00	
285	RQ145888	OCC_211	cpcc3_sd	HVDC LINE CIRCUIT	500 KV HVDC RIHAND-DADRI (PG) CKT-2	С	Power line crossing work cum tapping arrangement for under construction of Loop In CKT of LILO of 765kV Ghatampur-Hapur line at Rampur S/S	06/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	07-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before chraging of Line.

286	RQ145887	OCC_211	cpcc3_sd	HVDC LINE CIRCUIT	500 KV HVDC RIHAND-DADRI (PG) CKT-1		С	Power line crossing work cum tapping arrangement for under construction of Loop In CKT of LILO of 765kV Ghatampur-Hapur line at Rampur S/S	06/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	07-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before chraging of Line.
287	RQ146619	OCC_211	cpcc3_sd	BUS	500KV HVDC BUS 2 AT BALIA(PG)	POWER GRID	D	Polymer insulators replacement work	13/Oct/2023	10:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	10:00	13-Oct-23	18:00	
288	RQ146618	OCC_211	cpcc3_sd	BUS	500KV HVDC BUS 1 AT BALIA(PG)	POWER GRID	D	Polymer insulators replacement work	12/Oct/2023	10:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	10:00	12-Oct-23	18:00	
289	RQ145981	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV GR.NOIDA_2(UPC )-ALIGARH(PG) (PG) CKT-1	POWER GRID	D	Rectification of S/D nature defects	30/Oct/2023	08:00	30/Oct/2023	18:00		PLANNED	Approved	30-Oct-23	08:00	30-Oct-23	18:00	ATC Curtailment of of 600 MW in NR Import
290	RQ145966	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA-	POWER GRID	D	Rectification of S/D nature defects	27/Oct/2023	08:00	28/Oct/2023	18:00		PLANNED	Approved	27-Oct-23	08:00	28-Oct-23	18:00	
291	RQ145773	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV	POWER GRID	D	For S/D type defect rectification work	26/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
292	RQ145970	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA- JHATIKARA (PG) CKT-1	POWER GRID	D	Rectification of S/D nature defects	18/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	19-Oct-23	18:00	
293	RQ145963	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BALIA- LUCKNOW_2 (PG) CKT-1	POWER GRID	D	Insulator Cleaning Work	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
294	RQ145776	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA- JHATIKARA (PG) CKT-1	POWER GRID	D	For S/D type defect rectification work	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
295	RQ145827	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER- MOGA (PG) CKT-1		D	Shutdown required for rectification of shutdown nature defects	13/Oct/2023	08:00	13/Oct/2023	18:00	Kindly approve	PLANNED	Approved	13-Oct-23	17:00	13-Oct-23	23:00	
296	RQ146494	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI- FATEHPUR (PG) CKT-1	-POWER GRID	D	AMP work	07/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	08:00	07-Oct-23	18:00	
297	RQ145774	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV JHATIKARA- BHIWANI (PG) CKT-1	POWER GRID	D	For S/D type defect rectification work	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
298	RQ145962	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI BALIA (PG) CKT-1		D	AMP work	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
299	RQ146756	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA- ALIGARH (PG) CKT-1	POWER GRID	D	A/R non auto mode to facilitate changing of OPGW between tower no.131 to 132	01/Oct/2023	08:00	15/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	15-Oct-23	18:00	
300	RQ145712	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ANPARA_D- UNNAO (UP) CKT- 1	UPPCL	С	shutdown for height raising of 765 kv	27/Oct/2023	08:00	17/Nov/2023	18:00		PLANNED	Approved	27-Oct-23	08:00	17-Nov-23	18:00	All statuory clearences, FTC approval to be submitted before charging of line . UP informed to take s/d of 765k\ Obra_C-Unnao(UP) ckt-1 instead. Line is wrongly punched in the OMS portal

301	RQ145713	OCC_211	stuup_sd	AC TRANSPAISSION	765 KV	UPPTCL	С	height raising of 765	25/Oct/2023	08:00	13/Nov/2023	18:00	PLANNED	Rejected					s/d withdrawn by UPPTCL.
				TRANSMISSION LINE CIRCUIT	ANPARA_C(LAN)- UNNAO(UP) (UP) CKT-1			kv Anpara C Unnao											
302	RQ146640	OCC_211	stuup_śd	AC TRANSMISSION LINE CIRCUIT	765 KV JAWAHARPUR_TP S-MAINPURI (UP)	UPPTCL	С	For two SPS Logic implementation (Simulation test): 1. Incorporation of 1st logic of system protection scheme i.e. Tripping of all the running units of Jawaharpur TPS when 765KV jawaharpur-Greater Noida line trips. 2. Incorporation of 2nd logic of system protection scheme i.e. Tripping of all the running units of Jawaharpur TPS on flow of more than 50MW from Jawaharpur TPS to Mainpuri through 765KV line.	20/Oct/2023	09:00	21/Oct/2023	17:00	PLANNED	Approved	20-Oct-23	6:00	21-Oct-23	16:00	There may be restriction on Bara Generation depend on real time grid conditon
303	RQ146641	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	765 KV GR.NOIDA_2(UPC )- JAWAHARPUR_TP S (UP)	UPPTCL	С	For two SPS Logic implementation ((Simulation test): 1. Incorporation of lst logic of system protection scheme i.e. Tripping of all the running units of Jawaharpur TPS when 765KV jawaharpur-Greater Noida line trips. 2. Incorporation of 2nd logic of system protection scheme i.e. Tripping of all the running units of Jawaharpur TPS on flow of more than 50MW from Jawaharpur TPS to Mainpuri through 765KV line.	20/Oct/2023	09:00	21/Oct/2023	17:00	PLANNED	Approved	20-Oct-23	6:00	21-Oct-23	16:00	There may be restriction on Bara Generation depend on real time grid conditon
304	RQ145463	OCC_211	stuup_sd		765 KV AGRA FATEHBAD(UP)- LALITPUR(LPG) (UP) CKT-2	UPPTCL	D	* For Tightening of Jumper Cone Bolts and C.C Ring Bolts also replacing X the Broken Spacers.	06/Oct/2023	08:00	08/Oct/2023	18:00	PLANNED	Conditionall y Approved	06-Oct-23	08:00	08-Oct-23	18:00	To be clubbed with unit outage at lalitpur
305	RQ146491	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ANPARA_C(LAN)- UNNAO(UP) (UP) CKT-1	UPPTCL	С	height raising of 765 kv Anpara C Unnao	06/Oct/2023	08:00	24/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	08:00	24-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before charging of line . Kindly calrify th element.

306	RQ145462	2 OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA FATEHBAD(UP)- LALITPUR(LPG) (UP) CKT-1	UPPTCL	D	* For Tightening of Jumper Cone Bolts and C.C Ring Bolts also replacing X the Broken Spacers.	03/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Conditionall y Approved	03-Oct-23	08:00	05-Oct-23	18:00	To be clubbed with unit outage at lalitpur
307	RQ146142	2 OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV GR.NOIDA_2(UPC )-MEERUT(PG) (PG) CKT-1		С	Diversion of Lines Due ingrigement of Ganga Expressway of M/s UPEIDA	25/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	25-Oct-23	08:00	31-Oct-23	18:00	All statuory clearences, FTC approval to be submitted before charging of line.
308	RQ146149	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV MOGA- MEERUT (PG) CKT 1		D	For Line Equipment and LR AMP at Meerut end	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
309	RQ14614!	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KHETRI (PKTSL)- JHATIKARA(PG) (PKTSL) CKT-2		D	LINE BAY AMP	06/Oct/2023	09:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	18:00	
310	RQ14614	4 OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KHETRI (PKTSL)- JHATIKARA(PG) (PKTSL) CKT-1		D	LINE BAY AMP	05/Oct/2023	09:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
311	RQ146130	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER- MOGA (PG) CKT-1		С	Diversion work of transmission line due to infringement with Bharatmala Expressway of NHAI	04/Oct/2023	08:00	15/Oct/2023	20:00		PLANNED	Rejected	04-Oct-23	08:00	15-Oct-23	20:00	NRLDC to conduct study. S/d to be discussed seprately after the study.
312	RQ146132	2 OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER- MOGA (PG) CKT-2		С	Diversion work of transmission line due to infringement with Bharatmala Expressway of NHAI	04/Oct/2023	08:00	15/Oct/2023	20:00		PLANNED	Rejected	04-Oct-23	08:00	15-Oct-23	20:00	NRLDC to conduct study. S/d to be discussed seprately after the study.
313	RQ14576	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ANTA- PHAGI (RS) CKT-2	RRVPNL	D	Quarterly maintenance work	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
314	RQ145764	4 OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ANTA- PHAGI (RS) CKT-1	RRVPNL	D	Quarterly maintenance work	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
315	RQ14533	7 OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA FATEHBAD(UP)- GHATAMPUR_TP S(UP) (GTL) CKT-1	GTL	D	For Charging of 63MVAr Spare Phase unit as R- Phase unit at 765kV Substation Fatehabad	04/Oct/2023	10:00	04/Oct/2023	14:00		PLANNED	Approved	04-Oct-23	10:00	04-Oct-23	14:00	
316	RQ14584:	1 OCC_211	cpcc2_sd	BUS	765KV BUS 2 AT MOGA(PG)	POWER GRID	D	AMP WORKS	30/Oct/2023	08:00	31/Oct/2023	18:00	Kindly approve	PLANNED	Approved	30-Oct-23	08:00	31-Oct-23	18:00	
317	RQ146392	2 OCC_211	cpcc3_sd	BUS	765KV BUS 1 AT BALIA(PG)	POWER GRID	D	To attend Chattering at insulator string	27/Oct/2023	10:00	27/Oct/2023	18:00		PLANNED	Approved	27-Oct-23	10:00	27-Oct-23	18:00	
318	RQ145840	OCC_211	cpcc2_sd	BUS	765KV BUS 1 AT MOGA(PG)	POWER GRID	D	AMP WORKS	26/Oct/2023	08:00	27/Oct/2023	18:00	Kindly approve	PLANNED	Approved	26-Oct-23	08:00	27-Oct-23	18:00	
319	RQ14596	7 OCC_211	cpcc3_sd	BUS	765KV BUS 1 AT AGRA(PG)	POWER GRID	D	AMP work	13/Oct/2023	10:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	10:00	13-Oct-23	18:00	
320	RQ146266	5 OCC_211	cpcc1_sd	BUS	765KV BUS 2 AT JHATIKARA(PG)	GKID	D	ISOLATOR REPLCAMENT	26/Oct/2023	09:15	27/Oct/2023	18:00	AMP	PLANNED	Approved	26-Oct-23	09:15	27-Oct-23	18:00	
321	RQ146278	3 OCC_211	cpcc1_sd	BUS	765 KV BHADLA_2 (PG) - BUS 2		D	Bay Extension, For jumpering of new Bay in 713 and 716 and Bus Bar LBB testing	15/Oct/2023	17:00	19/Oct/2023	23:59		PLANNED	Approved	15-Oct-23	17:00	19-Oct-23	23:59	

		OCC_211		BUS	765 KV FATEHGARH_II(P G) - BUS 1		D	Jumpering and bay extension work by M/s TATA for TBCB package SS-01, SS-63 A1 & B1, commissioning works of Bus bar integration work of bay extensions	15/Oct/2023		28/Oct/2023			PLANNED	Approved	15-Oct-23	17:00	28-Oct-23	23:30	
323	RQ146246	OCC_211	cpcc1_sd	BUS	765 KV KHETRI (PG) - BUS 1		D	For stringing work under 765kV bay extension (M/s KEC)	15/Oct/2023	08:00	16/Oct/2023	20:00		PLANNED	Approved	15-Oct-23	08:00	16-Oct-23	20:00	
324	RQ146245	OCC_211	cpcc1_sd	BUS	765 KV KHETRI (PG) - BUS 2		D	For stringing work under 765kV bay extension (M/s KEC)	13/Oct/2023	08:00	14/Oct/2023	20:00		PLANNED	Approved	13-Oct-23	08:00	14-Oct-23	20:00	
325	RQ146256	OCC_211	cpcc1_sd	BUS	765KV BUS 2 AT CHITTORGARH(P G)		D	For AMP work	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
326	RQ146277	OCC_211	cpcc1_sd	BUS	765 KV BHADLA_2 (PG) - BUS 1		D	Bay Extension, For jumpering of new Bay in 713 and 716 and Bus Bar LBB testing	10/Oct/2023	17:00	14/Oct/2023	23:59		PLANNED	Approved	10-Oct-23	17:00	14-Oct-23	23:59	
327	RQ146299	OCC_211	cpcc1_sd	BUS	765 KV FATEHGARH_II(P G) - BUS 2		D	FOR AMP WORKS	09/Oct/2023	17:00	11/Oct/2023	23:30		PLANNED	Approved	09-Oct-23	17:00	11-Oct-23	23:30	
328	RQ146255	OCC_211	cpcc1_sd	BUS	765KV BUS 1 AT CHITTORGARH(P G)		D	For AMP work	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
329	RQ146298	OCC_211	cpcc1_sd	BUS	765 KV FATEHGARH_II(P G) - BUS 1		D	FOR AMP WORKS	07/Oct/2023	17:00	09/Oct/2023	23:30		PLANNED	Approved	07-Oct-23	17:00	09-Oct-23	23:30	
330	RQ146235	OCC_211	cpcc1_sd	BUS	765 KV FATEHGARH_II(P G) - BUS 2		D	Jumpering and bay extension work by M/s TATA for TBCB package SS-01, SS-63 A1 & B1, commissioning works of Bus bar integration work of bay extensions	01/Oct/2023	17:00	14/Oct/2023	23:30		PLANNED	Approved	01-Oct-23	17:00	14-Oct-23	23:30	
331	RQ145690	OCC_211	sldcrs_sd	BUS	765KV BUS 1 AT PHAGI(RS)	RRVPNL	D	For Attending alignment of Isolator 703-89AA	26/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	Bypass arrangement atAnta to be done. Generation at Chhbra Kawai complex to be restricted to 3500 MW. Subjected to Rajasthan consent
			stuup_sd		765KV BUS 2 AT MAINPURI(UP)	UPPTCL	С	FOR CONNECTION OF HAPUR BAY AND LINE REACTOR	03/Oct/2023		06/Oct/2023		BUS S/D REQUIRED 703, 706, 712 BAY CB SHUTDOWN NO POWER AFFECTED	PLANNED	Approved	03-Oct-23	08:30	06-Oct-23	18:00	
333	RQ146823	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765KV JHATIKARA(PG)		D	SPARE ROATATION	28/Oct/2023	09:15	28/Oct/2023	15:00		PLANNED	Approved	28-Oct-23	09:15	28-Oct-23	15:00	

334	RQ146813	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(P G)		D	Ladder logic commissioning with spare reactor logic scheme checking	19/Oct/2023	17:00	25/Oct/2023	23:00		PLANNED	Approved	19-Oct-23	17:00	25-Oct-23	23:00	
335	RQ146815	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV KOTESHWAR(PG)		D	AMP work	17/Oct/2023	09:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	
336	RQ146812	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(P G)		D	Ladder logic commissioning with spare reactor logic scheme checking	15/Oct/2023	17:00	20/Oct/2023	23:00		PLANNED	Approved	15-Oct-23	17:00	20-Oct-23	23:00	
337	RQ146821	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV KHETRI (PKTSL)		D	For attending leakage and internal inspection	11/Oct/2023	09:00	12/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	09:00	12-Oct-23	18:00	
		OCC_211		BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV KHETRI (PKTSL)		D	For attending leakage and internal inspection	09/Oct/2023		10/Oct/2023			PLANNED	Approved	09-Oct-23	09:00	10-Oct-23	18:00	
339	RQ146811	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(P G)		D	For final testing of CSD Relay of 765KV Bus Reactor	08/Oct/2023	17:00	12/Oct/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown	PLANNED	Approved	08-Oct-23	17:00	12-Oct-23	23:00	
				BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(P G)		D	For final testing of CSD Relay of 765KV Bus Reactor	07/Oct/2023		10/Oct/2023		Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown		Approved	07-Oct-23	17:00	10-Oct-23	23:00	
341	RQ146750	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765KV JHATIKARA(PG)	POWER GRID	D	For SPARE ROATATION	28/Oct/2023	09:00	28/Oct/2023	14:00		PLANNED	Approved	28-Oct-23	09:00	28-Oct-23	14:00	
		OCC_211		BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(P G)	POWER GRID	D	Ladder logic commissioning with spare reactor logic scheme checking	19/Oct/2023	17:00	25/Oct/2023	23:00		PLANNED	Approved	19-Oct-23	17:00	25-Oct-23	23:00	
343	RQ146743	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV KOTESHWAR(PG)	POWER GRID	D	For AMP work	17/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	

344	RQ146740	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(P G)	POWER GRID	D	Ladder logic commissioning with spare reactor logic scheme checking	15/Oct/2023	17:00	20/Oct/2023	23:00		PLANNED	Approved	15-Oct-23	17:00	20-Oct-23	23:00	
345	RQ146737	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(P G)	POWER GRID	D	For final testing of CSD Relay of 765KV Bus Reactor	08/Oct/2023	17:00	12/Oct/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown	PLANNED	Approved	08-Oct-23	17:00	12-Oct-23	23:00	
346	RQ146738	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(P G)	POWER GRID	D	For final testing of CSD Relay of 765KV Bus Reactor	07/Oct/2023	17:00	10/Oct/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown	PLANNED	Approved	07-Oct-23	17:00	10-Oct-23	23:00	
347	RQ146616	OCC_211	cpcc3_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765KV AGRA(PG)	POWER GRID	D	AMP and OTI WTI modification work	07/Oct/2023	10:00	07/Oct/2023	18:00	3. actaowii	PLANNED	Approved	07-Oct-23	10:00	07-Oct-23	18:00	
348	RQ146615	OCC_211	cpcc3_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765KV AGRA(PG)	POWER GRID	D	AMP and OTI WTI modification work	05/Oct/2023	10:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	10:00	05-Oct-23	18:00	
349	RQ145742	OCC_211	sldcrs_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV PHAGI(RS)	PAPTL	D	For taken R-Phase into Circuit in place of spare reactor	27/Oct/2023	08:00	27/Oct/2023	18:00		PLANNED	Approved	27-Oct-23	08:00	27-Oct-23	18:00	
350	RQ145383	OCC_211	stuup_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765KV AGRA FATEHBAD(UP)	UPPTCL	D	* For Checking of CVT Selection Logic of Bus Reactor as it is not working X properly by SCADA Engineer	12/Oct/2023	09:00	12/Oct/2023	13:00		PLANNED	Approved	12-Oct-23	09:00	12-Oct-23	13:00	
351	RQ146747	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 2 AT 765 KV KHETRI (PKTSL)	PKTSL	D	For attending leakage and internal inspection	11/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	12-Oct-23	18:00	
352	RQ146748	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765 KV KHETRI (PKTSL)	PKTSL	D	For attending leakage and internal inspection	09/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	10-Oct-23	18:00	
353	RQ145767	OCC_211	sldcrs_sd	LINE REACTOR	240 MVAR NON- SWITCHABLE LR ON ANTA-PHAGI (RS) CKT-2 @PHAGI(RS)	RRVPNL	D	Quarterly Maintenance work OF REACTORS ALONGWITH LINE	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	

354	RQ145766	OCC_211	sldcrs_sd	LINE REACTOR	240 MVAR NON- SWITCHABLE LR ON ANTA-PHAGI (RS) CKT-1 @PHAGI(RS)	RRVPNL	D	Quarterly Maintenance work OF REACTORS ALONGWITH LINE	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
355	RQ146427	OCC_211	cpcc1_sd	ВАУ	709 MAIN BAY - 765/400KV 1500 MVA ICT 2 AT CHITTORGARH(P G)		D	For AMP work	31/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	31-Oct-23	08:00	31-Oct-23	18:00	
356	RQ146423	OCC_211	cpcc1_sd	BAY	714 TIE BAY - 765 KV BIKANER(PG)- KHETRI (PKTSL) (BKTL) CKT-1 (BKTL) AND FUTURE AT 765 KV KHETRI (PKTSL) (BKTL)		D	For bay AMP Works	29/Oct/2023	09:00	30/Oct/2023	18:00		PLANNED	Approved	29-Oct-23	09:00	30-Oct-23	18:00	
357	RQ146422	OCC_211	cpcc1_sd	ВАУ	713 MAIN BAY - 765 KV BIKANER(PG)- KHETRI (PKTSL) (BKTL) CKT-1 (BKTL)		D	For bay AMP Works	27/Oct/2023	09:00	28/Oct/2023	18:00		PLANNED	Approved	27-Oct-23	09:00	28-Oct-23	18:00	
358	RQ146421	OCC_211	cpcc1_sd	BAY	711 TIE BAY - 765 KV BIKANER(PG)- KHETRI (PKTSL) (BKTL) CKT-2 (BKTL) AND FUTURE AT 765 KV KHETRI (PKTSL) (BKTL)		D	For bay AMP Works	25/Oct/2023	09:00	26/Oct/2023	18:00		PLANNED	Approved	25-Oct-23	09:00	26-Oct-23	18:00	
359	RQ146478	OCC_211	cpcc1_sd	BAY	721 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-1 (POWERGRID)		D	For bay AMP Works	23/Oct/2023	17:00	24/Oct/2023	23:00	For Bay AMP works	PLANNED	Approved	23-Oct-23	17:00	24-Oct-23	23:00	
360	RQ146420	OCC_211	cpcc1_sd	ВАУ	710 MAIN BAY - 765 KV BIKANER(PG)- KHETRI (PKTSL) (BKTL) CKT-2 (BKTL)		D	For bay AMP Works	23/Oct/2023	09:00	24/Oct/2023	18:00		PLANNED	Approved	23-Oct-23	09:00	24-Oct-23	18:00	
361	RQ146404	OCC_211	cpcc1_sd	ВАУ	718 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 (POWERGRID)		D	For bay AMP Works	21/Oct/2023	17:00	22/Oct/2023	23:00	For Bay AMP works	PLANNED	Approved	21-Oct-23	17:00	22-Oct-23	23:00	
362	RQ146426	OCC_211	cpcc1_sd	ВАУ	706 MAIN BAY - 765/400KV 1500 MVA ICT 1 AT CHITTORGARH(P G)		D	For AMP work	14/Oct/2023	08:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	
363	RQ146417	OCC_211	cpcc1_sd	BAY	704 MAIN BAY - 765/400KV 1500 MVA ICT 2 AT AJMER(PG)		D	For bay AMP Works	13/Oct/2023	09:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	09:00	13-Oct-23	18:00	

Mathematical   Math	364	RQ146445	OCC_211	cpcc1_sd	BAY	715 MAIN BAY - 765/400KV 1500 MVA ICT 3 AT	D	АМР	12/Oct/2023	09:15	13/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	09:15	13-Oct-23	18:00	
Bendance   Particulary   Bendance   Bendan	365	RQ146479	OCC_211	cpcc1_sd	BAY	JHATIKARA(PG) 721 MAIN BAY -	D		10/Oct/2023	17:00	17/Oct/2023	23:00		PLANNED	Approved	10-Oct-23	17:00	17-Oct-23	23:00	
March   Marc						BHADLA_2 - FATEHGARH_II							A1, B1 & TBCB							
No.						(POWERGRID)														
MANACE   ACC   MILES   MANACE   MANAC	366	RQ146444	OCC_211	cpcc1_sd	BAY	712 MAIN BAY -	D	AMP	10/Oct/2023	09:15	11/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	09:15	11-Oct-23	18:00	
## ## ## ## ## ## ## ## ## ## ## ## ##						MVA ICT 2 AT														
Post	367	RO146415	OCC 211	cncc1 sd	RΔV		D	For hay AMP Works	10/Oct/2023	ng-nn	10/Oct/2023	18:00		DI ANNED	Approved	10-Oct-23	00.00	10-Oct-23	18:00	
MAIN	307	110113	000_211	cpcci_su	DAI			TOT BUY AIVIT WORKS	10/000/2023	05.00	10/000/2025	10.00		LANNED	Арргочса	10 000 25	05.00	10 000 25	10.00	
AMERIPS AND AMERIPS (PG) CCT-1 (SPECIAL MERIPS) (PG) CCT-1																				
AMAPPING																				
CCT-1   CCT-1   CCC_211   CCC_210   SAV   T1A TIE BAY-755   NAMP   CS/OCC/2023   09:00   OS/OCC/2023   18:00   PLANNED   Approved   OS-OCC-23   O9:00   OS-OCC-23   18:00																				
18						AJMER(PG) (PG)														
RQ146452   DCC_211   QDCC1_sd   DAY   DAMP   DA/OCC/2023   DP.00   DA/OCC/2023   DP.00   DP.ANNED   DA/OCC/2023   DP.ANNED   DA/OCC/2023   DP.00   DP.ANNED   DP.ANNED   DP.OCC/2023   DP.00   DP.ANNED   DP.OCC/2023   DP.00   DP.ANNED   DP.OCC/2023   DP.00   DP.OCC/2023   DP.OCC/2023   DP.00   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.O																				
RQ146452   DCC_211   QDCC1_sd   DAY   DAMP   DA/OCC/2023   DP.00   DA/OCC/2023   DP.00   DP.ANNED   DA/OCC/2023   DP.ANNED   DA/OCC/2023   DP.00   DP.ANNED   DP.ANNED   DP.OCC/2023   DP.00   DP.ANNED   DP.OCC/2023   DP.00   DP.ANNED   DP.OCC/2023   DP.00   DP.OCC/2023   DP.OCC/2023   DP.00   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.OCC/2023   DP.O									0= (0 . (05		0.00 . 10								10.00	
GR.NOIDA_2UPC   SHADE   SHAD	368	KQ146453	OCC_211	cpcc1_sd	BAY		D	AMP	U5/Oct/2023	09:00	U5/Oct/2023	18:00		PLANNED	Approved	U5-Oct-23	09:00	U5-Oct-23	18:00	
D-MERIUTIPG  (PG) CRT-1 AND FUTURE AT   MERIUTIPG  (PG) CRT-1 AND FUTURE AT   MERIUTIPG  AND FUTURE																				
Fig. Crt.1 AND   FULL AND   FUL					1										1					
FUTURE AT   MERUTIFICS     MAP   O4/Oct/2023 09:00   O4/Oct/2023 18:00   PLANNED   Approved   O4-Oct-23   O9:00   O4-Oct-23   O0:00   O0:00   O0																				
MERBUTIPO   TOS TIE BAY   TOS MANH BAY   TOS TIE BAY   TOS MANH BAY   TOS MANH BAY   TOS TIE BA																				
369   R0146452   OCC_211   CpcL_5d   BAY   705 TIE BAY-																				
MMA LET 2 AT MEREUTIPG) AND 240 MAYA BUS REACTOR NO 1 AT 765KV   MEDITIPG	369	RQ146452	OCC_211	cpcc1_sd	BAY	705 TIE BAY -	D	AMP	04/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	18:00	
MEERUTICS AND 240 MAR BUS REACTOR NO 1																				
240 MYAR BUS   REACTOR NO.1   AT 765KV   MERUIT(PG)																				
REACTOR NO 1 A7 755KV MEERUT(PG)  370 R0146451 OCC_211 cpcc1_sd BAY 703 MAIN BAY-765/400KV 1500 MAIN AICT 1 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)																				
A7 765KV   MERRUTIPG    AMP   O3/Oct/2023 09:00   O3/Oct/2023 18:00   PLANNED   Approved   O3-Oct-23   O9:00   O0:00   O					1										1					
MERCUT(PG)																				
370 RQ146451   OCC_211   Cpcc1_sd   BAY   703 MAIN BAY   705 /400KV 1500   MVA ICT 1 AT MERRUT(PG)   MAP   O3/Oct/2023   18:00   PLANNED   Approved   O3-Oct-23   09:00   O3-Oct-23   18:00   O3-Oct-23   09:00   O3-Oct-23   09																				
Test	370	RO146451	OCC 211	cncc1 sd	BAY		D	AMP	03/Oct/2023	09:00	03/Oct/2023	18:00	1	PLANNED	Annroyed	03-Oct-23	09:00	03-Oct-23	18:00	
MVA   CT 1 AT   MERUTIPG	370		JCC_211	cpcc1_3u	5.31			,	55,000,2025	55.00	33,000,2023	23.00		LANGED	Approved	33 OCC-23	05.00	33 OCC-23	10.00	
MERUT(PG)					1										1					
371   RQ146455   OCC_211   cpcc1_sd   BAY   714 TIE BAY - 765/400 KV 1500   MVA ICT 1 AT BHADLA_2 (PG) (POWERGRID)   AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)   AND FUTURE AT 765/400 KV 1500   MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID)   AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)   AND FUTURE AT 765/400 KV 1500   MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID)   AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)   AND FUTURE AT 765					1										1					
MVA ICT 1 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)  372 RQ146454 OCC_211 cpcc1_sd BAY 717 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG)	371	RQ146455	OCC_211	cpcc1_sd	BAY	714 TIE BAY -	С		01/Oct/2023	17:00	31/Oct/2023	23:59		PLANNED	Approved	01-Oct-23	17:00	31-Oct-23	23:59	
BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)  C New bay extension 716 MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)  C New bay extension 716  Now bay extension 716								716												
C   New bay extension   716 KV   RADIAL 2 (PG)   POWERGRID   RADIAL 2 (PG)   POWERGRID   RADIAL 2 (PG)   POWERGRID   RADIAL 2 (PG)   POWERGRID   RADIAL 2 (PG)   PLANNED   P																				
AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)  372 RQ146454 OCC_211 cpcc1_sd BAY 717 TIE BAY - 765/400 KV 1500 MVA (CT 2 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG)																				
Total   Tota																				
BHADLA_2 (PG) (POWERGRID)  372 RQ146454 OCC_211 cpcc1_sd BAY 717 TIE BAY-765/400 KV 1500 MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG)																				
C   New bay extension   717 TIE BAY - 765/400 KV 1500   MVA ICT 2 AT   BHADLA_2 (PG)   (POWERGRID)   AND FUTURE AT 765 KV   BHADLA_2 (PG)   C   BHADLA_2 (PG)   C   C   C   C   C   C   C   C   C					1										1					
372 RQ146454 OCC_211 cpcc1_sd BAY 777 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG)																				
765/400 KV 1500 MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG)																				
MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG)	372	RQ146454	OCC_211	cpcc1_sd	BAY		С		01/Oct/2023	17:00	31/Oct/2023	23:59		PLANNED	Approved	01-Oct-23	17:00	31-Oct-23	23:59	
BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG)								716												
(POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG)																				
AND FUTURE AT 765 KV BHADLA_2 (PG)																				
765 KV BHADLA_2 (PG)																				
BHADLA_2 (PG)																				
					1										1					
						<u>'</u>														

			cpcc1_sd		720 TIE BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AND 765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-1 AT 765 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID		For DGA oil testing of bay 765kV CT			28/Oct/2023			PLANNED	Approved	28-Oct-23	17:00	28-Oct-23	23:00	
374	RQ146727	OCC_211	cpcc1_sd	ВАУ	719 MAIN BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AT 765 KV FATEHGARH_II(P G)	POWER GRID		For DGA oil testing of bay 765kV CT	27/Oct/2023	17:00	27/Oct/2023	23:00		PLANNED	Approved	27-Oct-23	17:00	27-Oct-23	23:00	
	RQ146757			ВАУ	720 TIE BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AND 765 KV BHADIA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-1 AT 765 KV FATEHGARH_II(P G) (POWERGRID)		D	For bay AMP Works	25/Oct/2023		26/Oct/2023			PLANNED	Approved	25-Oct-23	17:00	26-Oct-23	23:00	
376	RQ146769	OCC_211	cpcc1_sd	BAY	718 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 (POWERGRID)	POWER GRID	D	For AMP work	23/Oct/2023	17:00	24/Oct/2023	23:00		PLANNED	Approved	23-Oct-23	17:00	24-Oct-23	23:00	
377	RQ146758	OCC_211	cpcc1_sd	BAY	719 MAIN BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AT 765 KV FATEHGARH_II(P G)	POWER GRID		For erection works of SS-63 A1, B1 & TBCB bay extension.	23/Oct/2023	17:00	30/Oct/2023		For erection works of SS-63 A1, B1 & TBCB bay extension.	PLANNED	Approved	23-Oct-23	17:00	30-Oct-23	23:00	

378	RQ145858	OCC_211	cpcc2_sd	ВАУ	702 TIE BAY - 240 MVAR BUS REACTOR NO 1 AT 765KV MOGA(PG) (POWERGRID) AND 765 KV BIKANER-MOGA (PG) CKT-1 AT 765 KV MOGA(PG) (POWERGRID)	POWER GRID	С	AMP WORKS	23/Oct/2023	08:30	24/Oct/2023	18:00	Kindly approve	PLANNED	Approved	23-Oct-23	08:30	24-Oct-23	18:00	
379	RQ146768	OCC_211	cpcc1_sd	ВАҮ	716 MAIN BAY - 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For AMP work	21/Oct/2023	17:00	22/Oct/2023	23:00		PLANNED	Approved	21-Oct-23	17:00	22-Oct-23	23:00	
380	RQ146770	OCC_211	cpcc1_sd	ВАУ	720 TIE BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AND 765 KV BHADLA_2 (PG)- FATEHGARH_II(P G) (PFTL) CKT-1 AT 765 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID		For erection works of SS-63 A1, B1 & TBCB bay extension.	21/Oct/2023	17:00	27/Oct/2023	23:00	For erection works of SS-63 A1, B1 & TBCB bay extension.	PLANNED	Approved	21-Oct-23	17:00	27-Oct-23	23:00	
381	RQ146776	OCC_211	cpcc1_sd	BAY	709 MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT KHETRI (PKTSL) (POWERGRID) AT 765 KV KHETRI (PKTSL)	POWER GRID	D	For AMP work	21/Oct/2023	08:00	22/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	08:00	22-Oct-23	18:00	
382	RQ146767	OCC_211	cpcc1_sd	ВАУ	717 TIE BAY - 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(P G) (POWERGRID) AND 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWER GRID	D	For AMP work	19/Oct/2023	17:00	20/Oct/2023	22:00		PLANNED	Approved	19-Oct-23	17:00	20-Oct-23	22:00	

383	RQ145857	OCC_211	cpcc2_sd	ВАУ	705 TIE BAY - 240 MVAR BUS REACTOR NO 2 AT 765KV MOGA(PG) (POWERGRID) AND 330 MVAR LR ON 765 KV BIKANER-MOGA (PG) CKT-2 @MOGA(PG) AT 765 KV	POWER GRID	С	AMP WORKS	19/Oct/2023	08:30	20/Oct/2023	18:00	Kindly approve	PLANNED	Approved	19-Oct-23	08:30	20-Oct-23	18:00	
384	RQ146775	OCC_211	cpcc1_sd	BAY	(POWERGRID)  707 MAIN BAY - 765 KV KHETRI (PKTSL)- JHATIKARA(PG) (PKTSL) CKT-2 (POWERGRID) AT 765 KV KHETRI (PKTSL)	POWER GRID	D	For AMP work	19/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	20-Oct-23	18:00	
385	RQ146588	OCC_211	cpcc3_sd	ВАУ	710 MAIN BAY - 765KV AGRA- FATEHPUR (PG) CKT-2 AT FATEHPUR(PG)	POWER GRID	D	AMP work	18/Oct/2023	10:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	10:00	18-Oct-23	18:00	
386	RQ146766	OCC_211	cpcc1_sd	BAY		POWER GRID	D	For AMP work	17/Oct/2023	17:00	18/Oct/2023	23:00		PLANNED	Approved	17-Oct-23	17:00	18-Oct-23	23:00	
387	RQ146587	OCC_211	cpcc3_sd	ВАУ	703 MAIN BAY - 765/400KV 1500 MVA ICT 2 AT FATEHPUR(PG)	POWER GRID	D	AMP work	17/Oct/2023	10:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	10:00	17-Oct-23	18:00	
388	RQ145856	OCC_211	cpcc2_sd	BAY	704 MAIN BAY - 765 KV BIKANER- MOGA (PG) CKT-2 (POWERGRID) AT MOGA	POWER GRID	С	AMP WORKS	16/Oct/2023	08:30	17/Oct/2023	18:00	Kindly approve	PLANNED	Approved	16-Oct-23	08:30	17-Oct-23	18:00	
389	RQ146765	OCC_211	cpcc1_sd	BAY	713 MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G) (POWERGRID) AT 765 KV FATEHGARH_II(P G)		D	For AMP work	15/Oct/2023	17:00	16/Oct/2023	23:00		PLANNED	Approved	15-Oct-23	17:00	16-Oct-23	23:00	

		OCC_211			714 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G) (POWERGRID) AND 240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(P G) AT 765 KV FATEHGARH_II(P G) (POWERGRID)		D	For bay AMP Works	15/Oct/2023		16/Oct/2023			PLANNED	Approved	15-Oct-23	17:00	16-Oct-23	23:00	
391	RQ146586	OCC_211	cpcc3_sd	BAY	701 MAIN BAY - 765 KV VARANASI- FATEHPUR (PG) CKT-1 AT FATEHPUR(PG)		D	AMP work	14/Oct/2023	10:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	10:00	14-Oct-23	18:00	
392	RQ146764	OCC_211	cpcc1_sd	ВАУ	714 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G) (POWERGRID) AND 240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(P G) AT 765 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For AMP work	13/Oct/2023	17:00	14/Oct/2023	23:00		PLANNED	Approved	13-Oct-23	17:00	14-Oct-23	23:00	
393	RQ145854	OCC_211	cpcc2_sd	BAY	701R MAIN BAY - 330 MVAR LR ON 765 KV BIKANER- MOGA (PG) CKT-1 @MOGA(PG) (POWERGRID) AT BIKANER		D	Bay AMP and SF6 Alarm ckt modification work	13/Oct/2023	08:30	13/Oct/2023	18:00	Kindly approve	PLANNED	Approved	13-Oct-23	08:30	13-Oct-23	18:00	
		OCC_211			712 MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT BAREILLY_2(PG) AND 765 KV BAREILLY_2(PG) - BUS 2			AMP work	12/Oct/2023		12/Oct/2023			PLANNED	Approved	12-Oct-23	10:00	12-Oct-23	18:00	
395	RQ145855	OCC_211	cpcc2_sd	ВАУ	704R MAIN BAY - 330 MVAR LR ON 765 KV BIKANER- MOGA (PG) CKT-2 @MOGA(PG) (POWERGRID) AT MOGA (PG) (POWERGRID)		D	Bay AMP and SF6 Alarm ckt modification work	12/Oct/2023	08:30	12/Oct/2023	18:00	Kindly approve	PLANNED	Approved	12-Oct-23	08:30	12-Oct-23	18:00	

	RQ146763			ВАУ	707 MAIN BAY - 240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(P G) (POWERGRID) AT 765 KV FATEHGARH_II(P G)	POWER GRID	D	For AMP work	11/Oct/2023		12/Oct/2023		PLANNED	Approved	11-Oct-23	17:00	12-Oct-23	23:00	
397	RQ146561	OCC_211	cpcc3_sd	BAY	711 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT BAREILLY_2(PG) AND FUTURE	POWER GRID	D	AMP work	10/Oct/2023	10:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	10:00	10-Oct-23	18:00	
			cpcc1_sd		712 MAIN BAY - 765 KV FATEHGARH_II- BHADLA (PG) CKT- 1 (POWERGRID) AT 765 KV FATEHGARH_II(P G)		D	For AMP work	09/Oct/2023	17:00	10/Oct/2023	23:00	PLANNED	Approved	09-Oct-23	17:00	10-Oct-23	23:00	
399	RQ146761	OCC_211	cpcc1_sd	ВАУ	711 TIE BAY - 765 KV FATEHGARH_II BHADLA (PG) CKT- 1 (POWERGRID) AND 765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(P G) AT 765 KV FATEHGARH_II(P G) (POWERGRID)		D	For AMP work	07/Oct/2023	17:00	08/Oct/2023	23:00	PLANNED	Approved	07-Oct-23	17:00	08-Oct-23	23:00	
400	RQ146563	OCC_211	cpcc3_sd	ВАУ	708 TIE BAY - 765 KV BAREILLY_2- LUCKNOW_2 (PG) CKT-1 AND 765/400 KV 1500 MVA ICT 1 AT BAREILLY_2(PG)	GRID	D	AMP work	06/Oct/2023	10:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	10:00	06-Oct-23	18:00	
401	RQ146773	OCC_211	cpcc1_sd	ВАУ	705 TIE BAY - 765 KV AJMER- BHADLA_2 (PG) CKT-2 (POWERGRID) AND 765/400 KV 1500 MVA ICT 2 AT AJMER(PG) AT 765 KV AJMER(PG) (POWERGRID)	POWER GRID	D	For bay AMP Works	06/Oct/2023	08:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	

402	RQ146760	OCC_211	cpcc1_sd	ВАУ	709 MAIN BAY - 765 KV FATEHGARH_II- BHADLA (PG) CKT- 2 (POWERGRID) AT 765 KV FATEHGARH_II(P G)	POWER GRID	D	For AMP work	05/Oct/2023	17:00	06/Oct/2023	23:00	PLANNED	Approved	05-Oct-23	17:00	06-Oct-23	23:00	
403	RQ146567	OCC_211	cpcc3_sd	BAY	707 MAIN BAY - 765KV BALIA(PG)- GAYA(PG) (UNDEF) CKT-1 AT BALIA(PG)	GRID	D	For changing connector and pilot insulator string	05/Oct/2023	10:00	05/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	10:00	05-Oct-23	18:00	
404	RQ146772	OCC_211	cpcc1_sd	BAY	701 MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT AJMER(PG)	POWER GRID	D	For bay AMP Works	05/Oct/2023	08:00	05/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
405	RQ146771	OCC_211	cpcc1_sd	BAY	707 MAIN BAY - 240 MVAR BUS REACTOR NO 1 AT 765KV AJMER(PG) AND 765KV BUS 2 AT AJMER(PG)	POWER GRID	D	For bay AMP Works	04/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
406	RQ146759	OCC_211	cpcc1_sd	ВАУ	708 TIE BAY - 765 KV FATEHGARH_II BHADLA (PG) CKT- 2 (POWERGRID) AND 240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(P G) AT 765 KV FATEHGARH_II(P G) (POWERGRID)	GRID	D	For AMP work	03/Oct/2023	17:00	04/Oct/2023	23:00	PLANNED	Approved	03-Oct-23	17:00	04-Oct-23	23:00	
407	RQ146568	OCC_211	cpcc3_sd	BAY	710 MAIN BAY - 765KV VARANASI- BALIA (PG) CKT-1 AT BALIA(PG)	POWER GRID	D	AMP work	03/Oct/2023	10:00	03/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	10:00	03-Oct-23	18:00	
408	RQ146572	OCC_211	cpcc3_sd	ВАУ	817 TIE BAY - 765 KV ALIGARH(PG)- SIKAR_2 (PASTL) CKT-2 (POWERGRID) AND 765/400 KV 1500 MVA ICT 2 AT ALIGARH(PG) AT 765 KV ALIGARH(PG) (POWERGRID)	POWER GRID		For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 2 (Construction). Actual S/D required on 27.09.2023 to 28.09.2023	03/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	08:00	04-Oct-23	18:00	

410	RQ146574 RQ145859	OCC_211	cpcc2_sd	BAY	816 MAIN BAY - 765 KV ALIGARH(PG)- SIKAR_2 (PASTL) CKT-2 (POWERGRID) AT 765 KV ALIGARH(PG) 707 MAIN BAY - 765KV MOGA- MEERUT (PG) CKT 1 AT MOGA(PG)		For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 2 (Construction). Actual S/D required on 27.09.2023 to 28.09.2023 AMP WORKS	03/Oct/2023 02/Oct/2023	08:30	04/Oct/2023 03/Oct/2023	18:00	Kindly approve		Approved	03-Oct-23	08:00	04-Oct-23	18:00	
	RQ146573			ВАУ	SIKAR_2 (PASTL) CKT-1 (POWERGRID) AND 765/400 KV 1500 MVA ICT 1 AT ALIGARH(PG) AT 765 KV ALIGARH(PG) (POWERGRID)	GRID	For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 1 (Construction). Actual S/D required on 25.09.2023 to 26.09.2023	01/Oct/2023		02/Oct/2023			PLANNED	Approved	01-Oct-23	08:00	02-Oct-23	18:00	
412	RQ146575	OCC_211	cpcc3_sd	ВАҮ	813 MAIN BAY - 765 KV ALIGARH(PG)- SIKAR_2 (PASTL) CKT-1 (POWERGRID) AT 765 KV ALIGARH(PG)	POWER GRID	For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 1 (Construction).Actual S/D required on 25.09.2023 to 26.09.2023	01/Oct/2023	08:00	02/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	02-Oct-23	18:00	
	RQ146631				706-52T TIE BAY - 765/400 KV 1500 MVA ICT 3 AT ANTA(RS) (RRVPNL) AND FUTURE AT 765 KV ANTA(RS) (RRVPNL)		HALF YEARLY & QUARTERLY MAINTENANCE	26/Oct/2023		26/Oct/2023			PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
414	RQ146638	OCC_211	sldcrs_sd	BAY	706-52B MAIN BAY - 765/400 KV 1500 MVA ICT 3 AT ANTA(RS) (RRVPNL)	RRVPNL	HALF YEARLY & QUARTERLY MAINTENANCE	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
415	RQ146632	OCC_211	sldcrs_sd	BAY	705-52A MAIN BAY - 765 KV ANTA-PHAGI (RS) CKT-2 (RRVPNL) AT 765KV ANTA(RS)	RRVPNL	HALF YEARLY & QUARTERLY MAINTENANCE	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	18:00	

416	RQ146633	OCC_211	sldcrs_sd	ВАУ	705-52T TIE BAY - 765/400 KV 1500 MVA ICT 2 AT ANTA(RS) (RRVPNL) AND 240 MVAR LR ON ANTA-PHAGI (RS) CKT-2 @ANTA(RS) AT 765 KV ANTA(RS) (RRVPNL)	RRVPNL	HALF YEARLY & QUARTERLY MAINTENANCE	13/Oct/2023	08:00	13/Oct/2023	18:00	F	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
417	RQ146637	OCC_211	sldcrs_sd	BAY	705-52B MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT ANTA(RS) (RRVPNL)	RRVPNL	HALF YEARLY & QUARTERLY MAINTENANCE	12/Oct/2023	08:00	12/Oct/2023	18:00	F	PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
			sldcrs_sd	BAY	704-52A MAIN BAY - 765 KV ANTA-PHAGI (RS) CKT-1 (RRVPNL) AT 765KV ANTA(RS)	RRVPNL	HALF YEARLY & QUARTERLY MAINTENANCE	09/Oct/2023	08:00	09/Oct/2023	18:00	F	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
419	RQ146635	OCC_211	sldcrs_sd	BAY	704-52T TIE BAY - 765/400 KV 1500 MVA ICT 1 AT ANTA(RS) (RRVPNL) AND 765 KV ANTA- PHAGI (RS) CKT-1 AT 765 KV ANTA(RS) (RRVPNL)	RRVPNL	HALF YEARLY & QUARTERLY MAINTENANCE	06/Oct/2023	08:00	06/Oct/2023	18:00	F	PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
420 I	RQ146636	OCC_211	sldcrs_sd	BAY	704-52B MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT ANTA(RS) (RRVPNL)	RRVPNL	HALF YEARLY & QUARTERLY MAINTENANCE	05/Oct/2023	08:00	05/Oct/2023	18:00	F	PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
421	RQ146608	OCC_211	sldcrs_sd	BAY	70752T TIE BAY - 765KV PHAGI(RS)- GWALIOR(PG) (UNDEF) CKT-2 AND 765KV ANTA- PHAGI (RS) CKT-2 AT PHAGI(RS)	RRVPNL	Quarterly maintenance work	04/Oct/2023	08:00	04/Oct/2023	18:00	F	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
422	RQ146607	OCC_211	sldcrs_sd	BAY	70752B MAIN BAY - 765KV ANTA-PHAGI (RS) CKT-2 AT PHAGI(RS)	RRVPNL	Quarterly maintenance work	03/Oct/2023	08:00	03/Oct/2023	18:00	F	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
423	RQ145385	OCC_211	stuup_sd	BAY		UPPTCL	* 1.Servicing & Overhauling of 765kV Breaker Mechanism by M/S CGL X including testing of Circuit Breaker.	25/Oct/2023	09:00	31/Oct/2023	17:00	F	PLANNED	Approved	25-Oct-23	09:00	31-Oct-23	17:00	

		OCC_211		BAY	704 MAIN BAY - 765KV ANPARA_C(LAN)- UNNAO(UP) (UP) CKT-1 AT UNNAO(UP) 706 MAIN BAY -	UPPTCL UPPTCL	С	* 1.Servicing & Overhauling of 765kV Breaker Mechanism by M/S CGLX including testing of Circuit Breaker. * 1.Servicing &	18/Oct/2023 11/Oct/2023		24/Oct/2023 17/Oct/2023			PLANNED		18-Oct-23	09:00	24-Oct-23	17:00	
					765/400KV 1000 MVA ICT 2 AT UNNAO(UP)			Overhauling of 765kV Breaker Mechanism by M/S CGL X including testing of Circuit Breaker.												
		OCC_211		BAY	712 MAIN BAY - 765KV/400KV AGRA FATEHBAD(UP)- ICT-1 AT AGRA FATEHBAD(UP)	UPPTCL	D	* For rectification of remote operation function of CB and Isolator by X SCADA Engineer	10/Oct/2023	10:00	10/Oct/2023	14:00		PLANNED	Approved	10-Oct-23	10:00	10-Oct-23	14:00	
427	RQ145369	OCC_211	stuup_sd	ВАЎ	703 MAIN BAY - 765/400KV 1000 MVA ICT 1 AT UNNAO(UP)	UPPTCL		* 1.Servicing & Overhauling of 765kV Breaker Mechanism by M/S CGL X including testing of Circuit Breaker.	04/Oct/2023	09:00	10/Oct/2023	17:00		PLANNED	Approved	04-Oct-23	09:00	10-Oct-23	17:00	
			cpcc1_sd		714 TIE BAY - 765 KV AJMER(PG)- PHAGI(RS) (PAPTL) CKT-2 (PAPTL) AND 765KV BUS 1 AT AJMER(PG) AT 765 KV AJMER(PG) (PAPTL)			For bay AMP Works	17/Oct/2023		17/Oct/2023			PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
		OCC_211			765/400 KV 1500 MVA ICT 2 AT BALIA(PG)	GRID		PRV modification work	25/Oct/2023		25/Oct/2023			PLANNED	Approved	25-Oct-23	10:00	25-Oct-23	18:00	
		OCC_211			765/400 KV 1500 MVA ICT 2 AT KANPUR_GIS(PG)	GRID		AMP WORK , IMPLEMENTATION OF 9TH AND 10TH PCC GUIDELINES PRV Modification	12/Oct/2023		12/Oct/2023			PLANNED	Approved	12-Oct-23	10:00	12-Oct-23	18:00	
431	RQ145849	OCC_211	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT BALIA(PG)	POWER GRID	D	PRV modification work	11/Oct/2023	10:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	10:00	11-Oct-23	18:00	
432	RQ145846	OCC_211	cpcc2_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT MOGA(PG)	POWER GRID	D	AMP WORKS	11/Oct/2023	08:00	11/Oct/2023	18:00	Kindly approve	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
433	RQ145845	OCC_211	cpcc2_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT MOGA(PG)	POWER GRID	D	AMP WORKS	09/Oct/2023	08:00	09/Oct/2023	18:00	Kindly approve	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
434	RQ146639	OCC_211	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT ALIGARH(PG)	POWER GRID		For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 1 (Construction). Actual S/D required on 25.09.2023	01/Oct/2023	08:00	01/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	01-Oct-23	18:00	

435	RQ146172	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(P G)		765KV/400KV ICT 1 for AMP works	24/Oct/2023	17:00	28/Oct/2023	23:59	PLANNED	Approved	24-Oct-23	17:00	28-Oct-23	23:59	
436	RQ146212	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT BHADLA_2 (PG)		BAY EXTENSION WORK (724)	23/Oct/2023	17:00	24/Oct/2023	23:59	PLANNED	Approved	23-Oct-23	17:00	24-Oct-23	23:59	
437	RQ146171	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G)		765KV/400KV ICT 2 for AMP works	22/Oct/2023	17:00	25/Oct/2023	23:59	PLANNED	Approved	22-Oct-23	17:00	25-Oct-23	23:59	
438	RQ146211	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT BHADLA_2 (PG)		FOR rectification WORK	22/Oct/2023	17:00	22/Oct/2023	23:59	PLANNED	Approved	22-Oct-23	17:00	22-Oct-23	23:59	
439	RQ146169	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G)		765KV/400KV ICT 4 for AMP works	18/Oct/2023	17:00	21/Oct/2023	23:59	PLANNED	Approved	18-Oct-23	17:00	21-Oct-23	23:59	
440	RQ146170	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(P G)		765KV/400KV ICT 3 for AMP works	18/Oct/2023	17:00	21/Oct/2023	23:59	PLANNED	Approved	18-Oct-23	17:00	21-Oct-23	23:59	
441	RQ146229	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT BHADLA(PG)	•	For installation and testing of Backup Impedance relay in ICT	18/Oct/2023	17:00	18/Oct/2023	23:59	PLANNED	Approved	18-Oct-23	17:00	18-Oct-23	23:59	
442	RQ146203	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT AJMER(PG)	D	FOR AMP WORK	18/Oct/2023	09:00	18/Oct/2023	18:00	PLANNED	Approved	18-Oct-23	09:00	18-Oct-23	18:00	
443	RQ146228	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT BHADLA(PG)	ŀ	For installation and testing of Backup Impedance relay in ICT	17/Oct/2023	17:00	17/Oct/2023	23:59	PLANNED	Approved	17-Oct-23	17:00	17-Oct-23	23:59	
444	RQ146227	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT BHADLA(PG)	•	For installation and testing of Backup Impedance relay in ICT	16/Oct/2023	17:00	16/Oct/2023	23:59	PLANNED	Approved	16-Oct-23	17:00	16-Oct-23	23:59	
445	RQ146167	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G)	,	Commissioning of ICT with Spare ICT Bank & CSD Fine tuning works	15/Oct/2023	17:00	24/Oct/2023	23:59	PLANNED	Approved	15-Oct-23	17:00	24-Oct-23	23:59	
		OCC_211		TRANSFORMER	MVA ICT 4 AT KOTESHWAR(PG)		CSD commissioning & FINE TUNING WORK AMP and Relay testing (Back- up impedance retrofitting)	12/Oct/2023		13/Oct/2023		PLANNED	Approved	12-Oct-23	09:00	13-Oct-23	18:00	
447	RQ146166	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(P G)	,	Commissioning of ICT with Spare ICT Bank & CSD Fine tuning works	10/Oct/2023	17:00	19/Oct/2023	23:59	PLANNED	Approved	10-Oct-23	17:00	19-Oct-23	23:59	

448	RQ146191	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 800 MVA ICT 3 AT KOTESHWAR(PG)		D	CSD commissioning & FINE TUNING WORK AMP and Relay testing (Back- up impedance retrofitting)	10/Oct/2023	09:00	11/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	09:00	11-Oct-23	18:00	
449	RQ146168	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G)		D	For Erection works of SS-63 A1 package 765 kV ICT-5 B phase unit	07/Oct/2023	17:00	11/Oct/2023	23:59	For commissioning works of SS-63 A1 package 765 kV ICT-5	PLANNED	Approved	07-Oct-23	17:00	11-Oct-23	23:59	
450	RQ146165	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G)		D	Commissioning of ICT with Spare ICT Bank & CSD Fine tuning works	05/Oct/2023	17:00	13/Oct/2023	23:59		PLANNED	Approved	05-Oct-23	17:00	13-Oct-23	23:59	
451	RQ146190	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 800 MVA ICT 2 AT KOTESHWAR(PG)		D	CSD commissioning & FINE TUNING WORK AMP and Relay testing (Back- up impedance retrofitting)	05/Oct/2023	09:00	06/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	09:00	06-Oct-23	18:00	
452	RQ146196	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT KHETRI (PKTSL)		D	For spare switching and inspection	05/Oct/2023	09:00	06/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	09:00	06-Oct-23	18:00	
453	RQ146201	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT CHITTORGARH(P G)		D	FOR AMP WORK AND For providing insulation on Tertiery connector and conductor	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
454	RQ146202	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT CHITTORGARH(P G)		D	For providing insulation on Tertiery connector and conductor	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
455	RQ146189	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 800 MVA ICT 1 AT KOTESHWAR(PG)		D	CSD commissioning & FINE TUNING WORK AMP and Relay testing (Back- up impedance retrofitting)	03/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	09:00	04-Oct-23	18:00	
456	RQ146195	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT KHETRI (PKTSL)		D	For leakage attending	03/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	09:00	04-Oct-23	18:00	
457	RQ146164	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(P G)		D	Commissioning of ICT with Spare ICT Bank & CSD Fine tuning works	01/Oct/2023	17:00	07/Oct/2023	23:59		PLANNED	Approved	01-Oct-23	17:00	07-Oct-23	23:59	
458	RQ146210	OCC_211	cpcc1_sd	TRANSFORMER	765/400 KV 1000 MVA ICT 2 AT BHIWANI(PG)		D	FOR AMP WORK	01/Oct/2023	09:00	01/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	09:00	01-Oct-23	18:00	
		OCC_211			765/400 KV 1500 MVA ICT 2 AT MEERUT(PG)		D	FOR AMP WORK	01/Oct/2023		01/Oct/2023			PLANNED	Approved	01-Oct-23	09:00	01-Oct-23	18:30	
460	RQ145529	OCC_211	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT HAPUR(UP)	UPPTCL	D	For Maintenance & testing work	20/Oct/2023	09:00	20/Oct/2023	13:00		PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	13:00	

461	RQ145361	OCC_211	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT AGRA FATEHBAD(UP)	UPPTCL	D	* For Checking of CVT Selection Logic of ICT HV and IV side as it is not X working properly by SCADA Engineer	13/Oct/2023	10:00	13/Oct/2023	17:00	PLANN	ED Approved	13-Oct-23	10:00	13-Oct-23	17:00	
462	RQ145528	OCC_211	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT GR.NOIDA_2(UPC )	UPPTCL	D	For Maintenance & testing and CSD tunning work	11/Oct/2023	09:00	11/Oct/2023	13:00	PLANN	D Approved	11-Oct-23	09:00	11-Oct-23	13:00	
463	RQ145451	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV UNNAO- LUCKNOW (UP) CKT-1	UPPTCL	D	* For Bay Maintenance and 400 KV Circuit Breaker timing at 400 KV X Sub- Station, Sarojini Nagar, Lucknow.	31/Oct/2023	09:00	31/Oct/2023	18:00	PLANN	ED Approved	31-Oct-23	09:00	31-Oct-23	18:00	
		OCC_211		LINE CIRCUIT	SULTANPUR (UP) CKT-1		D	* For Taking out of Circuit of Non Switchable 50MVAR Line Reactor at 400KV X S/S Sultanpur	25/Oct/2023		25/Oct/2023		PLANN			10:00	25-Oct-23	15:00	Subject to real time Grid conditions and no Generation backdown at Obra end
465	RQ145921	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL - BADAUNE (UP) CKT-1	UPPTCL	D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	25/Oct/2023	08:00	25/Oct/2023	18:00	PLANN	ED Approved	22-Oct-23	08:00	22-Oct-23	18:00	May be given subject to UP consent/B-7 and CEA clearance required before charging/May be given in Sunday.
466	RQ145922	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL - BADAUNE (UP) CKT-2	UPPTCL	D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	25/Oct/2023	08:00	25/Oct/2023	18:00	PLANN	ED Approved	22-Oct-23	08:00	22-Oct-23	18:00	May be given subject to UP consent/B-7 and CEA clearance required before charging/May be given in Sunday.
		OCC_211		AC TRANSMISSION LINE CIRCUIT	)-MAU(UP) (UP) CKT-1	UPPTCL	С	* DIVERSION OF 1.11 KM. 400KV ANPARA- SARNATH (L-5) & ANPARA-MAU X (L- 6) D/C LINE BETWEEN TOWER NO. 421 TO 424 DUE TO INF	21/Oct/2023		31/Oct/2023		PLANN	ED Approved		08:00	31-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Anpara generation backdown may be required
468	RQ145673	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA_B(UPUN )-SARNATH(UP) (UP) CKT-2	UPPTCL	С	1. * DIVERSION OF 1.11 KM. 400KV ANPARA-SARNATH (L- 5) & ANPARA-MAU X (L-6) D/C LINE BETWEEN TOWER NO. 421 TO 424 DUE TO INF. 2. * For Complete Bay tightening work	21/Oct/2023	08:00	31/Oct/2023	18:00	PLANN	ED Approved	21-Oct-23	08:00	31-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Anpara generation backdown may be required
469	RQ145438	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TANDA(NT)- SULTANPUR(UP) (UP) CKT-1	UPPTCL	D	* For Preventive maintenance of Bay at 400KV S/S Sultanpur.	20/Oct/2023	10:00	20/Oct/2023	18:00	PLANN	ED Approved	20-Oct-23	10:00	20-Oct-23	18:00	

F 1				1		1		T			T		T	1					
470	RQ145527	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR- DASNA (UP) CKT- 2	UPPTCL	D	For Line Maintenance & GIS bay gas quality testing work	18/Oct/2023	13:00	18/Oct/2023	16:00	PLANNEI	Approved	18-Oct-23	13:00	18-Oct-23	16:00	
471	RQ145526	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR- DASNA (UP) CKT- 1	UPPTCL	D	For Line Maintenance & GIS bay gas quality testing work	18/Oct/2023	09:00	18/Oct/2023	12:00	PLANNEI	Approved	18-Oct-23	09:00	18-Oct-23	12:00	
472	RQ145457	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA- AGRA FATEHBAD (UP) CKT-1	UPPTCL	D	* Defective polymer & jumper replacement/tigheni ng work	17/Oct/2023	10:00	19/Oct/2023	17:00	PLANNEI	Approved	17-Oct-23	10:00	19-Oct-23	17:00	
473	RQ145909	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL RAMPUR_PRSTL (UP) CKT-1	UPPTCL	С	Power line crossing work with diamond arrangement for E/w for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	17/Oct/2023	08:00	18/Oct/2023	18:00	PLANNEI	Approved	17-Oct-23	08:00	18-Oct-23	18:00	May be given subject to UP consent/B-7 and CEA clearance required before charging/ May be given if taken on daily basis and may be proposed on weekends(Sat &Sunday).
474	RQ145984	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL RAMPUR_PRSTL (UP) CKT-2	UPPTCL	С	Power line crossing work with diamond arrangement for E/w for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	17/Oct/2023	08:00	18/Oct/2023	18:00	PLANNEI	Approved	17-Oct-23	08:00	18-Oct-23	18:00	May be given subject to UP consent/B-7 and CEA clearance required before charging/ May be given if taken on daily basis and may be proposed on weekends(Sat &Sunday).
475	RQ145357	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV REWA ROAD-PANKI (UP) CKT-1	UPPTCL	D	* Installation of check meter (line s/d require)	16/Oct/2023	12:00	16/Oct/2023	14:00	PLANNEI	Approved	16-Oct-23	12:00	16-Oct-23	14:00	
476	RQ145358	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV UNNAO- PANKI (UP) CKT-1	UPPTCL	D	* 400 KV Panki Unnao Line S/D FOR INSTALLATION OF CHECK METER(LINE S/D X REQUIRED)	13/Oct/2023	12:00	13/Oct/2023	14:00	PLANNEI	Approved	13-Oct-23	12:00	13-Oct-23	14:00	
477	RQ146368	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA- OBRA_B (UP) CKT- 1		D	Checking of PLCC	12/Oct/2023	08:00	13/Oct/2023	18:00	PLANNE	Approved	12-Oct-23	08:00	13-Oct-23	18:00	May be given subject to real time grid conditions and no other shutdown from Anpara end.
478	RQ145453	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GR.NOIDA_2(UPC )-GR.NOIDA(UPC) (UP) CKT-2		D	* Jumper tightening work will be carried out on mentioned line during this X shutdown period.	11/Oct/2023	10:00	12/Oct/2023	18:00	PLANNEI	Approved	11-Oct-23	10:00	12-Oct-23	18:00	
479	RQ145456	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA FATEHBAD- MATHURA (UP) CKT-2	UPPTCL	D	* Defective polymer & jumper replacement/tighteni ng work	11/Oct/2023	10:00	13/Oct/2023	17:00	PLANNEI	Approved	11-Oct-23	10:00	13-Oct-23	17:00	
480	RQ145939	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI(UP)- MAINPURI(PG) (UP) CKT-2	UPPTCL	D	AMP work	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNEI	Approved	10-Oct-23	08:00	10-Oct-23	18:00	

481	RQ145671	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA- SARNATH (UP) CKT-1	UPPTCL	С	1. * DIVERSION OF 1.005 KM. 400KV ANPARA-SARNATH (L3) & X SARNATH- AZAMGARH D/C LINE BETWEEN TOWER NO. 19 TO 22 DUE TO INFR. 2. * For Replacement of Disc Insulator of Jack Bus.	10/Oct/2023	08:00	20/Oct/2023	18:00	PLAN	INED Ap	pproved	10-Oct-23	8:00	20-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Anpara generation backdown may be required/May be clubbed with unit outage at Anpara
482	RQ145747	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HARDUAGANJ - SIKANDRABAD (UP) CKT-1	UPPTCL	D	Preventive Maintenance of Line	10/Oct/2023	08:00	11/Oct/2023	18:00	PLAN	INED Ap	pproved	10-Oct-23	08:00	11-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV ANPARA- ANPARA_D (UP) CKT-1	UPPTCL	D	AMC	09/Oct/2023	08:00	10/Oct/2023	18:00	PLAN	INED Ap	pproved	09-Oct-23	08:00	10-Oct-23	18:00	May be given subject to real time grid conditions and no other shutdown from Anpara end.
484	RQ145433	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV REWA ROAD-PANKI (UP) CKT-1	UPPTCL	D	* FOR REPLACEMENT OF CU BOND OF EARTHWIRE AND RUSTED SUSPENSION FITTING X DAMAGE INSULATOR AND JUPMER AT VARIOUS LOCATION	09/Oct/2023	08:00	11/Oct/2023	18:00	PLAN	INED Ap	pproved	09-Oct-23	08:00	11-Oct-23	18:00	
485	RQ145748	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HARDUAGANJ - ALIGARH (UP) CKT-1	UPPTCL	D	Preventive Maintenance of Line	09/Oct/2023	08:00	09/Oct/2023	18:00	PLAN	INED Ap	pproved	09-Oct-23	08:00	09-Oct-23	18:00	
486	RQ145938	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAINPURI(UP)- MAINPURI(PG) (UP) CKT-1	UPPTCL	D	AMP work	06/Oct/2023	08:00	06/Oct/2023	18:00	PLAN	INED Ap	pproved	06-Oct-23	08:00	06-Oct-23	18:00	
487	RQ145746	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALIGARH- SIKANDRABAD (UP) CKT-1	UPPTCL	D	Preventive Maintenance of Line	06/Oct/2023	08:00	07/Oct/2023	18:00	PLAN	INED Ap	pproved	06-Oct-23	08:00	07-Oct-23	18:00	
488	RQ145745	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALIGARH- MAINPURI (UP) CKT-2	UPPTCL	D	Annual Testing and Preventive Maintenance of Line bay.	05/Oct/2023	08:00	05/Oct/2023	18:00	PLAN	INED Ap	pproved	05-Oct-23	08:00	05-Oct-23	18:00	
489	RQ145444	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- UNNAO (UP) CKT- 2	UPPTCL	D	* preventive mainteance and testing	05/Oct/2023	08:00	05/Oct/2023	18:00	PLAN	INED Ap	pproved	05-Oct-23	08:00	05-Oct-23	18:00	
490	RQ145443	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- UNNAO (UP) CKT- 1	UPPTCL	D	* preventive maintenace and testing	04/Oct/2023	08:00	04/Oct/2023	18:00	PLAN	INED Ap	pproved	04-Oct-23	08:00	04-Oct-23	18:00	
491	RQ145744	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALIGARH- MAINPURI (UP) CKT-1	UPPTCL	D	Annual Testing and Preventive Maintenance of Line bay.	04/Oct/2023	08:00	04/Oct/2023	18:00	PLAN	INED Ap	pproved	04-Oct-23	08:00	04-Oct-23	18:00	
492	RQ145452	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUZAFFARNAGA R-ATAUR (UP) CKT-1	UPPTCL	D	* RESAGGING OF LINE,LOOPING CHOPING OF TREES, AND OTHER M & R WORK	03/Oct/2023	09:00	06/Oct/2023	17:00	PLAN	INED Ap	pproved	03-Oct-23	09:00	06-Oct-23	17:00	

493	RQ1454	34 OC	CC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV OBRA_B- REWA ROAD (UP) CKT-1	UPPTCL	* FOR REPLACEMENT OF CU BOND OF EARTHWIRE, RUSTED SUSPENSION FITTING, X DAMAGE INSULATOR AND JUMPER OF 400 KV OBBA REWAROAD LIN	03/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	05-Oct-23	18:00	Subject to real time Grid conditions and no Generation backdown at Obra end
494	RQ14567	72 OC	CC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SARNATH- AZAMGARH (UP) CKT-1	UPPTCL	1. * DIVERSION OF 1.005 KM. 400KV ANPARA-SARNATH (L3) & X SARNATH- AZAMGARH D/C LINE BETWEEN TOWER NO. 19 TO 22 DUE TO INFR. 2. * For Complete Bay tightening work	01/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	08:00	20-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Anpara generation backdown may be required.
495	RQ14669	91 OC	C_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- UNNAO (UP) CKT- 1	UPPTCL	For De-stringing of 800 KV BNC-Agra line(Dismantalled portion) in overhead crossing span ( Ganga Expressway diversion works)	01/Oct/2023	08:00	02/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	02-Oct-23	18:00	No other shutdown be allowed from both ends/ may be proposed on weekends(Sat &Sunday).
496	RQ14669	92 OC	CC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- UNNAO (UP) CKT- 2	UPPTCL	For De-stringing of 800 KV BNC-Agra line(Dismantalled portion) in overhead crossing span ( Ganga Expressway diversion works)	01/Oct/2023	08:00	02/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	02-Oct-23	18:00	No other shutdown be allowed from both ends/ may be proposed on weekends(Sat &Sunday).
497	RQ14591	10 OC	C_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL RAMPUR_PRSTL (UP) CKT-2	UPPTCL	Power line crossing work with diamond arrangement for E/w for under construction of Loop Out CKT of LILO of 765kV GHatampur-Hapur line at Rampur	01/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Rejected					duplicate entry
498	RQ14552	21 OC	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)- WAGOORA(PG) (NRSS XXIX) CKT-2	POWER GRID,NR SS XXIX	Replacement of damaged insulators at Loc. 210	31/Oct/2023	09:00	31/Oct/2023	18:00	Kindly approve	PLANNED	Approved	31-Oct-23	09:00	31-Oct-23	18:00	
499	RQ14552	20 OC	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)- WAGOORA(PG) (NRSS XXIX) CKT-1	POWER GRID,NR SS XXIX	Replacement of damaged insulators at Loc. 210	25/Oct/2023	09:00	25/Oct/2023	18:00	Kindly approve	PLANNED	Approved	25-Oct-23	09:00	25-Oct-23	18:00	
500	RQ14552	22 OC	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV URI_1(NH)- AMARGARH(NRSS XXIX) (NRSS XXIX) CKT-1	POWER GRID,NR SS XXIX	Replacement of damaged insulators at Loc. 155	24/Oct/2023	09:00	24/Oct/2023	18:00	Kindly approve	PLANNED	Approved	24-Oct-23	09:00	24-Oct-23	18:00	Subject to NHPC/NRSS XXIX consent.

501	RQ146358	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SURATGARH(RVU N)-BIKANER(RS) (RS) CKT-1	RRVPNL	D	Rectification of Shutdown defects & Hardware Fittings Tightening	31/Oct/2023	08:00	31/Oct/2023	18:00	PLANNED	Approved	31-Oct-23	17:00	31-Oct-23	23:00	May be given from 1700 Hrs
502	RQ145763	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHHABRA(RVUN)- KAWAI SCTPS(APR) (RS) CKT-1	RRVPNL	D	Annual maintenance and testing of Line/Bay equipments.	26/Oct/2023	08:00	26/Oct/2023	18:00	PLANNED	Approved	26-Oct-23	17:00	26-Oct-23	23:59	May be given from 1700 Hrs
503	RQ145761	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA(RS)- KAWAI SCTPS(APR) (RS) CKT-2	RRVPNL	D	Annual maintenance and testing of Line/Bay equipments.	23/Oct/2023	08:00	23/Oct/2023	18:00	PLANNED	Approved	23-Oct-23	17:00	23-Oct-23	23:59	May be given from 1700 Hrs
504	RQ145760	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA(RS)- KAWAI SCTPS(APR) (RS) CKT-1	RRVPNL	D	Annual maintenance and testing of Line/Bay equipments.	20/Oct/2023	08:00	20/Oct/2023	18:00	PLANNED	Approved	20-Oct-23	17:00	20-Oct-23	23:59	May be given from 1700 Hrs
505	RQ145755	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SURATGARH(RVU N)-BIKANER(RS) (RS) CKT-1	RRVPNL	D	Testing and Routine Bay Maintenance Work	20/Oct/2023	08:00	20/Oct/2023	18:00	PLANNED	Approved	20-Oct-23	17:00	20-Oct-23	23:00	May be given from 1700 Hrs
506	RQ145759	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL- BARMER (RS) CKT- 1	RRVPNL	D	Maintenance along with testing of Bay equipments	18/Oct/2023	08:00	18/Oct/2023	18:00	PLANNED	Approved	18-Oct-23	17:00	18-Oct-23	23:00	May be given from 1700 Hrs
507	RQ145816	OCC_211	sldcrs_sd	AC	400 KV BHADLA- MERTA (RS) CKT-	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	17/Oct/2023	18:00	17/Oct/2023	23:00	PLANNED	Approved	17-Oct-23	17:00	17-Oct-23	23:00	May be given from 1700 Hrs
508	RQ145752	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHINMAL(PG)- BARMER(RS) (RS) CKT-2	RRVPNL	D	Maintenance along with testing of Bay equipments	17/Oct/2023	08:00	17/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	17:00	17-Oct-23	23:00	May be given from 1700 Hrs
509	RQ145751	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	RRVPNL	D	Maintenance along with testing of Bay equipments	16/Oct/2023	08:00	16/Oct/2023	18:00	PLANNED	Approved	16-Oct-23	17:00	16-Oct-23	23:00	May be given from 1700 Hrs
	RQ145818	_	_	AC TRANSMISSION LINE CIRCUIT	400 KV RAJWEST(RW)- JODHPUR (RS) CKT-1	RRVPNL	D	Planned maintenance	13/Oct/2023	08:00	13/Oct/2023		PLANNED	Approved	13-Oct-23	17:00	13-Oct-23	23:00	May be given from 1700 Hrs
511	RQ145815	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJWEST(RW)- KANKANI (RS) CKT	RRVPNL	D	Planned maintenance	12/Oct/2023	08:00	12/Oct/2023	18:00	PLANNED	Approved	12-Oct-23	17:00	12-Oct-23	23:00	May be given from 1700 Hrs
512	RQ145754	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JAISALMER- BARMER (RS) CKT- 2	RRVPNL	D	Maintenance along with testing of Bay equipments	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	17:00	11-Oct-23	23:00	May be given from 1700 Hrs
513	RQ145822	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA- RATANGARH (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS at both end.	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	17:00	10-Oct-23	23:00	May be given from 1700 Hrs
514	RQ145753	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JAISALMER- BARMER (RS) CKT- 1	RRVPNL	D	Maintenance along with testing of Bay equipments	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	17:00	10-Oct-23	23:00	May be given from 1700 Hrs
515	RQ145821	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA- HEERAPURA (RS) CKT-1	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	17:00	09-Oct-23	23:00	May be given from 1700 Hrs

516	RQ146367	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JODHPUR- KANKANI (RS) CKT 1	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
			sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BARMER(RS)- RAJWEST(RW) (RS) CKT-1	RRVPNL		Maintenance along with testing of Bay equipments AT BOTH END.	09/Oct/2023		09/Oct/2023			PLANNED	Approved	09-Oct-23	17:00	09-Oct-23	23:00	May be given from 1700 Hrs
		OCC_211		LINE CIRCUIT	400 KV AKAL- JAISALMER (RS) CKT-1	RRVPNL		Maintenance along with testing of Bay equipments	09/Oct/2023		09/Oct/2023			PLANNED	Approved	09-Oct-23	17:00	09-Oct-23	23:00	May be given from 1700 Hrs
		OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA- KANKANI (RS) CKT 1	RRVPNL		QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	06/Oct/2023		06/Oct/2023			PLANNED	Approved	06-Oct-23	17:00	06-Oct-23	23:00	May be given from 1700 Hrs
520	RQ146357	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PHAGI- HEERAPURA (RS) CKT-1	RRVPNL		Quarterly Maintenance/testing work of 400 KV side bay Equipments	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	17:00	06-Oct-23	23:00	May be given from 1700 Hrs
521	RQ146733	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER- MERTA (RS) CKT- 1	RRVPNL		QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS alongwith 50 MVAR LINE Reactor AT MERTA	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	17:00	05-Oct-23	23:00	May be given from 1700 Hrs
522	RQ145750	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANKANI- JAISALMER (RS) CKT-2	RRVPNL		Maintenance along with testing of Bay equipment AT BOTH END	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	17:00	05-Oct-23	23:00	May be given from 1700 Hrs
523	RQ146360	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA- HEERAPURA (RS) CKT-1	RRVPNL		Quarterly Maintenance/testing work of 400 KV side bay Equipments	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	17:00	05-Oct-23	23:00	May be given from 1700 Hrs
524	RQ146356	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL- KANKANI (RS) CKT 1	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	17:00	03-Oct-23	23:00	May be given from 1700 Hrs
525	RQ145828	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- MOGA (PG) CKT-1	POWER GRID	D	Shutdown required for rectification of shutdown nature defects	31/Oct/2023	08:00	31/Oct/2023	18:00	Kindly approve	PLANNED	Approved	31-Oct-23	08:00	31-Oct-23	18:00	
526	RQ145544	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	AMP WORKS	30/Oct/2023	09:00	30/Oct/2023	18:00	Kindly approve	PLANNED	Approved	30-Oct-23	09:00	30-Oct-23	18:00	
527	RQ145534	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JALANDHAR- HAMIRPUR (PG) CKT-1	POWER GRID		AR NON-AUTO MODE REQUIRED DURING AMP OF BANALA-ASR CKT	30/Oct/2023	09:00	30/Oct/2023	18:00	Kindly approve	PLANNED	Approved	30-Oct-23	09:00	30-Oct-23	18:00	
		OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- JALANDHAR (PG) CKT-2	POWER GRID		AR NON-AUTO MODE REQUIRED DURING AMP OF BANALA-ASR CKT	30/Oct/2023		30/Oct/2023		Kindly approve		Approved	30-Oct-23	09:00	30-Oct-23	18:00	
529	RQ145461	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA(PG)- AGRA(UP) (PG) CKT-1	POWER GRID	D	* Defective jumper replacement & tightening work	26/Oct/2023	10:00	27/Oct/2023	17:00		PLANNED	Approved	26-Oct-23	10:00	27-Oct-23	17:00	
530	RQ145518	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV URI_2(NH)- WAGOORA(PG) (PG) CKT-1	POWER GRID		Shutdown required for rectification of shut nature defects of line	26/Oct/2023	09:00	26/Oct/2023	18:00	Kindly approve	PLANNED	Approved	26-Oct-23	09:00	26-Oct-23	18:00	Subject to NHPC consent.

531	RQ146512	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- FATEHPUR(PG) (PG) CKT-1	POWER GRID	D	Rectification of S/D nature defects and installation of E/W between Tower 515- 516	25/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	25-Oct-23	08:00	26-Oct-23	18:00	May be given subject to real time grid conditions and no other shutdown from Singrauli end.
532	RQ145617	OCC_211	singrauli_s d	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- RIHAND(NT) (PG) CKT-1	POWER GRID	С	TBC SAS INTEGRATION	25/Oct/2023	08:00	26/Oct/2023	18:00	LINE UNDER SHUTDOWN	PLANNED	Approved	25-Oct-23	08:00	26-Oct-23	18:00	Only one continuous shutdown will be given at a time from Singrauli end
533	RQ145636	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMERA_2(NH)- KISHENPUR(PG) (PG) CKT-1	POWER GRID	D	For replacement of broken insulator at Loc No.271.	24/Oct/2023	08:00	25/Oct/2023	18:00	Kindly approve	PLANNED	Approved	24-Oct-23	08:00	25-Oct-23	18:00	Subject to NHPC consent.
534	RQ145483	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-3	POWER GRID	D	Shutdown required for rectification work of tower no. 185.	23/Oct/2023	08:00	23/Oct/2023	18:00	Kindly approve	PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
535	RQ145484	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID	D	Shutdown required for rectification work of tower no. 185.	23/Oct/2023	08:00	23/Oct/2023	18:00	Kindly approve	PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
536	RQ145805	OCC_211	sldchp_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GUMMA	POWER GRID	D	Periodical Testing	21/Oct/2023	09:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	09:00	21-Oct-23	18:00	
537	RQ145807	OCC_211	sldchp_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NATHPA	POWER GRID	D	Periodical Testing	21/Oct/2023	09:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	09:00	21-Oct-23	18:00	Subject to SJVNL/PG consent.
538	RQ146514	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID	D	AMP work	21/Oct/2023	08:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	08:00	21-Oct-23	18:00	
539	RQ145481	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-3	POWER GRID	D	Shutdown required for rectification work of tower no. 272.	20/Oct/2023	09:00	20/Oct/2023	18:00	Kindly approve	PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	18:00	
540	RQ145482	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-4	POWER GRID	D	Shutdown required for rectification work of tower no. 272.	20/Oct/2023	09:00	20/Oct/2023	18:00	Kindly approve	PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	18:00	
541	RQ146513	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR_GIS- KANPUR (PG) CKT- 1	POWER GRID	D	AMP work	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
542	RQ145356	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR(PG)- PANKI(UP) (PG) CKT-1	POWER GRID	D	* 400KV PANKI - FATEHPUR PG-I LINE FOR S/D BAY MAINTENANCE AND REPLACEMENT X OF R-PHASE CONDUCTOR TRASFER BUS ISOLATOR TO STAN	19/Oct/2023	10:00	19/Oct/2023	17:00		PLANNED	Approved	19-Oct-23	10:00	19-Oct-23	17:00	
543	RQ145819	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SHREE CEMENT(SCL)- MERTA(RS) (PG) CKT-1	POWER GRID	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	18:00	subject to PG consent in real time.
544	RQ145928	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2(PG)- KASHIPUR(UK) (PG) CKT-2	POWER GRID	D	Rectification of S/D nature defects	19/Oct/2023	08:00	21/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	21-Oct-23	18:00	

545	RQ145820	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTA(PG)- MERTA(RS) (PG) CKT-1	POWER GRID	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	subject to PG consent in real time.
			sldchp_sd	TRANSMISSION LINE CIRCUIT	GUMMA (HP) (PG) CKT-2	POWER GRID	D	Periodical Testing	17/Oct/2023		17/Oct/2023			PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	Subject to SJVNL/PG consent.
	RQ145806	_		AC TRANSMISSION LINE CIRCUIT	400 KV GUMMA (HP)- PANCHKULA(PG) (PG) CKT-2	POWER GRID	D	Periodical Testing	17/Oct/2023		17/Oct/2023			PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	
	RQ145394	_	. –	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA- SONIPAT (PG) CKT 2		D	Shutdown required for rectification of shut nature defects of line	17/Oct/2023		17/Oct/2023		Kindly approve		Approved	17-Oct-23	08:00	17-Oct-23	18:00	
	RQ146502	_	-	AC TRANSMISSION LINE CIRCUIT	BAREILLY (PG) CKT-1		D	Rectification of S/D nature defects and AMP work	17/Oct/2023		17/Oct/2023			PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
550	RQ145547	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	HAMIRPUR (PG) CKT-1	POWER GRID	D	AMP WORKS	16/Oct/2023	09:00	16/Oct/2023	18:00	Kindly approve	PLANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	
551	RQ145546	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	AR NON-AUTO MODE REQUIRED DURING AMP OF JAL- HAMIRPUR CKT	16/Oct/2023	09:00	16/Oct/2023	18:00	Kindly approve	PLANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	
552	RQ145545	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- JALANDHAR (PG) CKT-2	POWER GRID	D	AR NON-AUTO MODE REQUIRED DURING AMP OF JAL- HAMIRPUR CKT	16/Oct/2023	09:00	16/Oct/2023	18:00	Kindly approve	PLANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	
553	RQ145927	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2(PG)- KASHIPUR(UK) (PG) CKT-1	POWER GRID	D	Rectification of S/D nature defects	16/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	18-Oct-23	18:00	
554	RQ145678	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAMIRPUR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	AMP Works and rectification of shutdown nature defects	13/Oct/2023	09:00	13/Oct/2023	18:00	Kindly approve	PLANNED	Approved	13-Oct-23	09:00	13-Oct-23	18:00	
555	RQ145392	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PANCHKULA- ABDULLAPUR (PG) CKT-1	POWER GRID	D	Shutdown required for rectification of shutdown nature defects	13/Oct/2023	08:00	13/Oct/2023	18:00	Kindly approve	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
	RQ145616		singrauli_s d	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- LUCKNOW(UP) (PG) CKT-1	POWER GRID	С	REACTOR ISOLTOR REPLACEMNT	13/Oct/2023	08:00	16/Oct/2023	18:00	LINE UNDER SHUTDOWN	PLANNED	Approved	13-Oct-23	08:00	16-Oct-23	18:00	Only one continuous shutdown will be given at a time from Singrauli end
557	RQ145436	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1(PG)- BASTI(UP) (PG) CKT-1	POWER GRID	D	* For annual maintenance and testing work.	12/Oct/2023	11:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	11:00	12-Oct-23	18:00	
558	RQ145480	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-4	POWER GRID	D	AR Non auto mode required for safety of manpower working in ckt-3	12/Oct/2023	09:00	16/Oct/2023	18:00	Kindly approve	PLANNED	Approved	12-Oct-23	09:00	16-Oct-23	18:00	

559	RQ145415	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUDHIANA- JALANDHAR (PG) CKT-1	POWER GRID	D	For AMP of line Equipments and Protection Test	12/Oct/2023	09:00	12/Oct/2023	17:00	Kindly approve	PLANNED	Approved	12-Oct-23	09:00	12-Oct-23	17:00	
560	RQ145479	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID	С	Shutdown required for rectification of damaged cross-arm at Ckt-3 of tower no. 288.	12/Oct/2023	09:00	16/Oct/2023	18:00	Kindly approve	PLANNED	Approved	12-Oct-23	09:00	16-Oct-23	18:00	Only one continuous shutdown will be given at a time
	RQ145519			AC TRANSMISSION LINE CIRCUIT	400 KV NEWWANPOH- WAGOORA (PG) CKT-2	POWER GRID	D	Rectification of damaged peak at Loc No. 343	12/Oct/2023		12/Oct/2023		Kindly approve	PLANNED	Approved	12-Oct-23	09:00	12-Oct-23	18:00	
562	RQ146500	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2- JAULJIVI (PG) CKT 2	POWER GRID	D	AMP work	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
563	RQ146732	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI(PG) HEERAPURA(RS) (PG) CKT-1		D	Quarterly Maintenance/testing work of 400 KV side bay Equipments	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	subject to PG consent in real time.
564	RQ145393	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PANCHKULA- ABDULLAPUR (PG) CKT-2	POWER GRID	D	Shutdown required for rectification of shutdown nature defects	11/Oct/2023	08:00	11/Oct/2023	18:00	Kindly approve	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
565	RQ145416	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUDHIANA- MALERKOTLA (PG) CKT-1	POWER GRID	D	For AMP of line Equipments and Protection Test	10/Oct/2023	09:00	10/Oct/2023	17:00	Kindly approve	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	17:00	
566	RQ146499	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID	D	AMP work	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
567	RQ145932	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1- SOHAWAL (PG) CKT-1	POWER GRID	D	AMP work	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
568	RQ145615	OCC_211	singrauli_s d	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- LUCKNOW(UP) (PG) CKT-1	POWER GRID	С	LINE ISOLATOR REPLACEMENT	09/Oct/2023	08:00	12/Oct/2023	18:00	LINE UNDER SHUTDOWN	PLANNED	Approved					Only one continuous shutdown will be given at a time from Singrauli end/ May be clubbed with S. no. 556
569	RQ146693	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR- MAINPURI (PG) CKT-2	POWER GRID	D	For replacement of damaged conductor in span of 604-605	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
570	RQ145478	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID	D	Shutdown required for rectification work of tower no. 166 and 195.	09/Oct/2023	08:00	11/Oct/2023	18:00	Kindly approve	PLANNED	Approved	09-Oct-23	08:00	11-Oct-23	18:00	Subject to NHPC consent and no Generation loss.
571	RQ145772	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHATIKARA- DWARKA (PG)	POWER GRID	D	For S/D type defect rectification work	08/Oct/2023	08:00	08/Oct/2023	18:00		PLANNED	Approved	08-Oct-23	08:00	08-Oct-23	18:00	
572	RQ146682	OCC_211	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID	D	For CB testing and other PMS work	07/Oct/2023	09:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	09:00	07-Oct-23	18:00	

573	RQ145735	OCC_211	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG) DEEPALPUR(JHKT ) (PG) CKT-1	POWER GRID	D	AMP of Line Bay Equipment(Testing of line CVT, LA, CT and alignment checking of BUS isolator/ Earth Switch.	07/Oct/2023	09:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	09:00	07-Oct-23	18:00	
574	RQ145418	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUDHIANA- PATIALA (PG) CKT- 2	POWER GRID	D	For AMP of line Equipments and Protection Test	07/Oct/2023	09:00	07/Oct/2023	17:00	Kindly approve	PLANNED	Approved	07-Oct-23	09:00	07-Oct-23	17:00	
575	RQ146509	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD(PG)- MEJA TPS(MUN) (PG) CKT-2	POWER GRID	D	AMP work	07/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	08:00	07-Oct-23	18:00	
576	RQ146705	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AURAIYA(NT)- AGRA(PG) (PG) CKT-2	POWER GRID	D	Rectification of S/D nature defects	07/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	08:00	07-Oct-23	18:00	
			cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	NEWWANPOH (PG) CKT-1	POWER GRID	D	AMP work of Line Equipment	06/Oct/2023		06/Oct/2023		Kindly approve		Approved	06-Oct-23	09:30	06-Oct-23	17:00	
578	RQ145734	OCC_211	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEEPALPUR(JHKT )-BAWANA(DV) (PG) CKT-1	POWER GRID	D	AMP of Line Bay Equipment(Testing of line CVT, LA, CT and alignment checking of BUS isolator/ Earth Switch.	06/Oct/2023	09:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	18:00	
579	RQ145417	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUDHIANA- PATIALA (PG) CKT- 1	POWER GRID	D	For AMP of line Equipments and Protection Test	06/Oct/2023	09:00	06/Oct/2023	17:00	Kindly approve	PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	17:00	
580	RQ146704	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AURAIYA(NT)- AGRA(PG) (PG) CKT-1	POWER GRID	D	Rectification of S/D nature defects	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
581	RQ145829	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- FATEHABAD (PG) CKT-1	POWER GRID	D	Shutdown required for rectification of shutdown nature defects	06/Oct/2023	08:00	06/Oct/2023	18:00	Kindly approve	PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
582	RQ145472	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- JALANDHAR (PG) CKT-2	POWER GRID	D	AMP WORKS	05/Oct/2023	10:00	05/Oct/2023	14:00	Kindly approve	PLANNED	Approved	05-Oct-23	10:00	05-Oct-23	14:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV NEWWANPOH- WAGOORA (PG) CKT-2	POWER GRID	D	AMP WORKS	05/Oct/2023	09:00	05/Oct/2023		Kindly approve	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
584	RQ145548	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	AR NON-AUTO MODE REQUIRED DURING AMP OF JAL- ASR CKT-2	05/Oct/2023	09:00	05/Oct/2023	18:00	Kindly approve	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
585	RQ145549	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JALANDHAR- HAMIRPUR (PG) CKT-1	POWER GRID	D	AR NON-AUTO MODE REQUIRED DURING AMP OF JAL- ASR CKT-2	05/Oct/2023	09:00	05/Oct/2023	18:00	Kindly approve	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	

586	RQ145524	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	NEWWANPOH	POWER GRID	D	Jumper tightening of vulnerable towers in Pirpanjal Section	05/Oct/2023	09:00	05/Oct/2023	18:00	Kindly approve	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
587	RQ146508	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1 400 KV ALLAHABAD(PG)- MEJA TPS(MUN) (PG) CKT-1	POWER GRID	D	AMP work	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
588	RQ145956	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA(P G)- NAKODAR(PSG) (PG) CKT-1	POWER GRID	D	Installation of meters under SAMAST project	04/Oct/2023	13:30	04/Oct/2023	14:30		PLANNED	Approved	04-Oct-23	13:30	04-Oct-23	14:30	
589	RQ145955	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JALANDHAR(PG)- NAKODAR(PSG) (PG) CKT-1	POWER GRID	D	Installation of meters under SAMAST project	04/Oct/2023	13:00	04/Oct/2023	14:00		PLANNED	Approved	04-Oct-23	13:00	04-Oct-23	14:00	
590	RQ145471	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- JALANDHAR (PG) CKT-1	POWER GRID	D	AMP WORKS	04/Oct/2023	10:00	04/Oct/2023	14:00	Kindly approve	PLANNED	Approved	04-Oct-23	10:00	04-Oct-23	14:00	
591	RQ145411	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-3	POWER GRID	D	AMP work of Line Equipment	04/Oct/2023	09:30	04/Oct/2023	17:00	Kindly approve	PLANNED	Approved	04-Oct-23	09:30	04-Oct-23	17:00	
592	RQ146511	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR(PG)- PANKI(UP) (PG) CKT-1	POWER GRID	D	AMP work	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
593	RQ146366	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI(PG)- HEERAPURA(RS) (PG) CKT-2		D	Quarterly Maintenance/testing work of 400 KV side bay Equipments	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	17:00	04-Oct-23	23:00	May be given from 1700 Hrs
594	RQ145583	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEWWANPOH- WAGOORA (PG) CKT-1	POWER GRID	D	AMP WORKS	03/Oct/2023	09:00	03/Oct/2023	18:00	Kindly approve	PLANNED	Approved	03-Oct-23	09:00	03-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	KANPUR (PG)	POWER GRID	D	AMP work	03/Oct/2023		03/Oct/2023			PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
596	RQ145614	OCC_211	singrauli_s d	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- ALLAHABAD(PG) (PG) CKT-3	POWER GRID	С	SAS INTEGRATION	03/Oct/2023	08:00	05/Oct/2023	18:00	LINE UNDER SHUTDOWN	PLANNED	Approved	03-Oct-23	08:00	05-Oct-23	18:00	Only one continuous shutdown will be given at a time from Singrauli end
597	RQ146503	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW(UP)- BAREILLY(PG) (PG) CKT-1	POWER GRID	D	Lucknow (UPPCL) line reactor replacement work, Jumper opening and bushing dismantelling at 400 kv Bareilly Substation. under ADD-CAP	03/Oct/2023	08:00	03/Oct/2023	18:00	Line will be charged without line reactor as old reactor shall be replaced with new reactor under Add cap.	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
598	RQ146519	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD- KANPUR_GIS (PG) CKT-2	POWER GRID	D	AMP and replacement of Air cell/MOG in Line Reactor	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
599	RQ145477	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DULHASTI(NH)- KISHENPUR(PG) (PG) CKT-1	POWER GRID	С	Shutdown required for rectification work of tower no. 210.	03/Oct/2023	08:00	08/Oct/2023	18:00	Kindly approve	PLANNED	Approved	03-Oct-23	08:00	08-Oct-23	18:00	Subject to NHPC consent and no Generation loss.

600	RQ146801	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- HISSAR (PG) CKT- 3	POWER GRID	D	Defect rectification work in the line	02/Oct/2023	08:00	02/Oct/2023	18:00	SD may availed PL in sept month & other ckt will be in non auto	ANNED	Approved	02-Oct-23	08:00	02-Oct-23	18:00	
601	RQ145670	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JALANDHAR- HAMIRPUR (PG) CKT-1	POWER GRID	D	AR non auto mode required for hot line work	01/Oct/2023	09:00	14/Oct/2023	18:00	Non shutdown PL activity. Kindly approve	ANNED	Approved	01-Oct-23	09:00	14-Oct-23	18:00	
602	RQ146800	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- HISSAR (PG) CKT- 2	POWER GRID	D	Defect rectification work in the line	01/Oct/2023	08:00	01/Oct/2023	18:00	SD may availed PL in sept month.& other ckt will be in non auto	ANNED	Approved	01-Oct-23	08:00	01-Oct-23	18:00	
603	RQ145665	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	AR non auto mode required for hot line work	01/Oct/2023	08:00	14/Oct/2023	18:00	Non shutdown PL activity. Kindly approve	ANNED	Approved	01-Oct-23	08:00	14-Oct-23	18:00	
604	RQ145664	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAMIRPUR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	AR non auto mode required for hot line work	01/Oct/2023	08:00	14/Oct/2023	18:00	Non shutdown PL activity. Kindly approve	ANNED	Approved	01-Oct-23	08:00	14-Oct-23	18:00	
605	RQ145390	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DULHASTI(NH)- KISHENPUR(PG) (PG) CKT-2	POWER GRID	D	AR non auto mode required to carryout stringing on circuit 2	01/Oct/2023	08:00	31/Oct/2023	18:00	Under PL construction head, Kindly approve	ANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	Subject to NHPC consent and no Generation loss.
606	RQ145389	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DULHASTI(NH)- KISHENPUR(PG) (PG) CKT-2	POWER GRID	D	Shutdown is required to carryout stringing on circuit 2	01/Oct/2023	08:00	31/Oct/2023	18:00	Under PL construction head, Kindly approve	ANNED	Approved	01-Oct-23	08:00	31-Oct-23	18:00	Subject to NHPC consent and no Generation loss.
607	RQ145500	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMBA- JALANDHAR (PG) CKT-1		D	AR Non auto mode is required for OPGW works	01/Oct/2023	07:00	31/Oct/2023	18:00	Non shutdown PL activity. Kindly approve	ANNED	Approved	01-Oct-23	07:00	31-Oct-23	18:00	
608	RQ145501	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMBA- JALANDHAR (PG) CKT-2		D	AR Non auto mode is required for OPGW works	01/Oct/2023	07:00	31/Oct/2023	18:00	Non shutdown PL activity. Kindly approve	ANNED	Approved	01-Oct-23	07:00	31-Oct-23	18:00	
609	RQ145403	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAGLIHAR(JK)- KISHENPUR(PG) (JKSPDCL) CKT-3	POWER GRID,JK SPDCL	D	AMP Works and rectification of shutdown nature defects	30/Oct/2023	09:00	30/Oct/2023	18:00	Kindly approve PL	ANNED	Approved	30-Oct-23	09:00	30-Oct-23	18:00	
610	RQ145523	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEWWANPOH(P G)-BAGLIHAR(JK) (JKSPDCL) CKT-1	POWER GRID,JK SPDCL	D	Jumper tightening of vulnerable towers in Pirpanjal Section	10/Oct/2023	09:00	10/Oct/2023	18:00	Kindly approve PL	ANNED	Approved	10-Oct-23	09:00	10-Oct-23	18:00	

611	RO145878	OCC 211	sldcps_sd	AC	400 KV RAJPURA-	PSTCI	D	Jumper Checking	30/Oct/2023	08:00	31/Oct/2023	18:00	I p	PLANNED	Approved	30-Oct-23	08:00	31-Oct-23	18:00	
					DHURI (PS) CKT-1			/Tightining of dead end towers and tree trimming etc. & Cleaning of porcelain discs insulators in polluted areas eg. across railway crossings, near brick klin etc. and Checking & Tightening jumpers nut bolts and routine maintenance.												
612	RQ145900	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TALWANDI SABOO(PSG)- NAKODAR(PSG) (PS) CKT-1	PSTCL	D	Checking of Jumper,suspension clamp and Damper.Tree cutting and disc cleaning	27/Oct/2023	08:00	27/Oct/2023	18:00	P	PLANNED	Approved	27-Oct-23	08:00	27-Oct-23	18:00	
613	RQ145899	OCC_211	sldcps_sd		400 KV NAKODAR(PSG)- MOGA(PG) (PS) CKT-1	PSTCL	D	Checking of Jumper,suspension clamp and Damper.Tree cutting and disc cleaning	25/Oct/2023	08:00	25/Oct/2023	18:00	P	PLANNED	Approved	25-Oct-23	08:00	25-Oct-23	18:00	
614	RQ145881	OCC_211	sidcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TALWANDI SABOO(PSG)- DHURI(PS) (PS) CKT-2	PSTCL	D	Jumper Checking //Tightining of dead end towers and tree trimming etc., Maintenance of 410 89B, 411 89A & CT407 & Maintenanmce of 410 89L, allignment of isolators and checking of interlock, Tightness of clamp connectors of CVT(410). Tightness and cleaning of Wave trap, LA	25/Oct/2023	08:00	26/Oct/2023	18:00	P	PLANNED	Approved	25-Oct-23	08:00	26-Oct-23	18:00	
615	RQ145892	OCC_211	sldcps_sd		400 KV MUKTSAR- MAKHU (PS) CKT- 1	PSTCL	D	Jumper Tightening and tree cutting between Tower No. 132 to 169.	23/Oct/2023	08:00	23/Oct/2023	18:00	P	PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
616	RQ145879	OCC_211	sldcps_sd		400 KV RAJPURA- DHURI (PS) CKT-2		D	Maintenance of 404 89L, allignment of isolators and checking of interlock, Tightness of clamp connectors of CVT(404). Tightness and cleaning of Wave trap, LA	18/Oct/2023	08:00	19/Oct/2023	18:00	P	PLANNED	Approved	18-Oct-23	08:00	19-Oct-23	18:00	
617	RQ145907	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BEHMAN JASSA SINGH (PS)- HMEL (PS) (PSTCL) CKT-2		D	General Maintenance and Operation Checking of Line Side Equipment	17/Oct/2023	08:00	17/Oct/2023	18:00	P	PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	

C10 I	00145000	000 311	alalama ad	lac.	400 KV DELINGSS	DCTCI	-	Canada	10/0+/2022	00.00	10/0+/2022	10.00	ı	DIAMNED	A	16 0+ 22	00.00	16 0+ 22	10.00	1
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV BEHMAN JASSA SINGH (PS)- HMEL (PS) (PSTCL) CKT-1			General Maintenance and Operation Checking of Line Side Equipment	16/Oct/2023		16/Oct/2023			PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV MUKTSAR- MAKHU (PS) CKT- 1			Jumper Tightening and tree cutting between Tower No. 170 to 199.	16/Oct/2023		16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
620	RQ145883	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJPURA TPS(PSG)- NAKODAR(PSG) (PS) CKT-2	PSTCL		Checking of Jumper, suspension clamp and Damper. Tree cutting and disc cleaning	12/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	13-Oct-23	18:00	
621	RQ145882	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAJPURA TPS(PSG)- NAKODAR(PSG) (PS) CKT-1	PSTCL	D	Checking of Jumper,suspension clamp and Damper.Tree cutting and disc cleaning	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
622	RQ145880	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV TALWANDI SABOO(PSG)- DHURI(PS) (PS) CKT-1	PSTCL		Jumper Checking /Tightining of dead end towers and tree trimming etc, Maintenance of 407 89L allignment of isolators and checking of interlock, Tightness of clamp connectors of CVT(407), Checking of oil level and leakage, Tightness and cleaning of wave trap, for LA & Maintenance of 407 89 B, 408 89A. Tightness of clamp connectors of CT(407) associated with this ckt.	09/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	10-Oct-23	18:00	
623	RQ145889	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUKTSAR- MAKHU (PS) CKT- 1	PSTCL		Jumper Tightening and tree cutting between Tower No. 200 to 229.	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV BEHMAN JASSA SINGH (PS)- HMEL (PS) (PSTCL) CKT-2	PSTCL		Installation of meters under SAMAST project	06/Oct/2023	11:00	06/Oct/2023	13:30		PLANNED	Approved	06-Oct-23	11:00	06-Oct-23	13:30	
625	RQ145974	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BEHMAN JASSA SINGH (PS)- HMEL (PS) (PSTCL) CKT-1	PSTCL		Installation of meters under SAMAST project	06/Oct/2023	11:00	06/Oct/2023	13:30		PLANNED	Approved	06-Oct-23	11:00	06-Oct-23	13:30	
626	RQ145898	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NAKODAR(PSG)- MAKHU(PS) (PS) CKT-2	PSTCL		Checking of Jumper,suspension clamp and Damper.Tree cutting and disc cleaning	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	

627	RQ145905	OCC_211	sldcps sd	AC	400 KV BEHMAN	PSTCL	D	General	04/Oct/2023	08:00	13/Oct/2023	18:00	PLANN	ED Approved	04-Oct-23	08:00	13-Oct-23	18:00	
							_	Maintenance/ Jumper Tightening	.,,										
628	RQ145884	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUKTSAR- MAKHU (PS) CKT- 1	PSTCL	D	Jumper Tightening and tree cutting between Tower No. 230 to 262.	04/Oct/2023	08:00	04/Oct/2023	18:00	PLANN	ED Approved	04-Oct-23	08:00	04-Oct-23	18:00	
629	RQ145897	OCC_211	sldcps_sd		400 KV NAKODAR(PSG)- MAKHU(PS) (PS) CKT-1	PSTCL	D	Checking of Jumper,suspension clamp and Damper.Tree cutting and disc cleaning	03/Oct/2023	08:00	03/Oct/2023	18:00	PLANN	ED Approved	03-Oct-23	08:00	03-Oct-23	18:00	
630	RQ145908	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BEHMAN JASSA SINGH (PS)- TALWANDI SABOO(PSG) (PSTCL) CKT-1	PSTCL	D	General Maintenance/ Jumper Tightening	03/Oct/2023	08:00	03/Oct/2023	18:00	PLANN	ED Approved	03-Oct-23	08:00	03-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV ALAKNANDA GVK(UPC)- SRINAGAR(UK) (UK) CKT-1	PTCUL	D	Off line calibration of Energy Meters.	29/Oct/2023	12:00	29/Oct/2023	20:00	PLANN	ED Approved	29-Oct-23	12:00	29-Oct-23	20:00	
632	RQ145513	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALAKNANDA GVK(UPC)- SRINAGAR(UK) (UK) CKT-2	PTCUL	С	1. CB, ISOLATOR,EARTH SWITCH(Inspection, Testing, Connection tightness) 2. Off line calibration of Energy Meters.	26/Oct/2023	08:00	29/Oct/2023	12:00	PLANN	ED Approved	28-Oct-23	08:00	31-Oct-23	12:00	May be given on daily basis/Subject to Uttarakhand consent.
633	RQ145512	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALAKNANDA GVK(UPC)- SRINAGAR(UK) (UK) CKT-1	PTCUL	С	CB, ISOLATOR, EARTH SWITCH (Inspection,Testing & Connection tightness	23/Oct/2023	08:00	25/Oct/2023	20:00	PLANN	ED Approved	25-Oct-23	08:00	27-Oct-23	20:00	May be given on daily basis/Subject to Uttarakhand consent.
634	RQ145454	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MORADABAD(UP) KASHIPUR(UK) (UK) CKT-1	PTCUL	D	* PLANNED S/D OF 400KV MORADABAD- KASHIPUR LINE.THIS S/D IS REQURIED FOR X TESTING OF PROTECTION SYSTEM IN WHICH-	17/Oct/2023	09:00	18/Oct/2023	18:00	PLANN	ED Approved	17-Oct-23	09:00	18-Oct-23	18:00	
635	RQ146685	OCC_211	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAMNOLI(DV)- JHATIKARA(PG) (DTL) CKT-2	POWER GRID,DT L	D	For CB testing and other PMS work	28/Oct/2023	09:00	28/Oct/2023	18:00	PLANN	ED Approved	28-Oct-23	09:00	28-Oct-23	18:00	
636	RQ146689	OCC_211	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID,DT L	D	For CB testing and other PMS work	20/Oct/2023	09:00	20/Oct/2023	18:00	PLANN	ED Approved	20-Oct-23	09:00	20-Oct-23	18:00	
637	RQ146688	OCC_211	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID,DT L	D	For CB testing and other PMS work	19/Oct/2023	09:00	19/Oct/2023	18:00	PLANN	ED Approved	19-Oct-23	09:00	19-Oct-23	18:00	
638	RQ146684	OCC_211	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAMNOLI(DV)- TUGHLAKABAD(P G) (DTL) CKT-2	POWER GRID,DT L	D	For CB testing and other PMS work	18/Oct/2023	09:00	18/Oct/2023	18:00	PLANN	ED Approved	18-Oct-23	09:00	18-Oct-23	18:00	

639	RQ146725	OCC_211	sldcdv_sd		400 KV	POWER	D	tan delta testing	18/Oct/2023	07:00	18/Oct/2023	12:00	PLANNED	Approved	18-Oct-23	07:00	18-Oct-23	12:00	
				TRANSMISSION LINE CIRCUIT	JHATIKARA(PG)- MUNDKA(DV) (PG) CKT-2	GRID,DT L													
640	RQ146676	OCC_211	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	POWER GRID,DT L	D	Tan Delta testing	18/Oct/2023	07:00	18/Oct/2023	12:00	PLANNED	Approved	18-Oct-23	07:00	18-Oct-23	12:00	
			sldcdv_sd		400 KV BAMNOLI(DV)- TUGHLAKABAD(P G) (DTL) CKT-1		D	For CB testing and other PMS work	17/Oct/2023	09:00	17/Oct/2023		PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	
		OCC_211		LINE CIRCUIT	400 KV BAMNOLI(DV)- JHATIKARA(PG) (DTL) CKT-2	POWER GRID,DT L	D	For S/D type defect rectification work	11/Oct/2023		11/Oct/2023		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
		_	stuup_sd		400 KV SULTANPUR(UP)- LUCKNOW_1(PG) (PG) CKT-1	PTCL	D	* For Preventive maintenance of Bay at 400KV S/S Sultanpur	27/Oct/2023	10:00	27/Oct/2023	18:00	PLANNED	Approved	27-Oct-23	10:00	27-Oct-23	18:00	
644	RQ145437	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1(PG)- BASTI(UP) (PG) CKT-2	POWER GRID,UP PTCL	D	* For annual maintenance and testing work.	13/Oct/2023	11:00	13/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	11:00	13-Oct-23	18:00	
645	RQ145455	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA(UP)- AGRA FATEHBAD(UP) (PG) CKT-2	POWER GRID,UP PTCL	D	* Defective jumper replacement/tighteni ng work	09/Oct/2023	10:00	10/Oct/2023	17:00	PLANNED	Approved	09-Oct-23	10:00	10-Oct-23	17:00	
646	RQ145338	OCC_211	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW_1(PG)- JEHTA_HARDOI ROAD (UP) (PG) CKT-2	POWER GRID,UP PTCL	D	* Shutdown of 400 kV Jehta-PGCIL Ckt-2 for annual routine testing work	05/Oct/2023	11:00	05/Oct/2023	17:00	PLANNED	Approved	05-Oct-23	11:00	05-Oct-23	17:00	
647	RQ146614	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEHAR(BB)- PANCHKULA(PG) (PG) CKT-1	POWER GRID,BB MB	D	Pre foggy mtc.	26/Oct/2023	08:00	27/Oct/2023	18:00	PLANNED	Approved	26-Oct-23	08:00	27-Oct-23	18:00	
648	RQ146523	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEHAR(BB)- RAJPURA(PS) (PG) CKT-1	POWER GRID,BB MB	D	Pre-foggy Mtc.	17/Oct/2023	08:00	18/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	08:00	18-Oct-23	18:00	
649	RQ146025	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA- JAIPUR SOUTH (PG) CKT-1		D	For taking line reactor in service.	24/Oct/2023	17:00	24/Oct/2023		PLANNED	Approved	24-Oct-23	17:00	24-Oct-23	17:30	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1		D	For Line Reactor out of service for AMP Work	24/Oct/2023		24/Oct/2023		PLANNED	Approved	24-Oct-23	09:00	24-Oct-23	09:30	
	RQ146088	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTPUTLI- BHIWADI (PG) CKT-1		С	FOR NCRTC DIVERSION WORK	16/Oct/2023		30/Oct/2023		PLANNED	Approved	01-Nov-23	08:00	10-Nov-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Rajasthan consent required/Only two continuous shutdown would be given at a time.
652	RQ146051	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI- HISSAR (PG) CKT- 1		С	FOR NCRTC DIVERSION WORK	16/Oct/2023	08:00	30/Oct/2023	18:00	PLANNED	Approved	01-Nov-23	08:00	10-Nov-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Haryana consent required/Only two continuous shutdown would be given at a time.

653	RQ146090	OCC_211	cpcc1_sd	AC TRANSMISSION	400 KV KURUKSHETRA-	D	For current injection point for Bus-3 for	16/Oct/2023	07:00	16/Oct/2023	20:00		PLANNED	Approved	16-Oct-23	07:00	16-Oct-23	20:00	
				LINE CIRCUIT	JIND (PG) CKT-2		Busbar Relay Testing after HV test of ICT-3 bays.												
654	RO146036	OCC_211	cncc1 sd	AC	400 KV BAREILLY-	С	Diversion of Lines	15/Oct/2023	08:00	30/Oct/2023	18:00	Shutdown may	PLANNED	Approved	28-Oct-23	08:00	08-Nov-23	18:00	CEA clearance/PTCC
034	NQ140030	000_211	cpcc1_su		MEERUT (PG) CKT- 2		Due infrigement of Ganga Expressway of M/s UPEIDA		08.00	30/000/2023	18.00	be availed in Sept-23.	PEANNED	Арргочец	28-001-23	08.00	08-1100-23	18.00	clearance and Annexure B-7 required before charging/Only two continuous shutdown would be given at a time
655	RQ146035	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- MEERUT (PG) CKT- 1	С	Diversion of Lines Due infrigement of Ganga Expressway of M/s UPEIDA	15/Oct/2023	08:00	30/Oct/2023	18:00	Shutdown may be availed in Sept-23.	PLANNED	Approved	28-Oct-23	08:00	08-Nov-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Only two continuous shutdown would be given at a time
656	RQ146104	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEEMRANA- MANESAR (PG) CKT-2	D	SD nature defect rectification work i.e.IGR, Jumper Nut- bolt Tightinning,CC ring fixing etc.	14/Oct/2023	08:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	
657	RQ146103	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEEMRANA- MANESAR (PG) CKT-1	D	SD nature defect rectification work i.e.IGR, Jumper Nut- bolt Tightinning,CC ring fixing etc.	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
658	RQ146102	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEEMRANA(PG)- BABAI(RS) (NRSS36) CKT-1	D	SD nature defect rectification work i.e.IGR, Jumper Nut- bolt Tightinning,CC ring fixing etc.	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
659	RQ146089	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTPUTLI- BHIWADI (PG) CKT-1	D	SD nature defect rectification work i.e.IGR, Jumper Nut- bolt Tightinning,CC ring fixing etc.	10/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
660	RQ146087	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOLAYAT SOLAR NTPC_1 (NTPC_KOLAYAT SL)-BHADLA_2 (PG) (NTPC_KOLAYAT SL) CKT-1	D	AMP	08/Oct/2023	17:00	08/Oct/2023	23:59		PLANNED	Approved	08-Oct-23	17:00	08-Oct-23	23:59	May be given from 1700 Hrs
661	RQ146046	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(PG)- BHADLA_2 (PG) (FBTL) CKT-2	D	Line Bay AMP work	06/Oct/2023	17:00	06/Oct/2023	23:59		PLANNED	Approved	06-Oct-23	17:00	06-Oct-23	23:59	May be given from 1700 Hrs
662	RQ146062	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	D	PRD and mechanial tripping modification(Line reactor)	06/Oct/2023	09:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	17:00	06-Oct-23	23:00	May be given from 1700 Hrs
663	RQ146092	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAHINDERGARH( APL)- BHIWANI(PG) (PG) CKT-4	D	For Bypass commissioning work	05/Oct/2023	09:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
664	RQ146057	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI- HISSAR (PG) CKT- 2	D	For Bypass commissioning work	05/Oct/2023	09:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	

665	RQ146061	OCC_211	cpcc1_sd	AC TRANSMISSION		D	oil leakage ,PRD and mechanial tripping	05/Oct/2023	09:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	17:00	05-Oct-23	23:00	May be given from 1700 Hrs
	ì			LINE CIRCUIT	SIKAR(PG) (RS) CKT-1		modification(LINE REACTOR)												
666	RQ146098	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT- MANDOLA (PG) CKT-3	С	Diversion of Lines Due ingrigement of Ganga Expressway of M/s UPEIDA	05/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	15-Oct-23	08:00	26-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Only two continuous shutdown would be given at a time
	RQ146099		cpcc1_sd	LINE CIRCUIT	400 KV MEERUT- MANDOLA (PG) CKT-4	С	Diversion of Lines Due ingrigement of Ganga Expressway of M/s UPEIDA	05/Oct/2023		20/Oct/2023			PLANNED	Approved	15-Oct-23	08:00	26-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Only two continuous shutdown would be given at a time
668	RQ146043	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(PG)- BHADLA_2 (PG) (FBTL) CKT-1	D	Line Bay AMP work	04/Oct/2023	17:00	04/Oct/2023	23:59		PLANNED	Approved	04-Oct-23	17:00	04-Oct-23	23:59	May be given from 1700 Hrs
669	RQ146058	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI- HISSAR (PG) CKT- 3	D	For Bypass commissioning work	04/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	18:00	
670	RQ146091	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAHINDERGARH( APL)- BHIWANI(PG) (PG) CKT-3	D	For Bypass commissioning work	04/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	18:00	
671	RQ146160	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ATAUR- INDIRAPURAM (UP) CKT-2	D	For connection of LILO at Noida	01/Oct/2023	09:00	01/Oct/2023	18:00	Shutdown may be availed in Sept-23.	PLANNED	Approved	01-Oct-23	09:00	01-Oct-23	18:00	
672	RQ146159	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ATAUR- INDIRAPURAM (UP) CKT-1	D	For connection of LILO at Noida	01/Oct/2023	09:00	01/Oct/2023	18:00	Shutdown may be availed in Sept-23.	PLANNED	Approved	01-Oct-23	09:00	01-Oct-23	18:00	
		OCC_211		LINE CIRCUIT	400 KV DADRI(NT)- MANDOLA(PG) (PG) CKT-2	С	Diversion WORK BETWEEN 122-123 NHAI	01/Oct/2023		12/Oct/2023			PLANNED		20-Sep-23	08:00	30-Sep-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/subject to no other continuous shutdown in Meerut-Dadri complex. Bus sectionalizer to be closed by NTPC at dadri end.
674	RQ146072	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)- MANDOLA(PG) (PG) CKT-1	С	Diversion WORK BETWEEN 122-123 NHAI	01/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	20-Sep-23	08:00	30-Sep-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/subject to no other continuous shutdown in Meerut-Dadri complex. Bus sectionalizer to be closed by NTPC at dadri end.
675	RQ146097	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT- MANDOLA (PG) CKT-2	С	Diversion WORK of NHAI	01/Oct/2023	08:00	15/Oct/2023	18:00	S/D of Both the line shall be availed simultaneously for 15 days on continuous basis	PLANNED	Approved	01-Oct-23	08:00	12-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Only two continuous shutdown would be given at a time

676	RQ146096	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT- MANDOLA (PG) CKT-1		С	Diversion WORK of NHAI	01/Oct/2023	08:00	15/Oct/2023	18:00	S/D of Both the line shall be availed simultaneously for 15 days on continuous basis	PLANNED	Approved	01-Oct-23	08:00	12-Oct-23	18:00	CEA clearance/PTCC clearance and Annexure B-7 required before charging/Only two continuous shutdown would be given at a time
677	RQ145917	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- MEERUT (PG) CKT- 2		D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	22/Oct/2023	08:00	22/Oct/2023	18:00		PLANNED	Approved	22-Oct-23	08:00	22-Oct-23	18:00	
678	RQ145916	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- MEERUT (PG) CKT- 1		D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur- Hapur line at Rampur	22/Oct/2023	08:00	22/Oct/2023	18:00		PLANNED	Approved	22-Oct-23	08:00	22-Oct-23	18:00	
679	RQ146497	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GORAKHPUR(PG)- LUCKNOW_1(PG) (PL) CKT-2		D	AMP work	21/Oct/2023	08:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	08:00	21-Oct-23	18:00	
680	RQ146678	OCC_211	sldcdv_sd		400 KV BAWANA- MUNDKA (DV) CKT-2	DTL	D	Tan Delta testing	17/Oct/2023	07:00	17/Oct/2023	12:00		PLANNED	Approved	17-Oct-23	07:00	17-Oct-23	12:00	
681	RQ146677	OCC_211	sldcdv_sd		400 KV BAWANA- MUNDKA (DV) CKT-1	DTL	D	Tan Delta testing	16/Oct/2023	07:00	16/Oct/2023	12:00		PLANNED	Approved	16-Oct-23	07:00	16-Oct-23	12:00	
682	RQ146675	OCC_211	sldcdv_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JHAJJAR(APCL)- MUNDKA(DV) (APCL) CKT-2	APCPL	D	Tan Delta testing	16/Oct/2023	12:30	16/Oct/2023	17:00		PLANNED	Approved	16-Oct-23	12:30	16-Oct-23	17:00	May be given subject to real time grid conditions and Jhajjar consent.
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV KHEDAR(HPG)- NUHIAWALI(HV) (HV) CKT-1	HVPNL	D	For programming, testing, commisioning & enabling of Auto reclose of 400kV PGCIL-Matana line by firm engineer in presence of M&P Team	12/Oct/2023		13/Oct/2023			PLANNED	Approved	12-Oct-23	10:00	13-Oct-23	17:00	
684	RQ145711	OCC_211	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NUHIAWALI(HV)- FATEHABAD(PG) (HV) CKT-1	HVPNL	D	For programming, testing, commisioning & enabling of Auto reclose of 400kV PGCIL-Matana line by firm engineer in presence of M&P Team	10/Oct/2023	10:00	11/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	10:00	11-Oct-23	18:00	
685	RQ145675	OCC_211	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GURGAON(PG)- DAULATABAD(HV ) (HV) CKT-1	HVPNL	D	For providing Pilot string on various towers	09/Oct/2023	09:30	11/Oct/2023	17:00		PLANNED	Approved	09-Oct-23	09:30	11-Oct-23	17:00	

686	RO145657	OCC_211	sldchr sd	AC	400 KV CLP	HVPNL	D	To carry out the pre-	09/Oct/2023	09:00	09/Oct/2023	18:00	1	PLANNED	Approved	09-Oct-23	09:00	09-Oct-23	18:00	May be given subject to real
		000_211	sideiii_sd	TRANSMISSION LINE CIRCUIT			J	winter maintenance.	03,000,2023	03.00	03,000,2023	10.00			прриотеа	03 000 23	03.00	03 001 23	10.00	time grid conditions and Jhajjar consent.
687	RQ145729	OCC_211	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CLP	HVPNL	D	For providing Pilot string on various towers at Daultabad and to set right the worn-out conductor at Dhanoda	06/Oct/2023	09:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	18:00	May be given subject to real time grid conditions and Jhajjar consent.
688	RQ145656	OCC_211	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CLP JHAJJAR(CLP)- DHANODA(HV)	HVPNL	D	To carry out the pre- winter maintenance.	05/Oct/2023	09:00	05/Oct/2023	18:00		PLANNED	Approved					May be clubbed with S. no. 687
689	RQ145674	OCC_211	sldchr_sd	AC TRANSMISSION	(HVPNL) CKT-1 400 KV JIND(PG)- KIRORI(HV)	HVPNL	D	M&P testing of DPS relay	04/Oct/2023	11:00	04/Oct/2023	15:00		PLANNED	Approved	04-Oct-23	11:00	04-Oct-23	15:00	
690	RQ145730	OCC_211	sldchr_sd	LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	(HVPNL) CKT-1 400 KV CLP JHAJJAR(CLP)- DHANODA(HV) (HVPNL) CKT-2	HVPNL	D	For replacement of DPR Main-2 Relay at Daultabad and to attend the drone inspection observations at Dhanoda	04/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved					May be clubbed with S. no. 686
691	RQ145732	OCC_211	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEEPALPUR(JHKT )-KABULPUR(HV) (HVPNL) CKT-1	HVPNL	С	NHAI_Line Diversion work (De-strining and Stringing work) in between tower no. KD 165 to 168.	03/Oct/2023	09:00	17/Oct/2023	18:00		PLANNED	Approved	20-Sep-23	09:00	27-Sep-23	18:00	May be given subject to availiability of Champa-kurukshetra poles.
692	RQ145733	OCC_211	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEEPALPUR(JHKT )-KABULPUR(HV) (HVPNL) CKT-2	HVPNL	С	NHAI_Line Diversion work (De-strining and Stringing work) in between tower no. KD 165 to 168.	03/Oct/2023	09:00	17/Oct/2023	18:00		PLANNED	Approved	20-Sep-23	09:00	27-Sep-23	18:00	May be given subject to availiability of Champa-kurukshetra poles.
693	RQ146364	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALWAR(ATIL)- HINDAUN(RS) (ATIL) CKT-1	ATSL	D	Rectification of Shutdown defects & Hardware Fittings Tightening	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	17:00	11-Oct-23	23:00	May be given from 1700 Hrs
694	RQ145706	OCC_211	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	PUTL	С	Annual bay equipment maintenance and testing	09/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	10-Oct-23	18:00	Subject to real time grid conditions and PG consent/ May be allowed if taken on daily basis as per UP.
695	RQ145458	OCC_211	ntpcos_sd		400 KV FATEHPUR(PG)- UNCHAHAR(NTB) (PUTL) CKT-2	PUTL	С	bay equipment testing	09/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. no. 694
696	RQ146496	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR(PG)- UNCHAHAR(NTB) (PUTL) CKT-2	PUTL	D	AMP work	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
697	RQ146495	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	PUTL	D	AMP work	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
698	RQ145345	OCC_211	apl_sd	AC TRANSMISSION LINE CIRCUIT	400 KV	ATIL	D	Annual Maintenance	07/Oct/2023	09:00	07/Oct/2023	17:00	Annual Maintenance	PLANNED	Approved	07-Oct-23	09:00	07-Oct-23	17:00	

		OCC_211		LINE CIRCUIT	400 KV MAHINDERGARH( APL)- BHIWANI(PG) (ATIL) CKT-1	ATIL		Annual Maintenance	06/Oct/2023		06/Oct/2023		Annual Maintenance	PLANNED		06-Oct-23	09:00	06-Oct-23	17:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	400 KV MAHINDERGARH( APL)- DHANODA(HV) (ATIL) CKT-1	ATIL	D	Annual Maintenance	05/Oct/2023	09:00	05/Oct/2023	17:00	Annual Maintenance	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	17:00	
701	RQ145555	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2	NRSS XXIX		Line Reactor-2 shall be taken into service at Samba SS after completion of AMP	06/Oct/2023	16:00	06/Oct/2023	16:30	Kindly approve	PLANNED	Approved	06-Oct-23	16:00	06-Oct-23	16:30	
702	RQ145553	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2			To Isolate Line reactor -2 at Samba SS for AMP	06/Oct/2023	09:00	06/Oct/2023	09:30	Kindly approve	PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	09:30	
703	RQ145554	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1			Line Reactor-1 shall be taken into service at Samba SS after completion of AMP	04/Oct/2023	16:00	04/Oct/2023	16:30	Kindly approve	PLANNED	Approved	04-Oct-23	16:00	04-Oct-23	16:30	
704	RQ145552	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1	NRSS XXIX		To Isolate Line reactor -1 at Samba SS for AMP	04/Oct/2023	09:00	04/Oct/2023	09:30	Kindly approve	PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	09:30	
705	RQ146233	OCC_211	indigrid_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2	NRSS XXIX		Shut Down defect Rectification work as per annual plan	04/Oct/2023	08:00	04/Oct/2023	16:00	Annual Maintenance	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	16:00	
706	RQ146232	OCC_211	indigrid_sd		400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1	NRSS XXIX		Shut Down defect Rectification work as per annual plan	03/Oct/2023	08:00	03/Oct/2023	16:00	Annual Maintenance	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	16:00	
707	RQ146643	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALIGARH(PG)- PRITHALA (GPTL) (GPTL) CKT-2	GPTL		AMP of line bay equipments at Aligarh	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	PRITHALA (GPTL) (GPTL) CKT-1	GPTL		AMP of line bay equipments at Aligarh	04/Oct/2023		04/Oct/2023			PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
709	RQ146480	OCC_211	sldchp_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KALA AMB(PKTL)- SORANG(GREENK O) (GREENKO) CKT-1	PKATL,J PL,GREE NKO		DCRM testing, CB timing and SF6 gas analysis	04/Oct/2023	09:00	04/Oct/2023	16:00		PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	16:00	

710	RQ146230	OCC_211	indigrid_sd		400 KV KOLDAM(NT)- LUDHIANA(PG) (PKTCL) CKT-2	PKTCL	D	Shut Down defect Rectification work as per annual plan	01/Oct/2023	10:00	01/Oct/2023	16:00	Annual Maintenance	PLANNED	Approved	01-Oct-23	10:00	01-Oct-23	16:00	
711	RQ145502	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_3(NH)- PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL,P OWERG RID	D	AR Non auto mode is required for OPGW works	01/Oct/2023	07:00	31/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Rejected					IndiGrid denied Consent.
712	RQ145619	OCC_211	singrauli_s d	BUS	400KV BUS 4 AT SINGRAULI(NT)	NTPC	С	BUS -4 UNDER SHUTDOWN	31/Oct/2023	19:00	31/Oct/2023	23:00	DEAD BUS CHARGING OF UNIT-07 AFTER SAS INTEGRATON	PLANNED	Approved	31-Oct-23	19:00	31-Oct-23	23:00	May be given subject to no other shutdown at Singrauli end.
713	RQ145618	OCC_211	singrauli_s d	BUS	400KV BUS 2 AT SINGRAULI(NT)	NTPC	С	BUS -2 ISOLATOR REPLACEMENT	17/Oct/2023	08:00	20/Oct/2023	18:00	BUS-2 UNDERSHUTD OWN AND ANPARA LINE WILL BE CHARGED THROUGH TBC BREAKER	PLANNED	Approved	17-Oct-23	08:00	20-Oct-23	18:00	BUS-2 UNDERSHUTDOWN AND ANPARA LINE WILL BE CHARGED THROUGH TBC BREAKER
714	RQ145602	OCC_211	cpcc2_sd	BUS	400KV BUS 2 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40189B jumper Connection. (Isolator Retrofitting of 400kV TBC)	31/Oct/2023	12:30	31/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	31-Oct-23	12:30	31-Oct-23	17:30	
715	RQ145601	OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40189A jumper Connection. (Isolator Retrofitting of 400kV TBC)	31/Oct/2023	09:00	31/Oct/2023	12:30	Under construction head, Kindly approve	PLANNED	Approved	31-Oct-23	09:00	31-Oct-23	12:30	
716	RQ145600	OCC_211	cpcc2_sd	BUS	400KV BUS 2 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40189B jumper removal. (Isolator Retrofitting of 400kV TBC)	30/Oct/2023	12:30	30/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	30-Oct-23	12:30	30-Oct-23	17:30	
717	RQ145599	OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40189A jumper removal. (Isolator Retrofitting of 400kV TBC)	30/Oct/2023	09:00	30/Oct/2023	12:30	Under construction head, Kindly approve	PLANNED	Approved	30-Oct-23	09:00	30-Oct-23	12:30	
718	RQ145965	OCC_211	cpcc3_sd	BUS	400KV AGRA(PG) - BUS 2	POWER GRID	D	AMP work	29/Oct/2023	10:00	29/Oct/2023	18:00		PLANNED	Approved	29-Oct-23	10:00	29-Oct-23	18:00	
719	RQ145964	OCC_211	cpcc3_sd	BUS	400KV AGRA(PG) BUS 1	POWER GRID	D	AMP work	27/Oct/2023	10:00	27/Oct/2023	18:00		PLANNED	Approved	27-Oct-23	10:00	27-Oct-23	18:00	
	RQ145651		cpcc2_sd	BUS	400KV BUS 2 AT WAGOORA(PG)	POWER GRID	С	For BUS-2 isolator Retrofitting 40289B	25/Oct/2023		28/Oct/2023		Under construction head, Kindly approve	PLANNED	Approved	25-Oct-23	09:00	28-Oct-23	17:30	May be given subject to no other shutdown at Wagoora.
		OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40289A jumper connection. Isolator Retrofitting 40289A	24/Oct/2023		24/Oct/2023		Under construction head, Kindly approve	PLANNED	Approved	24-Oct-23	09:00	24-Oct-23	17:30	
722	RQ145655	OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40289A jumper removal. Isolator Retrofitting 40289A	20/Oct/2023	09:00	20/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	17:30	

723	RQ145989	OCC_211	cpcc3_sd	BUS	400KV BUS 2 AT GORAKHPUR(PG)	POWER GRID	D	AMP work	19/Oct/2023	10:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	10:00	19-Oct-23	18:00	
724	RQ145596	OCC_211	cpcc2_sd	BUS	400KV BUS 2 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40889B jumper Connection after retrofitting of isolator	18/Oct/2023	12:30	18/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	18-Oct-23	12:30	18-Oct-23	17:30	
725	RQ145595	OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40889A jumper Connection after retrofitting of isolator	18/Oct/2023	09:00	18/Oct/2023	12:30	Under construction head, Kindly approve	PLANNED	Approved	18-Oct-23	09:00	18-Oct-23	12:30	
726	RQ145988	OCC_211	cpcc3_sd	BUS	400KV BUS 1 AT GORAKHPUR(PG)	POWER GRID	D	AMP work	17/Oct/2023	10:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	10:00	17-Oct-23	18:00	
727	RQ145839	OCC_211	cpcc2_sd	BUS	400KV BUS 4 AT MOGA(PG)	POWER GRID	С	Attending SF6 Leakage in 400 kV GIS Bus-2	15/Oct/2023	08:00	30/Oct/2023	18:00	Kindly approve for 400KV GIS Bus-2 Shutdown	PLANNED	Approved	15-Oct-23	08:00	30-Oct-23	18:00	May be allowed subject to no other outage.
728	RQ146328	OCC_211	cpcc3_sd	BUS	400KV BUS 2 AT FATEHPUR(PG)	POWER GRID	D	AMP work	13/Oct/2023	10:00	13/Oct/2023	18:00	5114140	PLANNED	Approved	13-Oct-23	10:00	13-Oct-23	18:00	
729	RQ146327	OCC_211	cpcc3_sd	BUS		POWER GRID	D	AMP work	12/Oct/2023	10:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	10:00	12-Oct-23	18:00	
730	RQ145594	OCC_211	cpcc2_sd	BUS	400KV BUS 2 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40889B jumper removal for isolator retrofitting.	09/Oct/2023	12:30	09/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	09-Oct-23	12:30	09-Oct-23	17:30	
731	RQ145593	OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 40889A jumper removal for isolator retrofitting.	09/Oct/2023	09:00	09/Oct/2023	12:30	Under construction head, Kindly approve	PLANNED	Approved	09-Oct-23	09:00	09-Oct-23	12:30	
732	RQ145979	OCC_211	cpcc3_sd	BUS	400KV BUS 1 AT KANPUR(PG)	POWER GRID	D	to facilititate un- installation of Siemens CB and CT from bay-424	05/Oct/2023	10:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	10:00	05-Oct-23	18:00	
733	RQ145982	OCC_211	cpcc3_sd	BUS	400KV BUS 1 AT BAREILLY(PG)	POWER GRID	D	AMP works and Bus bar relay firmware upgradation	04/Oct/2023	10:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	10:00	04-Oct-23	18:00	
734	RQ145684	OCC_211	sldcrs_sd	BUS	BARMER(RS)	RRVPNL	D	Maintenance along with testing of Bay equipments	31/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	31-Oct-23	17:00	31-Oct-23	23:00	May be given from 1700 Hrs
		OCC_211		BUS	BIKANER(RS)	RRVPNL	D	Bay Maintenance Work	20/Oct/2023		20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	17:00	20-Oct-23	23:00	May be given from 1700 Hrs
736	RQ145689	OCC_211	sldcrs_sd	BUS	400 KV JAISALMER(RS) - BUS 2	RRVPNL	D	Maintenance along with testing of Bay equipments	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	17:00	20-Oct-23	23:00	May be given from 1700 Hrs
737	RQ145683	OCC_211	sldcrs_sd	BUS	400KV BUS 1 AT BARMER(RS)	RRVPNL	D	Maintenance along with testing of Bay equipments	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	17:00	19-Oct-23	23:00	May be given from 1700 Hrs
738	RQ145688	OCC_211	sldcrs_sd	BUS	400 KV JAISALMER(RS) - BUS 1	RRVPNL	D	Maintenance along with testing of Bay equipments	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	17:00	19-Oct-23	23:00	May be given from 1700 Hrs
739	RQ145682	OCC_211	sldcrs_sd	BUS		RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	17:00	16-Oct-23	23:00	May be given from 1700 Hrs
740	RQ145681	OCC_211	sldcrs_sd	BUS	400KV BUS 1 AT MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	17:00	13-Oct-23	23:00	May be given from 1700 Hrs

741	RQ145687	OCC_211	sldcrs_sd	BUS	400KV BUS 2 AT HEERAPURA(RS)	RRVPNL	D	Quarterly Maintenance work of 400 KV side bay Equipments	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	17:00	12-Oct-23	23:00	May be given from 1700 Hrs
742	RQ145686	OCC_211	sldcrs_sd	BUS	400KV BUS 1 AT HEERAPURA(RS)	RRVPNL	D	Quarterly Maintenance work of 400 KV side bay Equipments	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	17:00	03-Oct-23	23:00	May be given from 1700 Hrs
743	RQ145424	OCC_211	stuup_sd	BUS	400KV BUS 2 AT GR.NOIDA(UPC)	UPPCL	D	* maintenance work will be carried out of mentioned Bus during this X shutdown period.	29/Oct/2023	10:00	29/Oct/2023	16:00		PLANNED	Approved	29-Oct-23	10:00	29-Oct-23	16:00	
744	RQ145423	OCC_211	stuup_sd	BUS	400KV BUS 1 AT GR.NOIDA(UPC)	UPPCL	D	* maintenance work will be carried out of mentioned Bus during this X shutdown period.	14/Oct/2023	10:00	14/Oct/2023	16:00		PLANNED	Approved	14-Oct-23	10:00	14-Oct-23	16:00	
745	RQ145508	OCC_211	cpcc2_sd	BUS	400KV BUS 2 AT KALA AMB(PKTL)	PKATL	С	Link Interconnection and Bus Stability of Main Bus-2 for GIS Bay Ext. and 125MVAR BR installation	29/Oct/2023	09:00	31/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	29-Oct-23	09:00	31-Oct-23	18:00	May be given subject to real time grid conditions/One BUS shutdown at a time
746	RQ145507	OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT KALA AMB(PKTL)	PKATL	С	Link Interconnection and Bus Stability of Main Bus-1 for GIS Bay Ext. and 125MVAR BR installation	26/Oct/2023	09:00	28/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	26-Oct-23	09:00	28-Oct-23	18:00	May be given subject to real time grid conditions/One BUS shutdown at a time
747	RQ145506	OCC_211	cpcc2_sd	BUS	400KV BUS 2 AT KALA AMB(PKTL)	PKATL	D	HV Test of Main Bus- 2 for GIS Bay Ext. and 125MVAR BR installation	25/Oct/2023	09:00	25/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	25-Oct-23	09:00	25-Oct-23	18:00	
748	RQ145505	OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT KALA AMB(PKTL)	PKATL	D	HV Test of Main Bus- 1 for GIS Bay Ext. and 125MVAR BR installation	24/Oct/2023	09:00	24/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	24-Oct-23	09:00	24-Oct-23	18:00	
749	RQ145504	OCC_211	cpcc2_sd	BUS	400KV BUS 2 AT KALA AMB(PKTL)	PKATL	С	Construction of Interface Module for GIS Bay Ext. and 125MVAR BR installation	06/Oct/2023	09:00	09/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	06-Oct-23	09:00	09-Oct-23	18:00	May be given subject to real time grid conditions/One BUS shutdown at a time
750	RQ145503	OCC_211	cpcc2_sd	BUS	400KV BUS 1 AT KALA AMB(PKTL)	PKATL	С	Construction of Interface Module for GIS Bay Ext. and 125MVAR BR installation	01/Oct/2023	09:00	05/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	01-Oct-23	09:00	05-Oct-23	18:00	May be given subject to real time grid conditions/One BUS shutdown at a time
751	RQ145680	OCC_211	sldcrs_sd	BUS	400KV BUS 1 AT KAWAI SCTPS(APR)	APRL	D	Circuit Breaker Overhauling	27/Oct/2023	8 08:00	27/Oct/2023	18:00		PLANNED	Approved	27-Oct-23	17:00	27-Oct-23	23:59	May be given from 1700 Hrs
752	RQ146258	OCC_211	cpcc1_sd	BUS	400KV BUS 2 AT CHITTORGARH(P G)		С	For Bay Extension work by BHEL under TBCB at Chittorgarh SS	23/Oct/2023	08:00	28/Oct/2023	18:00		PLANNED	Approved	23-Oct-23	08:00	28-Oct-23	18:00	May be given subject to no other outage
753	RQ146303	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 2		D	For erection and construction works of bay extension of 400 kV Jackson line bay	21/Oct/2023	17:00	28/Oct/2023	23:30		PLANNED	Approved	21-Oct-23	17:00	28-Oct-23	23:30	May be given from 1700 Hrs
754	RQ146292	OCC_211	cpcc1_sd	BUS	400KV BUS 4 AT MANDOLA(PG)		С	BUS BAR RETROFITTING WORK	21/Oct/2023	08:00	24/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	08:00	24-Oct-23	18:00	Subject to Delhi consent one BUS shutdown at a time may be given

755	RQ146305	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 4	D	construction related works of Phase II, STATCOM-2 erection works, Bus Bar, LBB Relay Testing for Ph- II Commissionming work	20/Oct/2023	17:00	28/Oct/2023	23:30		PLANNED	Approved	20-Oct-23	17:00	28-Oct-23	23:30	May be given from 1700 Hrs
756	RQ146282	OCC_211	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 4	D	Bay Extension, For jumpering of new Bay in 430 and 431 and Bus Bar LBB testing	19/Oct/2023	17:00	21/Oct/2023	23:59		PLANNED	Approved	19-Oct-23	17:00	21-Oct-23	23:59	May be given from 1700 Hrs
757	RQ146248	OCC_211	cpcc1_sd	BUS	400 KV KHETRI (PKTSL) - BUS 2	D	AMP work	19/Oct/2023	08:00	20/Oct/2023	20:00		PLANNED	Approved	19-Oct-23	17:00	20-Oct-23	23:00	May be given from 1700 Hrs
758	RQ146281	OCC_211	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 3	D	Bay Extension, For jumpering of new Bay in 407 and 410 and Bus Bar LBB testing	18/Oct/2023	17:00	20/Oct/2023	23:59		PLANNED	Approved	18-Oct-23	17:00	20-Oct-23	23:59	on daily basis. May be given from 1700 Hrs
759	RQ146265	OCC_211	cpcc1_sd	BUS	400KV BUS 4 AT JHATIKARA(PG)	С	ISOLATOR REPLCAMENT	18/Oct/2023	09:15	19/Oct/2023	18:00	ISOLATOR REPLACEMENT	PLANNED	Approved	18-Oct-23	09:15	19-Oct-23	18:00	Subject to Real time Grid conditions, one BUS shutdown at a time may be given
760	RQ146280	OCC_211	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 2	D	Bay Extension, For jumpering of new Bay in 407 and 410 and Bus Bar LBB testing	17/Oct/2023	17:00	19/Oct/2023	23:59		PLANNED	Approved	17-Oct-23	17:00	19-Oct-23	23:59	May be given from 1700 Hrs
761	RQ146247	OCC_211	cpcc1_sd	BUS	400 KV KHETRI (PKTSL) - BUS 1	D	AMP work	17/Oct/2023	08:00	18/Oct/2023	20:00		PLANNED	Approved	17-Oct-23	17:00	18-Oct-23	23:00	May be given from 1700 Hrs on daily basis.
762	RQ146291	OCC_211	cpcc1_sd	BUS	400KV BUS 3 AT MANDOLA(PG)	С	BUS BAR RETROFITTING WORK	17/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	08:00	20-Oct-23	18:00	Subject to Delhi consent one BUS shutdown at a time may be given
763	RQ146279	OCC_211	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 1	D	Bay Extension, For jumpering of new Bay in 407 and 410 and Bus Bar LBB testing	16/Oct/2023	17:00	18/Oct/2023	23:59		PLANNED	Approved	16-Oct-23	17:00	18-Oct-23	23:59	May be given from 1700 Hrs
764	RQ146264	OCC_211	cpcc1_sd	BUS	400KV BUS 2 AT JHATIKARA(PG)	С	ISOLATOR REPLCAMENT	16/Oct/2023	09:15	17/Oct/2023	18:00	ISOLATOR REPLACEMENT	PLANNED	Approved	16-Oct-23	09:15	17-Oct-23	18:00	Subject to Real time Grid conditions, one BUS shutdown at a time may be given
765	RQ146257	OCC_211	cpcc1_sd	BUS	400KV BUS 1 AT CHITTORGARH(P G)	С	For Bay Extension work by BHEL under TBCB at Chittorgarh SS	16/Oct/2023	08:00	21/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	21-Oct-23	18:00	May be given subject to no other outage
766	RQ146274	OCC_211	cpcc1_sd	BUS	400KV BUS 3 AT KURUKSHETRA(P G)	С	For connection of internal conductor of new ICT-3 GIS bay with Existing GIS Bus-3 after HV test and busbar relay testing.	15/Oct/2023	07:00	16/Oct/2023	20:00		PLANNED	Approved	15-Oct-23	07:00	16-Oct-23	20:00	May be availed with All 4 pole SD for diversion work
767	RQ146250	OCC_211	cpcc1_sd	BUS	400KV BUS 1 AT	D	AMP work	14/Oct/2023	10:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	10:00	14-Oct-23	18:00	
768	RQ146297	OCC_211	cpcc1_sd	BUS	SONIPAT(PG) 400KV BUS 3 AT MANDOLA(PG)	D	FOR AMP	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
769	RQ146290	OCC_211	cpcc1_sd	BUS	400KV BUS 2 AT MANDOLA(PG)	С	BUS BAR RETROFITTING WORK	13/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	16-Oct-23	18:00	Subject to Delhi consent one BUS shutdown at a time may be given

770	RQ146273	OCC_211	cpcc1_sd	BUS	400KV BUS 4 AT KURUKSHETRA(P G)	С	For connection of internal conductor of new ICT-3 GIS bay with Existing GIS Bus- 4 after HV test and busbar relay testing	13/Oct/2023	07:00	14/Oct/2023	20:00	PLANNED	Approved	13-Oct-23	07:00	14-Oct-23	20:00	May be availed with All 4 pole SD for diversion work
771	RQ146260	OCC_211	cpcc1_sd	BUS	400KV BUS 2 AT NEEMRANA(PG)	D	FOR AMP & Bay integration WORK	12/Oct/2023	08:00	12/Oct/2023	20:00	PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	20:00	
772	RQ146317	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 4	D	FOR AMP WORKS	11/Oct/2023	17:00	13/Oct/2023	23:30	PLANNED	Approved					May be clubbed with Sr. no. 755
773	RQ146302	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 2	D	Construction works of Fatehgarh-3 double ckt line and their commissioning works for bus bar testing.	11/Oct/2023	17:00	20/Oct/2023	23:30	PLANNED	Approved	11-Oct-23	17:00	20-Oct-23	23:30	May be given from 1700 Hrs
774	RQ146254	OCC_211	cpcc1_sd	BUS	400KV BUS 2 AT CHITTORGARH(P G)	D	For AMP work	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	17:00	10-Oct-23	23:00	May be given from 1700 Hrs
775	RQ146259	OCC_211	cpcc1_sd	BUS	400KV BUS 1 AT NEEMRANA(PG)	D	FOR AMP & Bay integration WORK	10/Oct/2023	08:00	10/Oct/2023	20:00	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	20:00	
776	RQ146316	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 3	D	FOR AMP WORKS	09/Oct/2023	17:00	11/Oct/2023	23:30	PLANNED	Approved					May be clubbed with Sr. no. 782
777	RQ146289	OCC_211	cpcc1_sd	BUS	400KV BUS 1 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	09/Oct/2023	08:00	12/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	08:00	12-Oct-23	18:00	Subject to Delhi consent one BUS shutdown at a time may be given.
778	RQ146270	OCC_211	cpcc1_sd	BUS	400KV BUS 4 AT KURUKSHETRA(P G)	D	For HV Test of GIS Extension bay of Bus- 4	09/Oct/2023	07:00	10/Oct/2023	20:00	PLANNED	Approved	09-Oct-23	07:00	10-Oct-23	20:00	May be availed with All 4 pole SD for diversion work
779	RQ146300	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 1	D	Construction related works of Phase II, Busbar, LBB Testing,under Phase 2 commissioning works	08/Oct/2023	17:00	15/Oct/2023	23:30	PLANNED	Approved	08-Oct-23	17:00	15-Oct-23	23:30	May be given from 1700 Hrs
780	RQ146315	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 2	D	FOR AMP WORKS	07/Oct/2023	17:00	09/Oct/2023	23:30	PLANNED	Approved					May be clubbed with Sr. no. 773
781	RQ146253	OCC_211	cpcc1_sd	BUS	400KV BUS 1 AT CHITTORGARH(P G)	D	For AMP work	07/Oct/2023	08:00	07/Oct/2023	18:00	PLANNED	Approved	07-Oct-23	17:00	07-Oct-23	23:00	May be given from 1700 Hrs
782	RQ146304	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 3	D	For erection of LV side Jack bus of 765/400 kV ICT-5 & ICT-6, Busbar, LBB Testing of ICT-6 under Phase 2 commissioning works	06/Oct/2023	17:00	13/Oct/2023	23:30	PLANNED	Approved	06-Oct-23	17:00	13-Oct-23	23:30	May be given from 1700 Hrs

783	RQ146269	OCC_211	cpcc1_sd	BUS	400KV BUS 4 AT KURUKSHETRA(P G)		С	For Erection of interface module for connection of ICT-3 main bay with existing Bus-4. After erection, internal conductor link will be removed and corona shield applied on both ends to isolate existing & new GIS.	06/Oct/2023	07:00	08/Oct/2023	20:00	PLANNED	Approved	06-Oct-23	07:00	08-Oct-23	20:00	May be availed with All 4 pole SD for diversion work
								Internal conductor will be connected after HV test.											
784	RQ146314	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 1		D	FOR AMP WORKS	05/Oct/2023	17:00	07/Oct/2023	23:30	PLANNED	Approved					May be clubbed with Sr. no. 788
785	RQ146237	OCC_211	cpcc1_sd	BUS	400KV BUS 2 AT SAHARANPUR(PG		D	AMP work	05/Oct/2023	09:00	05/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
786	RQ146236	OCC_211	cpcc1_sd	BUS	400KV BUS 1 AT SAHARANPUR(PG )		D	AMP work	04/Oct/2023	09:00	04/Oct/2023	18:00	PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	18:00	
787	RQ146268	OCC_211	cpcc1_sd	BUS	400KV BUS 3 AT KURUKSHETRA(P G)		D	For HV Test of GIS Extension bay of Bus- 3	04/Oct/2023	07:00	05/Oct/2023	20:00	PLANNED	Approved	04-Oct-23	07:00	05-Oct-23	20:00	May be availed with All 4 pole SD for diversion work
788	RQ146301	OCC_211	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 1		D	For erection work of bay extension of 400 kV Jackson line bays	01/Oct/2023	17:00	10/Oct/2023	23:30	PLANNED	Approved	01-Oct-23	17:00	10-Oct-23	23:30	May be given from 1700 Hrs
			cpcc1_sd		400KV BUS 3 AT KURUKSHETRA(P G)		C	For Erection of interface module for connection of ICT-3 tie bay with existing Bus-3. After erection, internal conductor link will be removed and corona shield applied on both ends to isolate existing an enw GIS. Internal conductor will be connected after HV test.	01/Oct/2023		03/Oct/2023		PLANNED	Approved	01-Oct-23	07:00	03-Oct-23	20:00	May be availed with All 4 pole SD for diversion work
790	RQ146674	OCC_211	sldcdv_sd	BUS	400KV BUS 2 AT MUNDKA(DV)	DTL	D	Tan Delta testing of 400kV Bus I CVT, CTs and CBs	21/Oct/2023	07:00	21/Oct/2023	14:00	PLANNED	Approved	21-Oct-23	07:00	21-Oct-23	14:00	
791	RQ146673	OCC_211	sldcdv_sd	BUS	400KV BUS 1 AT BAWANA(DV)	DTL	D	Tan Delta testing of CT and CBs towards Bus-I	14/Oct/2023	09:00	14/Oct/2023	17:00	PLANNED	Approved	14-Oct-23	09:00	14-Oct-23	17:00	
792	RQ145787	OCC_211	sldcup_sd	BUS	400KV BUS 3 AT LUCKNOW(UP)	UPPTCL	С	* For bay Maintenance work and CB Timing work. The Shutdown of 80 MVAR Bus X reactor will be required simulateneously as 80 MV	19/Oct/2023	09:00	19/Oct/2023	18:00	PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	18:00	

								T.						1					1
793	RQ145425	OCC_211	stuup_sd	BUS	400KV BUS 2 AT AGRA(UP)	UPPTCL	D	* Annual routine maintenance of 400 kV Main Bus -2 at 400 kV S/s Agra	11/Oct/2023	09:00	11/Oct/2023	17:00	PLANNED	Approved	11-Oct-23	09:00	11-Oct-23	17:00	
794	RQ145692	OCC_211	stuup_sd	BUS	400KV BUS 2 AT SULTANPUR(UP)	UPPTCL	С	* Shutdown required of 400KV Main Bus-B for replacement of Bus-B X Pantograph isolator of 315MVA ICT-IV (Cont. basis). During	10/Oct/2023	08:00	14/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	14-Oct-23	18:00	May be given subject to real time grid conditions/One BUS shutdown at a time
		OCC_211		BUS	400KV BUS 2 AT SARNATH(UP)		С	* For repairing and tightening of 400KV Main Bus - II	09/Oct/2023	09:00	10/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	09:00	10-Oct-23	18:00	Subject to real time grid conditions and no other shutdown at Anpara complex/One BUS shutdown at a time
			stuup_sd	BUS	400KV BUS 1 AT SARNATH(UP)		С	* For Repairing & tightening of 400KV Main Bus-I	06/Oct/2023		07/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	09:00	07-Oct-23	18:00	Subject to real time grid conditions and no other shutdown at Anpara complex/One BUS shutdown at a time
		OCC_211	stuup_sd	BUS	400KV BUS 1 AT SULTANPUR(UP)		С	* Shutdown required of 400KV Main Bus-A for replacement of Bus-A X Pantograph isolator of 315MVA ICT-IV (Cont. basis). During	04/Oct/2023		08/Oct/2023		PLANNED	Approved	04-Oct-23	09:00	08-Oct-23	18:00	May be given subject to real time grid conditions/One BUS shutdown at a time
798	RQ145387	OCC_211	stuup_sd	BUS	400KV BUS 1 AT BAREILLY(UP)	UPPTCL	D	* preventive maintenace of ict i pantograph isolator at 400 bareilly and X other maiteance work of bus I	03/Oct/2023	08:00	03/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
799	RQ145359	OCC_211	stuup_sd	BUS	400KV BUS 1 AT PANKI(UP)	UPPTCL	С	* 400KV A-BUS S/D FOR MAJOR OVER HAULING OF 400KV 'A' BUS PANTA ISOLATOR X AND STRINGING OF TWIN MOOSE CONDUTOR OF 315MVA ICT-	01/Oct/2023	10:00	10/Oct/2023	17:00	PLANNED	Approved	01-Oct-23	10:00	10-Oct-23	17:00	May be given Subject to real time grid conditions.
800	RQ145811	OCC_211	sldcps_sd	BUS	400KV BUS 2 AT RAJPURA(PS)	PSTCL	D	Annual maintenance of CVTs, Isolators, hardware fittings and annual protection testing of Bus-Bar equipments.	16/Oct/2023	08:00	19/Oct/2023	18:00	PLANNED	Approved	16-Oct-23	08:00	19-Oct-23	18:00	
801	RQ145810	OCC_211	sidcps_sd	BUS	400KV BUS 1 AT RAJPURA(PS)		D	Annual maintenance of CVTs, Isolators, hardware fittings and annual protection testing of Bus-Bar equipments.	11/Oct/2023	08:00	14/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	08:00	14-Oct-23	18:00	
802	RQ145812	OCC_211	sldcps_sd	BUS	400KV BUS 1 AT DHURI(PS)	PSTCL	D	Maintenance of (407 89 A isolator, 410 89 A isolator) Tightness of terminal connectors and cleaning of Marshalling boxes.	11/Oct/2023	08:00	12/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	08:00	12-Oct-23	18:00	

803	RQ145814	OCC_211	sldcps_sd	BUS	400KV BUS 1 AT DHURI(PS)	PSTCL	D	Maintenance & Tightness of Clamp connectors of Capactive Voltage Transformer, Tightness of terminal connectors and cleaning of marshalling box of Capacitve Voltage Transformer and C & R pannel.	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
			sldcps_sd		400KV BUS 2 AT DHURI(PS)		D	Maintenance & Tightness of Clamp connectors of Capactive Voltage Transformer, Tightness of terminal connectors and cleaning of marshalling box of Capactive Voltage Transformer anc C & R pannel.	03/Oct/2023		05/Oct/2023			PLANNED	Approved	03-Oct-23	08:00	05-Oct-23	18:00	
		OCC_211		BUS	TEHRI(THDC) - 400KV - BUS 3	THDC	D	For Bus-bar protection related work of PSP	04/Oct/2023		04/Oct/2023			PLANNED	Approved	04-Oct-23	07:00	04-Oct-23	17:00	May be given subject to real time grid conditions/One BUS shutdown at a time
		OCC_211		BUS	TEHRI(THDC) - 400KV - BUS 1	THDC	D	For Bus-bar protection related work of PSP	03/Oct/2023	07:00	03/Oct/2023	17:00		PLANNED	Approved	03-Oct-23	07:00	03-Oct-23	17:00	May be given subject to real time grid conditions/One BUS shutdown at a time
807	RQ145386	OCC_211	stuup_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON OBRA_B- SULTANPUR (UP) CKT-1 @SULTANPUR(UP	UPPTCL	С	* For Replacement of T/F oil of Reactor and Centrifuging work	25/Oct/2023	10:00	04/Nov/2023	18:00		PLANNED	Approved	25-Oct-23	10:00	04-Nov-23	18:00	
808	RQ145695	OCC_211	stuup_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON BAREILLY- UNNAO (UP) CKT- 2 @BAREILLY(UP)	UPPTCL	С	* to replace this 50 MVAR line reactor with 63 MVAR line reactor at 400 KV X S/S Bareilly	01/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	26-Oct-23	18:00	
809	RQ145556	OCC_211	cpcc2_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON 400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-2 @SAMBA(PG)		D	AMP WORKS	06/Oct/2023	09:00	06/Oct/2023	16:30	Kindly approve	PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	16:30	
810	RQ145557	OCC_211	cpcc2_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON 400 KV AMARGARH(NRSS XXIX)-SAMBA(PG) (NRSS XXIX) CKT-1 @SAMBA(PG)		D	AMP WORKS	04/Oct/2023	09:00	04/Oct/2023	16:30	Kindly approve	PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	16:30	
811	RQ145737	OCC_211	sldcrs_sd	BR/BSR/MSC/ MSR	50 MVAR BUS REACTOR NO 1 AT 400KV BIKANER(RS)	RRVPNL	D	Testing and Routine Bay Maintenance Work	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	17:00	20-Oct-23	23:00	May be given from 1700 Hrs

812	RQ145738	OCC_211	sldcrs_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400KV BIKANER(RS)	RRVPNL	D	Testing and Routine Bay Maintenance Work	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	17:00	13-Oct-23	23:00	May be given from 1700 Hrs
813	RQ145740	OCC_211	sldcrs_sd	BR/BSR/MSC/ MSR	50 MVAR BUS REACTOR NO 1 AT 400KV RATANGARH(RS)	RRVPNL	D	Maintenance work of bay equipments , isolators and testing work of bay equipments.	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	17:00	12-Oct-23	23:00	May be given from 1700 Hrs
814	RQ146394	OCC_211	sidcrs_sd	BR/BSR/MSC/ MSR	80 MVAR BUS REACTOR NO 2 AT 400 KV CHHABRA SCTPS(RS)	RRVPNL	С	Annual maintenance for Reactor, Fileration of Reactor Oil, tightening of Bay equipments, Relay testing, Protection checking of Trasnformer	10/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	08:00	16-Oct-23	18:00	
815	RQ145741	OCC_211	sldcrs_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400 KV JAISALMER(RS)	RRVPNL	D	Maintenance along with testing of Bay equipments	08/Oct/2023	08:00	08/Oct/2023	18:00		PLANNED	Approved	08-Oct-23	17:00	08-Oct-23	23:00	May be given from 1700 Hrs
		OCC_211	_	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV BARMER(RS)	RRVPNL	D	Maintenance along with testing of Bay equipments	08/Oct/2023		08/Oct/2023	18:00		PLANNED	Approved	08-Oct-23	17:00	08-Oct-23	23:00	May be given from 1700 Hrs
817	RQ145739	OCC_211	sldcrs_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	07/Oct/2023	08:00	07/Oct/2023	18:00		PLANNED	Approved	07-Oct-23	17:00	07-Oct-23	23:00	May be given from 1700 Hrs
818	RQ146393	OCC_211	sldcrs_sd	BR/BSR/MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400 KV CHHABRA SCTPS(RS)	RRVPNL	c	Annual maintenance for Reactor, Fileration of Reactor Oil, tightening of Bay equipments, Relay testing, Protection checking of Trasnformer	03/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	09-Oct-23	18:00	
			sidcup_sd	BR/BSR/MSC/ MSR	50 MVAR BUS REACTOR NO 1 AT 400KV LUCKNOW(UP)	UPPTCL	С	* For Annual Maintenance of 80 MVAR Bus Reactor.The Shutdown will be X required along with 400 KV Transfer Bus which is applie	19/Oct/2023		19/Oct/2023		Kindly update 80MVAR Bus Reactor inplace of 50MVAR Bus Reactor in outage portal	PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	18:00	
820	RQ145379	OCC_211	stuup_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400 KV BASTI(UP)	UPPTCL	D	* For annual maintenance and testing work.	11/Oct/2023	11:00	11/Oct/2023	17:00		PLANNED	Approved	11-Oct-23	11:00	11-Oct-23	17:00	
821	RQ145384	OCC_211	stuup_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV AGRA FATEHBAD(UP)	UPPTCL	D	* For Checking of CVT Selection Logic of Bus Reactor as it is not working X properly by SCADA Engineer	11/Oct/2023	09:00	11/Oct/2023	13:00		PLANNED	Approved	11-Oct-23	09:00	11-Oct-23	13:00	
822	RQ145381	OCC_211	stuup_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400 KV BANDA(UP)	UPPTCL	D	* MENTINACE OF 125 MVAR REACTOR AND COMMISIONING OF NIPS SYSTEM	11/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	12-Oct-23	18:00	

823	RQ145743	OCC_211	stuup_sd	BR/BSR/MSC/ MSR	63 MVAR BUS REACTOR NO 1 AT 400KV ALIGARH(UP)	UPPTCL	D	Annual Testing and Preventive Maintenance of Line bay.	03/Oct/2023	08:00	03/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
824	RQ146816	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV KOTESWAR(TH)		D	AMP work	18/Oct/2023	09:00	18/Oct/2023	18:00	PLANNED	Approved	18-Oct-23	09:00	18-Oct-23	18:00	May be given subject to real time grid conditions.
825	RQ146825	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400 KV MANDOLA(PG)		D	FOR CSD FINE TUNING	18/Oct/2023	08:00	18/Oct/2023	18:00	PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
826	RQ146819	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400KV BALLABHGARH(P G)		D	AMP work	16/Oct/2023	09:00	16/Oct/2023	18:00	PLANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	
827	RQ146827	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400 KV MANDOLA(PG)		С	BUS BAR RETROFITTING WORK	13/Oct/2023	08:00	14/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	08:00	14-Oct-23	18:00	
828	RQ146809	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400KV JAIPUR SOUTH(PG)		D	AMP work	11/Oct/2023	09:00	11/Oct/2023	17:30	PLANNED	Approved	11-Oct-23	09:00	11-Oct-23	17:30	
829	RQ146818	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400KV KANKROLI(PG)		D	AMP work	10/Oct/2023	09:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	15:00	10-Oct-23	23:00	May be given from 1500 Hrs
830	RQ146824	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400 KV MEERUT(PG)		С	For dismantling of Reactor CB and commissioning of CSD in Main & tie Bay CB	10/Oct/2023	09:00	17/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	09:00	17-Oct-23	18:00	
831	RQ146826	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	50 MVAR BUS REACTOR NO 1 AT 400KV MANDOLA(PG)		С	BUS BAR RETROFITTING WORK	10/Oct/2023	08:00	12/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	12-Oct-23	18:00	
832	RQ146817	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	50 MVAR BUS REACTOR NO 1 AT 400KV KANKROLI(PG)		D	AMP work	09/Oct/2023	09:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	15:00	09-Oct-23	23:00	May be given from 1500 Hrs
833	RQ146814	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400KV NEEMRANA(PG)		D	AMP work	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
834	RQ146822	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV SONIPAT(PG)		D	AMP work	06/Oct/2023	10:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	10:00	06-Oct-23	18:00	
835	RQ146808	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV JAIPUR SOUTH(PG)		D	AMP work	04/Oct/2023	09:00	04/Oct/2023	17:30	PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	17:30	
836	RQ146742	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV KOTESWAR(TH)	POWER GRID	D	For AMP work	18/Oct/2023	08:00	18/Oct/2023	18:00	PLANNED	Rejected					Duplicate entry with S. No. 824

837	RQ146752	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400 KV	POWER GRID	D	FOR CSD FINE TUNING	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
838	RQ146746	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	MANDOLA(PG) 80 MVAR BUS REACTOR NO 1 AT 400KV BALLABHGARH(P G)	POWER GRID	D	For AMP work	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
839	RQ146754	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400 KV MANDOLA(PG)	POWER GRID	С	BUS BAR RETROFITTING WORK	13/Oct/2023	08:00	14/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. no. 827
840	RQ146736	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400KV JAIPUR SOUTH(PG)	POWER GRID	D	For AMP work	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
		OCC_211		BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 2 AT 400KV KANKROLI(PG)	POWER GRID	D	For AMP work	10/Oct/2023		10/Oct/2023			PLANNED	Approved	10-Oct-23	15:00	10-Oct-23	23:00	May be given from 1500 Hrs
842	RQ146751	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400 KV MEERUT(PG)	POWER GRID	С	For dismantling of Reactor CB and commissioning of CSD in Main & tie Bay CB	10/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. no. 830
843	RQ146753	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	50 MVAR BUS REACTOR NO 1 AT 400KV MANDOLA(PG)	POWER GRID	С	BUS BAR RETROFITTING WORK	10/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. no. 831
844	RQ146741	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400KV NEEMRANA(PG)	POWER GRID	D	For AMP work	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
845	RQ146744	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	50 MVAR BUS REACTOR NO 1 AT 400KV KANKROLI(PG)	POWER GRID	D	For AMP work	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	15:00	09-Oct-23	23:00	May be given from 1500 Hrs
846	RQ146749	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV SONIPAT(PG)	POWER GRID	D	For AMP work	06/Oct/2023	10:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	10:00	06-Oct-23	18:00	
847	RQ146735	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV JAIPUR SOUTH(PG)	POWER GRID	D	For AMP work	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
848	RQ145412	OCC_211	cpcc2_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 3 AT 400 KV KISHENPUR(PG)	POWER GRID	С	For Erection and Commissioning work of New Equipment under 400 kV Bay Extension Package at Kishenpur S/s(Package No.:N2JM/C&M/CS/O 4(21) and Conversion of 125 MVAr Bus Reactor into Line Reactorof 400KV Kishenpur Dulhasti	01/Oct/2023	09:30	31/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	01-Oct-23	09:30	31-Oct-23	18:00	

849	RQ145847	OCC_211	sldcps_sd	BR/BSR/MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400KV MAKHU(PS)	PSTCL	D	Nut bolt tightening of HV Jumpers, cleaning of bushes,BMK,CTR Panel and C&R Panels	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
850	RQ145863	OCC_211	sldcps_sd	BR/BSR/MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400KV MUKTSAR(PS)	PSTCL	D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.Mtc of NIPFS	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
851	RQ146543	OCC_211	indigrid_sd	BR/BSR/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400 KV PRITHALA (GPTL)	GPTL	D	AMP works of Bus Reactor	06/Oct/2023	08:00	06/Oct/2023	20:00	BR associated bays 411 & 412 will also be under shutdown	PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	20:00	
852	RQ146797	OCC_211	cpcc1_sd	BAY	401 MAIN BAY - 400/220 KV 500 MVA ICT 2 AT FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For bay AMP Works	30/Oct/2023	17:00	31/Oct/2023	23:00		PLANNED	Approved	30-Oct-23	15:00	31-Oct-23	23:00	May be given from 1500 Hrs
853	RQ146796	OCC_211	cpcc1_sd	BAY	416 MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For bay AMP Works	28/Oct/2023	17:00	29/Oct/2023	23:00		PLANNED	Approved	28-Oct-23	17:00	29-Oct-23	23:00	
854	RQ146795	OCC_211	cpcc1_sd	BAY	417 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(P G) (POWERGRID) AND 400 KV FATEHGARH_II(P G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-2 AT 400 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For bay AMP Works	26/Oct/2023	17:00	27/Oct/2023	23:00		PLANNED	Approved	26-Oct-23	17:00	27-Oct-23	23:00	
855	RQ145647	OCC_211	cpcc2_sd	BAY	402 BUS COUPLER BAY - 400KV BUS 1 AT WAGOORA(PG) AND 400KV BUS 2 AT WAGOORA(PG)	POWER GRID	С	Isolator retrofitting of 40289B isolators to be retrofitted	25/Oct/2023	09:00	28/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	25-Oct-23	09:00	28-Oct-23	17:30	

856	RQ146794	OCC_211	cpcc1_sd	ВАУ	418 MAIN BAY - 400 KV FATEHGARH_II(P G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-2 (POWERGRID) AT 400 KV FATEHGARH_II(P G)	POWER GRID	D	For bay AMP Works	24/Oct/2023	17:00	25/Oct/2023	23:00	PLAI	NNED A	Approved	24-Oct-23	15:00	25-Oct-23	23:00	May be given from 1500 Hrs
857	RQ146627	OCC_211	bbmb_sd	ВАҮ	X6-CB MAIN BAY- 400/220 KV 450 MVA ICT 1 AT PANIPAT(BB) AND 400KV BUS 1 AT PANIPAT(BB) AT 400 KV PANIPAT(BB)	GRID	D	Yearly Mtc.	23/Oct/2023	08:00	23/Oct/2023	18:00	PLAI	NNED A	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
858	RQ146793	OCC_211	cpcc1_sd	ВАУ	413 MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(P G) (POWERGRID) AT 400 KV FATEHGARH_II(P G)	POWER GRID	D	For bay AMP Works	22/Oct/2023	17:00	23/Oct/2023	22:00	PLAI	NNED A	Approved	22-Oct-23	17:00	23-Oct-23	22:00	
859	RQ146591	OCC_211	cpcc3_sd	BAY	414 MAIN BAY - 400KV KANPUR(PG)- AURAIYA(NT) (PG) CKT-2 AT KANPUR(PG)	POWER GRID	С	'For dismantling of BHEL make CB and installation of SIEMENS make CB	22/Oct/2023	10:00	26/Oct/2023	18:00	PLAI	NNED A	Approved	22-Oct-23	10:00	26-Oct-23	18:00	Element must remain in service via other bay.
860	RQ146792	OCC_211	cpcc1_sd	BAY	415 MAIN BAY - 400/220 KV 500 MVA ICT 5 AT FATEHGARH_II(P G) (POWERGRID) AT 400 KV FATEHGARH_II(P G)	POWER GRID	D	For bay AMP Works	20/Oct/2023	17:00	21/Oct/2023	23:00	PLAT	NNED A	Approved	20-Oct-23	15:00	21-Oct-23	23:00	May be given from 1500 Hrs
861	RQ146791	OCC_211	cpcc1_sd	BAY	404 MAIN BAY - 400/220 KV 500 MVA ICT 1 AT FATEHGARH_II(P G) (POWERGRID) AT 400 KV FATEHGARH_II(P G)	POWER GRID	D	For bay AMP Works	19/Oct/2023	17:00	20/Oct/2023	23:00	PLAI	NNED A	Approved	19-Oct-23	15:00	20-Oct-23	23:00	May be given from 1500 Hrs
862	RQ146596	OCC_211	cpcc3_sd	ВАҮ	418 MAIN BAY - 400KV KANPUR(PG)- AURAIYA(NT) (PG) CKT-1 AT KANPUR(PG)	POWER GRID	С	'For dismantling of BHEL make CB and installation of SIEMENS make CB	19/Oct/2023	10:00	22/Oct/2023	18:00	PLAI	NNED A	Approved	19-Oct-23	10:00	22-Oct-23	18:00	Element must remain in service via other bay.

863	RQ146649	OCC_211	bbmb_sd	BAY	X9-CB TIE BAY - 400 KV BHIWANI(PG)- BHIWANI(BB) (PG) CKT-1 AND	POWER GRID	D	Yearly mtc.	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	18:00	
864	RQ146790	OCC_211	cpcc1_sd	BAY	FUTURE AT 400 KV BHIWANI(BB) 406 MAIN BAY - 400/220 KV 500	POWER GRID	D	For bay AMP Works	17/Oct/2023	17:00	18/Oct/2023	23:00		PLANNED	Approved	17-Oct-23	15:00	18-Oct-23	23:00	May be given from 1500 Hrs
					MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AT 400 KV FATEHGARH_II(P G)															
865	RQ146590	OCC_211	cpcc3_sd	BAY	426 MAIN BAY - 400/220KV 315 MVA ICT 1 AT KANPUR(PG)	POWER GRID	С	'For dismantling of BHEL make CB and installation of SIEMENS make CB	16/Oct/2023	10:00	20/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	10:00	20-Oct-23	18:00	Element must remain in service via other bay.
866	RQ145853	OCC_211	cpcc2_sd	ВАҮ	414 TIE BAY - 50 MVAR BUS REACTOR NO 1 AT 400KV MOGA(PG) (POWERGRID) AND 400 KV KISHENPUR- MOGA (PG) CKT-1 AT 400 KV MOGA(PG) (POWERGRID)		C	CB Overhauling work	16/Oct/2023	08:00	21/Oct/2023	18:00	Kindly approve	PLANNED	Approved	16-Oct-23	08:00	21-Oct-23	18:00	Element must remain in service via other bay.
867	RQ146799	OCC_211	cpcc1_sd	ВАУ	421 MAIN BAY - 400 KV FATEHGARH_II(P G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-1 (POWERGRID) AT 400 KV FATEHGARH_II(P G)	POWER GRID	D	For bay AMP Works	13/Oct/2023	17:00	14/Oct/2023	23:00		PLANNED	Approved	13-Oct-23	15:00	14-Oct-23	23:00	May be given from 1500 Hrs
868	RQ146788	OCC_211	cpcc1_sd	ВАУ	420 TIE BAY - 400 KV FATEHGARH_II(P G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-1 (POWERGRID) AND 125 MVAR BUS REACTOR NO 1 AT 400 KV FATEHGARH_II(P G) AT 400 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For bay AMP Works	13/Oct/2023	17:00	14/Oct/2023	23:00		PLANNED	Approved	13-Oct-23	15:00	14-Oct-23	23:00	May be given from 1500 Hrs

869	RQ146781	OCC_211	cpcc1_sd	BAY	425 MAIN BAY - 400/220 KV 500 MVA ICT 7 AT BHADLA(PG) (POWERGRID) AT 400 KV BHADLA(PG)	POWER GRID	D	For AMP work	12/Oct/2023	17:00	12/Oct/2023	23:00	I	PLANNED	Approved	12-Oct-23	15:00	12-Oct-23	23:00	May be given from 1500 Hrs
870	RQ146787	OCC_211	cpcc1_sd	BAY	403 MAIN BAY - 400/220 KV 500 MVA ICT 3 AT FATEHGARH_II(P G) (POWERGRID) AT 400 KV FATEHGARH_II(P G)	POWER GRID	D	For bay AMP Works	11/Oct/2023	17:00	12/Oct/2023	23:00	i	PLANNED	Approved	11-Oct-23	15:00	12-Oct-23	23:00	May be given from 1500 Hrs
871	RQ146786	OCC_211	cpcc1_sd	ВАУ	402 TIE BAY - 400/220 KV 500 MVA ICT 3 AT FATEHGARH_II(P G) (POWERGRID) AND 400/220 KV 500 MVA ICT 2 AT FATEHGARH_II(P G) AT 400 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For bay AMP Works	09/Oct/2023	17:00	10/Oct/2023	23:00		PLANNED	Approved	09-Oct-23	15:00	10-Oct-23	23:00	May be given from 1500 Hrs
872	RQ146629	OCC_211	bbmb_sd	ВАУ	X5-CB MAIN BAY 400/220 KV 450 MVA ICT 1 AT PANIPAT(BB) AND 400KV BUS 2 AT PANIPAT(BB) AT 400 KV PANIPAT(BB)	GRID	D	Half yearly mtc	09/Oct/2023	08:00	09/Oct/2023	18:00	ı	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
873	RQ146778	OCC_211	cpcc1_sd	BAY	429 TIE BAY - 400/220 KV 500 MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AND FUTURE AT 400 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	STATCOM erection works	08/Oct/2023	16:00	13/Oct/2023	22:00	1	PLANNED	Approved	08-Oct-23	15:00	13-Oct-23	22:00	May be given from 1500 Hrs
874	RQ146777	OCC_211	cpcc1_sd	BAY	412 MAIN BAY - 400 KV BIKANER_2 (PBTSL)- BIKANER(PG) (PSTCL) CKT-1 (POWERGRID) AT 400 KV BIKANER(PG)	POWER GRID	D	For AMP work	08/Oct/2023	08:00	08/Oct/2023	18:00	ı	PLANNED	Approved	08-Oct-23	15:00	08-Oct-23	23:00	May be given from 1500 Hrs

875	RQ146785	OCC_211	cpcc1_sd	BAY	428 MAIN BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AT 400 KV FATEHGARH_II(P G)	POWER GRID	D	For bay AMP Works	07/Oct/2023	17:00	08/Oct/2023	23:00	F	PLANNED	Approved	07-Oct-23	17:00	08-Oct-23	23:00	
876	RQ146784	OCC_211	cpcc1_sd	BAY	429 TIE BAY - 400/220 KV 500 MVA ICT 4 AT FATEHGARH_II(P G) (POWERGRID) AND FUTURE AT 400 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For bay AMP Works	05/Oct/2023	17:00	06/Oct/2023	23:00	F	PLANNED	Approved	05-Oct-23	15:00	06-Oct-23	23:00	May be given from 1500 Hrs
877	RQ146798	OCC_211	cpcc1_sd	BAY	419 MAIN BAY - 125 MVAR BUS REACTOR NO 1 AT 400 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For bay AMP Works	05/Oct/2023	17:00	06/Oct/2023	23:00	F	PLANNED	Approved	05-Oct-23	15:00	06-Oct-23	23:00	May be given from 1500 Hrs
878	RQ145698	OCC_211	stuup_sd	BAY	409 MAIN BAY - 400 KV AGRA(UP)- AGRA FATEHBAD(UP) (PG) CKT-2 AT AGRA(UP)	POWER GRID	D	* Annual routine maintenance of 400 kV Fatehabad ckt- 2bay at 400 kV S/s Agra	05/Oct/2023	09:00	05/Oct/2023	17:00	F	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	17:00	
879	RQ146593	OCC_211	cpcc3_sd	ВАУ	425 TIE BAY - SVC NO 2(- 140/+140MVAR) AT 400 KV KANPUR(PG) (POWERGRID) AND 400/220 KV 315 MVA ICT 1 AT KANPUR(PG) AT 400 KV KANPUR(PG) (POWERGRID)	POWER GRID	С	'For dismantling Main bay(424) CB and CT along with bypassing bus protection scheme to 425 bay	04/Oct/2023	10:00	05/Oct/2023	18:00	F	PLANNED	Approved	04-Oct-23	10:00	05-Oct-23	18:00	Element must remain in service via other bay.
880	RQ145701	OCC_211	stuup_sd	BAY	402 MAIN BAY - 400 KV AGRA- AGRA FATEHBAD (UP) CKT-1 AT AGRA	POWER GRID	D	* Annual routine maintenance of 400 kV Fatehabad ckt-1 bay at 400 kV S/s Agra	04/Oct/2023	09:00	04/Oct/2023	17:00	F	PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	17:00	
881	RQ146645	OCC_211	bbmb_sd	ВАҮ	X5 MAIN BAY - 400 KV BHIWANI(BB)- RAJPURA(PS) (BB) CKT-1 AT BHIWANI(BB)	POWER GRID	D	Yearly Mtc.	04/Oct/2023	08:00	04/Oct/2023	18:00	F	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	

882	RQ146783	OCC_211	cpcc1_sd	ВАУ	423 TIE BAY - 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(P G) (POWERGRID) AND FUTURE AT 400 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	For bay AMP Works	03/Oct/2023	17:00	04/Oct/2023	23:00	PLANNED	Approved	03-Oct-23	17:00	04-Oct-23	23:00	
883	RQ146592	OCC_211	cpcc3_sd	BAY	424 MAIN BAY - SVC NO 2(- 140/+140MVAR) AT 400 KV KANPUR(PG)	POWER GRID	С	For dismantlig Main bay CB and CT along with bypassing bus protection scheme to 425 bay	02/Oct/2023	10:00	06/Oct/2023	18:00	PLANNED	Approved	02-Oct-23	10:00	06-Oct-23	18:00	Element must remain in service via other bay.
884	RQ146782	OCC_211	cpcc1_sd	BAY	422 MAIN BAY - 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(P G) (POWERGRID) AT 400 KV FATEHGARH_II(P G)	POWER GRID	D		01/Oct/2023	16:00	02/Oct/2023	22:00	PLANNED	Approved	01-Oct-23	16:00	02-Oct-23	22:00	
885	RQ146411	OCC_211	cpcc1_sd	ВАУ	406 MAIN BAY - 400/220KV 315 MVA ICT 2 AT KOTPUTLI(PG)		D	For bay AMP Works	28/Oct/2023	09:00	28/Oct/2023	18:00	PLANNED	Approved	28-Oct-23	09:00	28-Oct-23	18:00	
886	RQ146477	OCC_211	cpcc1_sd	BAY	428 MAIN BAY - 225 MVAR BUS SERIES REACTOR NO 1 AT 400 KV MANDOLA(PG) (POWERGRID)		D	BUS BAR RETROFITTING WORK	28/Oct/2023	08:00	28/Oct/2023	18:00	PLANNED	Approved	28-Oct-23	08:00	28-Oct-23	18:00	
887	RQ146410	OCC_211	cpcc1_sd	ВАУ	405 TIE BAY - 400KV KOTPUTLI- BHIWADI (PG) CKT-1 AND 400/220KV 315 MVA ICT 2 AT KOTPUTLI(PG)		D	For bay AMP Works	27/Oct/2023	09:00	27/Oct/2023	18:00	PLANNED	Approved	27-Oct-23	09:00	27-Oct-23	18:00	
888	RQ146476	OCC_211	cpcc1_sd	ВАҮ	427 MAIN BAY - 400KV MEERUT(PG)- MANDOLA(PG) (PL) CKT-4 AT MANDOLA(PG)			BUS BAR RETROFITTING WORK	27/Oct/2023	08:00	27/Oct/2023	18:00	PLANNED	Approved	27-Oct-23	08:00	27-Oct-23	18:00	
889	RQ146443	OCC_211	cpcc1_sd	ВАҮ	411 TIE BAY - 400KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-2 AND 125 MVAR BUS REACTOR NO 1 AT 400KV ROORKEE(PG)		D	For bay AMP Works	26/Oct/2023	08:00	26/Oct/2023	18:00	PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	

890	RQ146475	OCC_211	cpcc1_sd	ВАУ	426 TIE BAY - 400KV MEERUT(PG)- MANDOLA(PG) (PL) CKT-4 AND FUTURE AT	D	BUS BAR RETROFITTING WORK	26/Oct/2023	08:00	26/Oct/2023	18:00	PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
891	RQ146403	OCC_211	cpcc1_sd	BAY	MANDOLA(PG) 417 TIE BAY - 400KV AGRA- JAIPUR SOUTH (PG) CKT-2 AND 400KV AGRA- BHIWADI (PG) CKT-2 AT AGRA(PG)	D	AMP work	25/Oct/2023	09:30	25/Oct/2023	17:30	PLANNED	Approved	25-Oct-23	09:30	25-Oct-23	17:30	
892	RQ146474	OCC_211	cpcc1_sd	ВАУ	424 MAIN BAY - 400KV MEERUT- MANDOLA (PG) CKT-1 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	24/Oct/2023	08:00	24/Oct/2023	18:00	PLANNED	Approved	24-Oct-23	08:00	24-Oct-23	18:00	
893	RQ146473	OCC_211	cpcc1_sd	BAY	423 TIE BAY - 400KV MEERUT(PG)- MANDOLA(PG) (PL) CKT-3 AND 400KV MEERUT- MANDOLA (PG) CKT-1 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	23/Oct/2023	08:00	23/Oct/2023	18:00	PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
894	RQ146437	OCC_211	cpcc1_sd	ВАҮ	407 MAIN BAY - 400KV BAHADURGARH- SONIPAT (PG) CKT- 2 AT SONIPAT(PG)	D	For bay AMP Works	21/Oct/2023	09:00	21/Oct/2023	18:00	PLANNED	Approved	21-Oct-23	09:00	21-Oct-23	18:00	
895	RQ146472	OCC_211	cpcc1_sd	ВАҮ	422 MAIN BAY - 400KV MEERUT(PG)- MANDOLA(PG) (PL) CKT-3 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	21/Oct/2023	08:00	21/Oct/2023	18:00	PLANNED	Approved	21-Oct-23	08:00	21-Oct-23	18:00	
896	RQ146442	OCC_211	cpcc1_sd	ВАУ	410 MAIN BAY - 400KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-2 AT ROORKEE(PG)	D	For bay AMP Works	20/Oct/2023	08:00	20/Oct/2023	18:00	PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
897	RQ146471	OCC_211	cpcc1_sd	ВАУ	421 MAIN BAY - 400KV DADRI(NT)- MANDOLA(PG) (PG) CKT-1 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	20/Oct/2023	08:00	20/Oct/2023	18:00	PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	Element must remain in service via other bay.
898	RQ146402	OCC_211	cpcc1_sd	BAY	415 MAIN BAY - 400KV AGRA- JAIPUR SOUTH (PG) CKT-1 AND SELECT AT AGRA(PG)	D	AMP work	19/Oct/2023	09:30	19/Oct/2023	17:30	PLANNED	Approved	19-Oct-23	09:30	19-Oct-23	17:30	

r r-	1			I	1			I			T	r	I						1
899 F	RQ146429	OCC_211	cpcc1_sd	BAY	208 MAIN BAY -		D	For bay AMP Works	19/Oct/2023	09:00	19/Oct/2023	17:30	PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	17:30	
					400/220 KV 315														
					MVA ICT 1 AT														
					BHINMAL(PG)														
					(POWERGRID)														
900 F	RQ146470	OCC_211	cpcc1_sd	BAY	420 TIE BAY -		D	BUS BAR	19/Oct/2023	08:00	19/Oct/2023	18:00	PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	18:00	Element must remain in
					400KV MEERUT-			RETROFITTING											service via other bay.
					MANDOLA (PG)			WORK											
					CKT-2 AND 400KV			-											
					DADRI(NT)-														
					MANDOLA(PG)														
					(PG) CKT-1 AT														
					MANDOLA(PG)														
									10/0 //0000		10/0 //000				40.000		40.000	10.00	
901 F	RQ146433	OCC_211	cpcc1_sd	BAY	405 TIE BAY -		D	For bay AMP Works	18/Oct/2023	09:00	18/Oct/2023	18:00	PLANNED	Approved	18-Oct-23	09:00	18-Oct-23	18:00	
					400KV														
					BAHADURGARH(P														
					G)-														
					KABULPUR(HV)														
					(PG) CKT-1 AND														
					400/220KV 500			1											
					MVA ICT 2 AT														
					BAHADURGARH(P														
					G)														
902	RQ146469	OCC_211	cpcc1 sd	BAY	419 MAIN BAY -		D	BUS BAR	18/Oct/2023	08:00	18/Oct/2023	18:00	PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
302	(41 10 103	000_211	cpcci_sa	5711	400KV MEERUT-		-	RETROFITTING	10,000,2025	00.00	10,000,2020	10.00		/ ipproved	10 000 25	00.00	10 000 20	10.00	
					MANDOLA (PG)			WORK											
					CKT-2 AT			WORK											
					MANDOLA(PG)														
002 5	00146450	000 211	1	DAY			D	AMP	17/0+/2022	17.00	17/0-+/2022	22.50	PLANNED	A	17-Oct-23	15:00	17-Oct-23	23:59	Mari ha airea faara 1500 Haa
903	10140430	OCC_211	cpcc1_su	DAT	440 TIE BAY -		D	AIVIP	17/Oct/2023	17.00	17/Oct/2023	23.39	PLAININED	Approved	17-001-23	15.00	17-001-25	25.59	May be given from 1500 Hrs
					400/220 KV 500														
					MVA ICT 1 AT														
					BHADLA_2 (PG)														
					(POWERGRID)														
					AND FUTURE AT														
					400 KV														
					BHADLA_2 (PG)														
					(POWERGRID)														
904 F	RQ146401	OCC_211	cpcc1_sd	BAY	414 TIE BAY -		D	AMP work	17/Oct/2023	09:30	17/Oct/2023	17:30	PLANNED	Approved	17-Oct-23	09:30	17-Oct-23	17:30	
					400KV AGRA-														
					JAIPUR SOUTH														
					(PG) CKT-1 AND														
					400KV AGRA-														
					BHIWADI (PG)			ĺ	l										
					CKT-1 AT			ĺ											
					AGRA(PG)			ĺ											
905	RO146468	OCC_211	cpcc1_sd	BAY	418 MAIN BAY -		D	BUS BAR	17/Oct/2023	08:00	17/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	Element must remain in
505	0 .00	- 50		I	400KV DADRI(NT)-		-	RETROFITTING			_,,000,2025		. S.MILD		- 500 25	55.55		10.00	service via other bay.
					MANDOLA(PG)			WORK											Service via other bay.
					(PG) CKT-1 AND			W OIR											
					50 MVAR BUS			İ	İ										1
								İ	İ										1
					REACTOR NO 1			ĺ											
					AT 400KV			ĺ											
					MANDOLA(PG)														
906	20146440	OCC_211	cncc1 sd	DAV	401 MAIN BAY -		С	BAY LBB	16/Oct/2023	10:00	17/Oct/2023	18:00	PLANNED	Approved	16-Oct-23	10:00	17-Oct-23	18:00	Element must remain in
900	140449	OCC_211	cpcc1_su	DAI	400 KV BASSI(PG)-		C	RETROFITMENT	10/000/2023	10.00	1//001/2023	10.00	PLANNED	Approved	10-001-23	10.00	17-001-23	10.00	
				i	-100 KV BASSI(PG)-	i I			l		1				1			l	service via other bay.
					HEED V DI ID V (DC)			MORK											
					HEERAPURA(RS)			WORK											
					(PG) CKT-1 AT			WORK											
								WORK											

									,										
			cpcc1_sd		410 MAIN BAY - 400KV BAHADURGARH- SONIPAT (PG) CKT- 2 AT BAHADURGARH(P G)	D	For bay AMP Works	16/Oct/2023		16/Oct/2023			ANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	
908 F	RQ146467	OCC_211	cpcc1_sd	BAY	417 TIE BAY - 400KV DADRI(NT)- MANDOLA(PG) (PG) CKT-2 AND 50 MVAR BUS REACTOR NO 1 AT 400KV MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	16/Oct/2023	08:00	16/Oct/2023	18:00	PL	ANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	Element must remain in service via other bay.
909 F	RQ146418	OCC_211	cpcc1_sd	ВАҮ	436 MAIN BAY - 400KV KANPUR- BALLABHGARH (PG) CKT-2 AT BALLABHGARH(P G)	D	For bay AMP Works	15/Oct/2023	09:00	15/Oct/2023	18:00	PLA	ANNED	Approved	15-Oct-23	09:00	15-Oct-23	18:00	
910 F	RQ146409	OCC_211	cpcc1_sd	вау	404 MAIN BAY - 400KV KOTPUTLI- BHIWADI (PG) CKT-1 AT KOTPUTLI(PG)	D	For bay AMP Works	14/Oct/2023	09:00	14/Oct/2023	18:00	PLA	ANNED	Approved	14-Oct-23	09:00	14-Oct-23	18:00	
911 F	RQ146466	OCC_211	cpcc1_sd	ВАҮ	416 MAIN BAY - 400KV DADRI(NT)- MANDOLA(PG) (PG) CKT-2 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	14/Oct/2023	08:00	14/Oct/2023	18:00	PLA	ANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	Element must remain in service via other bay.
912 F	RQ146405	OCC_211	cpcc1_sd	ВАҮ	426 TIE BAY - 400/220 KV 500 MVA ICT 7 AT BHADLA(PG) (POWERGRID) AND FUTURE AT 400 KV BHADLA(PG) (POWERGRID)	D	FOR BAY AMP WORK	13/Oct/2023	17:00	13/Oct/2023	23:59	PLF	ANNED	Approved	13-Oct-23	15:00	13-Oct-23	23:59	May be given from 1500 Hrs
913 F	RQ146448	OCC_211	cpcc1_sd	ВАҮ	403 MAIN BAY - 400KV HEERAPURA- HINDAUN (RS) CKT-1 AT HEERAPURA(RS)	С	BAY LBB RETROFITMENT WORK	13/Oct/2023	10:00	14/Oct/2023	18:00	PLA	ANNED	Approved	13-Oct-23	10:00	14-Oct-23	18:00	Element must remain in service via other bay.
914 F	RQ146400	OCC_211	cpcc1_sd	ВАУ	413 MAIN BAY - 125 MVAR BUS REACTOR NO 2 AT 400KV JAIPUR SOUTH(PG)	D	AMP work	13/Oct/2023	09:30	13/Oct/2023	17:30	PLA	ANNED	Approved	13-Oct-23	09:30	13-Oct-23	17:30	
915 F	RQ146436	OCC_211	cpcc1_sd	ВАУ	404 MAIN BAY - 400KV BAHADURGARH(P G)- KABULPUR(HV) (PG) CKT-1 AT BAHADURGARH(P G)	D	For bay AMP Works	13/Oct/2023	09:00	13/Oct/2023	18:00	PLA	ANNED	Approved	13-Oct-23	09:00	13-Oct-23	18:00	

				1								-	1	1				1
916	RQ146446	OCC_211	cpcc1_sd	BAY	409 MAIN BAY - 80 MVAR BUS REACTOR NO 1 AT 400KV SIKAR(PG)	D	АМР	13/Oct/2023	09:00	13/Oct/2023	18:00	PLANNE	Approved	13-Oct-23	09:00	13-Oct-23	18:00	
			cpcc1_sd		407 MAIN BAY - 400KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-1 AT ROORKEE(PG)	D	For bay AMP Works			13/Oct/2023			O Approved		08:00	13-Oct-23	18:00	
918	RQ146465	OCC_211	cpcc1_sd	BAY	415 MAIN BAY - 400/220KV 500 MVA ICT 1 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	13/Oct/2023	08:00	13/Oct/2023	18:00	PLANNE	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
919	RQ146419	OCC_211	cpcc1_sd	BAY	419 MAIN BAY - 400KV MAINPURI- BALLABHGARH (PG) CKT-2 AT BALLABHGARH(P G)	D	For bay AMP Works	12/Oct/2023	09:00	12/Oct/2023	18:00	PLANNE	O Approved	12-Oct-23	09:00	12-Oct-23	18:00	
920	RQ146416	OCC_211	cpcc1_sd	BAY	405 TIE BAY - 125 MVAR BUS REACTOR NO 2 AT 400KV AJMER(PG) AND 400 KV AJMER(RS)- AJMER(PG) (PG) CKT-2	D	For bay AMP Works	12/Oct/2023	09:00	12/Oct/2023	18:00	PLANNE	O Approved	12-Oct-23	09:00	12-Oct-23	18:00	
921	RQ146435	OCC_211	cpcc1_sd	BAY	403 MAIN BAY - 400/220KV 315 MVA ICT 1 AT BAHADURGARH(P G)	D	For bay AMP Works	12/Oct/2023	09:00	12/Oct/2023	18:00	PLANNE	O Approved	12-Oct-23	09:00	12-Oct-23	18:00	
922	RQ146464	OCC_211	cpcc1_sd	ВАҮ	414 TIE BAY - 400/220KV 500 MVA ICT 1 AT MANDOLA(PG) AND 400/220KV 500 MVA ICT 3 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	12/Oct/2023	08:00	12/Oct/2023	18:00	PLANNE	O Approved	12-Oct-23	08:00	12-Oct-23	18:00	
923	RQ146425	OCC_211	cpcc1_sd	ВАУ	412 MAIN BAY - 400/220KV 315 MVA ICT 1 AT SONIPAT(PG)	D	For bay AMP Works	11/Oct/2023	10:00	11/Oct/2023	18:00	PLANNE	Approved	11-Oct-23	10:00	11-Oct-23	18:00	
			cpcc1_sd		4402 TIE BAY - 400KV BASSI(PG)- HEERAPURA(RS) (PG) CKT-1 AND 400KV HEERAPURA- HINDAUN (RS) CKT-1 AT HEERAPURA(RS)	С	BAY LBB RETROFITMENT WORK	11/Oct/2023	10:00	12/Oct/2023	18:00	PLANNE		11-Oct-23	10:00	12-Oct-23	18:00	Element must remain in service via other bay.
925	RQ146463	OCC_211	cpcc1_sd	ВАУ	413 MAIN BAY - 400/220KV 500 MVA ICT 3 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNE	Approved	11-Oct-23	08:00	11-Oct-23	18:00	

926	RQ146424	OCC_211	cpcc1_sd	BAY	406 MAIN BAY -	D	For bay AMP Works	10/Oct/2023	10:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	10:00	10-Oct-23	18:00	
					400/220KV 315 MVA ICT 2 AT SONIPAT(PG)													
927	RQ146434	OCC_211	cpcc1_sd	ВАУ	402 TIE BAY - 400 KV BAWANA CCGTB(DTL)- BAHADURGARH(P G) (PG) CKT-1 AND 400/220 KV 315 MVA ICT 1 AT BAHADURGARH(P G)	D	For bay AMP Works	10/Oct/2023	09:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	18:00	
928	RQ146440	OCC_211	cpcc1_sd	BAY	403 MAIN BAY - 400/220KV 315 MVA ICT 1 AT	D	For bay AMP Works	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
929	RQ146462	OCC_211	cpcc1_sd	BAY	ROORKEE(PG)  412 MAIN BAY - 400/220KV 500  MVA ICT 2 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
930	RQ146461	OCC_211	cpcc1_sd	ВАУ	411 TIE BAY - 400/220KV 500 MVA ICT 2 AT MANDOLA(PG) AND 400/220KV 500 MVA ICT 4 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
931	RQ146460	OCC_211	cpcc1_sd	ВАҮ	410 MAIN BAY - 400/220KV 500 MVA ICT 4 AT MANDOLA(PG)	D	BUS BAR RETROFITTING WORK	08/Oct/2023	08:00	08/Oct/2023	18:00	PLANNED	Approved	08-Oct-23	08:00	08-Oct-23	18:00	
932	RQ146431	OCC_211	cpcc1_sd	ВАУ	411 TIE BAY - 400KV BAHADURGARH- SONIPAT (PG) CKT- 2 AND FUTURE AT BAHADURGARH(P G)	D	For bay AMP Works	07/Oct/2023	09:00	07/Oct/2023	18:00	PLANNED	Approved	07-Oct-23	09:00	07-Oct-23	18:00	
933	RQ146428	OCC_211	cpcc1_sd	BAY	411 TIE BAY - 400 KV BHINMAL(PG)- BARMER(RS) (RS) CKT-2 (POWERGRID) AND FUTURE AT 400 KV BHINMAL(PG) (POWERGRID)	D	For bay AMP Works	07/Oct/2023	09:00	07/Oct/2023	17:30	PLANNED	Approved	07-Oct-23	09:00	07-Oct-23	17:30	
934	RQ146408	OCC_211	cpcc1_sd	ВАУ	403 MAIN BAY - 400/220KV 315 MVA ICT 1 AT KOTPUTLI(PG)	D	For bay AMP Works	06/Oct/2023	09:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	18:00	
935	RQ146430	OCC_211	cpcc1_sd	BAY	406 MAIN BAY - 400/220KV 500 MVA ICT 2 AT BAHADURGARH(P G)	D	For bay AMP Works	06/Oct/2023	09:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	09:00	06-Oct-23	18:00	

Section   Sect
SAMAMARADUR   POLICET AT   POLICET AT
Fig. CCT.21   GRCL   GRCL   GRCL   GRCL   GRCL   GRCC
SOURCE   COLUMN   C
337   IQLI46459   OCC_211   CIPCL_30   SAV   SAVE
BETROFTING   WORK   W
BETROFTING   WORK   W
MANDOLAIPG    NOT COLUMN   NAME   N
BANNANION   COLUMN
BOJ CCT-2 AND   FULL AT   MANDOLAPIC)   FOR bey AMP Works   DF For bey AMP Works   DF FOR
FUTURE AT   MANOCURPS   MAY
MANDOLIFIC   Market
938   RQ146413   CCC_211   CCC_1.5d   SAV   SAVE
400KV   KAMRGUIPG-   ADDITION   REPROPERTIES   PEG CET-1 AND   ADDITION   A
MANISOLIPG    NOPPURES    IPG  CRT-1 AND     125 MAR B US     REACTOR NO 2     AT 4000PURES    IPG  CRT-1 AND     125 MAR B US     REACTOR NO 2     AT 4000PURES    REACTOR NO 2     AT 4000PURES    RAMADOLAIFO    BAW     AMADOLAIFO    BAW     AMADOLAIFO    BAW     AMADOLAIFO    BAW     AMADOLAIFO    CRT-1 AND     AMADOLAIFO    CRT-1 AN
DOI-PURISO   [PG CRT-1 AND   125 MVAR BUS   REACTOR NO 2   AT 400KV   SANKOU[PG   SANKABUS   REACTOR NO 2   AT 400KV   SANKOU[PG   SANKABUS   RESTOR TITING   WORK   WORK   SANKOU[PG   SANKABUS   SANKOU[PG   SA
(PG) CRT-1 AND   125 MARR BUS   REACTOR NO 2   AT 4000'   ANABOLI   PG   ANABOL
125 MVAR BUS   REACTOR NO 2   AT 400KV   ANAMOLINE   APPROVED
REACTOR NO 2   A 7.00KV   A 7.0
AT 400KV   ANNOCULFG    ANNOC
MANDICALIFICATION   RETAINTING   MAY   M
338   R0146486   OCC_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   MANDOL(R/G)   R010646(0)   Cocc_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   BASSH   Cocc_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   BASSH   Cocc_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   BASSH   Cocc_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   BASSH   Cocc_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   BASSH   Cocc_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   BASSH   Cocc_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   BASSH   Cocc_211   Cpc1_3d   BAY   A07 MAIN BAY- A060K   BASSH   Cocc_211   Cpc1_3d   BAY   Cocc_211   Cpc1_3d   BAY   Cocc_21
MANDOLAPG    BAWANAIQN    (DV) CKT-2 AT     MANDOLAPG    BAWANAIQN    (DV) CKT-2 AT     MANDOLAPG    BAWANAIQN    (DV) CKT-2 AT     MANDOLAPG    BAWANAIQN    (DV) CKT-2 AT     MANDOLAPG    BAY   A02 TIE BAY-400K BASSI-   KOTPIUTI (PG)   CKT-3 AND     MO/220W 315     MWA LCT 1 AT     KOTPIUTI (PG)   CKT-3 AND     MO/220W 315     MWA LCT 1 AT     KOTPIUTI (PG)   CKT-3 AND     MO/220W 315     MWA LCT 1 AT     KOTPIUTI (PG)   CKT-3 AND     MO/220W 315     MWA LCT 1 AT     KOTPIUTI (PG)   DIPHOLAPIN (PG)     For bay AMP Works   04/Oct/2023 09:00   04/Oct/2023 18:00   PLANNED     Approved   04-Oct-23   15:00   04-Oct-23   23:00     May be given from 1500 Hr     MANGOLIPG    MANGOLIPG    CKT-1 AT     MANGOLIPG    MA
MANDOLA/RC  BAWANA(DV)   (UV) (CT-2 AT MANDOLA/RC)   (UV) (CT-2 AT MANDOLA/RC)   (UV) (CT-2 AT MANDOLA/RC)   (UV) (CT-2 AT MANDOLA/RC)   (UV) (UV) (CT-2 AT MANDOLA/RC)   (UV) (UV) (CT-2 AT MANDOLA/RC)   (UV) (UV) (UV) (UV) (UV) (UV) (UV) (UV)
SAMANAIQUA   COV
DOV CKT-2 AT   MANDOLA/PG    MANDOLA/PG
MANDOLA[PG]
940   RQ146407   OCC_211   cpcc1_sd   BAY   A07 TIE BAY- 400K MASS- KOTPUTLI (PG)   CKT-1 AND 400/CV MASS KOTPUTLI (PG)   CKT-1 AND 400/CV MASS MASS KOTPUTLI (PG)   CKT-1 AND 400/CV MASS MASS MASS MASS MASS MASS MASS MAS
400KV BASSI- KOTPUTLI(PG) CKT-1 AND 400/220KV 315 MVA ICT 1 AT KOTPUTLI(PG)  941 RQ146412 OCC_211 cpcc1_sd BAY 401 MAIN BAY- 400KV KANKROLI(PG)- LIODHPUR(RS) (PG) CKT-1 AT KANKROLI(PG) CKT-1 AT KANKROLI(PG) CKT-1 AT ROORKEE(PG)  942 RQ146438 OCC_211 cpcc1_sd BAY 405 MAIN BAY- 400KV ROOKKEE DEHRADUN (PG) CKT-1 AT ROORKEE(PG)  943 RQ146457 OCC_211 cpcc1_sd BAY 405 MAIN BAY- 400KV ROOKKEE DEHRADUN (PG) CKT-1 AT ROORKEE(PG)  944 RQ146457 OCC_211 cpcc1_sd BAY 405 MAIN BAY- 400KV ROOKKEE DEHRADUN (PG) CKT-1 AT ROORKEE(PG)  945 RQ146457 OCC_211 cpcc1_sd BAY 405 MAIN BAY- 400 KV ROOKKEE DEHRADUN (PG) CKT-1 AT ROORKEE(PG)  946 MAIN BAY- MANDOLA(PG) MAINBANDBAGHI PG) (DTI) CKT-1  PG BUS BAR RETROFITTING WORK WORK PLANNED Approved 04-Oct-23 08:00 04-Oct-23 18:00  PLANNED Approved 04-Oct-23 08:00 04-Oct-23 18:00  PLANNED Approved 04-Oct-23 08:00 04-Oct-23 18:00  PLANNED Approved 04-Oct-23 08:00 04-Oct-23 18:00  PLANNED Approved 04-Oct-23 08:00 04-Oct-23 18:00  PLANNED Approved 04-Oct-23 08:00 04-Oct-23 18:00
KOTPUTLI (PG)   CKT-1 AND   A00/220KV 315   MVA ICT 1 AT   KOTPUTLIPG)
CKT-1 AND   A00/220KV 315   MVA ICT 1 AT   KOTPUTI(PG)
400/220X 315   MVA ICT 1 AT   KOTPUTLI(PG)   P41 RQ146412   OCC_211   Cpcc1_sd   BAY   401 MAIN BAY - 400KV   KANKROLI(PG)- 1/10 DHPURRS)   P67 bay AMP Works   O4/Oct/2023   08:00   O4/Oct/2023   18:00   O4/Oct/2023
MVA ICT 1 AT KOTPUTLI(PG)
SOTPUTILIF(G)   NOTPUTILIF(G)
941 RQ146412 OCC_211 cpcc1_sd BAY
400KV   KANKROLI(PG)- JODHPUR(RS)   (PG) CKT-1 AT KANKROLI(PG)     D For bay AMP Works   04/Oct/2023 08:00   04/Oct/2023 18:00   PLANNED   Approved   04-Oct-23   08:00   04-Oct-23   18:00
SANKROLI(PG)-  JODHPUR(RS)   (PG) CKT-1 AT   KANKROLI(PG)
SOUTH   SOUT
Part   Part
SANKROLI(PG)
942 RQ146438 OCC_211 cpcc1_sd BAY 413 MAIN BAY- 400KV ROORKEE- DEHRADUN (PG) CKT-1 AT ROORKEE(PG)  943 RQ146457 OCC_211 cpcc1_sd BAY  406 MAIN BAY- 406 WAIN BAY- 400 KV MANDOLA(PG)- MAHARANIBAGH( PG) (DTL) CKT-1  Approved  94. Q16 MAIN BAY- 406 WORK  D For bay AMP Works  04/Oct/2023 08:00  04/Oct/2023 18:00  04/Oct/2023 18:00  PLANNED Approved  04-Oct-23  08:00  04-Oct-23  08:00  04-Oct-23  18:00  PLANNED Approved  04-Oct-23  08:00  04-Oct-23  18:00  O4-Oct-23  18:00  O4-Oct-23  O5:00  O4-Oct-
400KV ROORKEE- DEHRADUN (PG) CKT-1 AT ROORKEE(PG)  943 RQ146457 OCC_211 cpcc1_sd BAY 406 MAIN BAY- 400 KV MANDOLA(PG)- MAHARANIBAGH( PG) (DTL) CKT-1  400 KV MANDOLA(PG)- MAHARANIBAGH( PG) (DTL) CKT-1
DEHRADUN (PG) CKT-1 AT ROORKEE(PG)  943 RQ146457 OCC_211 cpcc1_sd BAY 406 MAIN BAY - 400 KV MANDOLA(PG)- MAHARANIBAGH( PG) (DTL) CKT-1  407 CKT-1  Approved 404-Oct-23 408:00 408:00 408:
Second   CKT-1 AT   ROORKEE(PG)   Seco
Second   ROORKEE(PG)
943 RQ146457 OCC_211 cpcc1_sd BAY
400 KV RETROFITTING MANDOLA(PG)- MAHARANIBAGH( PG) (DTL) CKT-1
400 KV RETROFITTING WORK MANDOLA(PG)- WORK PG (DTL) CKT-1
MANDOLA(PG)- MAHARANIBAGH( PG) (DTL) CKT-1
MAHARANIBAGH( PG) (DTL) CKT-1
PG) (DTL) CKT-1
(POWERGRID)
AND FUTURE AT
400 KV
MANDOLA(PG)
(POWERGRID)
944 RQ146456 OCC_211 cpcc1_sd BAY 404 MAIN BAY - D BUS BAR 03/Oct/2023 08:00 03/Oct/2023 18:00 PLANNED Approved 03-Oct-23 08:00 03-Oct-23 18:00
400KV RETROFITTING
MANDOLA(PG)- WORK
MANDOLA(PG)- BAWANA(DV) WORK
MANDOLA(PG)- WORK

945	RQ146628	OCC_211	bbmb_sd	BAY	407 TIE BAY - 400KV PANCHKULA(PG)- PANIPAT(BB) (BB) CKT-1 AND 400KV DADRI(NT)- PANIPAT(BB) (PG) CKT-2 AT PANIPAT(BB)		D	Yearly mtc.	27/Oct/2023	08:00	27/Oct/2023	18:00	PLANNED	Approved	27-Oct-23	08:00	27-Oct-23	18:00	Element must remain in service via other bay.
946	RQ146644	OCC_211	bbmb_sd	BAY	X2 TIE BAY - 400 KV BHIWANI(BB)- RAJPURA(PS) (BB) CKT-1 AND FUTURE AT 400 KV BHIWANI(BB)	ВВМВ	D	Yearly mtc.	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
947	RQ146626	OCC_211	bbmb_sd	BAY	X2 MAIN BAY - 400/220 KV 500 MVA ICT 2 AT PANIPAT(BB) (BBMB)	ВВМВ	D	Half yearly mtc	05/Oct/2023	08:00	05/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
948	RQ146630	OCC_211	bbmb_sd	BAY	401 MAIN BAY - 400KV PANCHKULA(PG)- PANIPAT(BB) (BB) CKT-1 AT PANIPAT(BB)	ввмв	D	Half yearly mtc	03/Oct/2023	08:00	03/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
949	RQ145870	OCC_211	sidcps_sd	BAY	402 TIE BAY - 400KV TALWANDI SABOO(PSG)- MUKTSAR(PS) (PS) CKT-1 AND 400KV MUKTSAR- MAKHU (PS) CKT- 1 AT MUKTSAR(PS)	PSTCL		General maintenance for nut-bolt tightening,cleaning and IR of equipments.	27/Oct/2023	08:00	27/Oct/2023	18:00	PLANNED	Approved	27-Oct-23	08:00	27-Oct-23	18:00	
950	RQ145850	OCC_211	sidcps_sd	ВАУ	405 TIE BAY - 400 KV NAKODAR(PSG)- MAKHU(PS) (PS) CKT-1 (PSTCL) AND 400 KV AMRITSAR(PG)- MAKHU(PS) (PSTCL) CKT-1 AT 400 KV MAKHU(PS) (PSTCL) (PSTCL)	PSTCL		Nut bolt tightening of clamp and connectors of bay 405 and cleaning of CR panel and BMK of CT,CB related with associated bay	25/Oct/2023	08:00	25/Oct/2023	18:00	PLANNED	Approved	25-Oct-23	08:00	25-Oct-23	18:00	

			sldcps_sd		402 TIE BAY - 400 KV NAKODAR(PSG)- MAKHU(PS) (PS) CKT-2 (PSTCL) AND 400 KV AMRITSAR(PG)- MAKHU(PS) (PSTCL) CKT-2 AT 400 KV MAKHU(PS) (PSTCL)			Nut bolt tightening of clamp and connectors of bay 402 and cleaning of CR panel and BMK of CT, CB related with associated bay	23/Oct/2023		23/Oct/2023			PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
			sldcps_sd		403 MAIN BAY - 400KV MUKTSAR- MAKHU (PS) CKT- 1 AT MUKTSAR(PS)	PSTCL	D	General maintenance for nut-bolt tightening, cleaning and IR of equipments.	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
953	RQ145872	OCC_211	sldcps_sd	BAY	401 MAIN BAY - 400KV TALWANDI SABOO(PSG)- MUKTSAR(PS) (PS) CKT-1 AT MUKTSAR(PS)	PSTCL	D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
954	RQ145940	OCC_211	sidchp_sd	BAY	409 MAIN BAY - 400 KV GUMMA (HP)- PANCHKULA(PG) (PG) CKT-1 (HPPTCL) AT 400 KV GUMMA (HP)	HPPTCL	D	Periodical Testing	21/Oct/2023	09:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	09:00	21-Oct-23	18:00	
955	RQ145942	OCC_211	sldchp_sd	BAY	407 MAIN BAY - 400 KV NATHPA JHAKRI(SJ)- GUMMA (HP) (PG) CKT-1 (HPPTCL) AT 400 KV GUMMA (HP)	HPPTCL	D	Periodical Testing	21/Oct/2023	09:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	09:00	21-Oct-23	18:00	Subject to SJVNL/PG consent.
956	RQ145941	OCC_211	sldchp_sd	ВАУ	408 TIE BAY - 400 KV NATHPA JHAKRI(SJ)- (PG) CKT-1 (HPPTCL) AND 400 KV GUMMA (HP)- PANCHKULA(PG) (PG) CKT-1 AT 400 KV GUMMA (HP) (HPPTCL)	HPPTCL	D	Periodical Testing	21/Oct/2023	09:00	21/Oct/2023	18:00		PLANNED	Approved	21-Oct-23	09:00	21-Oct-23	18:00	Subject to SJVNL/PG consent.
			sldchp_sd		401 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT GUMMA (HP) (HPPTCL)	HPPTCL	D	Periodical Testing	20/Oct/2023		20/Oct/2023		spare Transformer	PLANNED		20-Oct-23	09:00	20-Oct-23	18:00	
958	RQ145948	OCC_211	sldchp_sd	BAY	401 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT GUMMA (HP) (HPPTCL)	HPPTCL	D	Periodical Testing	19/Oct/2023	09:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	18:00	

959	RQ14594	9 OCC_211	sldchp_sd	BAY	402 TIE BAY - 400/220 KV 315	HPPTCL	D	Periodical Testing	19/Oct/2023	09:00	19/Oct/2023	18:00	PL	ANNED	Approved	19-Oct-23	09:00	19-Oct-23	18:00	
					MVA ICT 1 AT GUMMA (HP) (HPPTCL) AND															
					400/220 KV 315															
					MVA ICT 2 AT GUMMA (HP) AT															
					400 KV GUMMA (HP) (HPPTCL)															
					(HP) (HPPTCL)															
960	RQ14594	6 OCC_211	sldchp_sd	BAY	403 MAIN BAY - 400/220 KV 315	HPPTCL	D	Periodical Testing	18/Oct/2023	09:00	18/Oct/2023	18:00	PL	ANNED	Approved	18-Oct-23	09:00	18-Oct-23	18:00	
					MVA ICT 2 AT															
					GUMMA (HP) (HPPTCL)															
961	RQ14594	7 OCC_211	sldchp_sd	BAY	402 TIE BAY -	HPPTCL	D	Periodical Testing	18/Oct/2023	09:00	18/Oct/2023	18:00	PL	ANNED	Approved	18-Oct-23	09:00	18-Oct-23	18:00	
					400/220 KV 315 MVA ICT 1 AT															
					GUMMA (HP)															
					(HPPTCL) AND 400/220 KV 315															
					MVA ICT 2 AT															
					GUMMA (HP) AT 400 KV GUMMA															
					(HP) (HPPTCL)															
962	RQ14594	4 OCC_211	sldchp_sd	BAY	405 TIE BAY - 400	HPPTCL	D	Periodical Testing	17/Oct/2023	09:00	17/Oct/2023	18:00	PL	ANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	Subject to SJVNL/PG consent.
					KV GUMMA (HP)- PANCHKULA(PG)															
					(PG) CKT-2															
					(HPPTCL) AND 400 KV NATHPA															
					JHAKRI(SJ)-															
					GUMMA (HP) (PG) CKT-2 AT															
					400 KV GUMMA															
					(HP) (HPPTCL)															
963	RQ14594	3 OCC_211	sldchp_sd	BAY	406 MAIN BAY - 400 KV NATHPA	HPPTCL	D	Periodical Testing	17/Oct/2023	09:00	17/Oct/2023	18:00	PL	ANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	Subject to SJVNL/PG consent.
					JHAKRI(SJ)-															
					GUMMA (HP) (PG) CKT-2															
					(HPPTCL)															
964	RQ14594	5 OCC_211	sldchp_sd	BAY	404 MAIN BAY - 400 KV GUMMA	HPPTCL	D	Periodical Testing	17/Oct/2023	09:00	17/Oct/2023	18:00	PL	ANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	
					(HP)-															
					PANCHKULA(PG) (PG) CKT-2															
					(HPPTCL)															
965	RQ14665	0CC_211	sldcrs_sd	BAY	411 TIE BAY - 400KV PHAGI-	RRVPNL	D	QUARTERLY MAINTENANCE	19/Oct/2023	08:00	19/Oct/2023	18:00	PL	ANNED	Approved	19-Oct-23	15:00	19-Oct-23	23:00	May be given from 1500 Hrs
					AJMER (RS) CKT-2			WORK OF BAY &												
					AND FUTURE AT AJMER(RS)			EQUIPMENTS												
966	RQ14665	2 OCC_211	sldcrs_sd	BAY		RRVPNL	D	QUARTERLY	18/Oct/2023	08:00	18/Oct/2023	18:00	PL	ANNED	Approved	18-Oct-23	15:00	18-Oct-23	23:00	May be given from 1500 Hrs
					400KV PHAGI-			MAINTENANCE WORK OF BAY &												
					AJMER (RS) CKT-2 AND SELECT AT			EQUIPMENTS												
					AJMER(RS)															

967	RQ146620	OCC_211	sldcrs_sd	BAY	412T TIE BAY -	RRVPNL	D	Quarterly	16/Oct/2023	08:00	16/Oct/2023	18:00	PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	08:00	18:00	
					765/400 KV 1500			maintenance work												
					MVA ICT 3 AT															
					PHAGI(RS)															
					(RRVPNL) AND															
					FUTURE AT 400															
					KV PHAGI(RS)															
					(RRVPNL)															
968	RQ146621	OCC_211	sldcrs_sd	BAY	412C MAIN BAY -	RRVPNL	D	Quarterly	13/Oct/2023	08:00	13/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	08:00	18:00	
					765/400 KV 1500			maintenance work												
					MVA ICT 3 AT															
					PHAGI(RS)															
					(RRVPNL) AT 400															
					KV PHAGI(RS)															
969	RQ146653	OCC_211	sldcrs_sd	BAY	408 TIE BAY -	RRVPNL	D	QUARTERLY	12/Oct/2023	08:00	12/Oct/2023	18:00	PLANNED	Approved	12-Oct-23	15:00	12-Oct-23	15:00	23:00	May be given from 1500 Hrs
					400/220KV 315			MAINTENANCE												
					MVA ICT 1 AT			WORK OF BAY &												
					AJMER(RS) AND			EQUIPMENTS												
					400KV PHAGI-															
					AJMER (RS) CKT-1															
					romen (no) en 1															
970	RQ146650	OCC_211	sldcrs sd	BAY	407 MAIN BAY -	RRVPNL	D	QUARTERLY	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	15:00	11-Oct-23	15:00	23:00	May be given from 1500 Hrs
					400 KV PHAGI-		_	MAINTENANCE	,,		,,									, 8
					AJMER (RS) CKT-1			WORK OF BAY &												
								EQUIPMENTS												
074	20446622	000 244	alalana ad	DAY	(RRVPNL)	DD) (DNII	-		40/0 - /2022	00.00	40/0 - /2022	40.00	DI ANINED		40.0.1.22	45.00	40.0.1.22	15.00	22.00	Mar. 1
9/1	RQ146622	OCC_211	sldcrs_sd	BAY	40852D MAIN	RRVPNL	D	QUARTERLY	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	15:00	10-Oct-23	15:00	23:00	May be given from 1500 Hrs
					BAY - 400KV			MAINTENANCE												
					PHAGI-AJMER			WORK OF MAIN BAY												
					(RS) CKT-2 AT			EQUIPMENTS OF												
					PHAGI(RS)			400KV PHAGI-AJMER												
								LINE-2												
972	RQ146623	OCC_211	sldcrs_sd	BAY	40852C MAIN	RRVPNL	D	HALF YEARLY	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	15:00	09-Oct-23	15:00	23:00	May be given from 1500 Hrs
					BAY - 400KV			MAINTENANCE												
					PHAGI-			WORK OF ASSOCITED												
					HEERAPURA (RS)			BAY EQUIPMENTS												
								DAT EQUIPIVIENTS												
					CKT-1 AT															
					PHAGI(RS)															
973	KQ146624	OCC_211	sidcrs_sd	RAY	40752T TIE BAY -	KKVPNL	D	QUARTERLY	06/Oct/2023	U8:UU	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	00:8U	18:00	
					765/400KV 1500			MAINTENANCE						l						
1 1					MVA ICT 1 AT			WORK OF ASSOCITED	1			1		]						
1 1					PHAGI(RS) AND			BAY EQUIPMENTS	1			1		]						
1 1					400KV PHAGI-			1	1			1		]						
					HEERAPURA (RS)									l						
					CKT-2															
974	RQ146660	OCC_211	slders sd	BAY	405 TIE BAY -	RRVPNL	D	Routine maintenance	06/Oct/2023	08:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	15:00	06-Oct-23	15:00	23:00	May be given from 1500 Hrs
"		- 301	ac. s_sa	I	400KV			of 400 KV Tie	3,000,2023		50,000,2023	-5.00	I S JANEED	, ipproved	20 000 25	25.05	20 000 25		20.00	, 22 8
				1					l					l						
					BHILWARA(RS)-	.]		1	]			1		]			1			
				1	CHITTORGARH(RS	1		1	l					l						
1 1					) (UNDEF) CKT-1			1	]			1		]			1			
1 1					AND 400/220KV			1	]			1		]			1			
					315 MVA ICT 2 AT	1								l						
					BHILWARA(RS)															
					<u> </u>						<u> </u>									
975	RQ146625	OCC_211	sldcrs_sd	BAY	40752C MAIN	RRVPNL	D	QUARTERLY	05/Oct/2023	08:00	05/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	08:00	18:00	
1					BAY - 765/400KV			MAINTENANCE	]			1		]						
1 1					1500 MVA ICT 1			WORK OF ASSOCITED	]			1		]						
					AT PHAGI(RS)			BAY EQUIPMENTS	1					1						
					1		i e													i

976	RQ146659	OCC_211	sldcrs_sd	BAY	4152T TIE BAY - 400/220 KV 315 MVA ICT 1 AT BHILWARA(RS) AND 400 KV BHILWARA- CHITTORGARH (RS) CKT-2 AT 400 KV BHILWARA(RS)		D	Routine maintenance of 400 KV Tie	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	15:00	05-Oct-23	23:00	May be given from 1500 Hrs
977	RQ146658	OCC_211	sldcrs_sd	BAY	4452T TIE BAY - 50 MVAR BUS REACTOR NO 1 AT 400KV BHILWARA(RS) (RRVPNL) AND 400 KV AJMER- BHILWARA (RS) (KT-2 AT 400 KV BHILWARA(RS) (RRVPNL)	RRVPNL	D	Routine maintenance of 400 KV Tie bay	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	15:00	04-Oct-23	23:00	May be given from 1500 Hrs
978	RQ145620	OCC_211	singrauli_s d	ВАУ	407 MAIN BAY - 400 KV SINGRAULI(NT)- ANPARA(UP) (PG) CKT-1 AT SINGRAULI(NT)		С	BUS-2 ISOLATOR REPLACEMENT	17/Oct/2023	08:00	20/Oct/2023	18:00	ANPARA LINE WILL BE CHARGED THROUGH TRANSFER BREAKER	PLANNED	Approved	17-Oct-23	08:00	20-Oct-23	18:00	Element must remain in service via other bay.
979	RQ145804	OCC_211	sldcup_sd	BAY	412 MAIN BAY - 400/220 KV 100 MVA ST 1 AT HARDUAGANJ (UP)	UPRVU NL	С	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	Element must remain in service via other bay.
980	RQ145803	OCC_211	sldcup_sd	ВАУ	411 TIE BAY - 400/220 KV 315 MVA ICT 1 AT HARDUAGANJ (UP) AND 400/220 KV 100 MVA ST 1 AT HARDUAGANJ (UP) AT 400 KV HARDUAGANJ (UP) (UP)	UPRVU NL	С	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	13/Oct/2023	08:00	14/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	14-Oct-23	18:00	Element must remain in service via other bay.
981	RQ145802	OCC_211	sldcup_sd	ВАУ	410 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT HARDUAGANJ (UP)	UPRVU NL	С	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	Element must remain in service via other bay.
982	RQ146710	OCC_211	sldcdv_sd	BAY		DTL	D	For CB testing and other PMS work	13/Oct/2023	09:30	13/Oct/2023	17:00		PLANNED	Approved	13-Oct-23	09:30	13-Oct-23	17:00	

983	RQ146715	OCC_211	sldcdv_sd	BAY		DTL	D	For CB testing and	12/Oct/2023	09:30	12/Oct/2023	17:00	PLANNED	Approved	12-Oct-23	09:30	12-Oct-23	17:00	
					400 KV BAMNOLI(DV)- JHATIKARA(PG) (DV) CKT-1 AND 400KV BUS 1 AT BAMNOLI(DV)			other PMS work				_							
984	RQ146698	OCC_211	sldcdv_sd	вау	420-52 MAIN BAY - 400 KV BAWANA- MUNDKA (DV) CKT-1 (DTL) AND 400KV BUS 2 AT MUNDKA(DV) AT 400 KV MUNDKA(DV) (DTL)	DTL	D	Circuit Breaker Timing and CRM testing	12/Oct/2023	07:00	12/Oct/2023	11:00	PLANNED	Approved	12-Oct-23	07:00	12-Oct-23	11:00	
			sldcdv_sd		424 MAIN BAY - 400/220 KV 500 MVA ICT 2 AT BAMNOLI(DV) AND 400KV BUS 2 AT BAMNOLI(DV)	DTL	D	For CB testing and other PMS work	11/Oct/2023		11/Oct/2023		PLANNED	Approved	11-Oct-23	09:30	11-Oct-23	17:00	
986	RQ146699	OCC_211	sldcdv_sd	ВАУ	419-52 MAIN BAY - 400 KV BAWANA- MUNDKA (DV) CKT-1 (DTL) AND 400KV BUS 1 AT MUNDKA(DV) AT 400 KV MUNDKA(DV) (DTL)	DTL	D	Circuit Breaker Timing and CRM testing	11/Oct/2023	07:00	11/Oct/2023	11:00	PLANNED	Approved	11-Oct-23	07:00	11-Oct-23	11:00	
987	RQ146708	OCC_211	sldcdv_sd	BAY	421 MAIN BAY - 400/220 KV 500 MVA ICT 3 AT BAMNOLI(DV) AND 400KV BUS 2 AT BAMNOLI(DV)	DTL	D	For CB testing and other PMS work	10/Oct/2023	09:30	10/Oct/2023	17:00	PLANNED	Approved	10-Oct-23	09:30	10-Oct-23	17:00	
988	RQ146696	OCC_211	sldcdv_sd	BAY	418-52 MAIN BAY - 400 KV BAWANA- MUNDKA (DV) CKT-2 (DTL) AND 400KV BUS 2 AT MUNDKA(DV) AT 400 KV MUNDKA(DV) (DTL)	DTL	D	Circuit Breaker Timing and CRM testing	10/Oct/2023	07:00	10/Oct/2023	11:00	PLANNED	Approved	10-Oct-23	07:00	10-Oct-23	11:00	
989	RQ146707	OCC_211	sldcdv_sd	ВАУ	419 MAIN BAY - 400/220 KV 500 MVA ICT 3 AT BAMNOLI(DV) AND 400KV BUS 1 AT BAMNOLI(DV)	DTL	D	For CB testing and other PMS work	09/Oct/2023	09:30	09/Oct/2023	17:00	PLANNED	Approved	09-Oct-23	09:30	09-Oct-23	17:00	

990	RQ146697	OCC_211	sldcdv_sd	ВАУ	417-52 MAIN BAY - 400 KV BAWANA- MUNDKA (DV) CKT-2 (DTL) AND 400KV BUS 1 AT MUNDKA(DV) AT 400 KV MUNDKA(DV) (DTL)	DTL	D	Circuit Breaker Timing and CRM testing	09/Oct/2023	07:00	09/Oct/2023	11:00	I	PLANNED	Approved	09-Oct-23	07:00	09-Oct-23	11:00	
991	RQ146711	OCC_211	sldcdv_sd	BAY	417 MAIN BAY - 400 KV BAMNOLI(DV)- TUGHLAKABAD(P G) (DTL) CKT-2 AND 400KV BUS 2 AT BAMNOLI(DV)	DTL	D	For CB testing and other PMS work	06/Oct/2023	09:30	06/Oct/2023	17:00		PLANNED	Approved	06-Oct-23	09:30	06-Oct-23	17:00	
992	RQ146700	OCC_211	sldcdv_sd	BAY	404 MAIN BAY - 400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-2 AND 400KV BUS 2 AT MUNDKA(DV)	DTL	D	Circuit Breaker Timing and CRM testing	06/Oct/2023	07:00	06/Oct/2023	11:00	ı	PLANNED	Approved	06-Oct-23	07:00	06-Oct-23	11:00	
993	RQ146712	OCC_211	sldcdv_sd	BAY	416 MAIN BAY - 400 KV BAMNOLI(DV)- TUGHLAKABAD(P G) (DTL) CKT-2 AND 400KV BUS 1 AT BAMNOLI(DV)	DTL	D	For CB testing and other PMS work	05/Oct/2023	09:30	05/Oct/2023	17:00		PLANNED	Approved	05-Oct-23	09:30	05-Oct-23	17:00	
994	RQ146701	OCC_211	sldcdv_sd	BAY	403 MAIN BAY - 400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-2 AND 400KV BUS 1 AT MUNDKA(DV)	DTL	D	Circuit Breaker Timing and CRM testing	05/Oct/2023	07:00	05/Oct/2023	11:00	i	PLANNED	Approved	05-Oct-23	07:00	05-Oct-23	11:00	
995	RQ146713	OCC_211	sldcdv_sd	BAY	414 MAIN BAY - 400 KV BAMNOLI(DV)- TUGHLAKABAD(P G) (DTL) CKT-1 AND 400KV BUS 2 AT BAMNOLI(DV)	DTL	D	For CB testing and other PMS work	04/Oct/2023	09:30	04/Oct/2023	17:00		PLANNED	Approved	04-Oct-23	09:30	04-Oct-23	17:00	
996	RQ146702	OCC_211	sldcdv_sd	BAY	402 MAIN BAY - 400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-1 AND 400KV BUS 2 AT MUNDKA(DV)	DTL	D	Circuit Breaker Timing and CRM testing	04/Oct/2023	07:00	04/Oct/2023	11:00		PLANNED	Approved	04-Oct-23	07:00	04-Oct-23	11:00	

997	RQ146714	OCC_211	sldcdv_sd	BAY	413 MAIN BAY -	DTL	D	For CB testing and	03/Oct/2023	09:30	03/Oct/2023	17:00	PLANNED	Approved	03-Oct-23	09:30	03-Oct-23	17:00	
					400 KV BAMNOLI(DV)- TUGHLAKABAD(P G) (DTL) CKT-1 AND 400KV BUS 1 AT BAMNOLI(DV)			other PMS work											
998	RQ146703	OCC_211	sldcdv_sd	BAY	401 MAIN BAY - 400 KV JHATIKARA(PG)- MUNDKA(DV) (DV) CKT-1 AND 400KV BUS 1 AT MUNDKA(DV)	DTL	D	Circuit Breaker Timing and CRM testing	03/Oct/2023	07:00	03/Oct/2023	11:00	PLANNED	Approved	03-Oct-23	07:00	03-Oct-23	11:00	
999	RQ146646	OCC_211	sldcrs_sd	BAY	409 MAIN BAY - 63 MVAR BUS REACTOR NO 2 AT 400 KV KAWAI SCTPS(APR)		С	There is deviation in CB DCRM (Dynamic Contact Resistance Measurement) signature. Circuit Breaker Overhauling need to be done to attend the defect.	13/Oct/2023	08:00	17/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	08:00	17-Oct-23	18:00	Element must remain in service via other bay.
1000	RQ145466	OCC_211	stuup_sd	ВАҮ	418 MAIN BAY - 765KV/400KV AGRA FATEHBAD(UP)- ICT-1 AT AGRA FATEHBAD(UP)	UPPTCL	D	* For rectification of Status of CB and checking remote operation by SCADA X Engineer	12/Oct/2023	14:00	12/Oct/2023	17:00	PLANNED	Approved	12-Oct-23	14:00	12-Oct-23	17:00	
1001	RQ145795	OCC_211	sidcup_sd	BAY	405 TIE BAY - 400KV AGRA(PG)- AGRA FATEHBAD(UP) (PG) CKT-1 AND 400KV AGRA FATEHBAD-AGRA SOUTH (UP) CKT- 2 AT AGRA FATEHBAD(UP)	UPPTCL	С	* For rectification of Status of CB and checking remote operation by SCADA Engineer	11/Oct/2023	14:00	11/Oct/2023	17:00	PLANNED	Approved	11-Oct-23	14:00	11-Oct-23	17:00	Element must remain in service via other bay.
1002	RQ145801	OCC_211	sldcup_sd	BAY	409 MAIN BAY - 400/11 KV 100 MVA ST 2 AT HARDUAGANJ (UP) (UPPTCL)	UPPTCL	С	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	Element must remain in service via other bay.
1003	RQ145707	OCC_211	stuup_sd	ВАҮ	401 MAIN BAY - 400KV AGRA- UNNAO (UP) CKT- 1 AND SELECT AT AGRA(UP)	UPPTCL	D	* Annual routine maintenenace of 400 kV Unnao bay	10/Oct/2023	09:00	10/Oct/2023	17:00	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	17:00	
1004	RQ145708	OCC_211	stuup_sd	ВАУ	405 BUS COUPLER BAY - 400KV BUS 1 AT AGRA(UP) AND 400KV BUS 2 AT AGRA(UP)	UPPTCL	D	* Annual routine maintenance of 400 kV Main bus-1 at 400 kV S/s Agra	10/Oct/2023	09:00	10/Oct/2023	17:00	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	17:00	

1005	RQ145800	OCC_211	sldcup_sd	ВАҮ	407 MAIN BAY - 400 KV HARDUAGANJ - ALIGARH (UP) CKT-1 (UPPTCL) AT 400 KV HARDUAGANJ (UP)	UPPTCL	С	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	07/Oct/2023	08:00	07/Oct/2023	18:00	PLAI	NNED A	Approved	07-Oct-23	08:00	07-Oct-23	18:00	Element must remain in service via other bay.
1006	RQ146486	OCC_211	stuup_sd	BAY	407 BUS COUPLER BAY - 400KV BUS 1 AT ANPARA(UP) (UPPTCL) AND 400KV BUS 2 AT ANPARA(UP) AT 400 KV ANPARA(UP) (UPPTCL)	UPPTCL	С	For replacement of breaker.	05/Oct/2023	08:00	18/Nov/2023	18:00	PLAI	NNED A	Approved	05-Oct-23	08:00	18-Nov-23	18:00	Element must remain in service via other bay.
1007	RQ145342	OCC_211	stuup_sd	ВАУ	405 BUS COUPLER BAY - 400 KV JEHTA_HARDOI ROAD (UP) - BUS 1 (UPPTCL) AND 400 KV JEHTA_HARDOI ROAD (UP) - BUS 2 AT 400 KV JEHTA_HARDOI ROAD (UP) (UPPTCL)	UPPTCL	D	* Shutdown of 400 kV Bus Coupler for annual routine testing work	04/Oct/2023	11:00	04/Oct/2023	16:00	PLAI	NNED A	pproved	04-Oct-23	11:00	04-Oct-23	16:00	
1008	RQ145798	OCC_211	sldcup_sd	ВАУ	405 TIE BAY - 400 KV HARDUAGANJ - SIKANDRABAD (UP) CKT-1 (UPPTCL) AND FUTURE AT 400 KV HARDUAGANJ (UP) (UPPTCL)	UPPTCL	D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	04/Oct/2023	08:00	05/Oct/2023	18:00	PLAI	NNED A	pproved	04-Oct-23	08:00	05-Oct-23	18:00	
1009	RQ145797	OCC_211	sldcup_sd	BAY	404 MAIN BAY - 400 KV HARDUAGANJ - SIKANDRABAD (UP) CKT-1 (UPPTCL)	UPPTCL	С	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	03/Oct/2023	08:00	03/Oct/2023	18:00	PLAI	NNED A	approved	03-Oct-23	08:00	03-Oct-23	18:00	Element must remain in service via other bay.
1010	RQ146647	OCC_211	sldcrs_sd	BAY		APL	С	There is deviation in CB DCRM (Dynamic Contact Resistance Measurement) signature. Circuit Breaker Overhauling need to be done to attend the defect.	09/Oct/2023	08:00	12/Oct/2023	18:00	PLAI	NNED A	Approved	09-Oct-23	08:00	12-Oct-23	18:00	Element must remain in service via other bay.

1011	RQ146648	OCC_211	sldcrs_sd	BAY	413 MAIN BAY - 400KV	APL	D	Annual maintenance and testing of Bay	06/Oct/2023	08:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	19:00	06-Oct-23	23:59	May be given from 1500 Hrs
					CHHABRA(RVUN)- KAWAI SCTPS(APR) (RS) CKT-1 AT KAWAI SCTPS(APR)			equipments.											
1012	RQ145862	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MUKTSAR(PS)	PSTCL	D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.Mtc of NIFPS	31/Oct/2023	08:00	31/Oct/2023	18:00	PLANNED	Approved	31-Oct-23	08:00	31-Oct-23	18:00	
1013	RQ145834	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT DHURI(PS)	PSTCL	D	Maintenance of 411 89 B and 412 89A Tightness of terminal connectors and cleaning of Marshalling boxes	31/Oct/2023	08:00	31/Oct/2023	18:00	PLANNED	Approved	31-Oct-23	08:00	31-Oct-23	18:00	
1014	RQ145826	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT RAJPURA(PS)	PSTCL	D	Annual maintenance/protect ion testing of ICT and its related equipments.	30/Oct/2023	08:00	31/Oct/2023	18:00	PLANNED	Approved	30-Oct-23	08:00	31-Oct-23	18:00	
1015	RQ145825	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT RAJPURA(PS)	PSTCL	D	Annual maintenance/protect ion testing of ICT and its related equipments.	26/Oct/2023	08:00	27/Oct/2023	18:00	PLANNED	Approved	26-Oct-23	08:00	27-Oct-23	18:00	
1016	RQ145831	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT RAJPURA(PS)	PSTCL	D	Annual maintenance/protect ion testing of ICT and its related equipments.	25/Oct/2023	08:00	25/Oct/2023	18:00	PLANNED	Approved	25-Oct-23	08:00	25-Oct-23	18:00	
1017	RQ145830	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT RAJPURA(PS)	PSTCL	D	Annual maintenance/protect ion testing of ICT and its related equipments.	23/Oct/2023	08:00	23/Oct/2023	18:00	PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
1018	RQ145836	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT DHURI(PS)	PSTCL	D	Maintenance of ICT Bushing clamps, 220 KV output bus bar, 406 89L	23/Oct/2023	08:00	23/Oct/2023	18:00	PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
1019	RQ145824	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT RAJPURA(PS)	PSTCL	D	Annual maintenance/protect ion testing of ICT and its related equipments.	20/Oct/2023	08:00	20/Oct/2023	18:00	PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
1020	RQ145835	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT DHURI(PS)	PSTCL	D	Maintenance of 405 89B and 406 89 A Tightness of terminal connectors and cleaning of Marshalling boxes	20/Oct/2023	08:00	20/Oct/2023	18:00	PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
1021	RQ145833	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT DHURI(PS)	PSTCL	D	Protection Testing	17/Oct/2023	08:00	17/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	

1022	RQ145844	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MAKHU(PS)	PSTCL	D	Nut bolt tightening of HV and LV Jumpers, cleaning of bushes,BMK,CTR Panel and C&R Panels	16/Oct/2023	08:00	16/Oct/2023	18:00	PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
1023	RQ145861	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MUKTSAR(PS)	PSTCL	D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.Mtc of NIFPS	13/Oct/2023	08:00	13/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1024	RQ145832	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT DHURI(PS)	PSTCL	D	Maintenance of 205 89A Tightness of terminal connectors and cleaning of Marshalling boxes	13/Oct/2023	08:00	13/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1025	RQ145842	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MAKHU(PS)	PSTCL	D	Nut bolt tightening of HV and LV Jumpers, cleaning of bushes,BMK,CTR Panel and C&R Panels	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
1026	RQ145972	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MUKTSAR(PS)	PSTCL	D	Installation of meters under SAMAST project	05/Oct/2023	11:00	05/Oct/2023	14:30	PLANNED	Approved	05-Oct-23	11:00	05-Oct-23	14:30	
1027	RQ145973	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MUKTSAR(PS)	PSTCL	D	Installation of meters under SAMAST project	05/Oct/2023	11:00	05/Oct/2023	14:30	PLANNED	Approved	05-Oct-23	11:00	05-Oct-23	14:30	
1028	RQ145971	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT MUKTSAR(PS)	PSTCL	D	Installation of meters under SAMAST project	05/Oct/2023	11:00	05/Oct/2023	14:30	PLANNED	Approved	05-Oct-23	11:00	05-Oct-23	14:30	
1029	RQ145951	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT NAKODAR(PSG)	PSTCL	D	Installation of meters under SAMAST project	04/Oct/2023	12:00	04/Oct/2023	13:00	PLANNED	Approved	04-Oct-23	12:00	04-Oct-23	13:00	
1030	RQ145952	OCC_211	sldcps_sd	TRANSFORMER		PSTCL	D	Installation of meters under SAMAST project	04/Oct/2023	11:00	04/Oct/2023	13:30	PLANNED	Approved	04-Oct-23	11:00	04-Oct-23	13:30	
1031	RQ145843	OCC_211	sldcps_sd	TRANSFORMER		PSTCL	D	Nut bolt tightening of HV and LV Jumpers, cleaning of bushes,BMK,CTR Panel and C&R Panels	04/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
1032	RQ145860	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT MUKTSAR(PS)	PSTCL	D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.Mtc of NIFPS	04/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
1033	RQ145987	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MAKHU(PS)	PSTCL	D	Installation of meters under SAMAST scheme	03/Oct/2023	11:00	03/Oct/2023	14:30	PLANNED	Approved	03-Oct-23	11:00	03-Oct-23	14:30	
1034	RQ145986	OCC_211	sldcps_sd	TRANSFORMER		PSTCL	D	Installation of meters under SAMAST scheme	03/Oct/2023	11:00	03/Oct/2023	14:30	PLANNED	Approved	03-Oct-23	11:00	03-Oct-23	14:30	
1035	RQ145985	OCC_211	sldcps_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT MAKHU(PS)	PSTCL	D	Installation of meters under SAMAST scheme	03/Oct/2023	11:00	03/Oct/2023	14:30	PLANNED	Approved	03-Oct-23	11:00	03-Oct-23	14:30	

1026 0	0146100	OCC_211	1	TDANCEODAGED	400/220 KV 500		Iran anadian	28/Oct/2023	17.00	30/Oct/2023	22.50	PLANNED	A	28-Oct-23	17:00	30-Oct-23	23:59	Marcha sires from 1700 Hrs
1030 H	Q146180	OCC_211	cpcc1_sa	IKANSFURIVIER	MVA ICT 5 AT	D	For pending construction related	28/001/2023	17:00	30/001/2023	23:59	PLANNED	Approved	28-001-23	17:00	30-001-23	23:59	May be given from 1700 Hrs
					FATEHGARH_II(P		works and LM											
					G)		erection Works											
1037 R	Q146214	OCC 211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	AMP	26/Oct/2023	17:00	26/Oct/2023	23-59	PLANNED	Approved	26-Oct-23	17:00	26-Oct-23	23:59	May be given from 1700 Hrs
1007	QI IOLI I	000_222	cpcci_su	THE WILLIAM	MVA ICT 4 AT			20,000,2023	27.00	20,000,2020	25.55		Approved	20 000 25	27.00	20 000 25	25.55	may be given nom 1700 ms
					BHADLA_2 (PG)													
1038 R	Q146213	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	TERTIARY	24/Oct/2023	17:00	25/Oct/2023	23:59	PLANNED	Approved	24-Oct-23	17:00	25-Oct-23	23:59	May be given from 1700 Hrs
		_			MVA ICT 6 AT		TRANSFORMER											-
					BHADLA_2 (PG)		ERECTION WORK											
1039 R	Q146178	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	For testing and	23/Oct/2023	17:00	25/Oct/2023	23:59	PLANNED	Approved	23-Oct-23	17:00	25-Oct-23	23:59	May be given from 1700 Hrs
					MVA ICT 3 AT		commissioning works											
					FATEHGARH_II(P		with TBC Bay											
					G)													
1040 R	Q146177	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	For testing and	21/Oct/2023	17:00	23/Oct/2023	23:59	PLANNED	Approved	21-Oct-23	17:00	23-Oct-23	23:59	May be given from 1700 Hrs
					MVA ICT 2 AT		commissioning works											
					FATEHGARH_II(P		with TBC Bay											
10/11	01/6191	OCC_211	cncc1 cd	TDANSEODMED	400/220 KV 500	D	For erection works of	21/Oct/2023	17:00	27/Oct/2023	22.50	PLANNED	Approved	21-Oct-23	17:00	27-Oct-23	23:59	May be given from 1700 Hrs
1041 L	Q140101	OCC_211	cpcc1_3u	TITALIVOI OINIVIER	MVA ICT 5 AT		33 kV Auxiliary	21/00/2023	17.00	27/000/2023	23.33	FLANNED	Approved	21-001-23	17.00	27-001-23	23.33	ividy be given nom 1700 fils
			1	I	FATEHGARH_II(P		transformer of											
				1	G)		Statcom-1 and its											
					-,		commissioning											
1042 R	Q146186	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D		21/Oct/2023	17:00	29/Oct/2023	23:59	PLANNED	Approved	21-Oct-23	17:00	29-Oct-23	23:59	May be given from 1700 Hrs
					MVA ICT 6 AT		tuning and TBC											
					FATEHGARH_II(P		testing of LV side bay											
					G)													
1043 R	Q146208	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	FOR AMP WORK	20/Oct/2023	17:00	20/Oct/2023	23:59	PLANNED	Approved	20-Oct-23	17:00	20-Oct-23	23:59	May be given from 1700 Hrs
					MVA ICT 4 AT													
					BHADLA(PG)			2010 : 10000		20/0 //2000							10.00	
1044 H	Q146207	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	FOR AMP WORK	20/Oct/2023	10:00	20/Oct/2023	18:00	PLANNED	Approved	20-Oct-23	10:00	20-Oct-23	18:00	
					MVA ICT 3 AT BASSI(PG)													
1045 R	O146193	OCC_211	cncc1 sd	TRANSFORMER	400/220 KV 315	D	AMP WORKS	20/Oct/2023	08:00	20/Oct/2023	20:00	PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	20:00	
10.5	Q1 10155	000_211	cpcci_sa	THE WILLIAM	MVA ICT 1 AT		7	20,000,2023	00.00	20,000,2020	20.00		Approved	20 000 25	00.00	20 000 25	20.00	
					KOTPUTLI(PG)													
1046 R	Q146176	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	For testing and	19/Oct/2023	17:00	21/Oct/2023	23:59	PLANNED	Approved	19-Oct-23	17:00	21-Oct-23	23:59	May be given from 1700 Hrs
					MVA ICT 1 AT		commissioning works											
					FATEHGARH_II(P		with TBC Bay											
					G)													
1047 R	Q146206	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315	D	FOR AMP WORK	18/Oct/2023	10:00	18/Oct/2023	18:00	PLANNED	Approved	18-Oct-23	10:00	18-Oct-23	18:00	
					MVA ICT 2 AT													
1040 0	0146305	OCC_211	1 ad	TDANICEODATED	BASSI(PG) 400/220 KV 315	D	FOR AMP WORK	17/Oct/2023	00.00	17/Oct/2023	10.00	PLANNED	A	17-Oct-23	08:00	17-Oct-23	18:00	
1048 H	Q146205	OCC_211	cpcc1_sa	IKANSFURIVIER	MVA ICT 2 AT	J D	FUR AIVIP WURK	17/001/2023	08:00	17/001/2023	18:00	PLANNED	Approved	17-001-23	08:00	17-001-23	18:00	
					SIKAR(PG)													
1049 R	Q146204	OCC 211	cpcc1_sd	TRANSFORMER	400/220 KV 315	D	FOR AMP WORK	17/Oct/2023	08:00	17/Oct/2023	20:00	PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	20:00	
		_			MVA ICT 2 AT													
					ROORKEE(PG)													
1050 R	Q146194	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315	D	AMP WORKS	15/Oct/2023	08:00	15/Oct/2023	20:00	PLANNED	Approved	15-Oct-23	08:00	15-Oct-23	20:00	
					MVA ICT 1 AT													
					BHIWADI(PG)													
1051 R	Q146184	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	LBB testing and TBC	14/Oct/2023	17:00	20/Oct/2023	23:59	PLANNED	Approved	14-Oct-23	17:00	20-Oct-23	23:59	May be given from 1700 Hrs
					MVA ICT 7 AT		testing of ICT-7 with											
					FATEHGARH_II(P		TBC Bay and Tertiary											
			1	1	G)		Bay erection and commissioning works											
				1	1		COIIISSIOIIIII WOLKS											
			1	1			1											
										1						42.0.1.22	22.50	Marcha sirran frans 1700 Usa
1052 R	Q146226	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500	D	For installation and	13/Oct/2023	17:00	13/Oct/2023	23:59	PLANNED	Approved	13-Oct-23	17:00	13-Oct-23	23:59	May be given from 1700 Hrs
1052 R	Q146226	OCC_211	cpcc1_sd	TRANSFORMER	MVA ICT 5 AT	D	For installation and testing of Backup	13/Oct/2023	17:00	13/Oct/2023	23:59	PLANNED	Approved	13-Oct-23	17:00	13-UCT-23	23:59	iviay be given from 1700 Hrs
1052 R	Q146226	OCC_211	cpcc1_sd	TRANSFORMER		D		13/Oct/2023	17:00	13/Oct/2023	23:59	PLANNED	Approved	13-Oct-23	17:00	13-Uct-23	23:59	imay be given from 1700 ms

1053	RO146225	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500		For installation and	12/Oct/2023	17:00	12/Oct/2023	23:59		PLANNED	Approved	12-Oct-23	17:00	12-Oct-23	23:59	May be given from 1700 Hrs
			.,,,,,,		MVA ICT 4 AT BHADLA(PG)		testing of Backup Impedance relay in ICT												
1054	RQ146221	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MANDOLA(PG)	D	FOR AMP	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
1055	RQ146224	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BHADLA(PG)		For installation and testing of Backup Impedance relay in ICT	11/Oct/2023	17:00	11/Oct/2023	23:59		PLANNED	Approved	11-Oct-23	17:00	11-Oct-23	23:59	May be given from 1700 Hrs
1056	RQ146223	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BHADLA(PG)	C	For installation and testing of Backup Impedance relay in ICT	10/Oct/2023	17:00	10/Oct/2023	23:59		PLANNED	Approved	10-Oct-23	17:00	10-Oct-23	23:59	May be given from 1700 Hrs
1057	RQ146222	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BHADLA(PG)	C	For installation and testing of Backup Impedance relay in ICT	09/Oct/2023	17:00	09/Oct/2023	23:59		PLANNED	Approved	09-Oct-23	17:00	09-Oct-23	23:59	May be given from 1700 Hrs
1058	RQ146179	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT FATEHGARH_II(P G)	C	For pending construction related works and LM erection Works	07/Oct/2023	17:00	17/Oct/2023	23:59		PLANNED	Approved	07-Oct-23	17:00	17-Oct-23	23:59	May be given from 1700 Hrs
1059	RQ146220	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT MANDOLA(PG)	C	BUS BAR RETROFITTING WORK	07/Oct/2023	08:00	08/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. No. 179
1060	RQ146174	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT BHADLA(PG)	D	AMP work	05/Oct/2023	17:00	05/Oct/2023	23:59		PLANNED	Approved	05-Oct-23	17:00	05-Oct-23	23:59	May be given from 1700 Hrs
1061	RQ146183	OCC_211	cpcc1_sd	TRANSFORMER		D	ICT-9 CSD Relay final tuning and other pending construction works		17:00	09/Oct/2023	23:59		PLANNED	Approved	05-Oct-23	17:00	09-Oct-23	23:59	May be given from 1700 Hrs
1062	RQ146185	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(P	D	ICT-7 CSD Relay final tuning and other pending construction works		17:00	11/Oct/2023	23:59		PLANNED	Approved	05-Oct-23	17:00	11-Oct-23	23:59	May be given from 1700 Hrs
1063	RQ146216	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT NEEMRANA(PG)	D	FOR AMP WORK	05/Oct/2023	08:00	05/Oct/2023	20:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	20:00	
1064	RQ146219	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT MANDOLA(PG)	C	BUS BAR RETROFITTING WORK	05/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. No. 192
1065	RQ146200	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT BALLABHGARH(P G)	C	For replacement of LBB relay of 220KV CB.	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
1066	RQ146173	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BHADLA(PG)	D	AMP work	03/Oct/2023	17:00	03/Oct/2023	23:59		PLANNED	Approved	03-Oct-23	17:00	03-Oct-23	23:59	May be given from 1700 Hrs
1067	RQ146182	OCC_211	cpcc1_sd	TRANSFORMER		C	For commissioning works of 400 kV ICT- 6 under SS-63 package and ICT-9 CSD Relay final tuning, other pending construction works	03/Oct/2023	17:00	10/Oct/2023	23:59	for LBB testing of Bay 443 for commissioning check with ICT- 6 LV Bay(BaY 231)	PLANNED	Approved	03-Oct-23	17:00	10-Oct-23	23:59	May be given from 1700 Hrs
1068	RQ146215	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT NEEMRANA(PG)	D	FOR AMP WORK	03/Oct/2023	08:00	03/Oct/2023	20:00		PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	20:00	

1069	RQ146199	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BALLABHGARH(P		D	For replacement of LBB relay of 220KV CB.	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
1070	RQ146218	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT MANDOLA(PG)		С	BUS BAR RETROFITTING WORK	03/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. No. 207
1071	RQ146188	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT DEHRADUN(PG)		D	AMP WORKS	02/Oct/2023	08:00	02/Oct/2023	18:00	Shutdown to be availed in Sept-23.	PLANNED	Approved	02-Oct-23	08:00	02-Oct-23	18:00	
1072	RQ146198	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BALLABHGARH(P G)		D	For replacement of LBB relay of 220KV CB.	02/Oct/2023	08:00	02/Oct/2023	18:00		PLANNED	Approved	02-Oct-23	08:00	02-Oct-23	18:00	
1073	RQ146175	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 6 AT FATEHGARH_II(P G)		D	FOR STRINGING WORKS OF 765/400 KV ICT-5 LV SIDE	01/Oct/2023	15:00	06/Oct/2023	23:59	REQUIRED FOR SS-63 A1 PACKAGE	PLANNED	Approved	01-Oct-23	17:00	06-Oct-23	23:59	May be given from 1700 Hrs
1074	RQ146187	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT DEHRADUN(PG)		D	AMP WORKS	01/Oct/2023	08:00	01/Oct/2023	18:00	Shutdown to be availed in Sept-23.	PLANNED	Approved	01-Oct-23	08:00	01-Oct-23	18:00	
1075	RQ146197	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BALLABHGARH(P G)		D	For replacement of LBB relay of 220KV CB.	01/Oct/2023	08:00	01/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	01-Oct-23	18:00	
1076	RQ146217	OCC_211	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT MANDOLA(PG)		С	BUS BAR RETROFITTING WORK	01/Oct/2023	08:00	02/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. No. 222
		OCC_211			400/132 KV 100 MVA ICT 3 AT ANPARA(UP)	UPPTCL	C	For Overhauling of 400/132/33 KV Interconnecting Transformer # 3	27/Oct/2023		27/Nov/2023		400/132/33 kV ICT-3 of ATPS will remain under shutdown on continous basis to attend overhauling as the given transformer has not underwent any overhauling since last 27 years. Overhauling also becomes inevitable as oil leakage has occured at several places and needs to be attended at the earliest.		Approved	27-Oct-23	08:00	27-Nov-23	18:00	May be given subject to no other shutdown at Anpara(UP)
1078	RQ145793	OCC_211	sldcup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 5 AT AGRA(UP)	UPPTCL	D	* Annual maintenance of 400 & 220 kV Bays with CT/CB/ICT of ICT-3 at 400 kV S/s Agra	20/Oct/2023	08:00	21/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	21-Oct-23	18:00	
1079	RQ145360	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BANDA(UP)	UPPTCL	D	* MAINTINANCE OF 315 MVA ICT II	18/Oct/2023	10:00	18/Oct/2023	15:00		PLANNED	Approved	18-Oct-23	10:00	18-Oct-23	15:00	

1080	RQ145705	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT AGRA(UP)	UPPTCL	D	* Annual maintenance of 400 & 220 kV Bays with CT/CB/ICT of ICT-2 at	18/Oct/2023	09:00	19/Oct/2023	17:00	PLANNED	Approved	18-Oct-23	09:00	19-Oct-23	17:00	
1081	RQ145376	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT	UPPTCL	D	* For Preventive maintenance and	17/Oct/2023	10:00	17/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	10:00	17-Oct-23	18:00	
1082	RQ145372	OCC_211	stuup_sd	TRANSFORMER	SULTANPUR(UP) 400/220 KV 500 MVA ICT 1 AT LUCKNOW(UP)	UPPTCL	D	Testing of T/F  * For Annual Protection testing, Bay Maintenance work and strenghtening of X Neutral Delta Earthing at 400 KV Sub-Station, Sar	17/Oct/2023	09:00	17/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	
1083	RQ145366	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT AGRA(UP)	UPPTCL	D	* Annual maintenance of 400 & 220 kV Bays with CT/CB/ICT at 400 kV X S/s Agra	16/Oct/2023	09:00	17/Oct/2023	17:00	PLANNED	Approved	16-Oct-23	09:00	17-Oct-23	17:00	
1084	RQ145373	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT BAREILLY(UP)	UPPTCL	D	* preventive maintence and testing	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
1085	RQ145378	OCC_211	stuup_sd	TRANSFORMER		UPPTCL	D	* For annual maintenance and testing work.	10/Oct/2023	11:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	11:00	10-Oct-23	18:00	
1086	RQ145367	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT MORADABAD(UP)	UPPTCL	D	* Planned Shutdown is requried for the Annual Routine Testing of X Protection System of 500MVA ICT-II(T&R make).	10/Oct/2023	09:00	11/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	09:00	11-Oct-23	18:00	
1087	RQ145351	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT SARNATH(UP)	UPPTCL	D	* For Bay & Bus Tightening	10/Oct/2023	09:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	18:00	
1088	RQ145377	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BASTI(UP)	UPPTCL	D	* For annual maintenance and testing work.	09/Oct/2023	11:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	11:00	09-Oct-23	18:00	
1089	RQ145791	OCC_211	sldcup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT GR.NOIDA(UPC)	UPPTCL	С	* Routine testing work will be carried out of mentioned ICT during this shutdown period.	08/Oct/2023	10:00	08/Oct/2023	15:00	PLANNED	Approved	08-Oct-23	10:00	08-Oct-23	15:00	May be given subject to load management by UP
1090	RQ145809	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT GR.NOIDA(UPC)	UPPTCL	D	* Routine testing work will be carried out of mentioned ICT during this X shutdown period.	08/Oct/2023	10:00	08/Oct/2023	15:00	PLANNED	Approved	08-Oct-23	10:00	08-Oct-23	15:00	
1091	RQ145368	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT GR.NOIDA(UPC)	UPPTCL	D	* Routine testing work will be carried out of mentioned ICT during this X shutdown period.	06/Oct/2023	10:00	06/Oct/2023	15:00	PLANNED	Approved	06-Oct-23	10:00	06-Oct-23	15:00	

4002 521	445274 1.	200 244		TD 4 N/CFO D4 :==	400/22010/522	LIBBTO:		* =	04/0-1/2022	00.00	04/0-1/2000	10.00	1	DI ANNES		04.0 -1.00	00.00	04.0.1.00	40.00	1
1092 RQ1	1453/1	JCC_211	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT	UPPTCL	D	* For Annual Protection testing,	04/Oct/2023	09:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	09:00	04-Oct-23	18:00	
					LUCKNOW(UP)			bay Maintenance												
								work & X												
								Strenghtening of												
								Neutral Delta												
								Earthing at 400 KV												
1093 RQ1	145375	OCC 211	stuup_sd	TRANSFORMER	400/220 KV 315	UPPTCL	С	Sub-Station,  * centrifusing of oil	04/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	10-Oct-23	18:00	May be given subject to load
1033 // 01	143373	JCC_211	stuup_su	TIONIVISI ONIVIEN	MVA ICT 2 AT	OTTICE	C	centinusing or on	04,000,2023	00.00	10,000,2023	10.00		LANINED	Арргочса	04 000 25	00.00	10 000 25	10.00	management by UP
					BAREILLY(UP)															management by or
1094 RQ1	145374	OCC 211	stuup_sd	TRANSFORMER	400/220 KV 315	UPPTCL	D	* preventive	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
					MVA ICT 1 AT			maintenace and												
					BAREILLY(UP)			testing												
1095 RQ1	145354	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 315	UPPTCL	С	* 315MVA ICT-1 S/D	01/Oct/2023	10:00	31/Oct/2023	17:00		PLANNED	Approved	01-Oct-23	10:00	31-Oct-23	17:00	One shutdown at a time may
					MVA ICT 1 AT			FOR REPLACEMENT												be given subject to load
					PANKI(UP)			OF 315MVA ICT-I TO 500MVA ICT AND												management by UP/CEA clearance/PTCC clearance and
								220KV X JACK BUS												Annexure B-7 required before
								STRINGING OF TWIN												charging.
								MOOSE CONDUCTOR												
1096 RQ1	145355	OCC_211	stuup_sd	TRANSFORMER	400/220 KV 315	UPPTCL	С	* 315 MVA ICT-II S/D	01/Oct/2023	10:00	06/Oct/2023	17:00		PLANNED	Approved	01-Oct-23	10:00	06-Oct-23	17:00	One shutdown at a time may
					MVA ICT 2 AT			FOR STRINGING OF												be given subject to load
					PANKI(UP)			TWIN MOOSE CONDUCTOR												management by UP/CEA
								CONDUCTOR												clearance/PTCC clearance and Annexure B-7 required before
																				charging.
1097 RQ1	145396	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP WORKS	26/Oct/2023	08:00	26/Oct/2023	18:00	Kindly approve	PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
					MVA ICT 1 AT	GRID														
					ABDULLAPUR(PG)															
1098 RQ1	145901	OCC 211	cpcc3_sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP work	23/Oct/2023	10:00	23/Oct/2023	18:00		PLANNED	Approved	23-Oct-23	10:00	23-Oct-23	18:00	
			.,		MVA ICT 1 AT	GRID			.,,		,,,,,									
					AGRA(PG)															
1099 RQ1	145876	OCC_211	cpcc3_sd	TRANSFORMER		POWER	D	For AMP works &	20/Oct/2023	10:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	10:00	20-Oct-23	18:00	
					MVA ICT 2 AT	GRID		compliance of 9'th &												
					ALLAHABAD(PG)			10th PCC observations												
1100 RQ1	145398	OCC 211	cpcc2 sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP Works and	19/Oct/2023	10:00	19/Oct/2023	17:00	Kindly approve	PLANNED	Approved	19-Oct-23	10:00	19-Oct-23	17:00	
			.,		MVA ICT 2 AT	GRID		WTI/OTI trip logic	.,,		,,,,,		, , , , , ,							
					PARBATI			modification.												
					POOLING															
4484 8 - :					BANALA(PG)				10/0 / /0		1010 10							40.0		
1101 RQ1	145590	UCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 315	POWER	D	As 400/220KV ICT-1	19/Oct/2023	09:00	19/Oct/2023	17:30	Under	PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	17:30	
					MVA ICT 1 AT WAGOORA(PG)	GRID		was charged via temporary					construction head, Kindly							
					WAGOOKA(PG)			arrangement and					approve							
								bypassing of					αρρίονε							
				1	1			isolators. After						1						
				1	1			retrofitting of old						1						
								isolators, the new												
				1	1			isolators will be						1						
				1	1			taken into service.						1						
	1			1	1	1		ICT-1 S/D will be						1						1
								taken to remove all												
								the temporary												
								the temporary arrangements from												
								the temporary arrangements from both 400kV and												
								the temporary arrangements from												

					T	1		I			1		_					1		1
1102	RQ145877	OCC_211	cpcc3_sd	TRANSFORMER	400/220 KV 315	POWER	D	For AMP works &	18/Oct/2023	10:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	10:00	18-Oct-23	18:00	
					MVA ICT 1 AT	GRID		Time Delay in												
					ALLAHABAD(PG)			Buchholz Protection												
1103	RQ145395	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 500	POWER	D	AMP WORKS	18/Oct/2023	08:00	18/Oct/2023	18:00	Kindly approve	PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
					MVA ICT 2 AT	GRID														
					PANIPAT(BB)															
1104	RQ145399	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP WORKS	17/Oct/2023	09:00	17/Oct/2023	18:00	Kindly approve	PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	
					MVA ICT 3 AT	GRID														
					NALLAGARH(PG)															
1105	RQ145902	OCC_211	cpcc3 sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP work	16/Oct/2023	10:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	10:00	16-Oct-23	18:00	
					MVA ICT 2 AT	GRID		-	.,,		., ,									
					AGRA(PG)															
1106	RO145397	OCC_211	cpcc2_sd	TRANSFORMER		POWER	D	AMP Works and	16/Oct/2023	10:00	16/Oct/2023	17:00	Kindly approve	PI ANNED	Approved	16-Oct-23	10:00	16-Oct-23	17:00	
1100	110143337	000_211	cpccz_su	TIVANSI ORIVIER	MVA ICT 1 AT	GRID		WTI/OTI trip logic	10,000,2023	10.00	10/000/2023	17.00	Killaly approve	LAMINED	Approved	10 000 25	10.00	10 000 25	17.00	
					PARBATI	GKID		modification.												
								mounication.												
					POOLING															
			<b>—</b>		BANALA(PG)								+		<u> </u>		10.01			1
1107	KQ145875	OCC_211	cpcc3_sd	TRANSFORMER		POWER	D	AMP work	14/Oct/2023	10:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	10:00	14-Oct-23	18:00	
					MVA ICT 2 AT	GRID									İ					
					SHAHJAHANPUR(										İ					
					PG)															
1108	RQ145868	OCC_211	cpcc3_sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP of ICT#2 and	14/Oct/2023	10:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	10:00	14-Oct-23	18:00	
			1	1	MVA ICT 2 AT	GRID		PRD & OSR scheme				l	İ		1					1
					GORAKHPUR(PG)			modification work							İ					
1109	RQ145638	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP Works and	12/Oct/2023	09:00	12/Oct/2023	18:00	Kindly approve	PLANNED	Approved	12-Oct-23	09:00	12-Oct-23	18:00	
		_	. –		MVA ICT 2 AT	GRID		WTI/OTI trip logic					,							
					HAMIRPUR(PG)			modification.												
1110	RO145402	OCC_211	cpcc2_sd	TRANSFORMER		POWER	D	AMP WORKS	12/Oct/2023	08:00	12/Oct/2023	20:00	Kindly approve	PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	20:00	
1110		000_211	cpccz_sa		MVA ICT 3 AT	GRID		7	12,000,2020	00.00	12,000,2025	20.00	initially approve		прриотец	12 000 20	00.00	12 000 25	20.00	
					KAITHAL(PG)	GINID														
1111	DO14E966	OCC_211	cocc3 cd	TRANSFORMER	400/220 KV 315	POWER	D	AMP work	11/Oct/2023	10:00	11/Oct/2023	10.00		PLANNED	Approved	11-Oct-23	10:00	11-Oct-23	18:00	
1111	NQ143600	OCC_211	cpccs_su	INANSFUNIVIER			U	AIVIP WOLK	11/001/2023	10.00	11/001/2023	10.00		PLAININED	Approved	11-001-25	10.00	11-001-23	16.00	
					MVA ICT 1 AT	GRID														
					FATEHPUR(PG)						44/0 //0000		-			44.000		44.0.00	10.00	
1112	RQ145867	OCC_211	cpcc3_sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP of ICT#1 and	11/Oct/2023	10:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	10:00	11-Oct-23	18:00	
					MVA ICT 1 AT	GRID		PRD & OSR scheme												
					GORAKHPUR(PG)			modification work												
					,													<b>+</b>		
1113	RQ145476	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 500	POWER	D	AMP WORKS	10/Oct/2023	10:00	10/Oct/2023	18:00	Kindly approve	PLANNED	Approved	10-Oct-23	10:00	10-Oct-23	18:00	1
			1	1	MVA ICT 4 AT	GRID						l	İ		1					1
			<u> </u>		AMRITSAR(PG)													1		
1114	RQ145400	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP WORKS	10/Oct/2023	09:00	10/Oct/2023	18:00	Kindly approve	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	18:00	
			1	1	MVA ICT 1 AT	GRID						l	İ		1					1
					NALLAGARH(PG)										İ					
															İ					
1115	RQ145511	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 315	POWER	С	Shutdown is required	10/Oct/2023	09:00	23/Oct/2023	18:00	Under	PLANNED	Approved	10-Oct-23	09:00	23-Oct-23	18:00	
				1	MVA ICT 2 AT	GRID		for GIB Erection of	,		,		construction							1
					KALA AMB(PKTL)			New Dia along with					head, Kindly		İ					
			1	1				existing GIB of ICT-2				l	approve		1					1
								CAUSTING GID OF ICT-Z					арріотс		İ					
1116	PO1/16671	OCC 211	cldcdy cd	TDANSEODMED	400/220 KV 315	POWER	D	Tan Delta testing of	10/Oct/2023	00.00	10/Oct/2023	16:00	+	DIANNED	Approved			1		to be club with powergrid
1110	NQ1400/1	OCC_211	siucuv_su	INMINOFUNIVIER			U		10/001/2023	09.00	10/000/2023	10.00		PLANNED	Approved					· · · · · · · · · · · · · · · · · · ·
					MVA ICT 3 AT	GRID		ICT Winding, bushings							İ					shutdown in september.
			1	1	BAWANA(DV)			and related CT, I/C				l	İ		1					
								and Bay							İ					
			L						00/0 /	00.00	00/0 /					20.0		00.0	40	
1117	KQ145551	OCC_211	cpcc2_sd	IRANSFORMER	400/220 KV 315	POWER	D	AMP WORKS	09/Oct/2023	υ9:00	09/Oct/2023	18:00	Kindly approve	PLANNED	Approved	09-Oct-23	09:00	09-Oct-23	18:00	1
					MVA ICT 3 AT	GRID							1							
					SAMBA(PG)															1

		OCC_211			400/220 KV 315 MVA ICT 1 AT WAGOORA(PG)	POWER GRID	D	Isolator retrofitting of 400kV/ 220kV ICT-1 Bay (20980C & 20980T, 40889T ISOLATORS). The S/D is taken to Bypass the 20989T & 40889T isolators, the conductor from CT to 20989T & 40889T. isolators shall be removed. For 20989C & 40889C, Temporary arrangement will be made from CT to TBC connection so that 20989C & 40889C isolators droppers from TBC shall be removed and WAGOORA-ICT-1 may be charged via 220kV TBC and 400kV TBC afterwards.	07/Oct/2023		07/Oct/2023		Under construction head, Kindly approve	PLANNED		07-Oct-23	09:00	07-Oct-23	17:30	
		OCC_211			400/220 KV 500 MVA ICT 3 AT PANCHKULA(PG)	POWER GRID	D	AMP WORKS	05/Oct/2023		05/Oct/2023		Kindly approve			05-Oct-23	09:30	05-Oct-23	18:00	
		OCC_211			400/220 KV 315 MVA ICT 2 AT CHAMBA(PG)	POWER GRID	D	AMP WORKS	05/Oct/2023		05/Oct/2023		Kindly approve	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
		OCC_211			400/220 KV 315 MVA ICT 1 AT HAMIRPUR(PG)	POWER GRID	D	AMP Works and WTI/OTI trip logic modification.	05/Oct/2023	09:00	05/Oct/2023	18:00	Kindly approve	PLANNED	Approved	05-Oct-23	09:00	05-Oct-23	18:00	
		OCC_211			400/220 KV 315 MVA ICT 2 AT JAULIIVI (PG)	POWER	D	For application of insulation coating or insulation sleeve on 33kV naked jumpers installed in Air Insulated switchyard pertaining to ICT-1 in order to prevent phase to phase fault due to any animal like cat's, Ape's and monkey's etc. and AMP of ICT-2	05/Oct/2023		05/Oct/2023			PLANNED		05-Oct-23	08:00	05-Oct-23	18:00	
					400/220 KV 500 MVA ICT 3 AT BALLABHGARH(P G)	POWER GRID	D	Yearly mtc. on 220 KV side at Samaypur BBMB.	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
1124 F	RQ145550	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT JALANDHAR(PG)	POWER GRID	D	AMP WORKS	04/Oct/2023	10:00	04/Oct/2023	18:00	Kindly approve	PLANNED	Approved	04-Oct-23	10:00	04-Oct-23	18:00	
1125 F	RQ145487	OCC_211	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT FATEHABAD(PG)	POWER GRID	D	AMP WORKS	04/Oct/2023	10:00	04/Oct/2023	18:00	Kindly approve	PLANNED	Approved	04-Oct-23	10:00	04-Oct-23	18:00	
1126 F	RQ145886	OCC_211	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT KANPUR(PG)	POWER GRID	D	AMP work	03/Oct/2023	10:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	10:00	03-Oct-23	18:00	

1127 F	Q145873	OCC_211	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT	POWER GRID	D	For application of insulation coating or	03/Oct/2023	10:00	03/Oct/2023	18:00	PLANNE	D Approved	03-Oct-23	10:00	03-Oct-23	18:00	
					JAULIIVI (PG)			insulation sleeve on 33kV naked jumpers											
								installed in Air											
								Insulated switchyard											
								pertaining to ICT-1											
								in order to prevent											
								phase to phase fault											
								due to any animal											
								like cat's, Ape's and monkey's etc. and											
								AMP of ICT-1											
1128 F	Q145885	OCC_211	cpcc3_sd	TRANSFORMER	400/220 KV 315	POWER	D	AMP work. S/D	01/Oct/2023	10:00	01/Oct/2023	18:00	PLANNE	D Approved	01-Oct-23	10:00	01-Oct-23	18:00	
		_	. –		MVA ICT 2 AT	GRID		actual required on											
					KANPUR(PG)			26.09.2023											
1129 F	Q145660	OCC_211	sldchr_sd	TRANSFORMER	400/220 KV 315	HVPNL	D	To verify the all-	25/Oct/2023	09:00	25/Oct/2023	18:00	PLANNE	D Approved	25-Oct-23	09:00	25-Oct-23	18:00	
					MVA ICT 1 AT			signal BIM, BOM in											
					DHANODA(HV)			SAS.			10/0 //0000				10.0		40.000	10.00	
1130 F	Q145661	OCC_211	siacnr_sd	IKANSFURMER	400/220 KV 315 MVA ICT 2 AT	HVPNL	D	To verify the all- signal BIM, BOM in	18/Oct/2023	09:00	18/Oct/2023	18:00	PLANNE	D Approved	18-Oct-23	09:00	18-Oct-23	18:00	
					DHANODA(HV)			SAS.											
1131 F	Q145727	OCC_211	sldcrs_sd	TRANSFORMER	400/220 KV 315	RRVPNL	D	Preventive	20/Oct/2023	08:00	21/Oct/2023	18:00	PLANNE	D Approved	20-Oct-23	17:00	21-Oct-23	23:00	May be given from 1700 Hrs
		_	_		MVA ICT 1 AT			maintenance &											, ,
					KANKANI(RS)			Testing of bay and											
								equipments											
1132 F	Q145720	OCC_211	sldcrs_sd	TRANSFORMER	400/220 KV 315	RRVPNL	D	Maintenance work of	18/Oct/2023	08:00	18/Oct/2023	18:00	PLANNE	D Approved	18-Oct-23	17:00	18-Oct-23	23:00	May be given from 1700 Hrs
					MVA ICT 3 AT			bay equipments ,											
					RATANGARH(RS)			isolators and testing											
								work of bay equipments.											
1133 F	0145728	OCC 211	sldcrs sd	TRANSFORMER	400/220 KV 500	RRVPNL	D	Preventive	18/Oct/2023	08:00	19/Oct/2023	18:00	PLANNE	D Approved	18-Oct-23	17:00	19-Oct-23	23:00	May be given from 1700 Hrs
1133	Q115720	000_211	Siders_sd	THE WAST CHANGE	MVA ICT 2 AT			maintenance &	20,000,2020	00.00	15,000,2025	20.00		7.pp.o.cu	10 000 25	17.00	15 000 25	25.00	may be given nom 1700 ms
					KANKANI(RS)			Testing of bay and											
								equipments											
1134 F	Q145719	OCC_211	sldcrs_sd	TRANSFORMER	400/220 KV 315	RRVPNL	D	Maintenance work of	16/Oct/2023	08:00	16/Oct/2023	18:00	PLANNE	D Approved	16-Oct-23	17:00	16-Oct-23	23:00	May be given from 1700 Hrs
					MVA ICT 2 AT			bay equipments ,											
					RATANGARH(RS)			isolators and testing											
								work of bay equipments.											
1135 F	Q145718	OCC_211	sldcrs sd	TRANSFORMER	400/220 KV 315	RRVPNL	D	Maintenance work of	14/Oct/2023	08:00	14/Oct/2023	18:00	PLANNE	D Approved	14-Oct-23	17:00	14-Oct-23	23:00	May be given from 1700 Hrs
	,				MVA ICT 1 AT			bay equipments ,			, ,								.,
					RATANGARH(RS)			isolators and testing											
								work of bay											
								equipments.											
1136 F	Q145726	OCC_211	sldcrs_sd	TRANSFORMER	400/220 KV 500	RRVPNL	D	Maintenance along	14/Oct/2023	08:00	15/Oct/2023	18:00	PLANNE	D Approved	14-Oct-23	17:00	15-Oct-23	23:00	May be given from 1700 Hrs
		1	1	1	MVA ICT 3 AT			with testing of Bay		1									
1127	01/15715	OCC_211	sldcrs_sd	TRANSFORMED	JAISALMER(RS) 400/220 KV 315	RRVPNL	D	equipments QUARTERLY	12/Oct/2023	08:00	12/Oct/2023	18:00	PLANNE	D Approved	12-Oct-23	17:00	12-Oct-23	23:00	May be given from 1700 Hrs
113/	(L14J/13	JCC_211	31UCI 3_5U	I MAINSI UNIVIER	MVA ICT 2 AT	INVPINE	J	MAINT.WORK OF	12/001/2023	00.00	12/00/2023	10.00	PLANNE	Approved	12-001-23	17.00	12-001-23	23.00	May be given from 1700 Hrs
					MERTA(RS)			BAY & EQUIPMENTS											
1138 F	Q145725	OCC_211	sldcrs_sd	TRANSFORMER	400/220 KV 500	RRVPNL	D	Maintenance along	12/Oct/2023	08:00	13/Oct/2023	18:00	PLANNE	D Approved	12-Oct-23	17:00	13-Oct-23	23:00	May be given from 1700 Hrs
					MVA ICT 1 AT			with testing of Bay											
					JAISALMER(RS)			equipments			<b> </b>								
1139 F	Q145723	OCC_211	sldcrs_sd	TRANSFORMER	400/220 KV 315	RRVPNL	D	UARTERLY	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNE	D Approved	11-Oct-23	17:00	11-Oct-23	23:00	May be given from 1700 Hrs
					MVA ICT 1 AT			MAINT.WORK OF											
11/0	01/1573/4	OCC 211	eldere ed	TDANISEODNAFD	MERTA(RS) 400/220 KV 315	DD\/DNII	D	BAY & EQUIPMENTS	10/Oct/2023	08:00	10/Oct/2023	10.00	PLANNE	D Approved	10-Oct-23	17:00	10-Oct-23	23:00	May be given from 1700 U
1140 1	·Q14J/24	JCC_211	31UCI 3_5U	I MAINSI UNIVIER	MVA ICT 4 AT	INVPINE	J	Quarterly Maintenance/testing	10/001/2023	00.00	10,000,2023	10.00	PLANNE	D Approved	10-001-23	17.00	10-001-23	23.00	May be given from 1700 Hrs
					HEERAPURA(RS)			work of 400 KV/220											
1 1																			
					,			KV side bay											

		OCC_211	sldcrs_sd		400/220 KV 315 MVA ICT 2 AT SURATGARH(RVU N)	RRVPNL		1) Checking of Tan Delta of Bushings 2) Oil Filteration 3) Checking of protections of Transformer. Attending Leakages 4) Mechanism Overhauling of 400KV SF6 Breaker of ILT#II by the service engineer of M/s CGPISL (PO issued on Numerical Relays in Protection panel of ILTs. After approval of Drg, Material received at site.(PO dtd 21.4.23) Quarterly	10/Oct/2023		19/Oct/2023			PLANNED	Rejected	09-Oct-23	17:00	09-Oct-23	23:00	there is no alternate supply, henceforth consent denied by Rajasthan SLDC.  May be given from 1700 Hrs
					MVA ICT 3 AT HEERAPURA(RS)			Maintenance/testing work of 400 KV/220 KV side bay Equipments							дриочец		17.00		23.00	May be given noin 1700 ms
		OCC_211	_		MVA ICT 1 AT BARMER(RS)	RRVPNL		Maintenance along with testing of Bay equipments	06/Oct/2023		06/Oct/2023			PLANNED	Approved	06-Oct-23	17:00	06-Oct-23	23:00	May be given from 1700 Hrs
		OCC_211			400/220 KV 315 MVA ICT 2 AT BARMER(RS)	RRVPNL		Maintenance along with testing of Bay equipments	04/Oct/2023		04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	17:00	04-Oct-23	23:00	May be given from 1700 Hrs
1145	RQ146489	OCC_211	indigrid_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT AMARGARH(NRSS XXIX)	NRSS XXIX		As per CEA guidelines switching of ICT-1 R- phase with Spare ICT. (Last Switching date: 10-May-23)	18/Oct/2023	11:00	18/Oct/2023	12:00	Associated 402 Tie bay, 403 Main bay & 203 Main Bay supply will also remain affected	PLANNED	Approved	18-Oct-23	11:00	18-Oct-23	12:00	
1146	RQ146670	OCC_211	sldcdv_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT BAWANA(DV)	DTL		Tan Delta testing of ICT Winding, bushings and related CT, I/C and Bay	09/Oct/2023	09:00	09/Oct/2023	16:00		PLANNED	Approved	09-Oct-23	09:00	09-Oct-23	16:00	
		OCC_211			MVA ICT 1 AT MUNDKA(DV)	DTL		winding resistance, pi and other annual testings	07/Oct/2023		07/Oct/2023	13:00		PLANNED	Approved	07-Oct-23	07:00	07-Oct-23	13:00	
1148	RQ146549	OCC_211	indigrid_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT PRITHALA (GPTL)	GPTL	D	AMP works of Transformer	04/Oct/2023	08:00	04/Oct/2023	20:00	Associated 408 TIE BAY, 409 MIAN BAY & 207 MAIN BAY will also be under shutdown	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	20:00	

1149	RQ146520	OCC_211	indigrid_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT PRITHALA (GPTL)	GPTL	D	AMP work of ICT	03/Oct/2023	08:00	03/Oct/2023	20:00	All the associated bays -401 MAIN BAY,402 TIE BAY & 203 MAIN BAY supply will also be affected	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	20:00	
1150	RQ145864	OCC_211	cpcc3_sd	TRANSFORMER	220/132 KV 100 MVA ICT 1 AT RAEBAREILLY(PG)	POWER GRID	D	For AMP works and implementation of time delay in ICT body protection.	17/Oct/2023	10:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	10:00	17-Oct-23	18:00	
1151	RQ145865	OCC_211	cpcc3_sd	TRANSFORMER	220/132 KV 200 MVA ICT 2 AT RAEBAREILLY(PG)	POWER GRID	D	For AMP works and implementation of time delay in ICT body protection.	10/Oct/2023	10:00	10/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	10:00	10-Oct-23	18:00	
1152	RQ145869	OCC_211	cpcc3_sd	TRANSFORMER	220/132 KV 100 MVA ICT 1 AT PITHORAGARH(P G)	POWER GRID	D	AMP work	05/Oct/2023	10:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	10:00	05-Oct-23	18:00	
1153	RQ145934	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MOGA(PG)- AJITWAL(PS) (PSTCL) CKT-1	PSTCL	D	Tree cutting and Jumper tightening TN 20 to 40	31/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	31-Oct-23	08:00	31-Oct-23	18:00	
1154	RQ145933	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DANDHARIKALAN I(PS)- LUDHIANA(PG) (PSTCL) CKT-1	PSTCL	D	Tree cutting and Jumper tightening TN 55 to 65	26/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
				AC TRANSMISSION LINE CIRCUIT	220 KV BHAKRA_R(BB)- MAHILPUR(PS) (PS) CKT-2	PSTCL	D	Patrolling of line alongwith Tree trimming and Jumper tightening			26/Oct/2023			PLANNED						to be clubbed with BBMB shutdown on same circuit on dated 17-10-2023 i.e. at Sr. No. 1159.
1156	RQ145532	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(PG)- KANJAL(PS) (PSTCL) CKT-2	PSTCL	D	AMP work	20/Oct/2023	10:00	20/Oct/2023	14:00	Kindly approve	PLANNED	Approved	20-Oct-23	10:00	20-Oct-23	14:00	
1157	RQ145926	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(PG)- KARTARPUR(PS) (PSTCL) CKT-2	PSTCL	D	Checking of Jumper,suspension clamp and Damper.Tree cutting and disc cleaning	20/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
			sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DANDHARIKALAN I(PS)- LUDHIANA(PG) (PSTCL) CKT-1	PSTCL	D	Tree cutting and Jumper tightening TN 40 to 55	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	18:00	
			bbmb_sd	LINE CIRCUIT	220 KV BHAKRA_R(BB)- MAHILPUR(PS) (PS) CKT-2	PSTCL	D	Half Yearly Mtc	17/Oct/2023		17/Oct/2023			PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	220 KV BHAKRA_R(BB)- MAHILPUR(PS) (PS) CKT-1	PSTCL	D	Patrolling of line alongwith Tree trimming and Jumper tightening	17/Oct/2023		17/Oct/2023			PLANNED	Approved					to be clubbed with BBMB shutdown on same circuit on dated 16-10-2023 i.e. at Sr. No. 1162.
1161	RQ145930	OCC_211	sldcps_sd		220 KV LUDHIANA(PG)- SAHNEWAL(PS) (PSTCL) CKT-1	PSTCL	D	Tree cutting and Jumper tightening TN 240 to 260	17/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	

1162	30146599	OCC_211	bbmb_sd	AC	220 KV	PSTCL	D	Half yearly mtc	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
					BHAKRA_R(BB)- MAHILPUR(PS) (PS) CKT-1			,	,,		3,00,000									
1163	RQ145925	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(PG)- KARTARPUR(PS) (PSTCL) CKT-1	PSTCL	D	Checking of Jumper,suspension clamp and Damper.Tree cutting and disc cleaning	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
1164	RQ146604	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BARNALA(BB)- LEHRAMOHABBA T(PS) (PSTCL) CKT- 1	PSTCL	D	Maintenance of transmission Line	16/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	17-Oct-23	18:00	
1165	RQ145414	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV LUDHIANA(PG)- DORAHA(PS) (PSTCL) CKT-1	PSTCL	D	For AMP of line Equipments and Protection Test	14/Oct/2023	09:00	14/Oct/2023	17:00	Kindly approve	PLANNED	Approved	14-Oct-23	09:00	14-Oct-23	17:00	
1166	RQ146595	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAMALPUR(BB)- DANDHARIKALAN I(PS) (PSTCL) CKT- 2	PSTCL	D	For yearly maintenance of Sub- Station Equipment	14/Oct/2023	08:00	14/Oct/2023	18:00		PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	
1167	RQ145413	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV LUDHIANA(PG)- LALTOKALAN(PS) (PSTCL) CKT-1	PSTCL	D	For AMP of line Equipments and Protection Test	13/Oct/2023	09:00	13/Oct/2023	17:00	Kindly approve	PLANNED	Approved	13-Oct-23	09:00	13-Oct-23	17:00	
1168	RQ146594	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAMALPUR(BB)- DANDHARIKALAN I(PS) (PSTCL) CKT- 1		D	For yearly maintenance of Sub- Station Equipment	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1169	RQ145533	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(PG)- KARTARPUR(PS) (PSTCL) CKT-2	PSTCL	D	AMP work	11/Oct/2023	10:00	11/Oct/2023	14:00	Kindly approve	PLANNED	Approved	11-Oct-23	10:00	11-Oct-23	14:00	
1170	RQ146579	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(BB)- BUTARI(PS) (PSTCL) CKT-1	PSTCL	D	For Early Maintenance of Line and Sub-Station Equipment	10/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
1171	RQ145936	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NALLAGARH(PG)- MOHALI(PS) (PS) CKT-2	PSTCL	D	Tightening of nut bolts of jumpers of T .no 176 to 183	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
1172	RQ146569	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(BB)- ALAWALPUR(PS) (PSTCL) CKT-1	PSTCL	D	For Early Maintenance of Line and Sub-Station Equipment	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
1173	RQ145935	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	PSTCL	D	Tightening of nut bolts of jumpers of T .no 176 to 183	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
1174	RQ145914	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAMALPUR(BB)- DANDHARIKALAN I(PS) (PSTCL) CKT- 2		D	Tree cutting and Jumper tightening TN 1 to 16	04/Oct/2023	08:00	04/Oct/2023	18:00		PLANNED	Approved					to be clubbed with BBMB shutdown on 14-10-2023 i.e. at Sr. No 1166.
1175	RQ145913	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAMALPUR(BB)- DANDHARIKALAN I(PS) (PSTCL) CKT- 1		D	Tree cutting and Jumper tightening TN 1 to 16	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved					to be clubbed with BBMB shutdown on 13-10-2023 i.e. at Sr. No 1168.

1176 F	RQ145609	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV WAGOORA(PG)- PAMPORE(PDD) (PG) CKT-1	POWER GRID	D	As 220KV Pampore- 1 was charged via temporary arrangement and bypassing of isolators. After retrofitting of old isolators, the new isolators will be taken into service. 220KV Pampore-1 S/D will be taken to remove all the temporary arrangements and connect via retrofitted isolators.	28/Oct/2023	09:00	28/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	28-Oct-23	09:00	28-Oct-23	18:00	
1177 F	RQ145405	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SALAL(NH) (PG) CKT-2	POWER GRID	D	Shifting of line from ERS to new tower at L-131	26/Oct/2023	09:00	28/Oct/2023	18:00	Kindly approve	PLANNED	Approved	26-Oct-23	09:00	28-Oct-23	18:00	Subject to NHPC consent.
		OCC_211		LINE CIRCUIT	220 KV FARIDABAD SEC- 58 (HV)- SAMAYPUR(BB) (PG) CKT-2	POWER GRID	D	Yearly Mtc.	26/Oct/2023		26/Oct/2023			PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
1179 F	RQ145531	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DASUYA(PS)- JALANDHAR(PG) (PG) CKT-2	POWER GRID	D	AMP work	24/Oct/2023	10:00	24/Oct/2023	14:00	Kindly approve	PLANNED	Approved	24-Oct-23	10:00	24-Oct-23	14:00	
1180 F	RQ145530	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DASUYA(PS)- JALANDHAR(PG) (PG) CKT-1	POWER GRID	D	AR NON-AUTO MODE REQUIRED DURING AMP OF CKT- 2	24/Oct/2023	10:00	24/Oct/2023	14:00	Kindly approve	PLANNED	Approved	24-Oct-23	10:00	24-Oct-23	14:00	
		OCC_211		LINE CIRCUIT	220 KV WAGOORA(PG)- PAMPORE(PDD) (PG) CKT-2	POWER GRID		As 220KV Pampore- 2 was charged via temporary arrangement and bypassing of isolators. After etrofitting of old isolators, the new isolators will be taken into service. 220KV Pampore- 2 S/D will be taken to remove all the temporary arrangements and connect via retrofitted isolators.	24/Oct/2023		24/Oct/2023		Under construction head, Kindly approve	PLANNED	Approved	24-Oct-23	09:00	24-Oct-23	18:00	
1182 F	RQ145404	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SALAL(NH) (PG) CKT-1	POWER GRID	D	Shifting of line from ERS to new tower at L-131	23/Oct/2023	09:00	25/Oct/2023	18:00	Kindly approve	PLANNED	Approved	23-Oct-23	09:00	25-Oct-23	18:00	Subject to NHPC consent.
		OCC_211		AC TRANSMISSION LINE CIRCUIT	220 KV HAMIRPUR(PG)- NEHRIAN(HP) (PG) CKT-1	POWER GRID	D	AR non auto mode required for hot line work	21/Oct/2023	09:00	30/Oct/2023	18:00	Non shutdown activity. Kindly approve	PLANNED	Approved	21-Oct-23	09:00	30-Oct-23	18:00	
1184 F	RQ145667	OCC_211	cpcc2_sd		220 KV HAMIRPUR(PG)- NEHRIAN(HP) (PG) CKT-2	POWER GRID	D	AR non auto mode required for hot line work	21/Oct/2023	09:00	30/Oct/2023	18:00	Non shutdown activity. Kindly approve	PLANNED	Approved	21-Oct-23	09:00	30-Oct-23	18:00	

1185	RQ145516	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENGANGA(N H)- WAGOORA(PG) (PG) CKT-2	POWER GRID	D	Repair of damaged conductor in span no 289-290	20/Oct/2023	09:00	20/Oct/2023	18:00	Kindly approve	PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SALAL(NH) (PG) CKT-4	POWER GRID	D	AMP Works and rectification of shutdown nature defects	20/Oct/2023		20/Oct/2023	18:00	Kindly approve	PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	18:00	Subject to NHPC consent.
		OCC_211		LINE CIRCUIT	220 KV HAMIRPUR(PG)- HAMIRPUR(HP) (PG) CKT-2	POWER GRID	D	AMP Works and rectification of shutdown nature defects	20/Oct/2023		20/Oct/2023		Kindly approve		Approved	20-Oct-23	09:00	20-Oct-23	18:00	
1188	RQ145515	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENGANGA(N H)- WAGOORA(PG) (PG) CKT-1	POWER GRID	D	Repair of damaged conductor in span no 289-290	19/Oct/2023	09:00	19/Oct/2023	18:00	Kindly approve	PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	18:00	
1189	RQ145676	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HAMIRPUR(PG)- HAMIRPUR(HP) (PG) CKT-1	POWER GRID	D	AMP Works and rectification of shutdown nature defects	19/Oct/2023	09:00	19/Oct/2023	18:00	Kindly approve	PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	PAMPORE(PDD) (PG) CKT-1	POWER GRID	D	Isolator retrofitting of 220KV Pampore-1 Bay (20789C & 20689L ISOLATORS). The S/D is taken to Bypass the 20789L isolator, the conductor from CT to 20789L isolator shall be removed. For 20789C, Temporary arrangement will be made from CT to TBC connection so that 20789C isolator droppers from TBC shall be removed and WAGOORA-pampore-1 may be charged via 220kV TBC afterwards.	19/Oct/2023		19/Oct/2023		Under construction head, Kindly approve	PLANNED	Approved	19-Oct-23	09:00	19-Oct-23	18:00	
1191	RQ145731	OCC_211	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)- UNCHAHAR(NT) (PG) CKT-2	POWER GRID	С	Annual bay equipment maintenance and testing	19/Oct/2023	08:00	20/Oct/2023	18:00		PLANNED	Approved					May be clubbed with S. no. 1205
			ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	POWER GRID	С	bay equipment testing	19/Oct/2023		20/Oct/2023			PLANNED	Approved					May be clubbed with S. no. 1204
1193	RQ145558	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JESSORE(HP)- PONG(BB) (PG) CKT-1	POWER GRID	С	Repalcement of CT, Isolators & E/S, Control & Relay Panel under Add Cap_Petition No. 712/TT/2020 at Pong end.	18/Oct/2023	10:00	31/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	18-Oct-23	10:00	31-Oct-23	18:00	may be given subject to HP/BBMB consent

1194	RQ1455	561 O	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SARNA(PS)- DASUYA(PS) (PG) CKT-2	POWER GRID	С	Repalcement of CT,CVT, Isolators & E/S, Control & Relay Panel under Add Cap_Petition No. 695/TT/2020 at both ends.	18/Oct/2023	09:00	31/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	18-Oct-23	09:00	31-Oct-23	18:00	May be given subject to Punjab consent/B-7 and CEA clearance required before charging
1195	RQ1466	695 O	CC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AURAIYA(NT)- SIKANDRA(UP) (PG) CKT-2	POWER GRID	D	Rectification of S/D nature defects	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
1196	RQ1454	475 O	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SARNA(PS) (PG) CKT-2	POWER GRID	С	FOR AD-CAP WORKS APPROVED UNDER CERC PETITION NO- 695/TT/2020 DATED 03.01.2022 FOR TARRIF BLOCK 2019- 2024 AT SARNA	17/Oct/2023	10:00	31/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	17-Oct-23	10:00	31-Oct-23	18:00	May be given subject to Jammu consent/B-7 and CEA clearance required before charging/One shutdown from sarna end at a time.
1197	RQ1454	408 O	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SARNA(PS) (PG) CKT-2	POWER GRID	D	AMP Works and rectification of shutdown nature defects	17/Oct/2023	09:00	17/Oct/2023	18:00	Kindly approve	PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	
1198	RQ1455	517 0	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV WAGOORA(PG)- PAMPORE(PDD) (PG) CKT-1	POWER GRID	D	Jumper tightening of vulnerable crossing towers	17/Oct/2023	09:00	17/Oct/2023	18:00	Kindly approve	PLANNED	Approved	17-Oct-23	09:00	17-Oct-23	18:00	
1199	RQ1466	694 O	CC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AURAIYA(NT)- SIKANDRA(UP) (PG) CKT-1	POWER GRID	D	Rectification of S/D nature defects	17/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
1200	RQ1456	668 O	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HAMIRPUR(PG)- HAMIRPUR(HP) (PG) CKT-1	POWER GRID	D	AR non auto mode required for hot line work	16/Oct/2023	09:00	20/Oct/2023	18:00	Non shutdown activity. Kindly approve		Approved	16-Oct-23	09:00	20-Oct-23	18:00	
1201	RQ1456	669 O	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HAMIRPUR(PG)- HAMIRPUR(HP) (PG) CKT-2	POWER GRID	D	AR non auto mode required for hot line work	16/Oct/2023	09:00	20/Oct/2023	18:00	Non shutdown activity. Kindly approve	PLANNED	Approved	16-Oct-23	09:00	20-Oct-23	18:00	
1202	RQ1454	407 O	CC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SARNA(PS) (PG) CKT-1	POWER GRID	D	AMP Works and rectification of shutdown nature defects	16/Oct/2023	09:00	16/Oct/2023	18:00	Kindly approve	PLANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	

1203	RQ145608	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV WAGOORA(PG)- PAMPORE(PDD) (PG) CKT-2	POWER GRID	D	Isolator retrofitting of 220KV Pampore-2 Bay (20689C & 20689L ISOLATORS). The S/D is taken to Bypass the 20689L isolator, the conductor from CT to 20689L isolator shall be removed. For 20689C, Temporary arrangement will be made from CT to TBC connection so that 20689C isolator droppers from TBC shall be removed and WAGOORA-pampore-2 may be charged via 220kV TBC afterwards.	16/Oct/2023	09:00	16/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	16-Oct-23	09:00	16-Oct-23	18:00	
1204	RQ145703	OCC_211	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)- UNCHAHAR(NT) (PG) CKT-1	POWER GRID	С	Annual bay equipment maintenance and testing	16/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	17-Oct-23	18:00	May be given subject to real time grid conditions/One circuit shutdwon at a time/PG consent required.
1205	RQ145460	OCC_211	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)- UNCHAHAR(NT) (PG) CKT-2	POWER GRID	С	bay equipment testing	16/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	17-Oct-23	18:00	May be given subject to real time grid conditions/One circuit shutdwon at a time/PG consent required.
1206	RQ146507	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ALLAHABAD(PG)- JHUSI(UP) (PG) CKT-1	POWER GRID	D	AMP work	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1207	RQ146501	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAULJIVI (PG)- DHAULIGANGA(N H) (PG) CKT-1	POWER GRID	D	AMP work	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1208	RQ146518	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	POWER GRID	D	AMP work	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1209	RQ146362	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BASSI(PG)- DAUSA(RS) (PG) CKT-2	POWER GRID	D	Half Yearly maintenance work	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1210	RQ146359	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV INDIRA NAGAR(RS)- HEERAPURA(RS) (PG) CKT-1	POWER GRID	D	Quartererly maintenance of Bay Equipment	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	15:00	13-Oct-23	23:00	May be given from 1500 Hrs
1211	RQ146517	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)- UNCHAHAR(NT) (PG) CKT-3	POWER GRID	D	AMP work	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
1212	RQ145473	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HIRANAGAR(PDD) SARNA(PS) (PG) CKT-1	POWER GRID	С	FOR AD-CAP WORKS APPROVED UNDER CERC PETITION NO- 695/TT/2020 DATED 03.01.2022 FOR TARRIF BLOCK 2019- 2024 AT SARNA	11/Oct/2023	10:00	25/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	11-Oct-23	10:00	25-Oct-23	18:00	May be given subject to Jammu consent/B-7 and CEA clearance required before charging/One shutdown from sarna end at a time.

1213	RQ146516	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)- UNCHAHAR(NT) (PG) CKT-2	POWER GRID	D	AMP work	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
1214	RQ146363	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BASSI(PG)- INDIRA NAGAR(RS) (PG) CKT-1	POWER GRID	D	Quartererly maintenance of Bay Equipment	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	15:00	11-Oct-23	23:00	May be given from 1500 Hrs
	RQ145409	_	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- UDHAMPUR(PDD ) (PG) CKT-2	POWER GRID	D	AMP work of Line Equipment at Udhampur and Kishenpur end.	10/Oct/2023		10/Oct/2023		Kindly approve		Approved	10-Oct-23	09:30	10-Oct-23	17:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	220 KV KANPUR(PG)- UNCHAHAR(NT) (PG) CKT-1	POWER GRID	D	AMP work	10/Oct/2023		10/Oct/2023			PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
1217	RQ146482	OCC_211	sldcjk_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SALAL(NH)- JAMMU(PDD) (PG) CKT-2	POWER GRID	D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc	08/Oct/2023	07:00	08/Oct/2023	12:00	40 -60 MW load may be shifted and fed from the sister 220 KV grids subject to realtime loading and availability of power from these grids. Rest 260-280 MW load shall be affected	PLANNED	Approved	08-Oct-23	07:00	08-Oct-23	12:00	Subject to NHPC/POWERGRID consent.
1218	RQ146481	OCC_211	sldcjk_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SALAL(NH)- JAMMU(PDD) (PG) CKT-1	POWER GRID	D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc	08/Oct/2023	07:00	08/Oct/2023	12:00	40 -60 MW load may be shifted and fed from the sister 220 KV grids subject to realtime loading and availability of power from these grids. Rest 260-280 MW load shall be affected	PLANNED	Approved	08-Oct-23	07:00	08-Oct-23	12:00	Subject to NHPC/POWERGRID consent.
1219	RQ146361	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BASSI(PG)- DAUSA(RS) (PG) CKT-1	POWER GRID	D	Half Yearly maintenance work	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	15:00	05-Oct-23	23:00	May be given from 1500 Hrs
1220	RQ145391	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ALUSTENG-DRASS (PG) CKT-1	POWER GRID	D	Jumper Tightening works and liquidation of shut down nature defects.	04/Oct/2023	09:00	05/Oct/2023	17:00	Kindly approve	PLANNED	Approved	04-Oct-23	09:00	05-Oct-23	17:00	
1221	RQ145474	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SARNA(PS) (PG) CKT-1	POWER GRID	C	FOR AD-CAP WORKS APPROVED UNDER CERC PETITION NO- 695/TT/2020 DATED 03.01.2022 FOR TARRIF BLOCK 2019- 2024 AT SARNA	03/Oct/2023	10:00	16/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	03-Oct-23	10:00	16-Oct-23	18:00	May be given subject to Jammu consent/B-7 and CEA clearance required before charging/One shutdown from sarna end at a time.

1222	RQ14555	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAIRASIUL(NH)- PONG(BB) (PG) CKT-1	POWER GRID	С	Repalcement of CT, Isolators & E/S, Control & Relay Panel under Add Cap_Petition No. 712/TT/2020 at Pong end.	02/Oct/2023	10:00	16/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	02-Oct-23	10:00	16-Oct-23	18:00	may be given subject to JK/ladakh/BBMB and NHPC consent
		OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SARNA(PS)- DASUYA(PS) (PG) CKT-1	POWER GRID	С	Repalcement of CT,CVT, Isolators & E/S, Control & Relay Panel under Add Cap_Petition No. 695/TT/2020 at both ends.	02/Oct/2023	09:00	16/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	02-Oct-23	09:00	16-Oct-23	18:00	May be given subject to Punjab consent/B-7 and CEA clearance required before charging
1224	RQ14635!	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AGRA(PG) SIKANDRA(UP) (PG) CKT-1	- POWER GRID,RR VPNL	D	maintenance of line	27/Oct/2023	08:00	27/Oct/2023	18:00		PLANNED	Approved	27-Oct-23	15:00	27-Oct-23	23:00	May be given from 1500 Hrs
1225	RQ14635	3 OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AGRA(PG) BHARATPUR(RS) (PG) CKT-1	- POWER GRID,RR VPNL	D	maintenance of line and bay at 220KV GSS RVPN, Bharatpur	26/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	26-Oct-23	15:00	26-Oct-23	23:00	May be given from 1500 Hrs
		OCC_211	_	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR- PONG (BB) CKT-2		D	For yearly maintenance of Line and Sub-Station Equipment	26/Oct/2023		26/Oct/2023			PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
1227	RQ146603	3 OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHATINDA (PS)- LEHRAMOHABBA T(PS) (BBMB) CKT	BBMB	D	Maintenance of transmission Line	25/Oct/2023	08:00	25/Oct/2023	18:00		PLANNED	Approved	25-Oct-23	08:00	25-Oct-23	18:00	
1228	RQ14660:	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHAKRA_R- JAMALPUR (BB) CKT-1	ВВМВ	D	Maintenance of transmission Line & Anuual mtc at Bhakra end	25/Oct/2023	08:00	27/Oct/2023	18:00		PLANNED	Approved	25-Oct-23	08:00	27-Oct-23	18:00	
1229	RQ146548	3 OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT- KURUKSHETRA (BB) CKT-1	ВВМВ	D	Yearly mtc.	23/Oct/2023	08:00	23/Oct/2023	18:00		PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
1230	RQ145580	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI(BB)- KHETRI(RS) (BB) CKT-1	ВВМВ	D	Stringing of 765 kV D/C Khetri-Narela TL	22/Oct/2023	07:00	25/Oct/2023	19:00		PLANNED	Approved	22-Oct-23	07:00	25-Oct-23	19:00	Subject to BBMB & Rajasthan consent.
1231	RQ145756	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(BB)- CHIRAWA(RS) (BB) CKT-1	ВВМВ	D	For bay Maintenance & For tree trimming under the line	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	15:00	19-Oct-23	23:00	May be given from 1500 Hrs
1232	RQ146582	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	ВВМВ	D	For Early Maintenance of Line and Sub-Station Equipment	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	18:00	
1233	RQ14654:	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	ВВМВ	D	Yearly mtc.	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
1234	RQ14658:	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(BB)- JAMSHER(PS) (BB) CKT-2	ВВМВ	D	For Early Maintenance of Line and Sub-Station Equipment	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	

1235	RQ145581	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI(BB)- KHETRI(RS) (BB) CKT-2	ВВМВ	D	Stringing of 765 kV D/C Khetri-Narela TL	18/Oct/2023	07:00	21/Oct/2023	19:00	PLANNED	Approved	18-Oct-23	07:00	21-Oct-23	19:00	Subject to BBMB & Rajasthan consent.
1236	RQ146542	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT(BB)- NARELA(DV) (BBMB) CKT-2	ВВМВ	D	Yearly Mtc.	17/Oct/2023	08:00	17/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
1237	RQ146613	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JAGADHARI- KURUKSHETRA (BB) CKT-1	BBMB	D	For Pre Winter/Yearly Maintenance of line and allied Sub- Station Equipment	17/Oct/2023	08:00	19/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	08:00	19-Oct-23	18:00	
1238	RQ146538	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL- JAMALPUR (BB) CKT-2	ввмв	D	For Maintenance of Sub-Station Equipment & yearly mtc. at Ganguwal end.	16/Oct/2023	08:00	16/Oct/2023	18:00	PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
1239	RQ146583	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR- JAMALPUR (BB) CKT-2	ВВМВ	D	For Early Maintenance of Line and Sub-Station Equipment	14/Oct/2023	08:00	14/Oct/2023	18:00	PLANNED	Approved	14-Oct-23	08:00	14-Oct-23	18:00	
1240	RQ146544	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT(BB)- NARELA(DV) (BBMB) CKT-3	ввмв	D	Yearly mtc.	13/Oct/2023	08:00	13/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1241	RQ146556	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	ВВМВ	D	Quarterly mtc	13/Oct/2023	08:00	13/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1242	RQ146570	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	ввмв	D	For Early Maintenance of Line and Sub-Station Equipment	13/Oct/2023	08:00	13/Oct/2023	18:00	PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1243	RQ146554	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI		D	Yearly mtc.	12/Oct/2023	08:00	12/Oct/2023	18:00	PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
1244	RQ146602	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHAKRA_R- JAMALPUR (BB) CKT-2	ввмв	D	Annual Maintenance	12/Oct/2023	08:00	13/Oct/2023	18:00	PLANNED	Approved	12-Oct-23	08:00	13-Oct-23	18:00	
1245	RQ145758	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI	ВВМВ	D	For Tree trimming & bay maintenance work	12/Oct/2023	08:00	12/Oct/2023	18:00	PLANNED	Approved					May be clubbed with s. No. 1235
1246	RQ146537	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL- JAMALPUR (BB) CKT-1	ввмв	D	For Maintenance of Sub-Station Equipment & yearly mtc. at Ganguwal end.	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
1247	RQ146580	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(BB)- JAMSHER(PS) (BB) CKT-1	ввмв	D	For Early Maintenance of Line and Sub-Station Equipment	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
1248	RQ146535	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL(BB)- GOBINDGARH(PS) (BB) CKT-2	ВВМВ	D	Yearly mtc.	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	

1249	RQ146589	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DELHI RR(BB)- NARELA(DV) (BBMB) CKT-1	ВВМВ	D	Half yearly mtc	10/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	11-Oct-23	18:00	
1250	RQ145757	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI	ВВМВ	D	For Tree trimming & bay maintenance work	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved					May be clubbed with s. No. 1230
1251	RQ146559	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR- SANGRUR (BB) CKT-2	ввмв	D	For Early Maintenance of Line and Sub-Station Equipment	10/Oct/2023	08:00	10/Oct/2023	18:00	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
1252	RQ146553	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI(BB)- KHETRI(RS) (BB) CKT-2	ВВМВ	D	Yearly mtc.	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved					May be clubbed with s. No. 1235
1253	RQ146558	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR- SANGRUR (BB) CKT-1	ввмв	D	Quarterly mtc	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
1254	RQ146536	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV GANGUWAL- JAGADHARI (BB) CKT-1	ВВМВ	D	For Pre Winter/Yearly Maintenance of line and allied Sub- Station Equipment	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
	RQ145929		sldcps_sd		(BBMB) CKT-1		D	Patrolling of line alongwith Tree trimming and Jumper tightening			09/Oct/2023		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
1256	RQ146552	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI(BB)- KHETRI(RS) (BB) CKT-1	ВВМВ	D	Yearly mtc.	08/Oct/2023	08:00	08/Oct/2023	18:00	PLANNED	Approved					May be clubbed with s. No. 1230
1257	RQ146547	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT- CHARKHI DADRI (BB) CKT-1	ввмв	D	Yearly mtc.	06/Oct/2023	08:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	18:00	
1258	RQ146540	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHAKRA_R- GANGUWAL (BB) CKT-2	ВВМВ	D	Yearly mtc.	05/Oct/2023	08:00	06/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	08:00	06-Oct-23	18:00	
1259	RQ146533	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI- SAMAYPUR (BB) CKT-1	ВВМВ	D	Yearly Mtc.	05/Oct/2023	08:00	05/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
1260	RQ146564	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWANI- HISSAR (BB) CKT- 2	ВВМВ	D	Quarterly mtc	05/Oct/2023	08:00	05/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	PONG (BB) CKT-1	ввмв	D	For Early Maintenance of Line and Sub-Station Equipment	05/Oct/2023		05/Oct/2023		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
1262	RQ146532	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BALLABHGARH- SAMAYPUR (BB) CKT-1	ввмв	D	Yearly mtc.	04/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	
1263	RQ146551	OCC_211	bbmb_sd		220 KV BALLABHGARH- CHARKHI DADRI (BB) CKT-1	ВВМВ	D	Yearly Mtc.	04/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	18:00	

1264	RQ146539	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHAKRA_R- GANGUWAL (BB) CKT-1	ВВМВ	D	Yearly Mtc.	03/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	08:00	04-Oct-23	18:00	
1265	RQ146521	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DEHAR- GANGUWAL (BB) CKT-1	ВВМВ		Erection of towers, String & sagging of line between T. no.75-77 depsit work of RVNL	01/Oct/2023	08:00	15/Oct/2023	18:00	PLANNED	Approved	01-Oct-23	08:00	15-Oct-23	18:00	Subject to real time Grid conditions/CEA safety clerance and B-7 annex required.
1266	RQ146522	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DEHAR- GANGUWAL (BB) CKT-2	ВВМВ		Erection of towers, String & sagging of line between T. no.75-77 depsit work of RVNL	01/Oct/2023	08:00	15/Oct/2023	18:00	PLANNED	Approved	01-Oct-23	08:00	15-Oct-23	18:00	Subject to real time Grid conditions/CEA safety clerance and B-7 annex required.
1267	RQ146524	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FARIDABAD SEC- 58 (HV)- SAMAYPUR(BB) (HVPNL) CKT-1	POWER GRID,HV PNL	D	Yearly mtc.	23/Oct/2023	08:00	23/Oct/2023	18:00	PLANNED	Approved	23-Oct-23	08:00	23-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	220 KV MEERUT(PG)- GAJRAULA(UP) (UP) CKT-1		D	For attending Hotspot & Line Equipment work at Meerut	21/Oct/2023		21/Oct/2023		PLANNED	Approved	21-Oct-23	08:00	21-Oct-23	18:00	
1269	RQ146014	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MEERUT(PG)- SHATABDINAGAR (UP) (PG) CKT-1			For attending Hotspot & Line Equipment work at Meerut	20/Oct/2023	08:00	20/Oct/2023	18:00	PLANNED	Approved	20-Oct-23	08:00	20-Oct-23	18:00	
1270	RQ146012	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MEERUT(PG)- MODIPURAM(UP) (PG) CKT-2			For attending Hotspot & Line Equipment work at Meerut	19/Oct/2023	08:00	19/Oct/2023	18:00	PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	18:00	
1271	RQ146015	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV			For attending Hotspot & Line Equipment work at Meerut	18/Oct/2023	08:00	18/Oct/2023	18:00	PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
1272	RQ146013	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV MEERUT(PG)- NEHTAUR(UP) (UP) CKT-1			For attending Hotspot & Line Equipment work at Meerut	17/Oct/2023	08:00	17/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
1273	RQ146008	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HEERAPURA(RS)- I.G.NAGAR(RS) (PG) CKT-1			LBB RETROFITMENT WORK OF IGNAGAR BAY AT HEERAPURA END	09/Oct/2023	10:00	10/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	10:00	10-Oct-23	18:00	May be given subject to Rajasthan consent.
		OCC_211		AC TRANSMISSION LINE CIRCUIT	220 KV RATANGARH(RS)- SIKAR(PG) (PG) CKT-1		D	Line Bay AMP work	09/Oct/2023	09:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	09:00	09-Oct-23	18:00	
		OCC_211		AC TRANSMISSION LINE CIRCUIT	MANSAROVAR(RS ) (PG) CKT-1			LBB RETROFITMENT WORK OF MANSAROVAR BAY AT HEERAPURA END	05/Oct/2023		06/Oct/2023		PLANNED	Approved	05-Oct-23	10:00	06-Oct-23	18:00	May be given subject to Rajasthan consent.
1276	RQ145990	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ABCRENEW_RJ01 _SL_BHD2_PG- BHADLA_2 (PG) (ABC RJ01) CKT-1		D	NEW BAY EXTENSION AND AMP	02/Oct/2023	17:00	02/Oct/2023	23:59	PLANNED	Approved	02-Oct-23	19:00	02-Oct-23	23:59	May be given from 1900 Hrs

1277 F	Q145998	OCC_211	cpcc1_sd	AC TRANSMISSION	220 KV BHADLA_2 (PG)-		D	NEW BAY EXTENSION AND AMP	01/Oct/2023	17:00	01/Oct/2023	23:59		PLANNED	Approved	01-Oct-23	19:00	01-Oct-23	23:59	May be given from 1900 Hrs
				LINE CIRCUIT	AVAADA SUNRAYS_SL_BH															
					D2_PG (AVAADA_SUNRA YS)															
					(AVAADA_SUNRA YS) CKT-1															
1278 F	Q146000	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV		С	FOR NCRTC DIVERSION WORK	01/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	01-Oct-23	08:00	12-Oct-23	18:00	May be given subject to haryana consent/B-7 and CEA clearance required before charging
1279 F	Q146531	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	HVPNL	D	Yearly Mtc	19/Oct/2023	08:00	19/Oct/2023	18:00		PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	18:00	
1280 F	Q146611	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWANI(HV)- BHIWANI(BB) (HVPNL) CKT-2	HVPNL	D	Yearly mtc.	17/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
1281 F	Q146530	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV	HVPNL	D	Yearly Mtc	16/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	18:00	
1282 F	Q146550	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHARKHI DADRI(BB)- LULAHIR(HV) (HVPNL) CKT-1	HVPNL	D	Yearly mtc.	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1283 F	Q146557	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(BB)- HISSAR IA(HV) (HVPNL) CKT-1	HVPNL	D	Quarterly mtc	13/Oct/2023	08:00	13/Oct/2023	18:00		PLANNED	Approved	13-Oct-23	08:00	13-Oct-23	18:00	
1284 F	Q146528	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAMAYPUR(BB)- BADSHAHPUR(HV ) (HVPNL) CKT-1	HVPNL	D	Yearly Mtc	12/Oct/2023	08:00	12/Oct/2023	18:00		PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
1285 F	Q146734	OCC_211	indigrid_sd		220 KV PRITHALA (GPTL)-RANGALA RAJPUR (HV) (HVPNL) CKT-1	HVPNL	D	AMP works of Bay	11/Oct/2023	08:00	11/Oct/2023	20:00	The line will be under shutdown because of planned maintenance in associated Main Bay 205	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	20:00	
1286 F	Q146545	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANIPAT(BB)- CHAJPUR(HV) (HVPNL) CKT-1	HVPNL	D	Yearly Mtc.	10/Oct/2023	08:00	10/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	18:00	
1287 F	Q146529	OCC_211	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAMAYPUR(BB)- BADSHAHPUR(HV ) (HVPNL) CKT-2	HVPNL	D	Yearly Mtc	09/Oct/2023	08:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	18:00	
1288 F	Q145485	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHABAD(PG)- HUKMAWALI (HV) (HVPNL) CKT- 2	HVPNL	D	For isolator Maintenance and alignment	06/Oct/2023	10:00	06/Oct/2023	14:00	Kindly approve	PLANNED	Approved	06-Oct-23	10:00	06-Oct-23	14:00	

1289	RO146527	OCC_211	hhmh sd	AC	220 KV	HVPNL	D	Yearly Mtc	06/Oct/2023	08:00	06/Oct/2023	18:00	PLANNED	Approved	06-Oct-23	08:00	06-Oct-23	3 18:0	n
1203	NQ140327	000_211	551115_34		SAMAYPUR(BB)-	IIIVIIIL		rearry wite	00/001/2023	00.00	00/000/2023	10.00	LAMMED	Арргочси	00 000 23	00.00	00 000 23	10.0	
				LINE CIRCUIT	PALLI(HV)														
					(HVPNL) CKT-2														
1290	RQ146546	OCC_211	bbmb_sd	AC	220 KV PANIPAT(BB)-	HVPNL	D	Yearly mtc.	04/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	3 18:0	0
				LINE CIRCUIT	CHAJPUR(HV)														
				LINE CINCOTT	(HVPNL) CKT-2														
1291	RQ146526	OCC_211	bbmb_sd	AC	220 KV	HVPNL	D	Yearly Mtc	03/Oct/2023	08:00	03/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	3 18:0	)
		_	_	TRANSMISSION	SAMAYPUR(BB)-														
				LINE CIRCUIT	PALLI(HV)														
					(HVPNL) CKT-1														
1292	RQ145704	OCC_211	ntpcos_sd		220 KV	UPPTCL	С	Annual bay	12/Oct/2023	08:00	13/Oct/2023	18:00	PLANNED	Approved	12-Oct-23	08:00	13-Oct-23	3 18:0	
				LINE CIRCUIT	UNCHAHAR(NT)- FATEHPUR(UP)			equipment maintenance and											conditions and PG consent/ May be allowed if taken on
				LINE CIRCUIT	(UP) CKT-1			testing											daily basis as per UP.
1293	RQ145352	OCC_211	stuup sd	AC	220 KV	UPPTCL	D	* Shutdown for	09/Oct/2023	09:00	12/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	09:00	12-Oct-23	3 18:0	
		_		TRANSMISSION	SARSAWAN(UP)-			Lopping Chopping in											
				LINE CIRCUIT	KHODRI(UK) (UP)			line corridor &											
					CKT-1			Jumper tighting X of											
								line 220 kv SARSAWA											
1294	RO145442	OCC_211	stuun sd	AC	220 KV	UPPTCL	D	* For maintenance of	09/Oct/2023	08:00	09/Oct/2023	17:00	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	3 17:0	1
1234	110143442	000_211	stuup_su		PANTNAGAR(UK)-	OTTICE		line	03/000/2023	00.00	03/001/2023	17.00	LAMINED	Аррготси	05 000 25	00.00	05 000 25	17.0	
				LINE CIRCUIT	BAREILLY(UP)														
					(UP) CKT-1														
1295	RQ145937	OCC_211	cpcc3_sd	AC	220 KV	UPPTCL	D	AMP work	05/Oct/2023	08:00	05/Oct/2023	18:00	PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	3 18:0	)
				TRANSMISSION	MAINPURI(PG)-														
				LINE CIRCUIT	ETAH(UP) (UP) CKT-1														
1296	RO146492	OCC_211	cncc3 sd	AC	220 KV	UPPTCL	D	AMP work	04/Oct/2023	08:00	04/Oct/2023	18:00	PLANNED	Approved	04-Oct-23	08:00	04-Oct-23	3 18:0	)
1230		000_211	cpccs_sa		FATEHPUR(PG)-	011102		THE HOLK	0.,000,2020	00.00	0 1, 000, 2023	10.00	· EE	прриотеа	0.00025	00.00	0.00025	10.0	
				LINE CIRCUIT	SARH(UP) (UP)														
					CKT-1														
1297	RQ145353	OCC_211	stuup_sd	AC	220 KV	UPPTCL	D	* Shutdown for	03/Oct/2023	09:00	06/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	09:00	06-Oct-23	3 18:0	0
				TRANSMISSION LINE CIRCUIT	,			Lopping Chopping in											
				LINE CIRCUIT	)-KHODRI(UK) (UP) CKT-1			line corridor &Jumper tighting X											
					(01) 0111 1			of line 220 kv											
								Saharanpur Khodri											
1298	RQ146493	OCC_211	cpcc3_sd	AC	220 KV	UPPTCL	D	AMP work	03/Oct/2023	08:00	03/Oct/2023	18:00	PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	3 18:0	)
					FATEHPUR(PG)-														
				LINE CIRCUIT	FATEHPUR(UP)														
1299	RO146506	OCC_211	cncc3 sd	AC	(UP) CKT-2 220 KV	RAILWA	D	AMP work	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	3 18:0	)
1233	110140500	000_211	cpccs_su	TRANSMISSION	ALLAHABAD(PG)-			AIVII WOIK	11,000,2023	00.00	11/00/2023	10.00	LAMINED	Аррготси	11 000 25	00.00	11 000 25	10.0	
				LINE CIRCUIT	NAINI(RLY)														
					(RAILWAYS) CKT-														
L					2														_
1300	RQ146505	OCC_211	cpcc3_sd	AC TRANSPAISSION	220 KV	RAILWA	D	AMP work	09/Oct/2023	08:00	09/Oct/2023	18:00	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	3 18:0	)
				LINE CIRCUIT	ALLAHABAD(PG)- NAINI(RLY)	Y5													
				LINE CINCOTT	(RAILWAYS) CKT-														
					1														
1301	RQ146555	OCC_211	bbmb_sd	AC	220 KV CHARKHI	ввмв,н	D	Yearly mtc.	11/Oct/2023	08:00	11/Oct/2023	18:00	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	3 18:0	)
				TRANSMISSION		VPNL													
				LINE CIRCUIT	MAHINDERGARH(														
					HV) (HVPNL) CKT-														
					1														
				L	ı	1		ı		l	1	L		l					

1302	RQ146483	OCC_211	sldcjk_sd		220 KV CHOWADHI (JK)- GLADNI(PDD) (PDD JK) CKT-1	POWER GRID,PD D JK	D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc	08/Oct/2023	07:00	08/Oct/2023	12:00	40-60 MW load may be shifted and fed from the sister 220 KV grids subject to realtime loading and availability of power from these grids. Rest 260-280 MW load shall be affected	PLANNED	Approved	08-Oct-23	07:00	08-Oct-23	12:00	Subject to NHPC/POWERGRID consent.
1303	RQ145491	OCC_211	cpcc2_sd		220 KV CHAMBA(PG)- KARIAN(HP) (HPSEB) CKT-1	HPSEB	С	For connecting existing bus-1 & Bus- 2 with newly constructed bay (bay no. 207 for Chamba- HPPTCL Majra Line)	01/Oct/2023	09:00	16/Oct/2023	19:00	Under construction head, Kindly approve	PLANNED	Approved	01-Oct-23	09:00	16-Oct-23	19:00	May be given subject to HP consent/B-7 and CEA clearance required before charging
1304	RQ145494	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PHOZAL(HP)- NALLAGARH(PG) (ADHPL) CKT-1	ADHPL	D	Shutdown required for re-installation of Aviation Globules	01/Oct/2023	07:00	15/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Rejected					consent denied by AD Hydro
1305	RQ145495	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AD HYDRO(AD)- NALLAGARH(PG) (ADHPL) CKT-1	ADHPL	D	Shutdown required for re-installation of Aviation Globules	01/Oct/2023	07:00	15/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Rejected					consent denied by AD Hydro
1306	RQ145492	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PHOZAL(HP)- NALLAGARH(PG) (ADHPL) CKT-1	ADHPL	D	AR Non auto mode is required for OPGW works	01/Oct/2023	07:00	31/Oct/2023	18:00	Non shutdown activity. Kindly approve	PLANNED	Approved	01-Oct-23	07:00	31-Oct-23	18:00	
		OCC_211	. –	AC TRANSMISSION LINE CIRCUIT	NALLAGARH(PG) (ADHPL) CKT-1	ADHPL		AR Non auto mode is required for OPGW works	01/Oct/2023		31/Oct/2023		Non shutdown activity. Kindly approve		Approved	01-Oct-23	07:00	31-Oct-23	18:00	
1308	RQ145496	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT-1	ADHPL	D	AR Non auto mode is required for OPGW works	01/Oct/2023	07:00	31/Oct/2023	18:00	Non shutdown activity. Kindly approve	PLANNED	Approved	01-Oct-23	07:00	31-Oct-23	18:00	

1309	RQ146807	OCC_211	cpcc1 sd	AC	220 KV	ASEJOL	D	Overhead crossing	01/Oct/2023	07:00	05/Oct/2023	19:00	Keeping in	PLANNED	Approved	01-Oct-23	07:00	05-Oct-23	19:00	
	,			TRANSMISSION	ASEJOL_HB			i.e. Stringing work of	, ,				View of safety							
				LINE CIRCUIT	FTGH2 -			400kV D/C Ramgarh					aspects and							
					ASEJOL_WIND FTGH2 (ASEJOL)			II (Fatehgarh-III) – Fatehgarh II					difficulty in power line							
					CKT-1			transmission Line					crossing work							
													in night hours							
													& in night							
													hours theft of							
													conductor may							
													occurred as theft issue is							
													more in							
													Jaisalmer area							
													therefore to							
													avoid any							
													damage to M/S SBE							
													Renewable							
													Ten Pvt. Ltd.							
					1								line, shutdown							
													is required in							
													day hours only.							
													Shutdown may be availed in							
													Sept-23.							
1310	RQ146667	OCC_211	bbmb_sd	BUS	220KV BUS 1 AT PANIPAT(BB)	ввмв	D	Yearly mtc.	31/Oct/2023	08:00	31/Oct/2023	18:00		PLANNED	Approved	31-Oct-23	08:00	31-Oct-23	18:00	
1311	RQ145568	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT	BBMB	D	Connecting of Bus	29/Oct/2023	10:00	29/Oct/2023	18:00	Under	PLANNED	Approved	29-Oct-23	10:00	29-Oct-23	18:00	
					PONG(BB)			Isolator connection					construction							
								after completion of ADD CAP works					head, Kindly approve							
1312	RQ145569	OCC 211	cpcc2_sd	BUS	220KV BUS 2 AT	ввмв	D	Connecting of Bus	28/Oct/2023	10:00	28/Oct/2023	18:00	Under	PLANNED	Approved	28-Oct-23	10:00	28-Oct-23	18:00	
					PONG(BB)			Isolator connection	,,		,,		construction							
								after completion of					head, Kindly							
4242	20446660	000 244	h handa and	DUIC	220/0/ 8//6 2 47	00140		ADD CAP works	27/0 - 1/2022	00.00	27/0 - /2022	10.00	approve	DI ANINED		27.0.1.22	00.00	27.0.1.22	10.00	
		OCC_211		BUS	220KV BUS 2 AT PANIPAT(BB)		D	Yearly mtc. at RHS section of Bus 2	27/Oct/2023		27/Oct/2023			PLANNED	Approved	27-Oct-23	08:00	27-Oct-23	18:00	
1314	RQ146665	OCC_211	bbmb_sd	BUS	220KV BUS 2 AT DELHI RR(BB)	ввмв	D	Half Yearly Mtc	26/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
					.,,							<u> </u>		<u> </u>						
1315	RQ146668	OCC_211	bbmb_sd	BUS	220KV BUS 2 AT PANIPAT(BB)	BBMB	D	Yearly Mtc. at LHS section of Bus 2	26/Oct/2023	08:00	26/Oct/2023	18:00		PLANNED	Approved	26-Oct-23	08:00	26-Oct-23	18:00	
1316	RQ145565	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT	BBMB	D	Removing of Bus	20/Oct/2023	10:00	20/Oct/2023	18:00	Under	PLANNED	Approved	20-Oct-23	10:00	20-Oct-23	18:00	
					PONG(BB)			Isolator connection					construction							
								for ADD CAP works					head, Kindly							
1317	30145564	OCC 211	cpcc2_sd	BUS	220KV BUS 1 AT	BBMB	D	Removing of Bus	19/Oct/2023	10:00	19/Oct/2023	18:00	approve Under	PLANNED	Approved	19-Oct-23	10:00	19-Oct-23	18:00	
	,550 T				PONG(BB)		-	Isolator connection	,, 2020		,,,		construction							
								for ADD CAP works					head, Kindly							
L					<u> </u>								approve							
1318	RQ146664	OCC_211	bbmb_sd	BUS	220KV BUS 1 AT	BBMB	D	Half yearly mtc	18/Oct/2023	08:00	18/Oct/2023	18:00		PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	18:00	
					DELHI RR(BB)															
1319	RQ146663	OCC_211	bbmb_sd	BUS	220KV BUS 1 AT	ввмв	D	Yearly mtc.	17/Oct/2023	08:00	17/Oct/2023	18:00		PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
					BHIWANI(BB)			,												
1320	RQ145567	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT	ввмв	D	Connecting of Bus	15/Oct/2023	10:00	15/Oct/2023	18:00	Under	PLANNED	Approved	15-Oct-23	10:00	15-Oct-23	18:00	
		_	_		PONG(BB)			Isolator connection					construction							
					1			after completion of					head, Kindly							
					L			ADD CAP works			l		approve							

1321	RQ145566	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT	BBMB	D	Connecting of Bus	14/Oct/2023	10:00	14/Oct/2023	18:00	Under	PLANNED	Approved	14-Oct-23	10:00	14-Oct-23	Oct-23	18:00	
					PONG(BB)			Isolator connection					construction								
								after completion of					head, Kindly								
								ADD CAP works					approve								
1322	RQ146662	OCC_211	bbmb_sd	BUS	220KV BUS 2 AT	BBMB	D	Yearly mtc.	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	Oct-23	18:00	
		_	_		BHIWANI(BB)			1													
1323	RQ146655	OCC_211	bbmb_sd	BUS	220KV BUS 2 AT	ввмв	D	For Maintenance of	09/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	08:00	11-Oct-23	Oct-23	18:00	
					BARNALA(BB)			Sub-Station			, ,										
								Equipment													
1324	RO146661	OCC 211	bbmb_sd	BUS	220KV BUS 4 AT	RRMR	D	Yearly mtc.	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	)ct-23	18:00	
152.	10001	000_211	551115_54	503	SAMAYPUR(BB)	55.11.5		rearry mee.	03,000,2023	00.00	03,000,2023	10.00			/ ipproved	03 000 23	00.00	05 000 25	200 23	10.00	
					SAIVIATI ON(DD)																
1225	DO1/15562	OCC 211	cncc2 cd	BUS	220KV BUS 2 AT	DDMD	D	Removing of Bus	04/Oct/2023	10:00	04/Oct/2023	19.00	Under	PLANNED	Approved	04-Oct-23	10:00	04-Oct-23	)ct-22	18:00	
1323	10145505	000_211	cpccz_su	503	PONG(BB)	DDIVID		Isolator connection	04/000/2023	10.00	04/001/2023	10.00	construction	DANNED	Аррготси	04 Oct 25	10.00	04 000 23	JCC 23	10.00	
					PONG(BB)			for ADD CAP works					head, Kindly								
								IOI ADD CAP WORKS													
1220	00146657	000 311	bbmb sd	BUS	220KV BUS 2 AT	DDMAD	D	Farrando	04/Oct/2023	00.00	04/Oct/2023	10.00	approve	PLANNED	A	04-Oct-23	08:00	04-Oct-23	) at 22	18:00	
1326	KQ140057	OCC_211	DDITID_SG	BUS		BBIVIB	D	For yearly	04/001/2023	08:00	04/001/2023	18:00		PLAINNED	Approved	04-061-23	08:00	04-061-23	JCI-23	18:00	
					JALANDHAR(BB)			maintenance of Line													
								and Sub-Station													
1				L				Equipment					4								
1327	RQ145562	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT	BBMB	D	Removing of Bus	03/Oct/2023	10:00	03/Oct/2023	18:00	Under	PLANNED	Approved	03-Oct-23	10:00	03-Oct-23	Oct-23	18:00	
					PONG(BB)			Isolator connection					construction								
								for ADD CAP works					head, Kindly								
													approve								
1328	RQ146656	OCC_211	bbmb_sd	BUS	220KV BUS 1 AT	BBMB	D	For yearly	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	Oct-23	18:00	
					JALANDHAR(BB)			maintenance of Line													
								and Sub-Station													
								Equipment													
1329	RQ146654	OCC_211	bbmb_sd	BUS	220KV BUS 1 AT	BBMB	D	For Maintenance of	03/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	05-Oct-23	Oct-23	18:00	
					BARNALA(BB)			Sub-Station													
								Equipment													
1330	RQ145576	OCC 211	cpcc2_sd	BUS	220KV BUS 1 AT	PSTCL	D	Connecting of Bus	29/Oct/2023	10:00	29/Oct/2023	18:00	Under	PLANNED	Approved	29-Oct-23	10:00	29-Oct-23	Oct-23	18:00	
		_	· -		DASUYA(PS)			Isolator connection					construction								
								after completion of					head, Kindly								
								ADD CAP works					approve								
1331	RO145577	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT	PSTCL	D	Connecting of Bus	28/Oct/2023	10:00	28/Oct/2023	18:00	Under	PLANNED	Approved	28-Oct-23	10:00	28-Oct-23	)ct-23	18:00	
			-,		DASUYA(PS)		_	Isolator connection	,,		,,		construction								
					57.50171(1.5)			after completion of					head, Kindly								
								ADD CAP works					approve								
1222	DO1/15572	OCC_211	cncc2 cd	BUS	220KV BUS 2 AT	DSTCI	D	Removing of Bus	20/Oct/2023	10:00	20/Oct/2023	19.00	Under	PLANNED	Approved	20-Oct-23	10:00	20-Oct-23	)ct-22	18:00	
1332	1477/2	000_211	cpccz_su	553	DASUYA(PS)	JICL	U	Isolator connection	20/000/2023	10.00	20,000,2023	13.00	construction	LANNIED	Approved	20-001-23	10.00	20-001-23	JCC-23	10.00	
					DASCIA(FS)			for ADD CAP works													l
								IOI ADD CAP WORKS					head, Kindly								l
1222	00145572	OCC 311	cncc2 -d	DLIC	220KV BUC 1 *T	DCTC	D	Romoving of Deep	10/0+/2022	10:00	10/0-1/2022	10:00	approve	DIANNED	Appress	10.0-+ 22	10:00	10 0-+ 22	)ct 22	18:00	
1333	nQ1455/2	UCC_211	cpcc2_sd	BUS	220KV BUS 1 AT	PSICL	ט	Removing of Bus	19/Oct/2023	10:00	19/Oct/2023	19:00	Under	PLANNED	Approved	19-Oct-23	10:00	19-Oct-23	JCI-23	19:00	
					DASUYA(PS)			Isolator connection					construction								
								for ADD CAP works	1	1	I		head, Kindly								
1				L		1		ļ					approve								
1334	RQ145575	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT	PSTCL	D	Connecting of Bus	15/Oct/2023	10:00	15/Oct/2023	18:00	Under	PLANNED	Approved	15-Oct-23	10:00	15-Oct-23	Oct-23	18:00	
1 1					DASUYA(PS)			Isolator connection	1	1	I		construction								
								after completion of					head, Kindly		l						
								ADD CAP works					approve								
1335	RQ145574	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT	PSTCL	D	Connecting of Bus	14/Oct/2023	10:00	14/Oct/2023	18:00	Under	PLANNED	Approved	14-Oct-23	10:00	14-Oct-23	Oct-23	18:00	
					DASUYA(PS)			Isolator connection					construction								
								after completion of					head, Kindly		l						
								ADD CAP works					approve		l						
1336	RQ145571	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT	PSTCL	D	Removing of Bus	04/Oct/2023	10:00	04/Oct/2023	18:00	Under	PLANNED	Approved	04-Oct-23	10:00	04-Oct-23	Oct-23	18:00	
		_	_		DASUYA(PS)			Isolator connection					construction		''						
					' '			for ADD CAP works					head, Kindly								
									1	1	I		approve								
-						1		1			1		1-5		1						

1337	RQ145570	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT DASUYA(PS)	PSTCL	D	Removing of Bus Isolator connection for ADD CAP works	03/Oct/2023	10:00	03/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	03-Oct-23	10:00	03-Oct-23	18:00	
		_	cpcc2_sd	BUS	220KV BUS 2 AT AMRITSAR(PG)	POWER GRID	D	For Construction Works and Stability of Upcoming 220kV LINE Bay (213).	27/Oct/2023		28/Oct/2023		Under construction head, Kindly approve	PLANNED	Approved	27-Oct-23	10:00	28-Oct-23	18:00	
		OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT AMRITSAR(PG)	POWER GRID	D	For Construction Works and Stability of Upcoming 220kV LINE Bay (213).	25/Oct/2023	10:00	26/Oct/2023		Under construction head, Kindly approve	PLANNED	Approved	25-Oct-23	10:00	26-Oct-23	18:00	
1340	RQ145649	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)	POWER GRID	С	For BUS-2 isolator 20889B isolator retrofitting	25/Oct/2023	09:00	28/Oct/2023		Under construction head, Kindly approve	PLANNED	Approved	25-Oct-23	09:00	28-Oct-23	17:30	
1341	RQ145648	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 20889A jumper connection. 20889A isolator retrofitting	24/Oct/2023	09:00	24/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	24-Oct-23	09:00	24-Oct-23	17:30	
1342	RQ145606	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)	POWER GRID	D	Retrofitted isolators will be connected to BUS-2 (20689B)	23/Oct/2023	14:00	23/Oct/2023	17:00	Under construction head, Kindly approve	PLANNED	Approved	23-Oct-23	14:00	23-Oct-23	17:00	
1343	RQ145605	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	Retrofitted isolators will be connected to BUS-1 (20689A)	23/Oct/2023	09:00	23/Oct/2023	12:00	Under construction head, Kindly approve	PLANNED	Approved	23-Oct-23	09:00	23-Oct-23	12:00	
1344	RQ145654	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 20889A jumper removal. 20889A isolator retrofitting	20/Oct/2023	09:00	20/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	20-Oct-23	09:00	20-Oct-23	17:30	
1345	RQ145598	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 20989B jumper Connection after retrofitting of isolators	18/Oct/2023	12:30	18/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	18-Oct-23	12:30	18-Oct-23	17:30	
1346	RQ145468	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT AMRITSAR(PG)	POWER GRID	D	For Construction Works and Stability of Upcoming 220kV LINE Bay (213).	18/Oct/2023	10:00	19/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	18-Oct-23	10:00	19-Oct-23	18:00	
1347	RQ145597	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 20989A jumper Connection after retrofitting of isolators	18/Oct/2023	09:00	18/Oct/2023	12:30	Under construction head, Kindly approve	PLANNED	Approved	18-Oct-23	09:00	18-Oct-23	12:30	
		OCC_211		BUS	220KV BUS 1 AT AMRITSAR(PG)	POWER GRID	D	For Construction Works and Stability of Upcoming 220kV LINE Bay (213).	16/Oct/2023		17/Oct/2023		Under construction head, Kindly approve	PLANNED	Approved	16-Oct-23	10:00	17-Oct-23	18:00	
1349	RQ145604	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)	POWER GRID	D	For Bus Isolator retrofitting of 220KV Pampore-2 Bay (206), Jumpers of 220kV BUS-2 will be removed to isolate the 20689B isolator completely.	15/Oct/2023	13:00	15/Oct/2023	17:00	Under construction head, Kindly approve	PLANNED	Approved	15-Oct-23	13:00	15-Oct-23	17:00	

1350	RQ145603	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For Bus Isolator retrofitting of 220KV Pampore-2 Bay (206), Jumpers of 220kV BUS-1 will be removed to isolate the 20689A isolator completely.	15/Oct/2023	09:00	15/Oct/2023	12:00	Under construction head, Kindly approve	PLANNED	Approved	15-Oct-23	09:00	15-Oct-23	12:00	
1351	RQ145486	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT FATEHABAD(PG)	POWER GRID	D	AMP WORKS	10/Oct/2023	10:00	10/Oct/2023	18:00	Kindly approve	PLANNED	Approved	10-Oct-23	10:00	10-Oct-23	18:00	
1352	RQ146326	OCC_211	cpcc3_sd	BUS	220KV BUS 2 AT FATEHPUR(PG)	POWER GRID	D	AMP work	10/Oct/2023	10:00	10/Oct/2023	18:00		PLANNED	Approved	10-Oct-23	10:00	10-Oct-23	18:00	
1353	RQ145592	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 20989B jumper removal. for isolator retrofitting	09/Oct/2023	13:00	09/Oct/2023	17:00	Under construction head, Kindly approve	PLANNED	Approved	09-Oct-23	13:00	09-Oct-23	17:00	
1354	RQ146325	OCC_211	cpcc3_sd	BUS	220KV BUS 1 AT FATEHPUR(PG)	POWER GRID	D	AMP work	09/Oct/2023	10:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	10:00	09-Oct-23	18:00	
1355	RQ145977	OCC_211	cpcc3_sd	BUS	220KV BUS 1 AT KANPUR(PG)	POWER GRID	D	AMP work	09/Oct/2023	10:00	09/Oct/2023	18:00		PLANNED	Approved	09-Oct-23	10:00	09-Oct-23	18:00	
1356	RQ145490	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT CHAMBA(PG)	POWER GRID	С	For connecting existing bus-2 with new bay (i.e. bay no. 207 for chamba- Majra Line) and testing of Bus Bar-2 after integration with new bay.	09/Oct/2023	09:00	16/Oct/2023	19:00	Under construction head, Kindly approve	PLANNED	Approved	09-Oct-23	09:00	16-Oct-23	19:00	Subject to NHPC, HP,LAHAL & BUDHIL consent. one BUS shutdown at a time may be given
1357	RQ145591	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWER GRID	D	For BUS-1 isolator 20989A jumper removal for isolator retrofitting.	09/Oct/2023	09:00	09/Oct/2023	12:30	Under construction head, Kindly approve	PLANNED	Approved	09-Oct-23	09:00	09-Oct-23	12:30	
1358	RQ145978	OCC_211	cpcc3_sd	BUS	220KV BUS 2 AT KANPUR(PG)	POWER GRID	D	'AMP works & To attend Hot spot in y phase 203-89 B isolator.220kV Kanpur-Sikandara line will be shifted to TBC for attending hot spot	08/Oct/2023	10:00	08/Oct/2023	18:00		PLANNED	Approved	08-Oct-23	10:00	08-Oct-23	18:00	
1359	RQ145838	OCC_211	cpcc2_sd	BUS	220KV BUS 2 AT MOGA(PG)	POWER GRID	С	Bus Bar Relay Modification work and Testing work and attending hot spot	06/Oct/2023	08:00	07/Oct/2023	18:00	Kindly approve	PLANNED	Approved	06-Oct-23	08:00	07-Oct-23	18:00	May be given subject to real time grid conditions/One BUS shutdown at a time
1360	RQ145837	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT MOGA(PG)	POWER GRID	С	Bus Bar Relay Modification work and Testing work and attending hot spot	04/Oct/2023	08:00	05/Oct/2023	18:00	Kindly approve	PLANNED	Approved	04-Oct-23	08:00	05-Oct-23	18:00	May be given subject to real time grid conditions/One BUS shutdown at a time
1361	RQ145489	OCC_211	cpcc2_sd	BUS	220KV BUS 1 AT CHAMBA(PG)	POWER GRID	С	For connecting existing bus-1 with new bay (i.e. bay no. 207 for chamba- Majra Line) and testing of Bus Bar-1 after integration with new bay	01/Oct/2023	09:00	08/Oct/2023	19:00	Under construction head, Kindly approve	PLANNED	Approved	01-Oct-23	09:00	08-Oct-23	19:00	Subject to NHPC, HP,LAHAL & BUDHIL consent. one BUS shutdown at a time may be given

1362	RQ146293	OCC_211	cpcc1_sd	BUS	220KV BUS 1 AT	С	BUS BAR	25/Oct/2023	08:00	28/Oct/2023	18:00	PLANNED	Approved	25-Oct-23	08:00	28-Oct-23	18:00	Subject to Delhi consent
					MANDOLA(PG)		RETROFITTING WORK											
1363	RQ146288	OCC_211	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 6	D	Bay Extension, For jumpering of new Bays	24/Oct/2023	17:00	27/Oct/2023	23:59	PLANNED	Approved	24-Oct-23	19:00	27-Oct-23	23:59	May be given from 1900 Hrs
1364	RQ146287	OCC_211	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 5	D	Bay Extension, For jumpering of new Bays	24/Oct/2023	17:00	26/Oct/2023	23:59	PLANNED	Approved	24-Oct-23	19:00	26-Oct-23	23:59	May be given from 1900 Hrs
1365	RQ146286	OCC_211	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 4	D	Bay Extension, For jumpering of new Bays	23/Oct/2023	17:00	25/Oct/2023	23:59	PLANNED	Approved	23-Oct-23	19:00	25-Oct-23	23:59	May be given from 1900 Hrs
1366	RQ146285	OCC_211	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 3	D	Bay Extension, For jumpering of new Bays	22/Oct/2023	17:00	24/Oct/2023	23:59	PLANNED	Approved	22-Oct-23	19:00	24-Oct-23	23:59	May be given from 1900 Hrs
1367	RQ146321	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 6	D	FOR AMP WORKS	21/Oct/2023	17:00	28/Oct/2023	23:30	PLANNED	Approved	21-Oct-23	19:00	28-Oct-23	23:30	May be given from 1900 Hrs
1368	RQ146319	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 2	D	FOR AMP WORKS	21/Oct/2023	17:00	28/Oct/2023	23:30	PLANNED	Approved	21-Oct-23	19:00	28-Oct-23	23:30	May be given from 1900 Hrs
1369	RQ146284	OCC_211	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 2	D	Bay Extension, For jumpering of new Bays	21/Oct/2023	17:00	23/Oct/2023	23:59	PLANNED	Approved	21-Oct-23	19:00	23-Oct-23	23:59	May be given from 1900 Hrs
1370	RQ146323	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 5	D	FOR AMP WORKS	20/Oct/2023	17:00	28/Oct/2023	23:30	PLANNED	Approved	20-Oct-23	19:00	28-Oct-23	23:30	May be given from 1900 Hrs
1371	RQ146283	OCC_211	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 1	D	Bay Extension, For jumpering of new Bay in 430 and 431and Bus Bar LBB testing	20/Oct/2023	17:00	22/Oct/2023	23:59	PLANNED	Approved	20-Oct-23	19:00	22-Oct-23	23:59	May be given from 1900 Hrs
1372	RQ146276	OCC_211	cpcc1_sd	BUS	220 KV KURUKSHETRA(P G) - BUS 2	С	For connection of internal conductor of new ICT-3 GIS bay with Existing GIS Bus-2 & Busbar Relay Testing		07:00	20/Oct/2023	20:00	PLANNED	Approved	19-Oct-23	07:00	20-Oct-23	20:00	May be given subject to real time grid conditions/One BUS shutdwon at a time
1373	RQ146313	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 6	D	For Bay extension and bus bar testing of 400 kV ICT-6 & 06 Nos. line Bay (Jumpering and bay extension work of new bays of Phase	18/Oct/2023	17:00	28/Oct/2023	23:30	PLANNED	Approved	18-Oct-23	19:00	28-Oct-23	23:30	May be given from 1900 Hrs
1374	RQ146311	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 8	D	For Bay extension and bus bar testing of line Bay A218(248 (Jumpering and bay extension work of new bays of Phase II)	17/Oct/2023	17:00	28/Oct/2023	23:30	PLANNED	Approved	17-Oct-23	19:00	28-Oct-23	23:30	May be given from 1900 Hrs
1375	RQ146263	OCC_211	cpcc1_sd	BUS	220KV BUS 3 AT NEEMRANA(PG)	D	For AMP work	17/Oct/2023	08:00	17/Oct/2023	18:00	PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	18:00	
1376	RQ146275	OCC_211	cpcc1_sd	BUS	220 KV KURUKSHETRA(P G) - BUS 1	С	For connection of internal conductor of new ICT-3 GIS bay with Existing GIS Bustand Busbar Relay Testing		07:00	18/Oct/2023	20:00	PLANNED	Approved	17-Oct-23	07:00	18-Oct-23	20:00	May be given subject to real time grid conditions/One BUS shutdown at a time

1377   RQ146262   OCC_211   cpcc1_sd   BUS   220KV BUS 2 AT   NEEMRANA(PG)   D   For AMP work   14/Oct/2023   08:00   14/Oct/2023   18:00   PLANNED   Approved   14-Oct-23   08:00   14-Oct-23   18   18   RQ146249   OCC_211   cpcc1_sd   BUS   220KV BUS 2 AT   SONIPAT(PG)   D   FOR AMP WORK   13/Oct/2023   10:00   13/Oct/2023   18:00   PLANNED   Approved   13-Oct-23   10:00   13-Oct-23   18   1379   RQ146261   OCC_211   cpcc1_sd   BUS   220KV BUS 1 AT   NEEMRANA(PG)   D   FOR AMP WORK   13/Oct/2023   08:00   13/Oct/2023   18:00   PLANNED   Approved   13-Oct-23   08:00   13-Oct-23   18   NEEMRANA(PG)   D   AMP work   12/Oct/2023   08:00   12/Oct/2023   20:00   PLANNED   Approved   12-Oct-23   08:00   12-Oct-23   20   NEEMRANA(PG)   D   FOR HVTEST OF 220   KV BUS-2 GIS   EXTENSION   EXTENSI	00
1378 RQ146249 OCC_211	
SONIPAT(PG)   SONIPAT(PG)   D FOR AMP WORK   13/Oct/2023 08:00   13/Oct/2023 18:00   PLANNED   Approved   13-Oct-23   08:00   13-Oct-23   18	
1379 RQ146261 OCC_211 cpcc1_sd BUS	00
NEEMRANA(PG)  1380 RQ146243 OCC_211 cpcc1_sd BUS  220KV BUS 3 AT BHIWADI(PG)  D AMP work  12/Oct/2023 08:00  12/Oct/2023 20:00  PLANNED Approved 12-Oct-23 08:00  12-Oct-23 20:00  PLANNED Approved 12-Oct-23 07:00  12-Oct-23 20:00  PLANNED Approved 12-Oct-23 07:00  PLANNED Approved 12-Oct-23 07:00  12-Oct-23 20:00  NKURUKSHETRA(P G) - BUS 2  EXTENSION	00
1380 RQ146243 OCC_211 cpcc1_sd BUS	
BHIWADI(PG)   BHIWADI(PG)	
BHIWADI(PG)   BHIWADI(PG)	20
1381 RQ146272 OCC_211 cpcc1_sd BUS	00
KURUKSHETRA(P KV BUS-2 GIS G) - BUS 2 EXTENSION	
KURUKSHETRA(P KV BUS-2 GIS G) - BUS 2 EXTENSION	00
G) - BUS 2 EXTENSION	
1382 RQ146241 OCC_211 cpcc1_sd BUS 220 KV D AMP work 11/Oct/2023 17:00 11/Oct/2023 23:59 PLANNED Approved 11-Oct-23 19:00 11-Oct-23 23	May be given from 1900 Hrs
Bus 2	
1383 RQ146320 OCC_211 cpcc1_sd BUS 220 KV D FOR AMP WORKS 11/Oct/2023 17:00 20/Oct/2023 23:30 PLANNED Approved 11-Oct-23 19:00 20-Oct-23 23	May be given from 1900 Hrs
FATEHGARH_II(P	
G) - BUS 4	
1384   RQ146244   OCC_211   cpcc1_sd   BUS   220KV BUS 2 AT   D   AMP work   11/Oct/2023   08:00   11/Oct/2023   20:00   PLANNED   Approved   11-Oct-23   08:00   11-Oct-23   20:00	00
1385 RQ146271 OCC_211 cpcc1_sd BUS	00
1385 RQ146271 OCC_211 cpcc1_sd BUS	50
G)-BUS 1 EXTENSION	
1386 RQ146240 OCC 211 cpcc1 sd BUS 220 KV D AMP work 10/Oct/2023[17:00 10/Oct/2023[23:59 PLANNED Approved 10-Oct-23 19:00 10-Oct-23 23	May be given from 1900 Hrs
BHADLA(PG) -   BHADLA(PG) -	may be given from 1500 ms
1387 RQ146242 OCC_211 cpcc1_sd BUS 220KV BUS 1 AT D AMP work 10/Oct/2023 08:00 10/Oct/2023 20:00 PLANNED Approved 10-Oct-23 08:00 10-Oct-23 20	00
BHIWADI(PG)	
1388   RQ146296   OCC_211   cpcc1_sd   BUS   220KV BUS 4 AT   C   BUS BAR   10/Oct/2023   08:00   13/Oct/2023   18:00   PLANNED   Approved   10-Oct-23   08:00   13-Oct-23   18	00 Subject to Delhi consent
MANDOLA(PG) RETROFITTING STATE OF THE STATE	
WORK	00 Marries sires subject to see
1389   RQ146239   OCC_211   cpcc1_sd   BUS   220KV BUS 2 AT   C   For the Replacement   09/Oct/2023   09:00   11/Oct/2023   18:00   PLANNED   Approved   09-Oct-23   09:00   11-Oct-23   18   18   18   19   19   19   19   19	
	time grid conditions/One BUS shutdown at a time
	Shataowh at a time
1390 RQ146318 OCC_211 cpcc1_sd BUS 220 KV D FOR AMP WORKS 08/Oct/2023 17:00 15/Oct/2023 23:30 PLANNED Approved 08-Oct-23 19:00 15-Oct-23 23	May be given from 1900 Hrs
-   -	, ,
G)-BUS1   G)-BUS1	
1391 RQ146309 OCC_211 cpcc1_sd BUS 220 KV D For erection and 07/Oct/2023 17:00 11/Oct/2023 23:30 PLANNED Approved 07-Oct-23 19:00 11-Oct-23 23:00 PLANNED Approved 07-Oct-23 19:00 11-Oct-23 23:00 PLANNED Approved 07-Oct-23 19:00 11-Oct-23	May be given from 1900 Hrs
FATEHGARH_II(P   commissioning works	
G) - BUS 4 In TBC Bay	
1392   RQ146308   OCC_211   cpcc1_sd   BUS   220 KV   D   For erection and   07/Oct/2023   17:00   11/Oct/2023   23:30   PLANNED   Approved   07-Oct-23   19:00   11-Oct-23   23:00   23:00   23:00   23:00   24:00	May be given from 1900 Hrs
FATEHGARH_II(P   commissioning works	
G) - BUS 2   In TBC Bay	0 14 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1393 RQ146322 OCC_211   cpcc1_sd   BUS   220 kV   D   FOR AMP WORKS   06/Oct/2023 17:00   13/Oct/2023 23:30   PLANNED   Approved   06-Oct-23   19:00   13-Oct-23   23	May be given from 1900 Hrs
FATEHGARH_II(P   G) - BUS 8	
1394 RQ146238 OCC_211 cpcc1_sd BUS 220KV BUS 1 AT D AMP work 06/Oct/2023 09:00 06/Oct/2023 18:00 PLANNED Approved 06-Oct-23 09:00 06-Oct-23 18	00
SAHARANPURIPG	
1395 RQ146295 OCC_211 cpcc1_sd BUS 220KV BUS 3 AT C BUS BAR 06/Oct/2023 08:00 09/Oct/2023 18:00 PLANNED Approved 06-Oct-23 08:00 09-Oct-23 18	00 Subject to Delhi consent
MANDOLA(PG) RETROFITTING	

		OCC_211		BUS	220 KV JIND(PG) - BUS 2		С	Interconnection between new bus and exixting bus and conductor dropping work for 211,212,214 and Bus Stability work for bay no 211 and 212 & 214,215	04/Oct/2023		06/Oct/2023			PLANNED	Approved	04-Oct-23	08:00	06-Oct-23	20:00	May be given subject to real time grid conditions/One BUS shutdown at a time
1397	RQ146310	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 7		D	For Bay extension and bus bar testing of line Bay A218(248) (Jumpering and bay extension work of new bays of Phase III)	02/Oct/2023	17:00	13/Oct/2023	23:30		PLANNED	Approved	02-Oct-23	19:00	13-Oct-23	23:30	May be given from 1900 Hrs
			cpcc1_sd		220 KV FATEHGARH_II(P G) - BUS 5		D	For Bay extension and bus bar testing of 400 kV ICT-6 & 06 Nos. line Bay (Jumpering and bay extension work of new bays of Phase II)	02/Oct/2023		13/Oct/2023			PLANNED	Approved	02-Oct-23	19:00	13-Oct-23	23:30	May be given from 1900 Hrs
1399	RQ146294	OCC_211	cpcc1_sd	BUS	220KV BUS 2 AT MANDOLA(PG)		С	BUS BAR RETROFITTING WORK	02/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	02-Oct-23	08:00	05-Oct-23	18:00	Subject to Delhi consent
1400	RQ146324	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 7		D	FOR AMP WORKS	01/Oct/2023	17:00	06/Oct/2023	23:30		PLANNED	Approved	01-Oct-23	19:00	06-Oct-23	23:30	May be given from 1900 Hrs
1401	RQ146306	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 1		D	For erection and commissioning works in TBC Bay, Bus Bar , LBB Relay Testing Under Phase-1 commissioning works	01/Oct/2023	17:00	06/Oct/2023	23:30		PLANNED	Approved	01-Oct-23	19:00	06-Oct-23	23:30	May be given from 1900 Hrs
1402	RQ146307	OCC_211	cpcc1_sd	BUS	220 KV FATEHGARH_II(P G) - BUS 3		D	For erection and commissioning works in TBC Bay, Bus Bar, LBB Relay Testing Under Phase-1 commissioning works	01/Oct/2023	17:00	06/Oct/2023	23:30		PLANNED	Approved	01-Oct-23	19:00	06-Oct-23	23:30	May be given from 1900 Hrs
1403	RQ146251	OCC_211	cpcc1_sd	BUS	220 KV JIND(PG) - BUS 1		С	Interconnection between new bus and exixting bus and conductor dropping work for 211,212,214 and Bus Stability work for bay no 211 and 212 & 214,215	01/Oct/2023	08:00	03/Oct/2023	20:00		PLANNED	Approved	01-Oct-23	08:00	03-Oct-23	20:00	May be given subject to real time grid conditions/One BUS shutdown at a time
1404	RQ145510	OCC_211	cpcc2_sd	BUS	220 KV KALA AMB(PKTL) - BUS 2	PKATL	D	For checking interconnection of bay extension	12/Oct/2023	09:00	12/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	12-Oct-23	09:00	12-Oct-23	18:00	
1405	RQ145509	OCC_211	cpcc2_sd	BUS	220 KV KALA AMB(PKTL) - BUS 1	PKATL	D	For checking interconnection of bay extension	10/Oct/2023	09:00	10/Oct/2023	18:00	Under construction head, Kindly approve	PLANNED	Approved	10-Oct-23	09:00	10-Oct-23	18:00	

		OCC_211		BUS	220KV BUS 1 AT GLADNI(PDD)		D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc	08/Oct/2023		08/Oct/2023	12:00	40 -60 MW load may be shifted and fed from the sister 220 KV grids subject to realtime loading and availability of power from these grids. Rest 260-280 MW load shall be affected	PLANNED	Approved	08-Oct-23	07:00	08-Oct-23	12:00	Subject to NHPC/POWERGRID consent.
1407	RQ146534	OCC_211	sldcjk_sd	BUS	220KV BUS 2 AT GLADNI(PDD)	PDD JK	D	Preventive maintenance works including replacement of worn out jumpers / droppers and allied clamps etc	08/Oct/2023	07:00	08/Oct/2023	12:00	40 -60 MW load may be shifted and fed from the sister 220 KV grids subject to realtime loading and availability of power from these grids. Rest 260-280 MW load shall be affected	PLANNED	Approved	08-Oct-23	07:00	08-Oct-23	12:00	Subject to NHPC/POWERGRID consent.
1408	RQ145700	OCC_211	ntpcos_sd	BUS	220KV BUS 2 AT UNCHAHAR(NT)	NTPC	С	bus side isolator maintenance and checking	03/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	05-Oct-23	18:00	
1409	RQ145924	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV HAMIRPUR(HP)- CHOHAL (PS) (PSTCL) CKT-1	PSTCL	D	Patrolling of line alongwith Tree trimming and Jumper tightening	30/Oct/2023	08:00	30/Oct/2023	18:00		PLANNED	Approved	30-Oct-23	08:00	30-Oct-23	18:00	
1410	RQ145923	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV HAMIRPUR(HP)- CHOHAL (PS) (PSTCL) CKT-1	PSTCL	D	Patrolling of line alongwith Tree trimming and Jumper tightening	12/Oct/2023	08:00	12/Oct/2023			PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	18:00	
1411	RQ145911	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV JAMALPUR(BBMB )-GHULAL(PS) (PSTCL) CKT-1	PSTCL	D	Tightning of jumpers ,Tree Cutting and ground Mtc.etc	03/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	11-Oct-23	18:00	
1412	RQ145920	OCC_211	sldcps_sd	AC TRANSMISSION LINE CIRCUIT	132 KV HAMIRPUR(HP)- CHOHAL (PS) (PSTCL) CKT-1	PSTCL	D	Patrolling of line alongwith Tree trimming and Jumper tightening	03/Oct/2023	08:00	03/Oct/2023	18:00		PLANNED	Approved	03-Oct-23	08:00	03-Oct-23	18:00	
1413	RQ146498	OCC_211	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	132 KV PITHORAGARH(P G)- ALMORA(PTCUL) (PTCUL) CKT-1	PTCUL	D	AMP work	11/Oct/2023	08:00	11/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	18:00	
1414	RQ146354	OCC_211	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	132 KV	RRVPNL	D	for Line Maintenance And Tree Trimming Work	06/Oct/2023	08:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	15:00	06-Oct-23	23:00	BBMB Consented. May be given from 1500 Hrs
1415	RQ145497	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV SEWA_2(NH)- KATHUA(JK) (PG) CKT-1	POWER GRID	D	AR Non auto mode is required for OPGW works	01/Oct/2023	07:00	31/Oct/2023	18:00	Non shutdown activity. Kindly approve	PLANNED	Approved	01-Oct-23	07:00	31-Oct-23	18:00	Subject to NHPC/JK consent.

1416	RQ145499	OCC_211	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV KATHUA(JK)- MAHANPUR(JK) (PG) CKT-1	POWER GRID	D	AR Non auto mode is required for OPGW works	01/Oct/2023	07:00	31/Oct/2023	18:00	Non shutdown activity. Kindly approve		Approved	01-Oct-23	07:00	31-Oct-23	18:00	
		OCC_211	. –	AC TRANSMISSION LINE CIRCUIT	132 KV SEWA_2(NH)- MAHANPUR(PDD) (PG) CKT-1	POWER GRID	D	AR Non auto mode is required for OPGW works	01/Oct/2023		31/Oct/2023		Non shutdown activity. Kindly approve	PLANNED	Approved	01-Oct-23	07:00	31-Oct-23	18:00	Subject to NHPC/JK consent.
1418	RQ145635	OCC_211	phtl_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)- KALA AMB(PKTL) (JPL) CKT-2		D	AMP and cleaning of disc insulators	17/Nov/2023	08:00	17/Nov/2023	21:00	AMP and cleaning of disc insulators	PLANNED	Approved	17-Nov-23	08:00	17-Nov-23	21:00	
1419	RQ145633	OCC_211	phtl_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)- KALA AMB(PKTL) (JPL) CKT-2		D	AMP and cleaning of disc insulators	17/Nov/2023	08:00	17/Nov/2023	21:00	AMP and cleaning of disc insulators	PLANNED	Approved	17-Nov-23	08:00	17-Nov-23	21:00	
1420	RQ145634	OCC_211	phtl_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)- KALA AMB(PKTL) (JPL) CKT-1		D	AMP and cleaning of disc insulators	16/Nov/2023	08:00	16/Nov/2023	17:00	AMP and cleaning of disc insulators	PLANNED	Approved	16-Nov-23	08:00	16-Nov-23	17:00	
1421	RQ145632	OCC_211	phtl_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ABDULLAPUR(PG)- KALA AMB(PKTL) (JPL) CKT-1		D	AMP and cleaning of disc insulators	16/Nov/2023	08:00	16/Nov/2023	17:00	AMP and cleaning of disc insulators	PLANNED	Approved	16-Nov-23	08:00	16-Nov-23	17:00	
1422	RQ146155	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA- DAULATABAD (HV) CKT-1		D	Stringing of 765 kV D/C Khetri-Narela TL	25/Oct/2023	07:00	28/Oct/2023	19:00		PLANNED	Approved					only two circuit at a time may be allowed.
1423	RQ146156	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DHANODA- DAULATABAD (HV) CKT-2		D	Stringing of 765 kV D/C Khetri-Narela TL	25/Oct/2023	07:00	28/Oct/2023	19:00		PLANNED	Approved					only two circuit at a time may be allowed.
		OCC_211	. –	AC TRANSMISSION LINE CIRCUIT	DHANODA(HV) (GPTL) CKT-2		D	Stringing of 765 kV D/C Khetri-Narela TL	25/Oct/2023		28/Oct/2023			PLANNED	Approved					only two circuit at a time may be allowed.
1425	RQ146157	OCC_211	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEEMRANA(PG)- DHANODA(HV) (GPTL) CKT-1		D	Stringing of 765 kV D/C Khetri-Narela TL	25/Oct/2023	07:00	28/Oct/2023	19:00		PLANNED	Approved					only two circuit at a time may be allowed.

1426	20146161	OCC_211	cncc1 sd	AC	220 KV	D	Overhead crossing	04/Oct/2023	07:00	06/Oct/2023	19:00	Keeping in	PLANNED	Approved	04-Oct-23	19:00	06-Oct-23	23:00	May be given from 1900 Hrs
1420	(Q140101	OCC_211	cpcci_su		FATEHGARH_II(P	D	i.e. Stringing work of	04/000/2023	07.00	00/001/2023		View of safety	FLAININED	Approved	04-001-23	13.00	00-001-23	23.00	iviay be given from 1900 fils
					G)-DEVIKOT		400kV D/C Ramgarh					aspects and							
					SL_FTGH2		II (Fatehgarh-III) –					difficulty in							
					(NTPC_DEVIKOT)		Fatehgarh II					power line							
					(NTPC_DEVIKOT)		transmission Line					crossing work							
					CKT-1		ti diisiilissioii Liiic					in night hours							
					CK1-1							& in night							
												hours theft of							
												conductor may							
												occurred as							
												theft issue is							
												more in							
												Jaisalmer area							
												therefore to							
												avoid any							
												damage to M/S SBE							
												Renewable							
												Ten Pvt. Ltd.							
												line, shutdown							
												is required in							
												day hours only.	-						
1427	RQ146162	000 211	1 -d	10	220 101	D	Overhead crossing	04/Oct/2023	07:00	06/Oct/2023	10:00	Keeping in	PLANNED	Approved	04-Oct-23	19:00	06-Oct-23	23:00	May be given from 1900 Hrs
1427																			
	(Q140102	OCC_211	cpcc1_sa		220 KV	U		04/000/2023	07.00	06/001/2023			LANIVED	Approved	04-001-23	13.00	00-001-23	23.00	iviay be given from 1900 Hrs
	(Q140102	OCC_211	cpcc1_sa	TRANSMISSION	Fatehgarh_II(PG)-		i.e. Stringing work of	04/001/2023	07.00	06/001/2023		View of safety	LANIVED	Арргочец	04-001-23	13.00	00-001-23	23.00	iviay be given from 1900 Hrs
	10102	OCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB		i.e. Stringing work of 400kV D/C Ramgarh	04/000/2023	07.00	06/000/2023		View of safety aspects and	LANNED	Approved	04-001-23	19.00	00-001-23	23.00	iviay be given from 1900 His
	(Q140102	OCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) –	04/001/2023	67.00	00/000/2025		View of safety aspects and difficulty in	PENNIED	Арргоveu	04-001-23	19.00	00-001-23	23.00	way be given noin 1500 his
	(Q140102	OCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	047 Oct 7 2023	67.00	00/001/2023		View of safety aspects and difficulty in power line	PENINED	Арргоved	04-001-23	19.00	00-001-23	23.00	iviay be given nom 1900 nis
	(Q1+0102	OCC_211	cpcc1_sd	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) –	047 Oct 7 2023	67.00	06/011/2023		View of safety aspects and difficulty in power line crossing work	PANNED	Арргоved	04-001-23	19.00	00-001-23	23.00	iway be given noin 1900 his
	(Q1+0102	OCC_211	cpcc1_sd	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/04/2023	67.00	06/011/2023		View of safety aspects and difficulty in power line crossing work in night hours	PANNED	Арргоveu	04-001-23	19.00	00-001-23	23.00	iway be given noin 1900 his
	(41-0102	OCC_211	cpcc1_sd	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/04/2023	67.00	06/011/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night	Palmes	Арргоveu	04-001-23	19.00	00-001-23	23.00	way be given from 1500 His
	(Q140102	OCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/000/2023	07.00	06/011/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of		дриочеи	04-001-23	19.00	00-011-23	23.00	way be given non 1500 ms
	(Q140102	OCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/04/2023	07.00	06/01/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may		жири очен	04-001-23	19.00	00-000-23	23.00	way be given if the 1900 His
	(Q140102	OCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04)00()2023	07.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as		жүргоved	04-001-23	19.00	00-000-23	23.00	way be given if unit 1900 His
	(0140102	UCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	07.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is		Арргочец	04-001-23	19.00	00-000-23	23.00	way be given noin 1900 his
	(0140102	UCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	07.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in		Арргочец	04-001-23	19.00	00-000-23	23.00	way be given noin 1900 his
	(0140102	UCC_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	07.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area		Арргочец	04-001-23	19.00	00-000-23	23.00	way be given Hull 1900 HIS
	(Q140102	000_211	cpcc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	07.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to		Арргочец	04-011-23	19.00	00-000-23	23.00	way be given noin 1900 his
		000_211	cpc.1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	0.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any		Арргочец	04-011-23	19.00	00-011-23	23.00	way be given noin 1900 his
		000_211	tpc:1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	0.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to		Арргочец	0400023	19.00	0000023	23.00	way be given noin 1900 his
		000_211	cpc.1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	0.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE		жүрлочей	0400023	1930	0000023	23.00	way be given from 1900 His
		000_211	tpc1_sa	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	0.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable		хүрлочей	0400023	1930	0000023	23.00	way be given noin 1900 his
		000_211	tpc1_su	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	0.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. Ltd.		хүрлочей	0400023	13.00	0000123	23.00	way be given Hull 1900 His
		000_211	cpc.1_su	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	0.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. Ltd. line, shutdown		хүрлочей	0400023	1930	0000123		way be given if Uiii 1900 His
		000_211	cpc.1_su	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	0.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. ttd. line, shutdown is required in		хүрлочей	0400023	1930	0000023		way be given from 1900 His
		000_211	tpc.1_su	TRANSMISSION LINE CIRCUIT	Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL)		i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II	04/00/2023	0.00	00/01/2023		View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. Ltd. line, shutdown		хүрлочей	040(12)	1930	0000123		way be given non 1900 ms

	46163 OCC_211		AC TRANSMISSION LINE CIRCUIT	220 KV Fatehgarh_II(PG)- ASEJOL_HB FTGH2 (ASEJOL) (ASEJOL) Ckt-2		Overhead crossing i.e. Stringing work of 400kV D/C Ramgarh III (Fatehgarh III transmission Line	04/Oct/2023		06/Oct/2023		Keeping in View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. Ltd. line, shutdown is required in day hours only. Keeping in	PLANNED	Approved	04-Oct-23	19:00	06-Oct-23	23:00	May be given from 1900 Hrs  May be given from 1900 Hrs
			TRANSMISSION LINE CIRCUIT	FATEHGARH G)-FATEHGARH POOLING(FBTL) (FBTL) CKT-1		400kV D/C Ramgarh II (Fatehgarh-III) — Fatehgarh II transmission Line					Keeping in View of safety aspects and difficulty in power line crossing work in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. Ltd. line, shutdown may be availed in Sept-23.			01-00-23	19:00	υσ-υτ-23	23:00	
1430 RQ14	46388 OCC_211	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV KHETRI (PKTSL)- JHATIKARA(PG) (PG) CKT-2 @JHATIKARA(PG)		IOM IMPLEMENTATION AND SPARE ROTATION	24/Oct/2023	09:15	24/Oct/2023	15:00		PLANNED	Rejected					To be clubbed with Line AMP/Outage work

		OCC_211		LINE REACTOR	240 MVAR SWITCHABLE LSR ON 765 KV AGRA- JHATIKARA (PG) CKT-1 @AFZALGARH(UP)		D	IOM IMPLEMENTATION AND SPARE ROTATION	23/Oct/2023		23/Oct/2023			PLANNED	Rejected					To be clubbed with Line AMP/Outage work.
1432	RQ146347	OCC_211	cpcc1_sa	LINE REACTOR	330 MVAR NON- SWITCHABLE LR ON JHATIKARA- ALIGARH (PG) CKT-1 @JHATIKARA(PG)		D	IOM IMPLEMENTATION AND SPARE ROTATION	20/Oct/2023	09:15	20/Oct/2023	15:00		PLANNED	Rejected					To be clubbed with Line AMP/Outage work
		OCC_211			240 MVAR SWITCHABLE LR ON 765 KV BHADLA-BIKANER (PG) CKT-1 @BIKANER(PG)		D	FOR AMP WORKS	17/Oct/2023		17/Oct/2023			PLANNED	Rejected					To be clubbed with Line AMP/Outage work
1434	RQ146828	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	25 MVAR BUS REACTOR NO 1 AT 220 KV MANDOLA(PG)		С	BUS BAR RETROFITTING WORK	15/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Approved	15-Oct-23	08:00	16-Oct-23	18:00	
1435	RQ146755	OCC_211	cpcc1_sd	BR/BSR/MSC/ MSR	25 MVAR BUS REACTOR NO 1 AT 220 KV MANDOLA(PG)	POWER GRID	С	BUS BAR RETROFITTING WORK	15/Oct/2023	08:00	16/Oct/2023	18:00		PLANNED	Rejected					Duplicate entry with S. No 434
1436	00145646																			
	MQ143040	OCC_211	cpcc2_sd	ВАУ	208 BUS COUPLER BAY - 220KV BUS 1 AT WAGOORA(PG) (POWERGRID) AND 220KV BUS 2 AT WAGOORA(PG) AT 220 KV WAGOORA(PG) (POWERGRID)	POWER GRID	С	Isolator retrofitting of 20889B isolators to be retrofitted	25/Oct/2023	09:00	28/Oct/2023	17:30	Under construction head, Kindly approve	PLANNED	Approved	25-Oct-23	09:00	28-Oct-23	17:30	

1438	RQ146598	OCC_211	cpcc3_sd	ВАУ	213 MAIN BAY - 220 KV KANPUR(PG)- KANPURNAUBAS TA(UP) (PG) CKT- 1 (POWERGRID) AT 220 KV KANPUR(PG)	POWER GRID	С	For overhauling of circuit breaker-ABB make. Line will remain charged from TBC	11/Oct/2023	10:00	13/Oct/2023	18:00		PLANNED	Approved	11-Oct-23	10:00	13-Oct-23	18:00	Element must remain in service via other bay.
1439	RQ146597	OCC_211	cpcc3_sd	ВАУ	210 MAIN BAY - 220 KV KANPUR(PG)- MAINPURI(UP) (PG) CKT-1 (POWERGRID) AT 220 KV KANPUR(PG)	POWER GRID	С	'For overhauling of circuit breaker-ABB make. Line will remain charged from TBC	08/Oct/2023	10:00	10/Oct/2023	18:00		PLANNED	Approved	08-Oct-23	10:00	10-Oct-23	18:00	Element must remain in service via other bay.
1440	RQ146779	OCC_211	cpcc1_sd	ВАУ	A217 BUS COUPLER BAY - 220 KV FATEHGARH_II(P G) - BUS 7 (POWERGRID) AND 220 KV FATEHGARH_II(P G) - BUS 8 AT 220 KV FATEHGARH_II(P G) (POWERGRID)	POWER GRID	D	FOR ConstructionWORKS OF PHASE-2	01/Oct/2023	17:00	05/Oct/2023	22:00		PLANNED	Approved	01-Oct-23	19:00	05-Oct-23	23:00	May be given from 1900 Hrs
1441	RQ146585	OCC_211	indigrid_sd	BAY	211 MAIN BAY - 220 KV PRITHALA (GPTL) - BUS 1 (GPTL) AT PRITHALA (GPTL)	GPTL	D	AMP works of Bay	19/Oct/2023	08:00	19/Oct/2023	20:00	Annual Maintenance	PLANNED	Approved	19-Oct-23	08:00	19-Oct-23	20:00	
1442	RQ146578	OCC_211	indigrid_sd	BAY	210 MAIN BAY - 220 KV PRITHALA (GPTL) - BUS 1 (GPTL) AT PRITHALA (GPTL)	GPTL	D	AMP works of Bay	18/Oct/2023	08:00	18/Oct/2023	20:00	Annual Maintenance	PLANNED	Approved	18-Oct-23	08:00	18-Oct-23	20:00	
1443	RQ146577	OCC_211	indigrid_sd	BAY	209 MAIN BAY - 220 KV PRITHALA (GPTL) - BUS 1 (GPTL) AT PRITHALA (GPTL)	GPTL	D	AMP works of Bay	17/Oct/2023	08:00	17/Oct/2023	20:00	Annual Maintenance	PLANNED	Approved	17-Oct-23	08:00	17-Oct-23	20:00	
1444	RQ146576	OCC_211	indigrid_sd	BAY	208 MAIN BAY - 220 KV PRITHALA (GPTL) - BUS 1 (GPTL) AT PRITHALA (GPTL)	GPTL	D	AMP works of Bay	16/Oct/2023	08:00	16/Oct/2023	20:00	Annual Maintenance	PLANNED	Approved	16-Oct-23	08:00	16-Oct-23	20:00	

1445	RQ146571	OCC_211	indigrid_sd	ВАУ	202 MAIN BAY- 220 KV PRITHALA (GPTL)-RANGALA RAJPUR (HV) (HVPNL) CKT-2 (GPTL) AT PRITHALA (GPTL)	GPTL	D	AMP works of Bay	12/Oct/2023	08:00	12/Oct/2023	20:00	Annual Maintenance	PLANNED	Approved	12-Oct-23	08:00	12-Oct-23	20:00	
1446	RQ146566	OCC_211	indigrid_sd	ВАУ	205 MAIN BAY- 220 KV PRITHALA (GPTL)-RANGALA RAJPUR (HV) (HVPNL) CKT-1 (GPTL) AT RANGALA RAJPUR-1 (GPTL)	GPTL	D	AMP works of Bay	11/Oct/2023	08:00	11/Oct/2023	20:00	Annual Maintenance	PLANNED	Approved	11-Oct-23	08:00	11-Oct-23	20:00	
1447	RQ146565	OCC_211	indigrid_sd	BAY	204 MAIN BAY - 220 KV PRITHALA (GPTL)- PALWAL(HV) (HVPNL) CKT-2 (GPTL) AT PRITHALA (GPTL)	GPTL	D	AMP works of Bay	10/Oct/2023	08:00	10/Oct/2023	20:00	Associated 220 KV Prithala (GPTL)- Palwal(HV) (HVPNL) Ckt-2 line will also be under shutdown	PLANNED	Approved	10-Oct-23	08:00	10-Oct-23	20:00	
1448	RQ146562	OCC_211	indigrid_sd	BAY	201 MAIN BAY - 220 KV PRITHALA (GPTL)- PALWAL(HV) (HVPNL) CKT-1 (GPTL) AT PRITHALA (GPTL)	GPTL	D	AMP works of Bay	09/Oct/2023	08:00	09/Oct/2023	20:00	Associated 220 KV Prithala (GPTL)- Palwal(HV) (HVPNL) Ckt-1 line will also be under shutdown	PLANNED	Approved	09-Oct-23	08:00	09-Oct-23	20:00	
1449	RQ145419	OCC_211	cpcc2_sd	SVC/STATCOM	SVC No 1(- 400/+600MVAR) at 400 KV Ludhiana(PG)	POWER GRID	D	AMP WORKS	16/Oct/2023	09:00	18/Oct/2023	18:00	Kindly approve	PLANNED	Approved	16-Oct-23	09:00	18-Oct-23	18:00	
1450	RQ146605	OCC_211	cpcc3_sd	TCSC	TCSC OF 400 KV GORAKHPUR- MUZAFFARPUR (PG) CKT-2 AT GORAKHPUR(PG)	POWER GRID	D	OPTO Card troubleshooting	08/Oct/2023	08:00	08/Oct/2023	18:00		PLANNED	Approved	08-Oct-23	08:00	08-Oct-23	18:00	
1451	RQ146606	OCC_211	cpcc3_sd	TCSC	TCSC OF 400 KV GORAKHPUR- MUZAFFARPUR (PG) CKT-1 AT GORAKHPUR(PG)	POWER GRID	D	OPTO Card troubleshooting	05/Oct/2023	08:00	05/Oct/2023	18:00		PLANNED	Approved	05-Oct-23	08:00	05-Oct-23	18:00	
1452	RQ146609	OCC_211	cpcc3_sd	FSC	FSC(30%) OF 400 KV LUCKNOW_1(PG)- BASTI(UP) (PG) CKT-1 AT LUCKNOW_1(PG)		D	AMP work	06/Oct/2023	10:00	06/Oct/2023	18:00		PLANNED	Approved	06-Oct-23	10:00	06-Oct-23	18:00	

			Outa	ges propo	sed in	other RP	Cs req	uiring l	NRPC approval						
SI No	in Agency Time														
1	WRPC	MP_SLDC	220KV-MALANPUR-AURIYA-1	10/6/2023	9:00	10/6/2023	17:00	D	FOR LINE MAINTENANCE WORK		approved				
2	WRPC	MP_SLDC	220KV-BHANPURA-RANPUR-1	10/10/2023	8:00	10/10/2023	18:00	D	FOR LINE MAINTENANCE WORK		approved				
3	WRPC	MP_SLDC	220KV-MEHGAON-AURIYA-1	10/13/2023	9:00	10/13/2023	17:00	D	FOR LINE MAINTENANCE WORK		approved				
4	WRPC	MP_SLDC	220KV-BHANPURA-MODAK-1	10/18/2023	8:00	10/18/2023	18:00	D	FOR LINE MAINTENANCE WORK		approved				

### PLANNED SHUT DOWN FOR THE MONTH OF OCT- 2023 WHICH ARE TO BE APPROVED BY OCC - 211

### Name of Transmission Zone: Uttar Pradesh Power Transmission Corporation Limited

SI. I	No.		Details of Transmission Line	Da	te	Tim	nings	Reason	"Outage Mode	Remarks	Shutdown Status	OCC Remaks
31. 1		Voltage Level	Name of Transmission Elements	From	To	From	То	Reason	(Daily/	Remarks	Silutuowii Status	OCC Remars
	. [	400KV	400 kV Main Bus I at 400KV S/s Rasra	0 Oct 22	10-Oct-23	10:00	17:00	For replacement of 0-ring and gasket in 9-1-Y compartment of 400 kV GIS.	Continous			May be given subject to real
		400KV	400 KV Maili Bus I at 400KV 3/5 Kasia	9-001-23	10-001-23	10.00	17.00		Continous		approved	time Grid conditions.
	,	400KV	400 kV Spare Bay 2(Bay no 409) at 400KV S/s Rasra	0 Oct 22	10-Oct-23	10:00	17:00	For replacement of 0-ring and gasket in 9-1-Y compartment of 400 kV GIS.	Continous			May be given subject to real
		400KV	400 KV Spare Bay 2(Bay 110 405) at 400KV 3/3 Kasia	9-0Ct-23	10-001-23	10.00	17.00		Continous		approved	time Grid conditions.
	, Т	400KV	125 MVAR Bus Reactor at 400KV S/s Rasra	11-Oct-23	12 Oct 22	10:00	17:00	For replacement of R phase GIS metering VT of 125MVAR Bus Reactor.	Continous			May be given subject to real
	<b>'</b>	400KV	123 IVIVAN DUS NEGOCIOI AL HOUNV 3/5 NASIA	11-001-25	12-001-23	10.00	17.00		Continous		approved	time Grid conditions.

# <u>Sub: Request for 400kV Daultabad - Jhajjar D/C shutdown line from 05.10.23 (08:00 hrs) to 22.10.23 (18:00 hrs) on continuous basis for shifting/re-routing to avoid infringement with HORC corridor</u>

HVPN has requested for shutdown of 400kV Daultabad - Jhajjar D/C shutdown line from 05.10.23 (08:00 hrs) to 22.10.23 (18:00 hrs) on continuous basis for shifting/re-routing to avoid infringement with HORC corridor (as a deposit work of HRIDC)

## **NLDC/NRLDC Comments:**

to be availed after s/d of champa-kurukshtra poles

### **Shutdown Status:**

rejected

Fo	rmat	I(B): Reque	st For Bus, Bay, ICTs, Rea	actor, FACTS, FS	Cs, SVCs e	tc (to be submitted b	y Indenting age	ncy to NRPC)						Shutdown	осс
Inc	lentii	ng Agency:	1500 MW CCGT, BAWAN	IA		For the M	onth: October	2023	D	ate of submi	ssion: 15.09.20	023		Status	Remarks
			I	Line Details		<del>-</del>			Proposed Da	ate and Time	!			Status	Kemarks
SI.	Nο	Voltage Level (kV)	Name of the Element	Substation	Owner	Category (A/B/C/D)	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks		
	1	400kV	Bay 409& 408 ( Main & Tie Bay of GTG#3 Unit)	1500 MW CCGT, BAWANA	PPCL	А	Continuous	Testing of Transformers GTGT#3, SAT#3	03.10.2023	0900 Hrs	06.10.2023	11800 Hrs	Generation of GTG#3 will be unavailable	approved	May be given subject to real time Grid conditions.

		Details of Transmission Element			DURATI	ON					
S.N.	Voltage level		Circuit No	FROM	И	Т	0	Daily/	Remarks	Shutdown	OCC Remaks
	(KV)	NAME OF THE ELEMENT AND SUBSTATION		DATE	TIME	DATE	TIME	Continuous		Status	
1	400kV	400 KV RAJPURA-DHURI (PS) CKT-1	Circuit No - I	03.10.2023	08.00 Hrs.	10.10.2023	19.00 Hrs.	Daily	For erection of 400kv tower, type DB+6mtr	approved	May be given subject to real time grid conditions. Subject to availability of other feeders at rajpura
2	400kV	400 KV RAJPURA-DHURI (PS) CKT-2	Circuit No - II	03.10.2023	08.00 Hrs.	10.10.2023	19.00 Hrs.	Daily	For erection of 400kv tower, type DB+6mtr	approved	May be given subject to real time grid conditions. Subject to availability of other feeders at rajpura
3	400kV	400 KV RAJPURA-DHURI (PS) CKT-1	Circuit No - I	11.10.2023	08.00 Hrs.	18.10.2023	19.00 Hrs.	Daily	For resagging of twin moose double conductor b/w newly erected tower no. 233-Tino.234 including the dismantlement of old tower no.233	approved	May be given subject to real time grid conditions/One Circuit shutdown at a time
4	400kV	400 KV RAJPURA-DHURI (PS) CKT-2	Circuit No - II	18.10.2023	08.00 Hrs.	25.10.2023	19.00 Hrs.	1 ,	for resagging of twin moose double conductor b/w newly erected tower no. 233-Tlno.234 including the dismantlement of old tower no.233	approved	May be given subject to real time grid conditions/One Circuit shutdown at a time

S. No.	Element name of Transmission line	Reason for proposed shutdown	Daily / Continuous	From Date	From Time	To Date	To Time	Remarks	Shutdown Status	OCC Remarks
1	220KV RAPS_C(NP) – RAPS_B Tie Line_2	Tan delta measurement of 0-513-CVT-10, 0-513-CT-10 (Tie Line_2) and preventive maintenance of Disconnecting switches, circuit breaker and relays.	Continuous	22-Sep-2023	09:00 Hrs.	23-Sep-2023	20:00 Hrs.		approved	May be given on daily basis subject to real time Grid conditions and other end consent.
2	220KV RAPS_C(NP) – RAPS_B Tie Line_1	Tan delta measurement of 0-513-CVT-01, 0-513-CT-01 (Tie Line_1) and preventive maintenance of Disconnecting switches, circuit breaker and relays.	Continuous	24-Sep-2023	09:00 Hrs.	25-Sep-2023	20:00 Hrs.		approved	May be given on daily basis subject to real time Grid conditions and other end consent.
3	220KV RAPS_C(NP) – ANTA Line	Tan delta measurement of 0-513-CVT-2, 0-513-CT-2 (Anta Line) and preventive maintenance of Disconnecting switches, circuit breaker and relays.	Daily	26-Sep-2023	09:00 Hrs.	27-Sep-2023	20:00 Hrs.		approved	May be given on daily basis subject to real time Grid conditions and other end consent.
4	400KV RAPS_C(NP) – KOTA (PG)(PG) CKT-1	Tan delta measurement of 0-513-CT-13 & 14 (Kota Line) and preventive maintenance of Disconnecting switches circuit breaker and relays	Daily	28-Sep-2023	09:00 Hrs.	29-Sep-2023	20:00 Hrs.		approved	May be given on daily basis subject to real time Grid conditions and other end consent.
5	400KV RAPS_C(NP) – CHITTORGARH (RS)(PG) CKT-1	Tan delta measurement of 0-513-CVT-1 0-513-CT-4 & 0-513-CT-5 (Chittorgarh Line) and preventive maintenance of Disconnecting switches circuit breaker and relays.	Daily	30-Sep-2023	09:00 Hrs.	1-Oct-2023	20:00 Hrs.		approved	May be given on daily basis subject to real time Grid conditions and other end consent.

S/d No	Element Name	Request Type	Requester	Meeting	C/D	Reason	From Date	From Time	To Date	To Time	Shutdown Status	OCC Remaks
1	220 KV Khodri-Saharanpur (UP)	Planned	sldcuk_sd	211th OCC		For overhauling & repairing of mechanism & poles of 220 kV SF-6breaker of ABB make of 220 kV Khodri Feeder 83 and 84 at Khodri Power Station	12-Oct-2023	10:00 Hrs.	15-Oct-2023		approved	May be given subject to UP consent.
2	220 KV Khodri-Sarasawa (UP)	Planned	sldcuk_sd	211th OCC		For overhauling & repairing of mechanism & poles of 220 kV SF-6breaker of ABB make of 220 kV Khodri Feeder 83 and 84 at Khodri Power Station	16-Oct-2023	10:00 Hrs.	19-Oct-2023		approved	May be given subject to UP consent.
3	400 KV Rishikesh-Roorkee (PTCUL)	Planned	sldcuk_sd	211th OCC	Daily	Preventive maintenance of bay and replacement of insulator	16-Oct-2023	09:00 Hrs.	16-Oct-2023		approved	May be given subject to real time Grid conditions.
4	400 KV Rishikesh-Nehtaur (PTCUL)	Planned	sldcuk sd	211th OCC	Daily	Preventive maintenance of bay and replacement of insulator	17-Oct-2023	09:00 Hrs.	17-Oct-2023		approved	May be given subject to real time Grid conditions.

# 211th OCC second additional shutdown list of Rajasthan for September-2023

S	.No.	No. Voltage level	Name	Cat	Di	ate	Timings	5	Type of Shutdown(daily/	Reason	Shutdown Status	OCC Remarks
	S.No. Voltag	C			From	То	From	То	Continous Basis)			
	1	400kV	400kV Akal-Kankani - I	A	20.09.2023	30.09.2023	09:00Hrs	18:00Hrs	Continous	For Shifting / raising work of Line (BHARAT MALA	approved	May be given subject availibility of other circuit in the corridor.  Curtailment in Rajasthan wind generation may be needed based
	2	400kV	40kV Jaisalmer (Bhensara) - Kankani	A	20.09.2023	30.09.2023	09:00Hrs	18:00Hrs	Continous	PROJECT)	approved	on real time Grid conditions.

		Name of								Requested				
	occ	Requesting				Daily/		Requested	Requested	То	Requested		Shutdown	
Sr No	Number	Agency	Element Type	Element Name	Owner	Continous	Reason	From Date	From Time	Date	To Time	Requester Remarks	Status	OCC Remaks
1	211	PPGCL_BARA	LINE	400kv Line#2 Tie Breaker 412	PPGCL-BARA	Continuous	To construct equipment foundations for FGD - 15 no's	20-Sep-23	9:00	5-Nov-23	18:00	Power Evacuation will be available through 400KV CKT-1&2 & 765KV CKT-2 ( only Tie Breaker 412 of 400KV Line-2 will be opened,power evacuation of 400KV Line-2 will be continued through CB 411)	approved	May be given subject to UP consent.

#### PLANNED SHUT DOWN FOR THE MONTH OF October- 2023 WHICH ARE TO BE APPROVED BY OCC

Name of Transmission Zone : Uttar Pradesh Power Transmission Corporation Limited

SI.		Details of Transmission Line	Category to	Dat	te	Timin	ngs		"Outage Mode			
No.	Voltage	Name of Transmission Elements	which	From	То	From	То	Reason	(Daily/	Remarks	Shutdown Status	OCC Remarks
	Level		transmission on					* For bay Maintenance work and CB Timing work. The	Continuous)" CONTINUOUS S/D			Marcha siran subinet to and
1	400kV	400kV TRANFER BUS BAR at 400KV SAROJINI NAGAR, LUCKNOW	A	19-Oct-23	19-Oct-23	9:00:00	18:00:00	Shutdown of 80 MVAR Bus X reactor will be required simulateneously as 80 MV	CONTINUOUS S/D		approved	May be given subject to real time Grid conditions.
2	400kV	400kV BUS REACTR BAY 80MVAR SHUNT REACTR 400KV SAROJINI NAGAR, LUCKNOW	А	19-Oct-23	19-Oct-23	9:00:00	18:00:00	* For Annual Maintenance of 80 MVAR Bus Reactor.The Shutdown will be X required along with 400 KV Transfer Bus which is applie	CONTINUOUS S/D		approved	May be given subject to real time Grid conditions.
3	400kV	400/220kV 315MVA T/F 3 at 400KV GR. NOIDA	А	8-Oct-23	8-Oct-23	10:00:00	15:00:00	* Routine testing work will be carried out of mentioned ICT during this X shutdown period.	CONTINUOUS S/D		approved	May be given subject to real time Grid conditions.
4	400kV	400kV POWER GRID BAY at 400KV AGRA	А	6-Oct-23	6-Oct-23	9:00:00	17:00:00	* Annual routine maintenance of 400 kV Power Grid bay at 400 kV S/s Agra	CONTINUOUS S/D		approved	May be given subject to real time Grid conditions.
5	400kV	400kV I/C-315MVA T/F 3 at 400KV AGRA	А	20-Oct-23	21-Oct-23	9:00:00	17:00:00	* Annual maintenance of 400 & 220 kV Bays with CT/CB/ICT of ICT-3 at X 400 kV S/s Agra	DAILY S/D		approved	May be given subject to real time Grid conditions.
6	400kV	400kV BAY 405 at 765KV FATEHABAD AGRA	А	11-Oct-23	11-Oct-23	14:00:00	17:00:00	* For rectification of Status of CB and checking remote operation by SCADA X Engineer	DAILY S/D		approved	May be given subject to real time Grid conditions.
7	400kV	Bay-404 at UPRVUNL, HARDUAGANJ	А	03.10.2023	03.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
8	400kV	Bay-405 at UPRVUNL, HARDUAGANJ	А	04.10.2023	05.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
9	400kV	Bay-406 at UPRVUNL, HARDUAGANJ	А	06.10.2023	06.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
10	400kV	Bay-407 at UPRVUNL, HARDUAGANJ	А	07.10.2023	07.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
11	400kV	Bay-408 at UPRVUNL, HARDUAGANJ	А	09.10.2023	10.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
12	400kV	Bay-409 at UPRVUNL, HARDUAGANJ	А	11.10.2023	11.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
13	400kV	Bay 410 at UPRVUNL, HARDUAGANJ	А	12.10.2023	12.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
14	400kV	Bay-411 at UPRVUNL, HARDUAGANJ	А	13.10.2023	14.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
15	400kV	Bay-412 at UPRVUNL, HARDUAGANJ	А	16.10.2023	16.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
16	400kV	Bay-401 at UPRVUNL, HARDUAGANJ	А	17.10.2023	17.10.2023	08:00 Hrs	18:00Hrs	For 400kV CT Testing	DAILY S/D	For routine testing and preventive maintanance of 400kV Current Transformer (CT)	approved	May be given subject to real time Grid conditions.
17	400kV	400kv Line 2 Tie Breaker 412 at PPGCL-BARA	А	20.09.2023	05.11.2023	9:00:00	18:00:00	To construct equipment foundations for FGD - 15 no's	CONTINUOUS S/D	Power Evacuation will be available through 400KV CKT-1&2 & 765KV CKT-2 ( only Tie Breaker 412 of 400KV Line-2 will be opened,power evacuation of 400KV Line-2 will be continued through CB 411)	approved	May be given subject to real time Grid conditions.
18	400kV	400kV Hapur(WUPPTCL) - Meerut (PMSTL) Line	А	27-Oct-23	27-Oct-23	9:00:00	11:00:00	For Line Maintenance and bay equipment testing	CONTINUOUS S/D		approved	May be given subject to real time Grid conditions.

### Sub: Shutdown (complete) of 320 MVA, 220/132/66 KV Grid Station Hiranagar

JKSLDC has requested for complete shutdown of 320 MVA, 220/132/66 KV Grid Station Hiranagar on 19-09-2023 from 1500 hrs to 18:00 hrs by JK SDC.

## **NLDC/NRLDC Comments:**

### **Shutdown Status:**

approved

## LIST OF ADDITIONAL SHUTDOWNS PROPOSED FOR APPROVAL IN OCC-211 MEETING (PLANNED SHUTDOWNS)

FROM: GM-RTAMC, New Delhi

DATE:-' 13/09/23

SE(OPN), NRPC, N DELHI GM (SO-1), NRLDC TO: Copy:

Following Additional S/D are required during the month of OCT, 2023 for 211th OCC. Kindly accord your approval so that site mobilisation may be arranged accordingly.

S.No.					DURATI						
	ELEMENTS	OWNER	MODE	FR: DATE	OM TIME	DATE TO	TIME	PURPOSE	Remarks	S/d Status	OCC Remarks
	765kV/400kV/220kV/132kV Lines			DATE	IIVIE	DATE	IIIVIE				
3	765KV BHIWANI-PHAGI(JPR)-I	POWERGRID	DAILY	6-Oct-23	08:00	9-Oct-23	19:00	Shut down for Line maintenance work & cleaning of insulator and defect rectification work.	Other Ckt put in Non-auto mode	approved	ATC Curtailment of 200 MW in NR Import
4	765KV BHIWANI-PHAGI(JPR)-I	POWERGRID	DAILY	1-Oct-23	09:00	31-Oct-23	19:00	Only Non auto mode for Tower rectification work		approved	
5	400KV ROORKI-KASHIPUR-I	POWERGRID	DAILY	4-Oct-23	10:00	6-Oct-23	19:00	Line Maintenenace work eg.Loping & choping of tree branch	Other Ckt put in Non-auto mode	approved	
6	400KV ROORKI-KASHIPUR-II	POWERGRID	DAILY	7-Oct-23	11:00	9-Oct-23	19:00	Line Maintenenace work eg.Loping & choping of tree branch	Other Ckt put in Non-auto mode	approved	
7	400KV JIND-KURUKSHETRA-II	POWERGRID	DAILY	16-Oct-23	07:00	16-Oct-23	20:00	For current injection point for Bus-3 for Busbar Relay Testing after HV test of ICT-3 bays.		approved	
9	400 KV ATAUR-INDIRAPURAM (UP) CKT-2	WUPPTCL	DAILY	20-Sep-23	10:00	21-Sep-23	16:00	For connection of LILO at Noida	The construction work of LILO of one circuit of 400 kV Ataur (WUPPTCL)- Indirapuram (WUPPTCL) D/C Quad Moose line at 400kV GIS Substation NOIDA Sector-123	approved	subject to UP consent.
10	400 KV ATAUR-INDIRAPURAM (UP) CKT-1	WUPPTCL	DAILY	20-Sep-23	10:00	21-Sep-23	16:00	For connection of LILO at Noida	The construction work of LILO of one circuit of 400 kV Ataur (WUPPTCL)- Indirapuram (WUPPTCL) D/C Quad Moose line at 400kV GIS Substation NOIDA Sector-123	approved	subject to UP consent.
13	220 KV D/C Daultabad-Manesar	HVPNL	Continuous	1-Oct-23	08:00	10-Oct-23	18:00	Diversion work for NCRTC Delhi-Gurgaon - Rewari SNB RRtS		approved	subject to haryana consent.
14	220 KV ASEJOL_HB FTGH2 -ASEJOL_WIND FTGH2 (ASEJOL) CKT-1	ADANI	DAILY	25-Sep-23	19:00	28-Sep-23	23:00	Overhead crossing i.e. Stringing work of 400kV D/C Ramgarh II (Fatchgarh-III) – Fatchgarh II transmission Line	Keeping in View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. Ltd. line, shutdown is required in day hours only.	approved	May be given from 1900 Hrs
15	400 KV FATEHGARH_II(PG)-FATEHGARH POOLING(FBTL) (FBTL) CKT-1	)WERGRID/ADA	DAILY	28-Sep-23	19:00	30-Sep-23	23:00	Tower Erection and stringing work in 400kV D/C Ramgarh II (Fatchgarh-III) – Fatchgarh II transmission Line	Keeping in View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. Ltd. line, shutdown is required in day hours only.	approved	May be given from 1900 Hrs
16	220 kV M/C line Fatehgarh-II to 180MW Solar PSS Devikot - (27/1-27/2)	NTPC	DAILY	4-Oct-23	17:00	6-Oct-23	23:00	Overhead crossing i.e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) – Fatehgarh II transmission Line	Keeping in View of safety aspects and difficulty in power line crossing work in night hours & in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. Ltd. line, shutdown is required in day hours only.	approved	May be given from 1700 Hrs
17	220 KV S/C Chirawa-Khetri Transmission Line	RRVPNL	DAILY	26-Oct-23	07:00	29-Oct-23	19:00	Stringing of 765 kV D/C Khetri-Narela TL		approved	subject to rajasthan consent.
18	132 KV S/C Khetri-Buhana Transmission Line	RRVPNL	DAILY	20-Oct-23	07:00	23-Oct-23	19:00	Stringing of 765 kV D/C Khetri-Narela TL		approved	subject to rajasthan consent.
19	132 KV D/C Dhanonda Nangal Mohanpur Transmission Line	HVPNL	DAILY	18-Oct-23	07:00	21-Oct-23	19:00	Stringing of 765 kV D/C Khetri-Narela TL		approved	subject to haryana consent.
20	132 KV S/C Mahendragarh- Kanina Transmission Line	HVPNL	DAILY	18-Oct-23	07:00	21-Oct-23	19:00	Stringing of 765 kV D/C Khetri-Narela TL		approved	subject to haryana consent.
	400/220kV ICT										
1	765KV/400KV BANASKANTHA-ICT-I	PG-WR2-	DAILY	10-Oct-23	09:00	10-Oct-23	15:00	FOR SWITCHING OF SPARE ICT UNIT WITH B PHASE OF ICT #1. DIA TO BE KEPT OPEN AT BOTH SIDES.	S/D Requested by WR-2	approved	ATC Curtailment of 650 MW in NR Export. Subjected to WRPC approval

2	765KV/400KV BANASKANTHA-ICT-2	PG-WR2-	DAILY	11-Oct-23	09:00	11-Oct-23	18:00	Yearly AMP. DIA TO BE KEPT OPEN AT BOTH SIDES	S/D Requested by WR-2	approved	ATC Curtailment of 650 MW in NR Export. Subjected to WRPC approval
	400/220kV BUS										
1	400KV Bus -1 400 kV Jaisalmer-II(RS)	RRVPNL	Daily	21.09.2023	15:00	23.09.2023	23:00	For Bay extention work for 400kV Fatehgarh-2 Fatehgarh-3 D/C under PRTL		approved	May be given from 1500 Hrs
2	400KV Bus -2 400 kV Jaisalmer-II(RS)	RRVPNL	Daily	24.09.2023	15:00	26.09.2023	17:00	For Bay extention work for 400kV Fatehgarh-2 Fatehgarh-3 D/C under PRTL		approved	May be given from 1500 Hrs
	765KV/400/220kV Bays										
1	714 TIE BAY - 765/400 KV 1500 MVA ICT 1 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)	POWERGRID	Daily	20.10.2023	17:00	30.10.2023	05:00	for Commissioning & erection of Bay equipment in 713 & 716 Bay	Aforementioned has shall be kent under shutdown till commissioning of Bay 713 and 716 Bay	approved	
2	717 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT BHADLA_2 (PG) (POWERGRID) AND FUTURE AT 765 KV BHADLA_2 (PG) (POWERGRID)	POWERGRID	Daily	20.10.2023	17:00	30.10.2023	05:00	for Commissioning & erection of Bay equipment in 713 & 716 Bay	Commissioning of Bay no 713 and 716 is expected by October 2023.		
3	Future Bay 713 Fatehgarh-2 Ckt-1 & future Bay 716 Fatehgarh-2 Ckt-2 at Bhadla-2	POWERGRID	Daily	20.10.2023	17:00	30.10.2023	05:00	for Commissioning & erection of Bay equipment in 713 & 716 Bay		approved	
4	A215 BAY 220 KV BUS 4A & BUS 4B SECTIONALIZER AT FATEHGARH- 2 S/S	POWERGRID	DAILY	19.10.2023	17:00	15.10.2023	23:00	Construction related works of Phase II (Jumpering and bay extension work of new bays of Phase II)		approved	Element must remain in service via other bay.
5	400kV Bay 408 at Kurukshetra S/s	POWERGRID	Continuous	23.10.2023	08:00	30.10.2023	17:00	For 400kV GIS CB rectification works		approved	Element must remain in service via other bay.
	STATCOM										
1	STATCOM-1 at 400 k V Bhadla- II S/s	POWERGRID	Continuous	22.09.2023	09:00	28.09.2023	20:00	For Erection, Testing & commissioning of Auxiliary Transformer Branch and completing balance work like PU coating, RTV coating, etc.		approved	
2	STATCOM-2 at 400 k V Bhadla- II S/s	POWERGRID	Continuous	30.09.2023	09:00	06.10.2023	20:00	For Erection, Testing & commissioning of Auxiliary Transformer Branch and completing balance work like PU coating, RTV coating, etc.		approved	

SI. No.		Date		Tim	nings	Reason	"Outage Mode	Remarks	Shutdown Status	OCC Remaks
31. INU.	Name of Transmission Elements	From	То	From	То		(Daily/	Remarks	Silutuowii Status	OCC Relians
1	220KV GIS Bus 1 at 220/66KV S/S LEH	3-Oct-23	6-Oct-23	0.00	17:00	S/d for Bay Extn work at 220kV Phyang GIS substation	Continous			subject to consent from
	220KV GIS BUS 1 at 220/66KV 5/5 LEH	3-001-23	6-UCI-23				Continous		approved	NHPC and LEH
	220/04 CIS Bur 2 -+ 220/CS/04 C/S LELL	7.0-+ 22	10-Oct-23	0.00	17.00	S/d for Bay Extn work at 220kV Phyang GIS substation	Continous			subject to consent from
	220KV GIS Bus 2 at 220/66KV S/S LEH	7-Oct-23	10-Oct-23				Continous		approved	NHPC and LEH
2	220/66KV ICT 2 at LEH	3-Oct-23	10-Oct-23	0.00	17:00	S/d for Bay Extn work at 220kV Phyang GIS substation	Continous			subject to consent from
3	220/00KV ICT 2 at LEH	3-001-23	10-001-23	8.00	17.00		Continous		approved	NHPC and LEH

#### FORMAT I(A): REQUEST FOR TRANSMISSION ELEMENT OUTAGE TO RPC

-							(SHUTDOWNS)								
INDENT	ING AGENCY		PGCIL, CPCC (NR-III),Lucknow	FOR THE M	ионтн	AUG'23			DAT	E	DD:MM:YY	ΥΥ			
<u> </u>			LINE DETAILS						ļ.,	חספרי	D DATE AND TIME				
	NAME OF	VOLT	LINE DETAILS				DAILY/	REASON	FRO		TO		Remarks	S/d Status	OCC Remarks
S.N.	REQUESTIN G AGENCY	LEVEL	LINE DETAILS	OWNER	CKT ID	INTER/ INTRA REGIONAL	CONTINUO		DATE		DATE	TIME			
1	POWERGRID _NR3	(KV)	400KV Agra - Ballabgarh Ckt 1			Intra	D	A/R non auto mode for attending the Hot spot by Hot line method.	26-Sep-2023	8:00	26-Sep-2023	18:00		approved	
2	POWERGRID _NR3		765kV Varanasi-Gaya Ckt I			Inter	D	for insulator cleaning as part of winter preparedness	15-Oct-2023	8:00	15-Oct-2023	18:00		approved	Subjected to ERPC approval
3	POWERGRID _NR3		765kV Varanasi-Gaya Ckt II			Inter	D	for insulator cleaning as part of winter preparedness	16-Oct-2023	8:00	16-Oct-2023	18:00		approved	Subjected to ERPC approval
4	POWERGRID _NR3		765kV Varanasi - Balia			Intra	D	for insulator cleaning as part of winter preparedness	17-Oct-2023	8:00	17-Oct-2023	18:00		approved	Subjected to ERPC approval
5	POWERGRID _NR3		400kV Allahabad - Varanasi			Intra	D	for insulator cleaning as part of winter preparedness	18-Oct-2023	8:00	18-Oct-2023	18:00		approved	
6	POWERGRID _NR3		400kV Sasaram-Allahabad			Inter	D	for insulator cleaning as part of winter preparedness	19-Oct-2023	8:00	19-Oct-2023	18:00		approved	Subjected to ERPC approval
7	POWERGRID _NR3		400kV Sasaram-Varanasi			Inter	D	for insulator cleaning as part of winter preparedness	20-Oct-2023	8:00	20-Oct-2023	18:00		approved	Subjected to ERPC approval
8	POWERGRID _NR3		400kV Lucknow-Shajahanpur Ckt I			Intra	D	for insulator cleaning as part of winter preparedness	21-Oct-2023	8:00	21-Oct-2023	18:00		approved	
9	POWERGRID _NR3		400kV Lucknow-Shajahanpur Ckt II			Intra	D	for insulator cleaning as part of winter preparedness	22-Oct-2023	8:00	22-Oct-2023	18:00		approved	
10	POWERGRID _NR3		400kV Fatehpur-Mainpuri Ckt I			Intra	D	for insulator cleaning as part of winter preparedness	23-Oct-2023	8:00	23-Oct-2023	18:00		approved	
11	POWERGRID _NR3		400kV Fatehpur-Mainpuri Ckt II			Intra	D	for insulator cleaning as part of winter preparedness	24-Oct-2023	8:00	24-Oct-2023	18:00		approved	
12	POWERGRID _NR3		400kV Bareilly - Moradabad Ckt I			Intra	D	for insulator cleaning as part of winter preparedness	26-Oct-2023	8:00	26-Oct-2023	18:00		approved	
13	PGYTL		400kV Rampur -Moradabad Ckt I			Intra	D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV Ghatampur-Hapur line at 765/400/220kV GIS SS Rampur	05-Oct-2023	8:00	05-Oct-2023	18:00		approved	
14	POWERGRID _WR2		765KV-VINDHYACHAL(PS)-JABALPUR-2			Inter	D	FOR AMP WORK OF LINE TERMINAL EQUIPMENT. DIA TO BE KEPT OPEN AT BOTH ENDS. FOR REACTOR AMP WORK & FOR SPARE ROTATION AT JABALPUR (DUE ON	07-Oct-2023	9:30	07-Oct-2023	18:30		approved	ATC Curtailment of 1100 MW in NR Import
16	POWERGRID _WR2		765KV-SATNA-BINA-2			Inter	D	For AMP of Line terminal equipment AND LINE AMP WORKS DIA TO BE KEPT OPEN AT BOTH ENDS.	04-Oct-2023	9:15	04-Oct-2023	18:15		approved	ATC Curtailment of 750 MW in NR Import
17	POWERGRID _WR2		765KV-SATNA-BINA-1			Inter	D	For AMP of Line reactor AND LINE AMP WORKS. DIA TO BE KEPT OPEN AT BOTH ENDS.	16-Oct-2023	9:15	16-Oct-2023	18:15		approved	ATC Curtailment of 750 MW in NR Import
18	POWERGRID _WR2		765KV-VADODARA-DHULE-1			Inter	D	be kept open at both ends.	10-Oct-2023	9:00	10-Oct-2023	18:00		approved	ATC Curtailment of 600 MW in NR Export
19	POWERGRID _WR2		765KV-INDORE-VADODARA-1			Inter	D	Line insulator replacement work Loc 576 AND LINE TERMINAL EQUIPMENT WORKS AND REACTOR AMP WORKS AT INDORE END. Dia to be kept open at both ends.	13-Oct-2023	8:00	13-Oct-2023	18:00		approved	ATC Curtailment of 700 MW in NR Export
20	POWERGRID _WR2		765KV-VADODARA-DHULE-1			Inter	D	Spare reactor free from Y ph & Yearly AMP work at Vadodara end. Dia to be kept open at both ends.	20-Oct-2023	9:00	20-Oct-2023	18:00		approved	ATC Curtailment of 600 MW in NR Export

21	POWERGRID _WR2		765KV-VINDHYACHAL(PS)-JAE	BALPUR-1			Inter	D	For Line terminal equipment AMP work at Vindhyachal PS. Dia to be kept open at both ends. For Reactor AMP work and spare rotation work at Vindhyachal PS	11-Oct-2023	9:00	11-Oct-2023	18:00		approved
22	POWERGRID _WR2		765KV/400KV BANASKANTH	HA-ICT-1			Inter	D	FOR SWITCHING OF SPARE ICT UNIT WITH B PHASE OF ICT #1. DIA TO BE KEPT OPEN AT BOTH SIDES.	10-Oct-2023	9:00	10-Oct-2023	15:00		approved
23	POWERGRID _WR2		765KV/400KV BANASKANTH	HA-ICT-2			Inter	D	Yearly AMP. DIA TO BE KEPT OPEN AT BOTH SIDES	11-Oct-2023	9:00	11-Oct-2023	18:00		approved
24	POWERGRID _WR2		765KV-SATNA-VINDHYACH <i>A</i>	AL(PS)-1			Inter	D	For rectification of shutdown nature defects . Dia to be kept open at both ends	05-Oct-2023	8:00	05-Oct-2023	18:00		approved
25	POWERGRID _WR2		765KV-SATNA-VINDHYACHA	AL(PS)-2			Inter	D	For rectification of shutdown nature defects . Dia to be kept open at both ends	06-Oct-2023	8:00	06-Oct-2023	18:00		approved
29	POWERGRID _WR2		765KV-GWALIOR-JAIPU	IR-1			Inter	D	AMP Works of Line. DIA TO BE KEPT OPEN AT BOTH ENDS.	03-Oct-2023	9:00	04-Oct-2023	18:00		approved
30	POWERGRID _WR2		765KV-GWALIOR-JAIPU	IR-2			Inter	D	AMP Works of Line. DIA TO BE KEPT OPEN AT BOTH ENDS.	05-Oct-2023	9:00	06-Oct-2023	18:00		approved
31	POWERGRID _WR2		765KV-GWALIOR-ORA	l-1			Inter		To take Spare LR in service(Spare Changeover) at Gwalior end. DIA TO BE KEPT OPEN AT BOTH ENDS.	14-Oct-2023	9:00	14-Oct-2023	12:00		approved
33	POWERGRID _ER1		400KV-GAYA-CHANDW	'A-1			Intra	D	Fixing of Jumper Spacer Keeper, Arcing Horn, Bird Guard & Other Shutdown type defects rectification works. A/R of 400KV-GAYA- CHANDWA-2 in Non Auto Mode	11-Oct-2023	9:00	11-Oct-2023	18:00		approved
34	POWERGRID _ER1		400KV-GAYA-CHANDW				Intra	D	Fixing of Jumper Spacer Keeper, CC Ring N&B, Bird Guard & Other Shutdown type defects rectification works. A/R of 400KV-GAYA- CHANDWA-1 in Non Auto Mode	12-Oct-2023	9:00	12-Oct-2023	18:00		approved
			FOR	MAT I(B):	REQUEST	FOR BUS	BAY,ICTs,FACTS,FS	Cs,SVCs etc	OUTAGE TO RPC						
II.	IDENTING AGE	ENCY	PGCIL, CPCC (NR-III), LUCKNOW EQUIPMENT DETAILS	FOI	R THE MOI	NTH	Mar-23	-1	DATE	DD:MM:	YYYY	:			
	NAME OF	VOLT			INTER/	DAILY/	_		PROPOSED DATE AND TIME FROM	тс	)	Remarks	S/d Status	OCC Remarks	
S.N	REQUESTIN G AGENCY	LEVEL (KV)	NAME OF ELEMENTS (ICT, B/R, SVC, Bays, etc)	OWNER	INTRA REGION	CONTIN	Reason	DATE	TIME	DATE	TIME				
1	POWERGRID		BLOCK#2 WEST SIDE SHUNT CAPACITOR BANK B2Z24 at VINDHYACHAL HVDC	POWERG RID	INTRA	DAILY	AMP OF BAY EQUIPMENTS. There will no power restriction due to outage of this filter bank. Redundant filter bank B1Z24 will be available for service	06.10.2023	8:00:00	06.10.2023	18:00:00		approved		
2	POWERGRID	400kV	AC SUB-FILTER BANK Z1.Z11 at Rihand HVDC	POWERG RID	INTRA	CONTIN	AMP of Sub Filter Bank - CB-Z11.Q. There shall not be any restriction on HVDC power Flow.	03.10.2023	8:00:00	04.10.2023	18:00:00		approved		
3	POWERGRID	400kV	AC SUB-FILTER BANK Z3.Z31 at Rihand HVDC	POWERG RID	INTRA	CONTIN UOUS	AMP of Sub Filter Bank - CB-Z31.Q. There shall not be any restriction on	05.10.2023	8:00:00	06.10.2023	18:00:00		approved		
							HVDC power Flow.								

any restriction on HVDC power Flow.

ATC Curtailment of 1100 MW in NR Import

ATC Curtailment of 650 MW in NR

ATC Curtailment of 650 MW in NR Export

ATC Curtailment of 750 MW in NR Import

ATC Curtailment of 750 MW in NR Import

ATC Curtailment of 450 MW in NR

ATC Curtailment of 450 MW in NR Import

ATC Curtailment of 400 MW in NR

ATC Curtailment of 400 MW in NR

Import

5	POWERGRID	400kV	AC SUB-FILTER BANK Z2.Z21 at Rihand HVDC	POWERG RID	INTRA	CONTIN	AMP of Sub Filter Bank - CB-221.Q. There shall not be any restriction on HVDC power Flow.	8:00:00	12.10.2023	18:00:00	ap	proved	
6	POWERGRID	400kV	AC SUB-FILTER BANK Z2.Z22 at Rihand HVDC	POWERG RID	INTRA	CONTIN	AMP of Sub Filter Bank - CB-Z22.Q. There shall not be any restriction on HVDC power Flow.	8:00:00	14.10.2023	18:00:00	ap	proved	
7	PRSTL	400kV	400kV BUS-1 at Rampur_PRSTL	UPPTCL	INTRA	DAILY	Validation of Bus CVT Isolator remote operation.	11:00:00	16.10.2023	12:00:00	ap	proved	
8	PRSTL	220kV	220kV BUS-1 at Rampur_PRSTL	UPPTCL	INTRA	DAILY	Validation of Bus CVT Isolator remote operation. 16.10.2023	14:00:00	16.10.2023	15:00:00	ap	proved	
9	PRSTL	400kV	400kV BUS-2 at Rampur_PRSTL	UPPTCL	INTRA	DAILY	Validation of Bus CVT Isolator remote operation. 17.10.2023	11:00:00	17.10.2023	12:00:00	ap	proved	
10	PRSTL	220kV	220kV BUS-2 at Rampur_PRSTL	UPPTCL	INTRA	DAILY	Validation of Bus CVT Isolator remote operation. 17.10.2023	14:00:00	17.10.2023	15:00:00	ap	proved	