



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
उत्तर क्षेत्रीय विद्युत समिति  
Northern Regional Power Committee

**विषय: प्रचालन समन्वय उप-समिति की 234<sup>th</sup> बैठक की कार्यसूची ।**

**Subject: Agenda of the 234<sup>th</sup> OCC meeting.**

प्रचालन समन्वय उप-समिति की 234<sup>th</sup> बैठक का आयोजन वीडियो कॉन्फ्रेंसिंग के माध्यम से दिनांक 14.08.2025 को 10:30 बजे से किया जायेगा। उक्त बैठक की कार्यसूची उत्तर क्षेत्रीय विद्युत समिति की वेबसाइट <http://164.100.60.165> पर उपलब्ध है।


बैठक में सम्मिलित होने के लिए लिंक व पासवर्ड सभी सदस्यों को ई-मेल द्वारा प्रदान किया जाएगा।

कृपया बैठक में उपस्थित होने की सुविधा प्रदान करें।

The 234<sup>th</sup> meeting of the Operation Co-ordination sub-committee will be conducted through Video Conferencing on 14.08.2025 from 10:30 Hrs. The agenda of this meeting has been uploaded on the NRPC web-site <http://164.100.60.165>.

The link and password for joining the meeting will be e-mailed to respective e-mail IDs in due course.

Kindly make it convenient to attend the meeting.

  
(डी. के. मीना) 2/8/25

अधीक्षण अभियंता (प्रचालन)

सेवा में : प्रचालन समन्वय उप समिति के सभी सदस्य।

To : All Members of OCC

## List of addressee (via mail)

| OCC Members for FY 2025-26 |                                      |   |  |
|----------------------------|--------------------------------------|---|--|
| S. No.                     | OCC Member                           | Category  | E-mail   |
| 1                          | NLDC                                 | National Load Despatch Centre   | <a href="mailto:nomination_awaited@susha@grid-india.in">nomination awaited (susha@grid-india.in)</a>   |
| 2                          | NRLDC                                | Northern Regional Load Despatch Centre  | <a href="mailto:somara.lakra@grid-india.in">somara.lakra@grid-india.in</a>   |
| 3                          | CTUIL                                | Central Transmission Utility  | <a href="mailto:sandeepk@powergrid.in">sandeepk@powergrid.in</a>   |
| 4                          | PGCIL                                | Central Government owned Transmission Company   | <a href="mailto:rtamc.nr1@powergrid.in">rtamc.nr1@powergrid.in</a><br><a href="mailto:rtamcjammu@powergrid.in">rtamcjammu@powergrid.in</a><br><a href="mailto:cpcc.nr3@powergrid.in">cpcc.nr3@powergrid.in</a> |
| 5                          | NTPC                                 | Central Generating Company  | <a href="mailto:RAMESHSINGH@NTPC.CO.IN">RAMESHSINGH@NTPC.CO.IN</a>   |
| 6                          | BBMB                                 |   | <a href="mailto:powerc@bbmb.nic.in">powerc@bbmb.nic.in</a>   |
| 7                          | THDC                                 |   | <a href="mailto:ravindrasrana@thdc.co.in">ravindrasrana@thdc.co.in</a>   |
| 8                          | SJVN                                 |   | <a href="mailto:sjvn.cso@sjvn.nic.in">sjvn.cso@sjvn.nic.in</a>   |
| 9                          | NHPC                                 |   | <a href="mailto:surendramishra@nhpc.nic.in">surendramishra@nhpc.nic.in</a>   |
| 10                         | NPCIL                                |   | <a href="mailto:df@npcil.co.in">df@npcil.co.in</a>   |
| 11                         | Delhi SLDC                           | State Load Despatch Centre  | <a href="mailto:gmsldc@delhisldc.org">gmsldc@delhisldc.org</a>   |
| 12                         | Haryana SLDC                         |   | <a href="mailto:cesocomml@hvpn.org.in">cesocomml@hvpn.org.in</a>   |
| 13                         | Rajasthan SLDC                       |   | <a href="mailto:ce.ld@rvpn.co.in">ce.ld@rvpn.co.in</a>   |
| 14                         | Uttar Pradesh SLDC                   |   | <a href="mailto:ceps@upsldc.org">ceps@upsldc.org</a>   |
| 15                         | Uttarakhand SLDC                     |   | <a href="mailto:se_sldc@ptcul.org">se_sldc@ptcul.org</a>   |
| 16                         | Punjab SLDC                          |   | <a href="mailto:ce-sldc@pstcl.org">ce-sldc@pstcl.org</a>   |
| 17                         | Himachal Pradesh SLDC                |   | <a href="mailto:cehpsldc@gmail.com">cehpsldc@gmail.com</a>   |
| 18                         | DTL                                  | State Transmission Utility  | <a href="mailto:bl.gujar@dtl.gov.in">bl.gujar@dtl.gov.in</a>   |
| 19                         | HVPNL                                |   | <a href="mailto:cetspk1@hvpn.org.in">cetspk1@hvpn.org.in</a>   |
| 20                         | RRVNL                                |   | <a href="mailto:ce.ppm@rvpn.co.in">ce.ppm@rvpn.co.in</a>   |
| 21                         | UPPTCL                               |   | <a href="mailto:smart.saxena@gmail.com">smart.saxena@gmail.com</a>   |
| 22                         | PTCUL                                |   | <a href="mailto:ce_oandmk@ptcul.org">ce_oandmk@ptcul.org</a>   |
| 23                         | PSTCL                                |   | <a href="mailto:ce-tl@pstcl.org">ce-tl@pstcl.org</a>   |
| 24                         | HPPTCL                               |   | <a href="mailto:gmprojects.tcl@hpmail.in">gmprojects.tcl@hpmail.in</a>   |
| 25                         | IPGCL                                | State Generating Company  | <a href="mailto:ncsharma@ipgcl-ppcl.nic.in">ncsharma@ipgcl-ppcl.nic.in</a>   |
| 26                         | HPGCL                                |   | <a href="mailto:seom2.rgtpp@hpgcl.org.in">seom2.rgtpp@hpgcl.org.in</a>   |
| 27                         | RRVUNL                               |   | <a href="mailto:ce.ppmcit@rrvun.com">ce.ppmcit@rrvun.com</a>   |
| 28                         | UPRVUNL                              |   | <a href="mailto:cgm.to@uprvunl.org">cgm.to@uprvunl.org</a>   |
| 29                         | UJVNL                                |   | <a href="mailto:gm_engg_ujvn@yahoo.co.in">gm_engg_ujvn@yahoo.co.in</a>   |
| 30                         | HPPCL                                |   | <a href="mailto:gm_generation@hppcl.in">gm_generation@hppcl.in</a>   |
| 31                         | PSPCL                                | State Generating Company & State owned Distribution Company                               | <a href="mailto:ce-ppr@pspcl.in">ce-ppr@pspcl.in</a>   |
| 32                         | DHBVN                                | State owned Distribution Company (alphabetical rotational basis/nominated by state govt.) | <a href="mailto:nomination_awaited(md@dhbvn.org.in)">nomination awaited (md@dhbvn.org.in)</a>  |
| 33                         | Ajmer Vidyut Vitran Nigam Ltd.       |   | <a href="mailto:nomination_awaited(md.avvnl@rajasthan.gov.in)">nomination awaited (md.avvnl@rajasthan.gov.in)</a>  |
| 34                         | Purvanchal Vidyut Vitaran Nigam Ltd. |   | <a href="mailto:nomination_awaited(mdpurvanchalvvn@gmail.com)">nomination awaited (mdpurvanchalvvn@gmail.com)</a>  |

|    |   |  |   |
|----|---|--|---|
| 35 | UPCL  |  | <a href="mailto:cgmupcl@yahoo.com">cgmupcl@yahoo.com</a>  |
| 36 | HPSEB   |  | <a href="mailto:cesysophpsebl@gmail.com">cesysophpsebl@gmail.com</a>  |
| 37 | Prayagraj Power Generation Co. Ltd.           | IPP having more than 1000 MW installed capacity  | <a href="mailto:sanjay.bhargava@tatapower.com">sanjay.bhargava@tatapower.com</a>                                |
| 38 | Aravali Power Company Pvt. Ltd                |  | <a href="mailto:amit.hooda01@apcpl.co.in">amit.hooda01@apcpl.co.in</a>  |
| 39 | Apraave Energy Ltd.,                          |  | <a href="mailto:niraj.gupta@apraava.com">niraj.gupta@apraava.com</a>  |
| 40 | Talwandi Sabo Power Ltd.                      |  | <a href="mailto:ravinder.thakur@vedanta.co.in">ravinder.thakur@vedanta.co.in</a>                                |
| 41 | Nabha Power Limited                           |  | <a href="mailto:Durvesh.Yadav@larsentoubro.com">Durvesh.Yadav@larsentoubro.com</a>                              |
| 42 | MEIL Anpara Energy Limited                    |  | <a href="mailto:arun.tholia@meilanparapower.com">arun.tholia@meilanparapower.com</a>                            |
| 43 | Rosa Power Supply Company Ltd                 |  | <a href="mailto:Suvendu.Dey@relianceada.com">Suvendu.Dey@relianceada.com</a>                                    |
| 44 | Lalitpur Power Generation Company Ltd         |  | <a href="mailto:avinashkumar.ltp@lpgcl.com">avinashkumar.ltp@lpgcl.com</a>                                      |
| 45 | MEJA Urja Nigam Ltd.                          |  | <a href="mailto:rsjuneja@ntpc.co.in">rsjuneja@ntpc.co.in</a>  |
| 46 | Adani Power Rajasthan Limited                 |  | <a href="mailto:manoj.taunk@adani.com">manoj.taunk@adani.com</a>  |
| 47 | JSW Energy Ltd. (KWHEP)                       |  | <a href="mailto:roshan.zipta@jsw.in">roshan.zipta@jsw.in</a>  |
| 48 | Transition Cleantech Services Private Limited | IPP having less than 1000 MW installed capacity (alphabetical rotational basis)  | <b>nomination awaited</b><br>( <a href="mailto:kswamidoss@evrenenergy.com">kswamidoss@evrenenergy.com</a> )     |
| 49 | UT of J&K                                     | From each of the Union Territories in the region, a representative nominated by the administration of the Union Territory concerned out of the entities engaged in generation/ transmission/ distribution of electricity in the Union Territory. | <a href="mailto:sojpdd@gmail.com">sojpdd@gmail.com</a>  |
| 50 | UT of Ladakh                                  |  | <a href="mailto:cepdladakh@gmail.com">cepdladakh@gmail.com</a>  |
| 51 | UT of Chandigarh                              |  | <a href="mailto:seelo-chd@nic.in">seelo-chd@nic.in</a>  |
| 52 | Tata Power Delhi Distribution Limited         | Private Distribution Company in region (alphabetical rotational basis)   | <b>nomination awaited</b><br>( <a href="mailto:sandeep.k@tatapower-ddl.com">sandeep.k@tatapower-ddl.com</a> )   |
| 53 | Gurgaon Palwal Transmission Limited           | Private transmission licensee (nominated by central govt.)   | ( <a href="mailto:samriddhi.gogoi@indigrid.com">samriddhi.gogoi@indigrid.com</a> )                              |
| 54 | PTC India Limited                             | Electricity Trader (nominated by central govt.)  | <b>nomination awaited</b><br>( <a href="mailto:bibhuti.prakash@ptcindia.com">bibhuti.prakash@ptcindia.com</a> ) |

## Contents

|  |    |
|--|----|
| A.1. Confirmation of Minutes.....  | 6  |
| A.2. Status of action taken on decisions of 233 <sup>rd</sup> OCC meeting of NRPC.....   | 6  |
| A.3. Review of Grid operations.....  | 6  |
| A.4. Maintenance Programme of Generating Units and Transmission Lines.....   | 7  |
| A.5. Planning of Grid Operation.....   | 7  |
| A.6. Follow-up of issues from previous OCC Meetings- Status update.....  | 8  |
| A.7. NR Islanding scheme.....  | 8  |
| A.8. Coal Supply Position of Thermal Plants in Northern Region.....  | 9  |
| A.9. Periodic testing of generators and FACTS/HVDC Devices (Agenda by NRPC Sectt.).  | 10 |
| A.10. Flexible Operation of Coal Based Thermal Power Plants (Agenda by NRPC Secretariat)   | 11 |
| A.11. Unit-wise Planned Maintenance schedule of Generating Units for the year 2026-27 (Agenda by NRPC Secretariat).....  | 12 |
| A.12. Approval of SPS at 400kV substation Bareilly (Agenda by UPSLDC).....   | 12 |
| A.13. Approval of SPS at 400 kV substation Panki (Agenda by UPSLDC).....   | 12 |
| A.14. Agenda on Varanasi Islanding Scheme (Agenda by UPSLDC).....  | 13 |
| A.15. SOP for diversion of RPC approved spare Transformers/Reactors to constituents/state transmission utilities (Agenda by Powergrid NR-1).....                           | 14 |
| A.16. Installation of 315 MVA 400/220kV Synthetic Ester Oil based Transformer in Delhi-NCR (Agenda by Powergrid NR-1).....   | 17 |
| A.17. Operational Reliability Concerns Arising from Frequent Switching of MSR/MSC Circuit Breakers in STATCOMs at Renewable Energy Complexes (Agenda by Powergrid NR-1)... | 18 |
| A.18. Regarding frequent/repetitive faults in 220KV Lines (Agenda by Powergrid NR-2)   | 19 |
| A.19. Rectification of Normal-Intermediate-Transfer scheme of 400kV RASRA-MAU transmission line at RASRA UPPTCL end (Agenda by Powergrid NR-3).....                        | 20 |
| A.20. Shutdown of 500kV HVDC Rihand-Dadri CKT- I&II for Construction 765kV Bareilly-Neemrana D/C line for Power line crossing work (Agenda by Powergrid NR-3).....         | 20 |
| B.1. NR Grid Highlights for July 2025.....   | 21 |
| B.2. State-wise transmission constraints in monsoon 2025 and SPS proposals.....  | 24 |
| B.3. Delay in revival of 400kV Jaisalmer-Barmer D/C and issues during present high wind season   | 30 |
| B.4. SPS for Champa-Kurukshetra HVDC and SOP actions in case of tripping.....  | 33 |
| B.5. Minimizing deviation against scheduled drawl by state control area.....   | 36 |
| B.6. Delay in return of shutdown of Transmission elements and prolonged outage of elements affecting grid operation.....   | 38 |
| B.7. Demand forecasting and resource adequacy related.....   | 41 |
| B.8. Near real-time monitoring of silt at NRLDC for hydro generating stations.....   | 43 |
| B.9. Mock testing of islanding scheme and simulation studies.....  | 45 |
| B.10. Multiple element tripping events in Northern region in the month of July 2025:....   | 46 |

|       |   |    |
|-------|---|----|
| B.11. | Status of submission of DR/EL and tripping report of utilities for the month of July 2025:  | 47 |
| B.12. | Frequency response performance for the reportable events of month of July 2025:   | 47 |
| B.13. | Mock testing of System Protection Schemes (SPS) in Northern Region.....   | 53 |
| B.14. | Voltage oscillations observed in the Rajasthan RE complex – Revision of NOC restriction for Northern Region ISGS RE plants whose GNA is yet to be effective and being scheduled under deemed T-GNA..... | 55 |

**खण्ड-क: उ.क्षे.वि.स.****Part-A: NRPC****A.1. Confirmation of Minutes**

233<sup>rd</sup> OCC meeting was held on 15.07.2025. Minutes of the meeting were issued vide letter dt. 09.08.2025. No comments received till date.

**Decision required from Forum:**

*Forum may approve the minutes of 233<sup>rd</sup> OCC meeting.*

**A.2. Status of action taken on decisions of 233<sup>rd</sup> OCC meeting of NRPC**

A.2.1. Status of action taken on decisions of 233<sup>rd</sup> OCC meeting is attached as **Annexure- A.I.**

**A.3. Review of Grid operations****A.3.1. Power Supply Position (Provisional) for July 2025**

Anticipated Power Supply Position v/s Actual Power Supply Position (Provisional) of Northern Region during the month of July-2025 is as under:

| State / UT       | Req. / Avl. | Energy (MU)  |         |              | Peak (MW)    |        |              |
|------------------|-------------|--------------|---------|--------------|--------------|--------|--------------|
|                  |             | Anticipate d | Actua l | % Variatio n | Anticipate d | Actual | % Variatio n |
| CHANDIGARH       | (Avl)       | 220          | 212     | -3.8%        | 430          | 399    | -7.2%        |
|                  | (Req )      | 248          | 212     | -14.6%       | 465          | 399    | -14.2%       |
| DELHI            | (Avl)       | 5994         | 4226    | -29.5%       | 8376         | 7568   | -9.6%        |
|                  | (Req )      | 4600         | 4227    | -8.1%        | 8200         | 7568   | -7.7%        |
| HARYANA          | (Avl)       | 7550         | 7946    | 5.2%         | 14496        | 14084  | -2.8%        |
|                  | (Req )      | 8857         | 7948    | -10.3%       | 15558        | 14084  | -9.5%        |
| HIMACHAL PRADESH | (Avl)       | 1256         | 1131    | -10.0%       | 1688         | 1835   | 8.7%         |
|                  | (Req )      | 1277         | 1136    | -11.1%       | 1693         | 1835   | 8.4%         |
| J&K and LADAKH   | (Avl)       | 2000         | 1621    | -19.0%       | 3370         | 2729   | -19.0%       |
|                  | (Req )      | 1810         | 1622    | -10.4%       | 2839         | 2729   | -3.9%        |
| PUNJAB           | (Avl)       | 8910         | 9595    | 7.7%         | 16950        | 16670  | -1.7%        |
|                  | (Req )      | 10915        | 9595    | -12.1%       | 16950        | 16670  | -1.7%        |
| RAJASTHAN        | (Avl)       | 9820         | 8567    | -12.8%       | 19220        | 14685  | -23.6%       |
|                  | (Req )      | 9920         | 8567    | -13.6%       | 17500        | 14685  | -16.1%       |
| UTTAR PRADESH    | (Avl)       | 17515        | 16891   | -3.6%        | 32000        | 30818  | -3.7%        |
|                  | (Req )      | 17360        | 16895   | -2.7%        | 32000        | 30818  | -3.7%        |

|                 |       |       |       |       |       |       |        |
|-----------------|-------|-------|-------|-------|-------|-------|--------|
| UTTARAKHAND     | (Avl) | 1528  | 1555  | 1.8%  | 2476  | 2673  | 8.0%   |
|                 | (Req) | 1550  | 1560  | 0.7%  | 2500  | 2673  | 6.9%   |
| NORTHERN REGION | (Avl) | 54792 | 51743 | -5.6% | 98300 | 81600 | -17.0% |
|                 | (Req) | 56537 | 51761 | -8.4% | 95300 | 81600 | -14.4% |

As per above, negative / significant variation ( $\geq 5\%$ ) in Actual Power Supply Position(Provisional) vis-à-vis Anticipated figures is observed for the month of July-2025 in terms of Energy Requirement for Chandigarh, Delhi, Haryana, HP, UTs of J&K and Ladakh, Punjab, Rajasthan, UP, and in terms of Peak Demand similar variation is noted for Chandigarh, Delhi, Haryana, HP, UTs of J&K and Ladakh, Punjab, Rajasthan, UP, and Uttarakhand. These states/UTs are requested to submit reason for such variations so that the same can be deliberated in the meeting.

All SLDCs are requested to furnish provisional and revised power supply position in prescribed formats on NRPC website portal by 2<sup>nd</sup> and 15<sup>th</sup> day of the month respectively for the compliance of Central Electricity Authority (Furnishing of Statistics, Returns and Information) Regulations, 2007.

#### A.4. Maintenance Programme of Generating Units and Transmission Lines

##### A.4.1. Maintenance Programme for Generating Units

The meeting on proposed maintenance programme for Generating Units for the month of September-2025 is scheduled on 13-August-2025 via Video Conferencing.

##### A.4.2. Outage Programme for Transmission Elements

The meeting on proposed outage programme of Transmission elements for the month of September -2025 is scheduled on 13- August -2025 via Video conferencing.

#### A.5. Planning of Grid Operation

##### A.5.1. Anticipated Power Supply Position in Northern Region for September 2025

The Anticipated Power Supply Position in Northern Region for September 2025 is as under:

| State / UT | Availability / Requirement | Revised Energy (MU) | Revised Peak (MW) | Date of revision      |
|------------|----------------------------|---------------------|-------------------|-----------------------|
| CHANDIGARH | Availability               | 190                 | 420               | No Revision submitted |
|            | Requirement                | 200                 | 434               |                       |



| State / UT       | Availability / Requirement | Revised Energy (MU) | Revised Peak (MW) | Date of revision      |
|------------------|----------------------------|---------------------|-------------------|-----------------------|
|                  | Surplus / Shortfall        | -10                 | -14               |                       |
|                  | % Surplus / Shortfall      | -5.0%               | -3.2%             |                       |
| DELHI            | Availability               | 3520                | 8420              | No Revision submitted |
|                  | Requirement                | 3860                | 7617              |                       |
|                  | Surplus / Shortfall        | -340                | 803               |                       |
|                  | % Surplus / Shortfall      | -8.8%               | 10.5%             |                       |
| HARYANA          | Availability               | 6750                | 14430             | No Revision submitted |
|                  | Requirement                | 7106                | 14097             |                       |
|                  | Surplus / Shortfall        | -356                | 333               |                       |
|                  | % Surplus / Shortfall      | -5.0%               | 2.4%              |                       |
| HIMACHAL PRADESH | Availability               | 1145                | 1545              | 08-Aug-2025           |
|                  | Requirement                | 1130                | 1560              |                       |
|                  | Surplus / Shortfall        | 15                  | -15               |                       |
|                  | % Surplus / Shortfall      | 1.3%                | -1.0%             |                       |
| J&K LADAKH and   | Availability               | 1570                | 3360              | No Revision submitted |
|                  | Requirement                | 1698                | 3429              |                       |
|                  | Surplus / Shortfall        | -128                | -69               |                       |
|                  | % Surplus / Shortfall      | -7.5%               | -2.0%             |                       |
| PUNJAB           | Availability               | 8420                | 16630             | No Revision submitted |
|                  | Requirement                | 8986                | 16206             |                       |
|                  | Surplus / Shortfall        | -566                | 424               |                       |
|                  | % Surplus / Shortfall      | -6.3%               | 2.6%              |                       |
| RAJASTHAN        | Availability               | 8810                | 18940             | No Revision submitted |
|                  | Requirement                | 10516               | 18536             |                       |
|                  | Surplus / Shortfall        | -1706               | 404               |                       |
|                  | % Surplus / Shortfall      | -16.2%              | 2.2%              |                       |
| UTTAR PRADESH    | Availability               | 15450               | 31000             | 07-Aug-2025           |
|                  | Requirement                | 15300               | 31000             |                       |
|                  | Surplus / Shortfall        | 150                 | 0                 |                       |
|                  | % Surplus / Shortfall      | 1.0%                | 0.0%              |                       |
| UTTARAKHAND      | Availability               | 1490                | 2555              | 05-Aug-2025           |
|                  | Requirement                | 1500                | 2575              |                       |



| State / UT      | Availability / Requirement | Revised Energy (MU) | Revised Peak (MW) | Date of revision |
|-----------------|----------------------------|---------------------|-------------------|------------------|
|                 | Surplus / Shortfall        | -10                 | -20               |                  |
|                 | % Surplus / Shortfall      | -0.7%               | -0.8%             |                  |
| NORTHERN REGION | Availability               | 47345               | 97000             |                  |
|                 | Requirement                | 50296               | 88900             |                  |
|                 | Surplus / Shortfall        | -2951               | 8100              |                  |
|                 | % Surplus / Shortfall      | -5.9%               | 9.1%              |                  |

SLDCs are requested to update the anticipated power supply position of their respective state / UT for the month of September-2025 and submit the measures proposed to be taken to bridge the gap between demand & availability, as well to dispose-off the surplus, if any, in the prescribed format.

#### A.6. Follow-up of issues from previous OCC Meetings- Status update.

The updated status of agenda items is enclosed at **Annexure-A.II**.

***All utilities are requested to update the status.***

#### A.7. NR Islanding scheme

Latest status of Islanding Scheme of NR is attached as **Annexure-A.III**.

***Members may kindly deliberate.***

#### A.8. Coal Supply Position of Thermal Plants in Northern Region

A.8.1 In 186<sup>th</sup> OCC meeting, it was agreed that coal stock position of generating stations in northern region may be reviewed in the OCC meetings on the monthly basis.

A.8.2 Accordingly, coal stock position of generating stations in northern region during current month (till 08<sup>th</sup> August 2025) is as follows:

| Station            | Capacity (MW) | PLF % (prev. months) | Normative Stock Req'd. (Days) | Actual Stock (Days) |
|--------------------|---------------|----------------------|-------------------------------|---------------------|
| ANPARA C TPS       | 1200          | 0.83                 | 16                            | 9.8                 |
| ANPARA TPS         | 2630          | 0.82                 | 16                            | 22.6                |
| BARKHERA TPS       | 90            | 0.00                 | 24                            | 52.4                |
| DADRI (NCTPP)      | 1820          | 0.42                 | 24                            | 25.1                |
| GH TPS (LEH.MOH.)  | 920           | 0.89                 | 24                            | 20.8                |
| GOINDWAL SAHIB TPP | 540           | 0.69                 | 24                            | 21.9                |
| HARDUAGANJ TPS     | 1265          | 0.40                 | 24                            | 44.4                |

| Station            | Capacity (MW) | PLF % (prev. months) | Normative Stock Reqd. (Days) | Actual Stock (Days) |
|--------------------|---------------|----------------------|------------------------------|---------------------|
| INDIRA GANDHI STPP | 1500          | 0.46                 | 24                           | 47.2                |
| KAWAI TPS          | 1320          | 0.70                 | 24                           | 25.0                |
| KHAMBARKHERA TPS   | 90            | 0.00                 | 24                           | 49.8                |
| KOTA TPS           | 1240          | 0.48                 | 24                           | 27.9                |
| KUNDARKI TPS       | 90            | 0.00                 | 24                           | 43.9                |
| LALITPUR TPS       | 1980          | 0.71                 | 24                           | 21.0                |
| MAHATMA GANDHI TPS | 1320          | 0.72                 | 24                           | 31.2                |
| MAQSOODPUR TPS     | 90            | 0.00                 | 24                           | 55.8                |
| MEJA STPP          | 1320          | 0.70                 | 24                           | 22.0                |
| OBRA TPS           | 1094          | 0.36                 | 24                           | 12.9                |
| PANIPAT TPS        | 710           | 0.54                 | 24                           | 41.5                |
| PARICHHA TPS       | 1140          | 0.64                 | 24                           | 17.3                |
| PRAYAGRAJ TPP      | 1980          | 0.77                 | 24                           | 28.4                |
| RAJIV GANDHI TPS   | 1200          | 0.68                 | 24                           | 36.4                |
| RAJPURA TPP        | 1400          | 0.90                 | 24                           | 24.5                |
| RIHAND STPS        | 3000          | 0.87                 | 16                           | 23.3                |
| ROPAR TPS          | 840           | 0.62                 | 24                           | 33.4                |
| ROSA TPP Ph-I      | 1200          | 0.68                 | 24                           | 30.4                |
| SINGRAULI STPS     | 2000          | 0.82                 | 16                           | 14.6                |
| SURATGARH TPS      | 1500          | 0.27                 | 24                           | 27.8                |
| TALWANDI SABO TPP  | 1980          | 0.72                 | 24                           | 22.8                |
| TANDA TPS          | 1760          | 0.55                 | 24                           | 32.1                |
| UNCHAHAHAR TPS     | 1550          | 0.72                 | 24                           | 27.5                |
| UTRAULA TPS        | 90            | 0.00                 | 24                           | 42.5                |
| YAMUNA NAGAR TPS   | 600           | 0.60                 | 24                           | 26.9                |
| CHHABRA-I PH-1 TPP | 500           | 0.38                 | 24                           | 28.5                |
| KALISINDH TPS      | 1200          | 0.36                 | 24                           | 23.1                |
| SURATGARH STPS     | 1320          | 0.47                 | 24                           | 31.3                |
| CHHABRA-I PH-2 TPP | 500           | 0.79                 | 24                           | 21.6                |
| CHHABRA-II TPP     | 1320          | 0.65                 | 24                           | 28.6                |
| JAWAHARPUR STPP    | 660           | 0.06                 | 24                           | 27.9                |

#### A.9. Periodic testing of generators and FACTS/HVDC Devices (Agenda by NRPC Sectt.)

A.9.1. Regulation 40 (1) of CERC (IEGC) Regulations, 2023 stipulate that there shall be periodic tests, as required under clause (3) of this Regulation, carried out on power

system elements for ascertaining the correctness of mathematical models used for simulation studies as well as ensuring desired performance during an event in the system.

- A.9.2. The tests shall be performed once every five (5) years or whenever major retrofitting is done. If any adverse performance is observed during any grid event, then the tests shall be carried out even earlier, if advised by SLDC/RLDC/NLDC/RPC, as the case may be.
- A.9.3. Further, Regulation 40(1)(b) stipulate that “All equipment owners shall submit a testing plan for the next year to the concerned RPC by 31st October to ensure proper coordination during testing as per the schedule. In case of any change in the schedule, the owners shall inform the concerned RPC in advance.”

Extract of IEGC 2023 clause 40,

**“40. PERIODIC TESTING**

*(1) There shall be periodic tests, as required under clause (3) of this Regulation, carried out on power system elements for ascertaining the correctness of mathematical models used for simulation studies as well as ensuring desired performance during an event in the system.*

*(2) General provisions*

*(a) The owner of the power system element shall be responsible for carrying out tests as specified in these regulations and for submitting reports to NLDC, RLDCs, CEA and CTU for all elements and to STUs and SLDCs for intra-State elements.*

***(b) All equipment owners shall submit a testing plan for the next year to the concerned RPC by 31st October to ensure proper coordination during testing as per the schedule. In case of any change in the schedule, the owners shall inform the concerned RPC in advance.***

*(c) The tests shall be performed once every five (5) years or whenever major retrofitting is done. If any adverse performance is observed during any grid event, then the tests shall be carried out even earlier, if so advised by SLDC, RLDC, NLDC, or RPC, as the case may be.*

*(d) The owners of the power system elements shall implement the recommendations, if any, suggested in the test reports in consultation with NLDC, RLDC, CEA, RPC and CTU.*

***(3) Testing requirements***

*The following tests shall be carried out on the respective power system elements:*

TABLE 9 : TESTS REQUIRED FOR POWER SYSTEM ELEMENTS

| Power System Elements                  | Tests  | Applicability   |
|--|--|---|
| Synchronous Generator                  | (1) Real and Reactive Power Capability assessment.<br>(2) Assessment of Reactive Power Control Capability as per CEA Technical Standards for Connectivity<br>(3) Model Validation and verification test for the complete Generator and Excitation System model including PSS.<br>(4) Model Validation and verification of Turbine/Governor and Load Control or Active Power/ Frequency Control Functions.<br>(5) Testing of Governor performance and Automatic Generation Control. | Individual Unit of rating 100MW and above for Coal/lignite, 50MW and above gas turbine and 25 MW and above for Hydro. |
| Non synchronous Generator (Solar/Wind) | (1) Real and Reactive Power Capability for Generator<br>(2) Power Plant Controller Function Test<br>(3) Frequency Response Test<br>(4) Active Power Set Point change test.<br>(5) Reactive Power (Voltage / Power Factor / Q) Set Point change test  | Applicable as per CEA Technical Standards for Connectivity.   |
| HVDC/FACTS Devices                     | (1) Reactive Power Controller (RPC) Capability for HVDC/FACTS<br>(2) Filter bank adequacy assessment based on present grid condition, in consultation with NLDC.<br>(3) Validation of response by FACTS devices as per settings.   | To all ISTS HVDC as well as Intra-State HVDC/FACTS, as applicable   |

A.9.4. In 73 NRPC meeting, NRPC forum asked all Generators and HVDC/FACT owners to furnish the Testing schedule for 2024-25 and 2025-26 to NRPC/NRLDC at the earliest. However, the same is still pending.

A.9.5. In 230<sup>th</sup> OCC meeting, MS NRPC asked Generators and HVDC/FACT owners to furnish Testing schedule for 2025-26 in the format attached at **Annexure-A.IV.a** to [seo-nrpc@nic.in](mailto:seo-nrpc@nic.in).

A.9.6. In view of the above Generators and HVDC/FACT owners are requested to furnish Testing schedule for 2025-26 in the format attached as **Annexure-A.IV.a** to [seo-nrpc@nic.in](mailto:seo-nrpc@nic.in).

A.9.7. List of Generating station from which information is received is attached as **Annexure-A.IV.b**

#### ***Utilities to update status.***

### **A.10. Flexible Operation of Coal Based Thermal Power Plants (Agenda by NRPC Secretariat)**

A.10.1. As per the CEA Gazette Notification dated January 30, 2023, coal-based thermal power generating units shall have flexible operation capability with a minimum power level 55%, along with specified ramp rates by January 2024. Additionally, a phased implementation plan for achieving a 40% minimum technical load (MTL) has been notified, with specific targets and timelines for compliance.

A.10.2. The status of MTDL achieved in intra-state thermal generating stations of Punjab, Rajasthan and Haryana noted in 223rd OCC meeting of NRPC is attached at **Annexure-A.V.**

A.10.3. NRPC Secretariat vide letter dated 31.07.2025 (**Annexure-A.VI**) had requested thermal generating stations mentioned at **Annexure-A.V** are requested to submit the reasons for not achieving 55% Technical Minimum Level.

***Members may kindly deliberate.***

**A.11. Unit-wise Planned Maintenance schedule of Generating Units for the year 2026-27 (Agenda by NRPC Secretariat)**

A.11.1. Central Electricity Authority vide mail dated 10.07.2025 has sought information regarding the Unit Wise Planned Maintenance schedule for the year 2026-27.

A.11.2. NRPC Secretariat vide letter dated 22.07.2025 (**Annexure-A.VII**) had requested respective SLDC's of Northern Region to co-ordinate with IPPs and State Generating Companies within their control area and submit the data as per **Annexure-A.VIII**. Further, Central Generating utilities are also requested to submit the abovementioned data as per **Annexure-A.VIII**.

A.11.3. All generating stations of NR are requested to submit Unit Wise Planned Maintenance schedule for the year 2026-27 in the format **Annexure-A.VIII** attached by email to seo-nrpc@nic.in by the 31st August 2025.

***Members may kindly deliberate.***

**A.12. Approval of SPS at 400kV substation Bareilly (Agenda by UPSLDC)**

A.12.1. UP SLDC has submitted that during peak load condition, ICTs at 400 kV substation Bareilly are observed to be N-1 noncompliant.

A.12.2. Meeting regarding identification of feeders for load shedding, logic of SPS and over current setting was held on 25.07.2025.

A.12.3. Based on discussion, UPSLDC has finalized SPS logic, which are enclosed as **Annexure-A.IX**.

A.12.4. UPSLDC has requested approval for its implementation of SPS.

***Members may kindly deliberate.***

**A.13. Approval of SPS at 400 kV substation Panki (Agenda by UPSLDC)**

A.13.1. UP SLDC has submitted that during peak load condition, ICTs at 400 kV S/S Panki are observed to be N-1 non-compliant. SPS for ICTs at 400 kV S/S Panki has been finalized by UPSLDC.

A.13.2. Agenda for approval of the same was put up in 232nd OCC Meeting wherein OCC forum found the SPS logic technically in order as per requirement. However, forum advised that Over Current settings may be reviewed in Protection Sub-Committee Meeting of NRPC.

A.13.3. UP SLDC has informed that over current settings at 400kV substation Panki has been implemented on 15.07.2025 as per NRPC Protection philosophy. The same

was communicated to NRLDC and NRPC vide e-mail on dated 16.07.2025 & 30.07.2025 respectively.

A.13.4. SPS logic and over current settings are attached as **Annexure-A.X**.


A.13.5. Therefore, UPSLDC has requested approval for its implementation of SPS.

**Members may kindly deliberate.**

#### **A.14. Agenda on Varanasi Islanding Scheme (Agenda by UPSLDC)**

A.14.1. UPSLDC has submitted that it has conducted steady state load flow study of Varanasi Islanding Scheme using generation of Anpara BTPS (2X500MW).

A.14.2. 400 kV Anpara BTPS is connected to 400 kV S/S Sarnath through 400 kV double circuit lines.



A.14.3. Study was conducted in various scenarios which are given as follows:-

| Sl. No | Case   | Area    | Number of Machine | Generation | Load                     | Remarks      |
|--------|--------|---------|-------------------|------------|--------------------------|--------------|
| 1      | Case-1 | A and B | 2                 | 874 MW     | 806 MW (Summer Peak)     | Not Feasible |
| 2      | Case-2 | A and B | 2                 | 442 MW     | 435 MW (Winter Peak)     | Not Feasible |
| 3      | Case-3 | A       | 1                 | 452 MW     | 440 MW ( Summer Peak )   | Feasible     |
| 4      | Case-4 | A       | 1                 | 310 MW     | 305 MW (Summer Off Peak) | Feasible     |
| 5      | Case-5 | A and B | 1                 | 409 MW     | 402 MW (Winter Peak)     | Feasible     |
| 6      | Case-6 | A and B | 1                 | 326 MW     | 322 MW (Winter Off Peak) | Feasible     |

A.14.4. As per the study, Islanding Scheme does not seem feasible in cases 1, due to under voltage observed at various node when 2 machine are taken considering area A & B

both, while in case 2 the load of area A & B is less than technical minimum of 2x500 MW units at Anpara BTPS for Winter scenario.

A.14.5. In case no. 3 and 4, one machine has been taken with load form Area A for summer scenario. Voltages and loading of transmission lines are within limit. However, for winter scenario, the load of area A is less than technical minimum of 1x500 MW units at Anpara BTPS. Therefore, to ensure technical minimum of unit, load of area A and B both has been taken in case no 5 and 6 for winter scenario. Study report is attached as **Annexure-A.XI**.

A.14.6. Therefore, UPSLDC has proposed that:-

- Varanasi Islanding is to be planned with one machine.
- For Summer and Winter seasons, two different island areas i.e. Area A for Summer season and Area A & B for Winter season is to be considered.
- Decision may be taken whether dynamic study is required or not.

**Members may kindly deliberate.**

#### **A.15. SOP for diversion of RPC approved spare Transformers/Reactors to constituents/state transmission utilities (Agenda by Powergrid NR-1)**

##### **A. Background**

- A.15.1. In line with the recommendations of committee formed under the direction of CERC in Petition No. 38/TT/2017, requirement of regional spare transformers and reactors is being assessed by POWERGRID and agreed in RPCs based on the population of existing transformers and reactors in POWERGRID substations.
- A.15.2. POWERGRID procures and maintains the RPC approved transformers and reactors as regional spares to meet any contingency in it's existing substations for ensuring grid reliability and minimize downtime.
- A.15.3. These spares are primarily for use in POWERGRID ISTS substations however, in some cases requests are being received by POWERGRID from constituents/state utilities to divert regional spare transformer(s)/reactor(s) on temporarily basis for their use in case of contingency to maintain power continuity and ensuring grid reliability. Further in past following ICTs has been provided to state constituents after approval of RPC forum: -

| S. No. | ICT provided to other Utilities     | Diverted from         | Diverted to                  | Date   | Tariff mech |
|--------|-------------------------------------|-----------------------|------------------------------|--------|-------------|
| 1      | BHEL Make 315 MVA 400/220 KV ICT    | Ludhiana (POWERGRID)  | Mundka (DTL)                 | Apr-23 | RPC Spare   |
| 2      | BHEL Make 315 MVA 400/220 KV ICT    | Ludhiana (POWERGRID)  | Jodhpur GSS - Surpura (RVPN) | Nov-23 | RPC Spare   |
| 6      | Toshiba make 500 MVA 400/220 KV ICT | Panchkula (POWERGRID) | Nakodar (PSTCL)              | May-23 | RPC Spare   |



- A.15.4. Considering the diversion of above regional spare to state utilities and prolong delays in returning, severe shortage of spare ICTs has been observed by POWERGRID to meet any contingent situation in its GRID Substations. Agenda for mechanisms to devise rental charges for ICT provided on loan basis was put up by POWERGRID in 78<sup>th</sup> NRPC meeting wherein following was decided by NRPC forum.

***“Forum decided that the agenda may be discussed in the next Commercial Sub Committee meeting/special meeting for preparing draft mechanism to devise rental charges for ICT provided on loan basis”***

Accordingly following SOP is put up for consideration by POWERGRID: -

## **B. General Conditions**

As Regional spares are approved primarily for use of POWERGRID in its ISTS Substations, its diversion to regional state transmission utility may be considered under exceptional circumstances considering the gravity of requirement to the constituent and its beneficiaries on expeditious replenishment basis. Further, Inter Regional diversion of equipment to the constituent shall not be considered

## **C. Utilities eligible for diversion:**

- I. State Transmission Utility: Diversions can be considered in case of failure of existing equipment in use and diversion required in the interest of Grid security and reliability. It is clarified that under normal circumstances, a regional spare shall not be diverted for commissioning of new assets.
- II. Other Utilities: For utilities other than State Transmission Utilities, under normal circumstances, such diversions are not envisaged. However, if agreed by RPC forum, such diversions may be allowed only under the exceptional circumstances.

## **D. Diversion Modalities of Regional spare transformer(S) / reactor(s) to State Transmission Utility:**

1. In case of requirement of Regional spare transformer/ reactor by the Borrower i.e. State Transmission Utility, the requirement shall be put up for consent of the respective RPC forum, including:
  - I. Contingency situations describing the requirement of spare equipment from POWERGRID.
  - II. Action plan along with timeline for return/ replenishment of the spare equipment to POWERGRID
2. Decision of diversion along with associated terms and conditions for diversion will be based on the agreement reached in RPC Forum after considering the merit of the request. It is clarified that regional spare transformer/ reactor can be diverted only in case of restoration of failed equipment and not for commissioning of new equipment.

3. Upon approval in the RPC, the Spare transformer/ reactor shall be diverted to the Borrower only on replenishment basis and the same shall not be sold to the Borrower under any circumstances.

## **E. Signing of agreement**

Upon approval in the RPC Forum & before diversion of Regional spare transformer/reactor, an agreement shall be signed between POWERGRID and the Borrower in the presence of Member Secretary of concerned RPC. The agreement shall cover the terms and conditions for the diversion of equipment in line with this SOP and as discussed below broadly;

### **a) Time period:**

The Borrower shall return the Spare transformer/ reactor within the timeframe agreed by the RPC which in all cases shall not exceed a maximum of 24 months from the date of diversion. The spare transformer/ reactor is to be lifted within 3 months of RPC approval. Failing which the consent for diversion as agreed in the RPC shall be deemed to be withdrawn.

RPC secretariat shall monitor the list of such diverted equipment and coordinate to ensure that the replenishment by the borrower is done as per agreed timeframe.

### **b) Cost implications:**

The equipment shall be diverted on zero cost basis/ cost neutral basis to POWERGRID. On account of the diversion, POWERGRID shall remain revenue neutral i.e. there shall be no change in CERC approved tariff or its sharing due to diversion of the concerned regional spare transformer/ reactor. The sharing of cost of the asset shall be as per Sharing Regulations. Further, if decided by RPC, tariff of the asset shall be borne by the requestor for the period of usage and charges of the asset shall be recovered bilaterally and adjusted back to pool.

### **c) Borrower Responsibilities:**

- 1) The Borrower shall be responsible for dismantling, to & fro transportation, transit insurance, statutory expenses, erection, testing & commissioning charges (including at POWERGRID station after return) etc., any other incidental expenditure associated with the diversion of equipment or any loss to POWERGRID on account of diversion and all such charges shall be borne by the Borrower.
- 2) Borrower shall verify the condition of equipment at POWERGRID substation before taking the equipment on loan basis. After verification, the equipment shall be handed over to the Borrower.
- 3) Before diversion, the Borrower shall submit the Bank Guarantee (BG) equivalent to prevailing cost of diverted equipment. Borrower shall maintain BG valid until the diverted equipment is taken over by POWERGRID in healthy condition.
- 4) The Borrower shall be responsible for transportation/ erection/ commissioning/operation & maintenance.

- 5) The Borrower shall be responsible to maintain the equipment in healthy condition as per the standard maintenance practices.
- 6) The Borrower shall be responsible to ensure that the equipment is returned to POWERGRID in healthy condition as per the commitment/ action plan agreed prior to diversion.
- 7) Any damage/failure of the equipment shall be the responsibility of the Borrower till the equipment is taken over by POWERGRID in healthy condition.
- 8) In case of failure/ breakdown of equipment during transportation/ erection/commissioning/ operation & maintenance or during any other activity, the Borrower shall return the equipment after repair/ refurbishment of the same from OEM as per the POWERGRID specification. Alternatively, new equipment matching with the POWERGRID specifications shall be replenished. All cost for repair/ refurbishment/ replacement as applicable shall be borne by the Borrower.
- 9) After returning of equipment, all pre-commissioning tests shall be jointly performed at POWERGRID station to ascertain healthiness. In case of any deviation, POWERGRID shall take up the repair of equipment and cost of the repair shall be borne by the Borrower.

#### d) Return of equipment:

In case of any exigency or if required in the interest of the Grid, POWERGRID reserves the right to demand the diverted Spare from the Borrower prior to the time period as agreed in the RPC after intimation to RPC. Once consented in RPC Forum, Borrower shall return the diverted spare to POWERGRID on immediate basis.

#### e) Penalty clause:

In case of delay of return/ replenishment of spare equipment to POWERGRID beyond agreed time (maximum 24 months from the date of diversion), a penalty @15% of the approved tariff of diverted equipment for the delayed period to be imposed on the Borrower as one time charge.

### A.16. Installation of 315 MVA 400/220kV Synthetic Ester Oil based Transformer in Delhi-NCR (Agenda by Powergrid NR-1)

A.16.1. Powergrid NR-1 has submitted that it has developed one number Synthetic Ester Oil based 315 MVA 400 / 220 Transformer in association with M/s Hitachi which is a first-of-its-kind, highlighting technological progress in the field of 400kV class Power Transformer in India due to following advantages:

- **Fire Safety:** Synthetic esters have a **high flash point (275–315°C)** and **fire point (317–355°C)**, significantly reducing fire risk compared to mineral oils.
- **Environmental Safety:** These fluids are **readily biodegradable** and **non-toxic**, minimizing ecological damage in case of leaks or spills.

- **Moisture Tolerance:** Synthetic esters can absorb more moisture without compromising insulation, which helps **extend transformer life** and **reduce aging of cellulose insulation**

- A.16.2. It is pertinent to mention that for ease of designing and adoptability, said transformer does not have OLTC due to fact that type tested OLTC with ester oil was not available during engineering stage.
- A.16.3. To have a close monitoring of performance of the Transformer, it is felt prudent to commission the transformer in Bhiwadi in place of existing operational transformer (ICT-2) for the following reason:
- Bhiwadi is near to Delhi and it has a state of art oil testing laboratory. Hence, close monitoring and analysis of oil can be undertaken in exhaustive manner. Further, the data collected during testing may be used in future for fine tuning the design and specifications.
  - ICT-2 at Bhiwadi exhibits high fault gases and is vulnerable which may affect the reliable power supply
  - Further, it is to mention that there is no OLTC operations at Bhiwadi for the last 5 years
- A.16.4. Powergrid NR-1 has proposed to replace 315 MVA 400/220kV ICT-2 with 315 MVA 400/220kV Synthetic Ester Oil based Transformer at Bhiwadi without any cost implication to constituents. Further the outage period for replacement to be considered as deemed available.

***Members may kindly deliberate.***

**A.17. Operational Reliability Concerns Arising from Frequent Switching of MSR/MSC Circuit Breakers in STATCOMs at Renewable Energy Complexes (Agenda by Powergrid NR-1)**

- A.17.1. Powergrid NR-1 has submitted that a recent failure of the 245kV circuit breaker associated with the 125 MVAR Mechanically Switched Reactor (MSR) of STATCOM-1 at Bikaner-2 on 20.07.2025 has raised significant reliability and operational concerns. The failure resulted in extensive collateral damage, including failure of BPI units, MSC capacitor, and chipping in smoothening reactors. Presently, CB operation counters of MSR / MSC at Bikaner-2 are in range of 3000.
- A.17.2. STATCOMs installed at RE complexes (Bikaner-2, Bhadla-2, Fatehgarh-2) are experiencing high switching frequency of MSR/MSC circuit breakers — averaging 5 to 6 operations per day — leading to accelerated wear and potential failure. Similar failures have already been observed in at other STATCOM sites of Eastern Region such as Jeypore, Kishanganj, and Ranchi etc.
- A.17.3. During the initial design and application stage, POWERGRID had anticipated only 1-2 switching operations per day for MSRs in STATCOM applications, based on switching experience of Bus Reactors in 400kV System. A circuit breaker specifically designed for frequent inductive switching observed in STATCOMs installed in RE complex is not available, and the one in use is a compromise solution.

A.17.4. Circuit breakers currently deployed are not specifically rated for such frequent high-current inductive switching, and are operating beyond originally anticipated limits. OEMs have indicated higher TRVs and arcing stress due to such applications. Given the current switching frequency, periodic testing and health assessment of the circuit breakers is essential every two years & may necessitate overhauling, in line manufacturer guidelines. This will result in increased outage durations and the need for spare components and assemblies to replace damaged parts.

A.17.5. Given the current switching frequency, periodic testing and health assessment of the circuit breakers is essential every two years & may necessitate overhauling, in line manufacturer guidelines. This will result in increased outage durations and the need for spare components and assemblies to replace damaged parts.

A.17.6. Technical Concern:

- a) Increased TRV due to frequent switching and high X/R ratio.
- b) Premature degradation of arcing contacts and DCRM deviation.
- c) Elevated maintenance requirements, potential outages, and risk of catastrophic failure.

A.17.7. Proposal for Deliberation:

1. Review and rationalization of MSC/MSR switching logic/settings to minimize unnecessary operations.
2. Consideration for periodic health assessment and mandatory overhauling of MSR breakers every two years.
3. Approval to claim replacement/major overhaul cost of MSR breakers under Add-Cap in case of high daily switching requirements.

A.17.8. Powergrid NR-1 has requested that members may deliberate on the matter and advise on suitable modifications in STATCOM operational logic and approval of Add-Cap expenditure, wherever applicable.

***Members may kindly deliberate.***

## **A.18. Regarding frequent/repetitive faults in 220KV Lines (Agenda by Powergrid NR-2)**

A.18.1. Powergrid NR-2 has submitted that frequent faults are incurred in various lines, especially 220KV Network, and line is cleared for charging without fault finding. Further after charging the line, no corrective action is taken to rectify the fault resulting in repetition of the faults. Frequent faults in 220KV Lines are resulting in stress to POWER Transformers.

A.18.2. In last year, 01 No 400/220/33KV 315MVA Transformer had failed while feeding faults in 220KV Lines

A.18.3. Some of the best practices followed by POWERGRID in maintenance of the Lines are as under:

- i. After each tripping, proper patrolling like ground patrolling/Tower top patrolling is done till identification of the fault
- ii. Replacement of porecelain insulators with Polymer insulators

- iii. Jumper clearance measurement and rectification in case of jumper flashover
- iv. Measurement of Tower footing impedance and based on the results, additional earthing is done
- v. In case of tripping due to lightening, installation of Line LAs has provided better results

A.18.4. Powergrid NR-2 has mentioned that it has analysed faults of various 220KV lines and most of the faults found to be of repetitive nature

***Members may kindly deliberate.***

**A.19. Rectification of Normal-Intermediate-Transfer scheme of 400kV RASRA-MAU transmission line at RASRA UPPTCL end (Agenda by Powergrid NR-3)**

- A.19.1. Powergrid NR-3 has submitted that Powergrid owned transmission assets are installed within premises of State utilities. While their maintenance is managed by Powergrid, operational activities such as shutdowns or shifting to Transfer Bus Coupler (TBC) are under the purview of the respective State utility.
- A.19.2. Sometimes, it observed that element/TL tripping had occurred due to wrong scheme implemented at state utility control Panel. In this regards Powergrid contacted concerned utilities numbers of time but issue is persisting.
- A.19.3. Similar incidence occurred in 400 kV MAU-RASRA transmission line, the said line tripped at 11:58 hrs on date 17.01.2025 due to a DT (Direct Trip) signal received at the RASRA (UP) end.
- A.19.4. Despite repeated requests made through the letter dated 18.01.2025, the email dated 12.02.2025 referencing the letter dated 28.07.2025, and the Minutes of Meeting (MoM) dated 21.01.2025, the issue has not yet been rectified by UPPTCL as per the directions outlined in the MoM.
- A.19.5. Powergrid NR-3 has requested to kindly instruct to M/s UPPTCL for resolution of the above issue on Priority.

***Members may kindly deliberate.***

**A.20. Shutdown of 500kV HVDC Rihand-Dadri CKT- I&II for Construction 765kV Bareilly-Neemrana D/C line for Power line crossing work (Agenda by Powergrid NR-3)**

- A.20.1. Powergrid NR-3 has submitted shutdown of 500kV HVDC Rihand-Dadri CKT- I&II for Power line crossing work towards under construction 765kV Bareilly-Neemrana D/C lines was proposed in 231st OCC meeting ( in May'25) for the month of June'25. In the meeting shutdown was not approved by the forum due prevailing high-power demand.
- A.20.2. Shutdown for the lines was then proposed in 232nd OCC meeting for the month July'25. The forum has approved the shutdown. However, in real time when shutdown was proposed from 24.07.2025 to 26.07.2025 (07:00 hrs to 19:00 hrs), it was rejected by RLDC mentioning that "To be availed in less NR demand period and with Unit outage at Rihand scheduled from 6th Aug".

A.20.3. In line with RLDC's comment, shutdown of the HVDC lines (also approved in 233rd OCC) were further applied in real time from 06-08-2025 06:00 - 08-08-2025 19:00 ( during the outage period of Rihand(NTPC)'s Generation unit). However, the same has been rejected again by RLDC mentioning that "In view of High generation at Rihand. At least 2 unit to be under shutdown in order to facilitate the shutdown".

A.20.4. Due to multiple time rejection of the shutdown since June'25, progress of construction work for 765kV Bareilly-Neemrana D/C line has been critically hampered.

A.20.5. Powergrid NR-3 has requested forum to look into matter to provide shutdown of above-mentioned lines in Aug'25.

**Members may kindly deliberate.**

**खण्ड-ख: उ.क्षे.भा.प्रे.के.**

**Part-B: NRLDC**

## **B.1. NR Grid Highlights for July 2025**

### **Demand met details of NR**

| S.N<br>o | Constituents | Max Demand met (in MW) | Date & Time of Max Demand met | Max Consumption (in MUs) | Date of Max Consumption | Average Demand met (in Mus) |
|----------|--------------|------------------------|-------------------------------|--------------------------|-------------------------|-----------------------------|
| 1        | Chandigarh   | 399                    | 25.07.25 at 15:00             | 7.9                      | 26.07.25                | 6.8                         |
| 2        | Delhi        | 7568                   | 25.07.25 at 15:11             | 152.7                    | 28.07.25                | 135.7                       |
| 3        | Haryana      | 14084                  | 05.07.25 at 15:00             | 292.7                    | 26.07.25                | 256.2                       |
| 4        | H.P.         | 1835                   | 23.07.25 at 09:00             | 40.0                     | 26.07.25                | 36.6                        |
| 5        | J&K          | 2729                   | 04.07.25 at 12:00             | 57.0                     | 04.07.25                | 52.3                        |
| 6        | Punjab       | 16670                  | 05.07.25 at 13:45             | 355.9                    | 27.07.25                | 311.8                       |
| 7        | Rajasthan    | 14685                  | 25.07.25 at 22:45             | 311.7                    | 25.07.25                | 276.2                       |
| 8        | UP           | 30818                  | 24.07.25                      | 600.6                    | 24.07.25                | 545.6                       |



|    |                    |       |                          |        |          |        |
|----|--------------------|-------|--------------------------|--------|----------|--------|
|    |                    |       | 5 at<br>22:45            |        |          |        |
| 9  | Uttarakhand        | 2673  | 26.07.2<br>5 at<br>22:00 | 54.9   | 26.07.25 | 50.7   |
| 10 | Northern<br>Region | 81583 | 26.07.2<br>5 at<br>22:00 | 1820.6 | 28.07.25 | 1672.0 |


\*As per SCADA

- In July'25, the Maximum energy consumption of Northern Region was **1820.6 MUs** on 28<sup>th</sup> July'25 and it was 5.18% lower than July'24 (1920 MU 30<sup>th</sup> July'24)
- In July'25, the Average energy consumption per day of Northern Region was **1672 MUs** and it was 4.83% lower than July'24 (1757 MUs/day)
- In July'25, the Maximum Demand met of Northern Region was **81583 MW** on 26<sup>th</sup> July'25 @22:00 hours as compared to 88085 MW on 30<sup>th</sup> Jul'24 @12:40 hours.

#### Comparison of Average Energy Consumption (MUs/Day) - July'24 vs July'25

| क्षेत्र/राज्य   | जून- 2024 | जून - 2025 | % अंतर |
|-----------------|-----------|------------|--------|
| चंडीगढ़         | 7.7       | 6.8        | -11.3% |
| दिल्ली          | 141.0     | 135.7      | -3.7%  |
| हिमाचल प्रदेश   | 38.1      | 36.6       | -3.9%  |
| हरियाणा         | 269.3     | 256.2      | -4.9%  |
| जम्मू और कश्मीर | 53.0      | 52.3       | -1.4%  |
| पंजाब           | 335.5     | 311.8      | -7.1%  |
| राजस्थान        | 310.6     | 276.2      | -11.1% |
| उत्तराखंड       | 50.3      | 50.7       | 0.7%   |
| उत्तर प्रदेश    | 551.3     | 545.6      | -1.0%  |
| उत्तरी क्षेत्र  | 1756.8    | 1672.0     | -4.8%  |


#### Energy Consumption



### Frequency profile

| Month   | Avg. Freq. (Hz) | Max. Freq. (Hz)                      | Min. Freq. (Hz)                      | <49.90 (% time) | 49.90 - 50.05 (% time) | >50.05 (% time) |
|---------|-----------------|--------------------------------------|--------------------------------------|-----------------|------------------------|-----------------|
| July'25 | 50.003          | 50.400<br>(27.07.25 at 14:02:00 hrs) | 49.504<br>(26.07.25 at 14:53:20 hrs) | 6.65            | 72.89                  | 20.46           |
| July'24 | 50.00           | 50.37<br>(06.07.24 at 13:12:20 hrs)  | 49.64<br>(20.07.24 at 15:24:40 hrs)  | 6.4             | 78.4                   | 15.2            |

### Reservoir Level and Generation on Last Day of Month



| Reservoir Level on last day of July month |        |      |            | (Low: -ve) | (High: +ve) |           |
|---|--------|------|------------|------------|-------------|-----------|
| Year                                      | Bhakra | Pong | Rihand HPS | RSD        | Tehri       | Koteshwar |
| 2025                                      | 495    | 414  | 265        | 510        | 797         | 610       |
| 2024                                      | 490    | 403  | 260        | 491        | 794         | 611       |
| Diff (in m)                               | 4.5    | 11.2 | 4.5        | 19.2       | 3.3         | -0.8      |

***Detailed presentation on grid highlights of July'2025 will be shared by NRLDC in OCC meeting.***

## **B.2. State-wise transmission constraints in monsoon 2025 and SPS proposals**

During the high demand season, the transmission system in Northern region remains heavily loaded. Transmission constraints observed in the grid during high demand period are regularly being highlighted in OCC meetings. Same is also being submitted to CTUIL and CEA through quarterly operational feedback.

Even after several follow-ups, it is observed that progress of several transmission elements are not up to the mark and expeditious actions from transmission utilities are required so that minimal issues are observed at transmission level during the high demand season.

State-wise anticipated issues and measures required thereof are listed below. Concerned transmission utilities are requested to provide update and ensure that these transmission elements are possibly commissioned before the high demand season.

### **Punjab:**

During 233 OCC meeting,

NRLDC representative stated that the loading of 400/220kV ICTs supplying power to Punjab state is within the N-1 limits when import is close to the ATC limits and suggested that Punjab SLDC further reviews the ATC/TTC assessment for paddy 2025 for any further enhancement also considering other constraints at 220kV level.

Punjab SLDC informed that the studies for review of ATC/TTC enhancement of Punjab state control area is under progress.

NRLDC representative further asked Punjab SLDC to study/review any intrastate constraints being observed in 220kV network as maximum demand of Punjab has also crossed 17000MW recently.

Punjab SLDC assured that no major transmission constraints are being observed in intrastate level even when demand crossed 17000MW. Further, studies after review of ATC/TTC enhancement of Punjab will be submitted to NRLDC at the earliest.

Subsequently, NRLDC vide email dated 01.08.2025 has mentioned that 400/220kV ICT-4 at Nallagarh has also been recently commissioned by POWERGRID. Punjab draws power from 220kV Nallagarh via 220kV Nallagarh-Mohali D/c lines. Accordingly, with ICT augmentation at Nallagarh, additional margin would be created for power drawl by Punjab state. Accordingly, Punjab SLDC was asked to review ATC/TTC limits of Punjab state control area for any further increase.

***Punjab SLDC may provide update.***

### **Haryana:**

During 233 OCC meeting, NRLDC representative requested HVPN regarding:

NRLDC representative highlighted that schedule as well as actual drawl by HVPNL is crossing the ATC/TTC limits during several time blocks.



After revival of 400kV Mahendragarh-Bhiwani D/C and 400kV Bhiwani-Babai D/C lines, following are present ATC/TTC limits of Haryana state:

- 10200/10500MW

After implementation of SPS at 765/400kV Bhiwani(PG) and 400/220kV Hissar(PG), following would be tentative ATC/TTC limits:

- 10600/10900MW

As POWERGRID has confirmed via e-mail that SPS has been implemented at 765/400kV Bhiwani(PG), ATC/TTC of Haryana state control area has been revised to 10400/10700 MW w.e.f. 07<sup>th</sup> Aug 2025.

### SPS proposals in Haryana

**For SPS at 400/220kV Hissar(PG) ICTs:** Haryana SLDC wanted to wire 220kV Hissar(BBMB)-220kV Sangrur D/C (supplying power to Punjab) and 220kV Hissar-Chirawa (supplying power to Rajasthan) lines in SPS. Punjab SLDC was assured from NRLDC side that there would not be impact on state ATC/TTC in case these feeders are wired, however, Punjab SLDC will need to take measures for managing loading of 220kV lines. Rajasthan SLDC agreed for wiring 220kV Hissar-Chirawa line in SPS logic.

POWERGRID informed that PLCC channel is not available for transferring signal from 220kV Hissar(PG)--->220kV Hissar(IA-HVPNL)--->220kV Hissar(BBMB) and it would require procurement of DTPC coupler for implementation of SPS. It was discussed that new 500MVA ICT is approved at Hissar(PG) but it may not be commissioned before next paddy season. Further, there are also loading issues in 220kV Hissar(PG)---220kV Hissar(IA-HVPNL)---220kV Hissar(BBMB) for most part of the year. Accordingly, SPS for N-1 contingency of 400/220kV Hissar(PG) ICTs and 220kV Hissar(PG)---220kV Hissar(IA-HVPNL)---220kV Hissar(BBMB) ckts is required. HVPNL and BBMB were asked to check at their respective substations regarding space for DTPC panel and also confirm feasibility of SPS implementation.

As a short term measure (till implementation of SPS at Hissar-PG), in case loading of 400/220kV Hissar(PG) ICTs crosses 90% of rated capacity, then NRLDC in consultation with BBMB, Haryana SLDC, Punjab SLDC and Rajasthan SLDC may ask BBMB to open 220kV Hissar(BBMB)-220kV Sangrur D/C (supplying power to Punjab) and 220kV Hissar-Chirawa (supplying power to Rajasthan) lines. Punjab SLDC and Rajasthan SLDC to ensure supply of these stations from other stations before disconnection from Hissar(BBMB).

**For SPS at 400/220kV Panipat ICTs:** Haryana SLDC was asked by NRLDC to review the requirement of SPS as continuous N-1 violation is being observed in June 2025. Further, BBMB was asked to expedite new ICT approval/implementation process. Haryana SLDC assured that after LILO of 2nd ckt of 220kV Samalkha-Mohana at 400/220kV Sonapat(PG), loading would be under limits. NRLDC suggested to review the loading as soon as 2nd ckt is LILOed and take necessary actions in case loading is not within N-1 limit.

During 233 OCC meeting,

NRLDC representative stated that loading of 400/220kV Panipat is still beyond the N-1 limits even after LILO of 2<sup>nd</sup> ckt of 220kV Samalkha-Mohana at 400/220kV Sonapat(PG). It was requested that Haryana SLDC may review requirement of SPS at 400/220kV Panipat (BBMB) in view of continuous N-1 violations of ICT loading.

BBMB representative informed that site has verbally confirmed space availability for DTPC at Hissar (BBMB) end. It was further informed that HVPNL would be implementing new ICT at 400/220kV Panipat(BBMB).

NRLDC and CTUIL representatives asked BBMB to share MoM/ consent from HVPNL regarding commissioning of new ICT at 400/220kV Panipat(BBMB).

HVPNL representative confirmed space availability in case of requirement of DTPC coupler positioning for SPS at 220kV Hissar-IA.

NRLDC representative further requested that Haryana SLDC may further explore shifting of some load from 400/220kV Panipat to 400/220kV Sonapat(PG).

***Haryana SLDC may provide update.***

**Rajasthan:**

| Constrained location                                   | Status as available with NRLDC  |
|--|---|
| N-1 contingency of 3*315=945 MVA ICT at Bhiwadi(PG)    | Additional 500MVA ICT approved in 29 CMETS on 17.05.2024                    |
| N-1 contingency of 2*315+500=1130 MVA ICT at Bassi(PG) | Additional 500MVA ICT has been approved. Same is anticipated by 14.12.2025. |
| N-1 contingency of 315+500=815 MVA ICT at Neemrana(PG) | Additional 500MVA ICT has been approved in 36 NR CMETS held on 15.01.2025.  |
| N-1 contingency of 2*500=1000                          | Additional 500MVA ICT has been approved                                     |

|  |   |
|--|---|
| MVA ICT at Jaipur South(PG)                                    | in 36 NR CMETS held on 15.01.2025.  |
| N-1 contingency of 2*315+500=1130 MVA ICT at Sikar(PG)         | Additional 500MVA ICT has been approved in 38 NR CMETS held on 28.05.2025..   |
| N-1 contingency of 3*315=945 MVA ICT at Kankroli(PG)           | ICT-4 has been approved and is expected to be commissioned by 22.09.2025.   |
| N-1 contingency of 2*315=630 MVA ICT at Kotputli(PG)           | Augmentation by 400/220 kV 500 MVA (3rd) ICT at Kotputli (PG) is expected by 31.12.2025   |
| N-1 contingency of 2*315=630 MVA ICT at Deedwana(RVPN)         | <p>As per latest status shared by Rajasthan SLDC order for 10 no. ICT has been placed recently. New 500MVA ICTs are expected to be commissioned at 400/220kV Merta, Ajmer and Bikaner by Sep 2025.</p> <p>SPS has been implemented as temporary measure for some of the stations such as Chittorgarh (RVPN), Ajmer (RVPN), Merta (RVPN), Bikaner (RVPN), Jodhpur (RVPN), Suratgarh(RVPN), Ratangarh(RVPN)</p> |
| N-1 contingency of 3*250+315=1065 MVA ICT at Heerapura(RVPN)   |   |
| N-1 contingency of 3*315 =945 MVA ICT at Chittorgarh (RVPN)    |   |
| N-1 contingency of 2*315 =630 MVA ICT at Ajmer (RVPN)          |   |
| N-1 contingency of 2*315 =630 MVA ICT at Merta (RVPN)          |   |
| N-1 contingency of 2*315 =630 MVA ICT at Bikaner (RVPN)        |   |
| N-1 contingency of 2*315 =630 MVA ICT at Jodhpur (RVPN)        |   |
| N-1 contingency of 2*315=630 MVA ICT at Suratgarh(RVPN)        |   |
| N-1 contingency of 3*315=945 MVA ICT at Ratangarh(RVPN)        |   |
| N-1 contingency of 1*500+1*315 =815 MVA ICT at Bhilwara (RVPN) |   |

In 232 OCC meeting, RRVNPL representative informed that:

- Work order has been placed for improvement of condition of 400kV Bhadla-Bikaner D/C and also upgradation of terminal equipment. Work is expected to be completed by Dec 2025.
- Proposal of upgradation of terminal equipment for other lines is being prepared and order would be placed shortly.
- Supply of 100 no. total 5.43MVar capacitors has been done and in next 1-2 months all the supplied capacitors would be commissioned.

- Proposal of 100no.s capacitor banks through PSDF funding are under development.
- Jaipur and Jodhpur DISCOMs have directly applied for PSDF funding. Ajmer DISCOM has already included proposal for capacitor under RDSS Scheme and is not going for additional capacitor banks
- New 500MVA ICTs are expected to be commissioned at 400/220kV Merta, Ajmer and Bikaner by Sep 2025.

In 233 OCC meeting,

RRVPNL representative informed that:

- Proposal of upgradation of terminal equipment for other lines is being prepared. Bidding document are under preparation for Akal and Kankani. Estimate has been prepared for switchgear upgradation at Jaisalmer.
- Work order has been placed for improvement of condition of 400kV Bhadla-Bikaner D/C and also upgradation of terminal equipment. Work is expected to be completed by Dec 2025.
- Supply of 100 no. total 5.43MVA capacitor has been done and in next 1-2 months all the supplied capacitors would be commissioned.
- Supply of additional 50 no. capacitors is further expected from Aug 2025 onwards.
- Jaipur and Jodhpur DISCOMs have also been asked to expedite capacitor commissioning.

NRLDC representative stated that peak demand season of Rajasthan starts from mid Nov onwards and accordingly any shutdown requirement of 400kV Bhadla-Bikaner for condition improvement may be taken up timely and work may preferably be completed by mid Nov so that line remains available during peak demand and high MVAR drawl season of Rajasthan.

### SPS proposals in Rajasthan

Majority of 400/220kV ICTs in Rajasthan state (both interstate as well as intrastate are N-1 non-compliant).

For intrastate substations, where SPS have not been planned and implemented, the same may be taken up. List of N-1 non-compliant substations is shown below:

| Constrained location                      | SPS Status as available with NRLDC |
|---|------------------------------------|
| 3*315=945 MVA ICT at Bhiwadi(PG)          | Not planned                        |
| 2*315+500=1130 MVA ICT at Bassi(PG)       | Not planned                        |
| 315+500=815 MVA ICT at Neemrana(PG)       | Not planned                        |
| 2*500=1000 MVA ICT at Jaipur South(PG)    | Not planned                        |
| 2*315+500=1130 MVA ICT at Sikar(PG)       | Not planned                        |
| 3*315=945 MVA ICT at Kankroli(PG)         | Not planned                        |
| 2*315=630 MVA ICT at Kotputli(PG)         | Not planned                        |
| 2*315=630 MVA ICT at Deedwana(RVPN)       | Not planned                        |
| 3*250+315=1065 MVA ICT at Heerapura(RVPN) | Not planned                        |
| 3*315 =945 MVA ICT at Chittorgarh (RVPN)  | Implemented                        |
| 2*315 =630 MVA ICT at Ajmer (RVPN)        | Implemented                        |



|   |             |
|---|-------------|
| 2*315 =630 MVA ICT at Merta (RVPN)          | Implemented |
| 2*315 =630 MVA ICT at Bikaner (RVPN)        | Implemented |
| 2*315 =630 MVA ICT at Jodhpur (RVPN)        | Implemented |
| 2*315=630 MVA ICT at Suratgarh(RVPN)        | Implemented |
| 3*315=945 MVA ICT at Ratangarh(RVPN)        | Implemented |
| 1*500+1*315 =815 MVA ICT at Bhilwara (RVPN) | Implemented |

Subsequently, NRLDC vide email dated 01.08.2025 had communicated to share simulation studies carried out at RRVN side for feeders identified for SPS at the earliest. Further, it was mentioned that NRLDC has also simulated feeders for SPS and need further discussion for feeders identified for Bassi SPS.

***Rajasthan SLDC may provide update.***

#### **Uttar Pradesh:**

In 233 OCC meeting,

POWERGRID representative stated that 500MVA ICT-4 at Allahabad is expected to be commissioned by Sep 2025.

UP SLDC informed that SPS logic of 400/220kV Panki S/s was approved from NRPC and OCC side. However, there were certain recommendations to modify the overcurrent settings for ICTs. The revised settings are under implementation at 400/220KV Panki S/s. Further, SPS at 400/220kV Panki is expected to be commissioned at the earliest.

It was also informed that 240MVA ICT at Obra is expected to be revived by Sep 2025 whereas 315MVA ICTs at Obra would be revived after some time due to requirement of procurement of ICTs.

***UP SLDC may provide update on implementation of SPS at 400/220kV Panki S/s.***

#### **SPS proposals in Uttar Pradesh**

NRLDC also received a request from UP SLDC vide email dated 24.05.2025 regarding implementation of SPS at 400/220kV Agra(PG) ICTs. During 232 OCC meeting, UP SLDC stated that they will shortly convene a meeting with participation from POWERGRID and STU in next week and submit agenda for SPS proposal at 400/220kV Agra(PG) in upcoming Protection subcommittee meeting of NRPC.

During 233 OCC meeting, MS NRPC suggested that NRLDC may prepare SPS logic for 400/220kV Agra(PG) ICTs and share with UPPTCL and POWERGRID. Thereafter, SPS logic can be discussed in next OCC meeting.

NRLDC vide email dated 29.07.2025 had proposed SPS logic for 400/220kV Agra(PG) ICTs. UP SLDC thereafter provided their comments on the SPS proposal. Revised SPS logic taking into account comments from UPPTCL side is attached as **Annexure-B.I** for comments of OCC members.

As discussed in previous OCC meetings, it is once again requested that:

- All SLDCs to take actions such that loading of ICTs and lines in their control area are below their N-1 contingency limits.
- While requisitioning power from various sources, states should take care to limit their scheduled drawl as well as actual drawl in real time within the Available Transfer Capability (ATC) limits assessed by SLDC and NRLDC.
- SLDCs also need to ensure that their drawl from grid remains within these limits during real-time operation. In the past, it has been observed that some states have drawn power beyond their ATC limits as assessed by SLDCs and NRLDC.
- Further, all SLDCs need to make sure that loading of 220kV and below voltage level intrastate lines remain within safe limits during the high demand season.

Further, it may be noted that CERC vide their order dated 29.09.2023 has granted approval of “Detailed Procedure for Allocation of Transmission Corridor for Scheduling of General Network Access and Temporary General Network Access under Central Electricity Regulatory Commission (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022” which requires SLDCs to submit network data as well as PSSE basecases on M-12, M-6, M-1 basis. The monitoring of submission of these data by SLDCs is being done in OCC meetings on monthly basis where response of some of the states needs improvement.

| March 2025 Mails |                     |           |                 |           |                         |           |  |
|------------------|---------------------|-----------|-----------------|-----------|-------------------------|-----------|--|
|                  | ATC/TTC Declaration |           |                 |           | Interconnection Studies |           |  |
|                  | M-1 (April-25)      |           | M-12 (March-26) |           | M-6 (September-25)      |           |  |
|                  | Data Values         | Basecases | Data Values     | Basecases | Data Values             | Basecases |  |
| Chandigarh       | No                  | No        | No              | No        | No                      | No        |  |
| Delhi            | No                  | No        | Yes             | Yes       | No                      | No        |  |
| Haryana          | No                  | No        | Yes             | Yes       | No                      | No        |  |
| Himachal         | Yes                 | No        | Yes             | No        | Yes                     | No        |  |
| J & K            | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Ladakh           | No                  | No        | No              | No        | No                      | No        |  |
| Punjab           | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Rajasthan        | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Uttar Pradesh    | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Uttarakhand      | No                  | No        | No              | No        | No                      | No        |  |

| April 2025 Mails |                     |           |                 |           |                         |           |  |
|------------------|---------------------|-----------|-----------------|-----------|-------------------------|-----------|--|
|                  | ATC/TTC Declaration |           |                 |           | Interconnection Studies |           |  |
|                  | M-1 (May-25)        |           | M-12 (April-26) |           | M-6 (October-25)        |           |  |
|                  | Data Values         | Basecases | Data Values     | Basecases | Data Values             | Basecases |  |
| Chandigarh       | No                  | No        | No              | No        | No                      | No        |  |
| Delhi            | No                  | No        | Yes             | Yes       | No                      | No        |  |
| Haryana          | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Himachal         | Yes                 | No        | Yes             | No        | Yes                     | No        |  |
| J & K            | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Ladakh           | No                  | No        | No              | No        | No                      | No        |  |
| Punjab           | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Rajasthan        | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Uttar Pradesh    | Yes                 | Yes       | Yes             | Yes       | Yes                     | Yes       |  |
| Uttarakhand      | No                  | No        | No              | No        | No                      | No        |  |

| May 2025 Mails |                     |           |               |           |                         |           |  |
|----------------|---------------------|-----------|---------------|-----------|-------------------------|-----------|--|
|                | ATC/TTC Declaration |           |               |           | Interconnection Studies |           |  |
|                | M-1 (June-25)       |           | M-12 (May-26) |           | M-6 (November-25)       |           |  |
|                | Data Values         | Basecases | Data Values   | Basecases | Data Values             | Basecases |  |
| Chandigarh     | No                  | No        | No            | No        | No                      | No        |  |
| Delhi          | No                  | No        | Yes           | Yes       | No                      | No        |  |
| Haryana        | No                  | No        | Yes           | Yes       | Yes                     | Yes       |  |
| Himachal       | Yes                 | No        | Yes           | No        | Yes                     | No        |  |
| J & K          | Yes                 | Yes       | Yes           | Yes       | Yes                     | Yes       |  |
| Ladakh         | No                  | No        | No            | No        | No                      | No        |  |
| Punjab         | Yes                 | Yes       | Yes           | Yes       | Yes                     | Yes       |  |
| Rajasthan      | No                  | No        | No            | No        | No                      | No        |  |
| Uttar Pradesh  | Yes                 | Yes       | Yes           | Yes       | Yes                     | Yes       |  |
| Uttarakhand    | No                  | No        | No            | No        | No                      | No        |  |

| June 2025 Mails |                     |           |                |           |                         |           |  |
|-----------------|---------------------|-----------|----------------|-----------|-------------------------|-----------|--|
|                 | ATC/TTC Declaration |           |                |           | Interconnection Studies |           |  |
|                 | M-1 (July-25)       |           | M-12 (June-26) |           | M-6 (December-25)       |           |  |
|                 | Data Values         | Basecases | Data Values    | Basecases | Data Values             | Basecases |  |
| Chandigarh      | No                  | No        | No             | No        | No                      | No        |  |
| Delhi           | No                  | No        | Yes            | Yes       | No                      | No        |  |
| Haryana         | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Himachal        | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| J & K           | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Ladakh          | No                  | No        | No             | No        | No                      | No        |  |
| Punjab          | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Rajasthan       | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Uttar Pradesh   | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Uttarakhand     | No                  | No        | No             | No        | No                      | No        |  |

| July 2025 Mails |                     |           |                |           |                         |           |  |
|-----------------|---------------------|-----------|----------------|-----------|-------------------------|-----------|--|
|                 | ATC/TTC Declaration |           |                |           | Interconnection Studies |           |  |
|                 | M-1 (August-25)     |           | M-12 (July-26) |           | M-6 (January-26)        |           |  |
|                 | Data Values         | Basecases | Data Values    | Basecases | Data Values             | Basecases |  |
| Chandigarh      | No                  | No        | No             | No        | No                      | No        |  |
| Delhi           | No                  | No        | Yes            | Yes       | No                      | No        |  |
| Haryana         | No                  | No        | No             | No        | No                      | No        |  |
| Himachal        | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| J & K           | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Ladakh          | No                  | No        | No             | No        | No                      | No        |  |
| Punjab          | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Rajasthan       | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Uttar Pradesh   | Yes                 | Yes       | Yes            | Yes       | Yes                     | Yes       |  |
| Uttarakhand     | No                  | No        | No             | No        | No                      | No        |  |

| August 2025 Mails |                     |           |                  |           |                         |           |  |
|-------------------|---------------------|-----------|------------------|-----------|-------------------------|-----------|--|
|                   | ATC/TTC Declaration |           |                  |           | Interconnection Studies |           |  |
|                   | M-1 (Sep-25)        |           | M-12 (August-26) |           | M-6 (February-26)       |           |  |
|                   | Data Values         | Basecases | Data Values      | Basecases | Data Values             | Basecases |  |
| Chandigarh        |                     |           |                  |           |                         |           |  |
| Delhi             |                     |           |                  |           |                         |           |  |
| Haryana           |                     |           |                  |           |                         |           |  |
| Himachal          |                     |           |                  |           |                         |           |  |
| J & K             | Yes                 | Yes       | Yes              | Yes       | Yes                     | Yes       |  |
| Ladakh            |                     |           |                  |           |                         |           |  |
| Punjab            | Yes                 | Yes       |                  |           |                         |           |  |
| Rajasthan         |                     |           |                  |           |                         |           |  |
| Uttar Pradesh     | Yes                 | Yes       | Yes              | Yes       | Yes                     | Yes       |  |
| Uttarakhand       |                     |           |                  |           |                         |           |  |

Submitted with one month delay

**Haryana, HP, Delhi, Rajasthan and Uttarakhand SLDCs are requested to provide update.**

**ATC/TTC limits of states for the month of September 2025 are attached as Annexure-B.II. Utilities are requested to go through these limits and provide comments.**


**Members may please discuss.**

### **B.3. Delay in revival of 400kV Jaisalmer-Barmer D/C and issues during present high wind season**


Rajasthan Control Area has been drawing huge MVAR from the ISTS grid. Regular emails and messages from NRLDC Control Room have been issued to Rajasthan SLDC and also conveyed telephonically to minimize MVAR drawl and facilitate in

keeping grid voltage profile of Rajasthan power network within safe limits. MVAR drawl from the grid by Rajasthan has reached alarming levels of 3200-3500 MVAR in the past first week of August due to high wind season and is posing serious challenge in safe and reliable grid operation.

The Wind generation in Rajasthan is on the higher side and low voltages are observed when high wind generation is coinciding with peak solar hours. It has also been time and again emphasized to maintain grid voltage profile  $\sim 1$  p.u. particularly in Western Rajasthan complex-dominated by the Renewables. Network snapshot during peak solar hours is shown below:



Huge MVAR drawl even when the demand is on lower side has been observed in the past few days (MVAR requirement reaching almost 30 percent of demand met in MW).



While MVAR support from the ISGS RE plants in Western Rajasthan is being taken on daily basis during peak solar hours, MVAR support from conventional and RE generators in state control area is not adequate. In fact, MVAR drawl at RE pooling stations viz. Bhadla(Raj),Bikaner(Raj) etc. are being observed on daily basis and has been flagged at various NRPC/OCC forums also. The issues being faced in Western Rajasthan Grid are broadly summarised as below:

1. Long outage of 400 KV Barmer(Raj)-Jaisalmer(Raj) D/C line (Outage on tower collapse from 01.05.2025)  
Consequences-High loading, low voltages and low SCR particularly in the ongoing High Wind season
2. Loading restriction on 400 KV Bhadla(Raj)-Bikaner(Raj) D/C line-750 MW instead of ~ 1700 MW each ckt. (Damaged conductors and underrated terminal equipment)  
Consequences-One of the major limiting constraints in RE evacuation and leading to restricted NOC of ISGS RE plants to the tune of ~ 4000 MW in peak solar hours. Opening of both 400 KV Bikaner(Raj)-Sikar PG D/C lines to control line loading as per above restriction.
3. Inadequate support from Renewable and Conventional plants in Rajasthan Control Area  
Consequences-Low Voltage in the network. Voltage oscillations observed in peak solar hours.
4. High Wind Generation-drawl of MVAR from grid (High Solar coinciding with high wind-old plants without PPC Control)  
Consequences- High wind generation in peak solar hours causing lowering of SCR and Voltage fluctuations in the depleted network.
5. Non-Availability of Dynamic devices in Rajasthan RE network.  
Consequences-Rajasthan Wind -Solar generation ~ 7000 MW observed in peak solar hours without any dynamic compensation installed in state Control area-leading to vulnerable grid operation.

Voltage oscillations to the tune of 70-80 KV and higher have been observed in the Western Rajasthan complex in this ongoing High Wind season with depleted network during the peak solar hours. It has already been suggested earlier and also intimated through regular mails from NRLDC Control Room to restrict Rajasthan Wind + Solar generation up to 6000 MW in view of the forced outage of 400 KV Barmer-Jaisalmer D/C line and restriction on loading capacity of 400 KV Bhadla(Raj)-Bikaner(Raj) D/C line-(750 MW only).

NRLDC had to curtail solar generation in real time at few occasions to mitigate Voltage oscillations as Rajasthan continued high amount of reactive power drawl from the grid.

Rajasthan SLDC is once again suggested to take following measures to maintain grid parameters within safe limits:

1. Maintain Bus Voltages particularly in RE complex around normative values by taking adequate support from RE as well as conventional plants thus avoiding huge MVAR drawl from grid.
2. Restrict RE generation (Wind + Solar) to around 6000 MW during the outage of 400 KV Barmer (Raj)-Jaisalmer (Raj) D/C line.
3. Expedite installation of capacitor banks giving priority to the nodes where bus voltages are on alarmingly lower side. Also, expediting installation of dynamic compensation devices.
4. Operators at SLDC and REMC Control Room in Rajasthan to take timely actions in maintaining grid parameters viz. Voltage profile etc. so that rise in generation is matched with adequate MVAR support. Day-ahead forecast may also be referred for actions to be taken beforehand to avoid delay.




***Rajasthan SLDC may provide update. Members may please discuss.***


#### **B.4. SPS for Champa-Kurukshetra HVDC and SOP actions in case of tripping**

During high demand period of Northern region, NR imports high power from Western and Eastern region. To optimize flows on AC paths, HVDC power orders are accordingly modulated. Power order of Champa-Kurukshetra HVDC is also kept on the higher side in summer months due to less demand in Western region and high demand in Northern region. However, there have been reliability issues related to Champa-Kurukshetra HVDC since long time. There have been events of simultaneous pole outages also, which creates stressful condition for grid and number of issues are observed in real-time. These effects are more pronounced when Champa-Kurukshetra poles trip simultaneously carrying huge power in antecedent condition. This switches out filter banks, increases power flow on parallel AC lines, increased loading reduces the grid voltages, further, due to increased distance for power to travel, the reactive power support requirement increases tremendously. This may lead to sudden dips in voltage and further load loss due to stalling of induction motor type load.

NRLDC has been continuously pursuing with NR states to take measures for reactive power support at local level so that reactive power exchange from ISTS is minimal. However, as per discussions held in 229-232 OCC meetings, no progress is being reported. From the plots presented by NRLDC in OCC meetings, it can be clearly seen that there is huge MVAR drawl by some of the states such as Haryana, Rajasthan, HP and UP during May-Sep months. These huge MVAR drawl leads to low voltages in the grid especially during the day-time as there is high agricultural as well as cooling load requirement during this time.







There have been two major events involving load loss with simultaneous all poles outage of Champa-Kurukshetra HVDC in last two years:

1. 16.5GW load loss event on 17.06.2024 due to tripping of Champa-Kurukshetra all poles carrying 4000MW with NR total load as 89.4GW
2. 0.9GW load loss event on 09.06.2025 due to tripping of Champa-Kurukshetra all poles carrying 4300MW with NR total load as 82.6GW

This year NR demand has been slightly on the lower side due to favorable weather conditions, however, prolonged dry spell may lead to sudden surge in demand and NR demand may again cross 85GW. It is expected that any incident of simultaneous outage of HVDC Champa-Kurukshetra poles may cause emergency conditions in the Grid. It is possible that voltages in NR stations may reach extremely low values as witnessed during similar incident which occurred on 17<sup>th</sup> Jun 2024.

Accordingly, it is proposed to implement a SPS scheme which can shed loads in case of simultaneous outage of all poles of HVDC Champa-Kurukshetra. Since, identification and wiring of new load groups may be difficult for implementation in short time frame and further utilities have also expressed concerns in identifying further new feeders for UFR or other load shedding schemes, it is suggested to utilise the wired loads of existing Agra-Gwalior or Rihand-Dadri SPS scheme. Signal of multiple HVDC pole outage can be extended from Kurukshetra station to Dadri/Agra SPS scheme and some load relief can be obtained. The automatic disconnection of wired loads post outage of multiple HVDC Poles at Kurukshetra may provide some relief and may help in containing the voltages till suitable static and dynamic compensation devices are commissioned.

List of feeders for Agra-Gwalior/ Rihand-Dadri SPS scheme is attached as **Annexure-B.III**. Concerned states are requested to verify the load quantum mentioned against each feeder. NRLDC will then carry out simulation studies and in consultation with SLDCs/NLDC propose SPS logic for Champa-Kurukshetra HVDC. As some load is proposed to be shed in SPS scheme, corresponding generation backing down will also need to be taken up in Western region.

This feeder review exercise becomes important as on 21.05.2025, at 20:21 hrs, 500kV HVDC Rihand-Dadri D/C tripped on commutation failure. Multiple elements tripped at



400kV Dadri(NTPC) during the event due to multiple faults. 500kV HVDC Rihand-Dadri D/C was carrying ~1150 MW before tripping.

As per SPS of 500kV HVDC Rihand-Dadri, Case-2 of SPS which is "Tripping of any or both poles resulting in power order reduction by 750 MW and above" operated during the event. As per SPS case-2 action, immediate load shed in load groups A, B, C & D and generation backdown at Singrauli / Rihand TPS by 500 MW should occur. However, no major load relief was observed based on demand pattern of states.

During 233 OCC meeting, NRLDC representative stated that SLDCs may share any comments from their side for feeders wired for Agra-Gwalior SPS or Rihand-Dadri SPS scheme by 31.07.2025.

MS NRPC stated that the agenda was also discussed in recent NPC meeting and it was agreed that separate committee would be formed under Member Power System, CEA to look into frequent tripping of Champa-Kurukshetra and suggest remedial measures. The committee would also include members from NLDC, NRLDC, WRLDC, WRPC, NRPC, CTUIL and POWERGRID.

***OCC asked all SLDCs to share any comments from their side for feeders wired for Agra-Gwalior SPS or Rihand-Dadri SPS scheme by 31.07.2025. However, comments from NR states are pending. Members may please discuss.***

#### **B.5. Minimizing deviation against scheduled drawl by state control area**

It has been observed that some of the NR states have been under drawing from the grid in June 2025. The under drawl in Energy terms has reached 8-12 MUs on daily basis as per the Daily Operation Report published by NRLDC. With inclement weather leading to load crash and lower demand, high frequency grid operation has been observed recently. NRLDC has been advising constituents to maintain load generation balance and messages are also regularly issued from Real time operators to the under-drawing constituents. Further, NRLDC has been pro-actively carrying out hydro moderation of ISGS plants in addition to TRAS down support from NLDC to arrest high frequency.

The details of Grid frequency remaining above 50.05 Hz (above IEGC band), maximum frequency of the day, daily under-drawl (MU) and max. under-drawl based on 5 minutes average telemetered data i.r.o. Rajasthan state control area is given below:

#### **Rajasthan Deviation and grid frequency**

| Date       | Deviation/UI<br>[Overdrawl (+)<br>Underdrawl (-)]<br>MUs | Max Under-drawl (in<br>MW) during high<br>frequency time | % of time frequency<br>above 50.05 Hz<br>(above IEGC band) |
|------------|--|--|--|
| 04.08.2025 | -7.81  | 1270 MW / 50.13 Hz at<br>09:00 Hrs                       | 17.3%  |
| 03.08.2025 | -9.28  | 1816 MW / 50.17Hz at<br>13:03Hrs                         | 14.9%  |
| 02.08.2025 | -12.63   | 906 MW / 50.28 Hz at<br>07:58 Hrs                        | 15.0%  |

|            |        |                                 |       |
|------------|--------|---------------------------------|-------|
| 01.08.2025 | -9.14  | 840 MW / 50.27 Hz at 14:03 Hrs  | 19.3% |
| 31.07.2025 | -6.55  | 260 MW / 50.20 Hz at 13:12 Hrs  | 21.8% |
| 30.07.2025 | -5.48  | 1050 MW / 50.18 Hz at 11:06 Hrs | 21.0% |
| 29.07.2025 | -13.28 | 2419 MW / 50.26 Hz at 13:05 Hrs | 23.2% |
| 28.07.2025 | -9.15  | 693 MW / 50.21 Hz at 13:04 Hrs  | 22.3% |
| 27.07.2025 | -2.76  | 1494 MW / 50.28 Hz at 16:06 Hrs | 22.0% |
| 26.07.2025 | -8.21  | 577 MW / 50.25 Hz at 11:34 Hrs  | 20.7% |
| 25.07.2025 | -2.47  | 837 MW / 50.11 Hz at 09:11 Hrs  | 12.8% |
| 24.07.2025 | -2.61  | 839 MW / 50.13 Hz at 18:31 Hrs  | 15.0% |
| 23.07.2025 | -7.02  | 541 MW / 50.25 Hz at 13:03 Hrs  | 20.4% |

Plots attached as Annexure-B.IV.

Such large deviations from schedule and high frequency operation are a threat to the system security.

To avoid continuous high frequency operation in the grid, following actions may be ensured during real-time grid operation and maintain their drawl close to schedule:

- Portfolio management through sale/purchase of power in T-GNA
- Lifting of planned load shedding, curtailments, if any
- Generation backing down in coal fired thermal stations to 55% of Maximum Continuous Rating (MCR) loading of the units on bar at the generating station after deducting the normative Auxiliary Energy Consumption plus Auxiliary Energy Consumption compensation as per the provisions of the Grid Code as per merit order based on variable charges
- Downward revision of requisitions from ISGS as per merit order on request of beneficiaries
- Generation reduction at hydro stations having storage capability

During 233 OCC meeting held on 15.07.2025,

Rajasthan SLDC representative stated the state demand has reduced drastically during Jun 2025 compared to previous year. Intrastate Thermal generation is being backed down to technical minimum level as well as requisitions from ISGS are being revised to revise net schedule of state from ISTS. Moreover, as a last resort, RE curtailment has also been done on few occasions to maintain state drawl from the grid.

CGM NRLDC highlighted that all available measures are being taken at GRID-INDIA level to manage frequency during day-time and all ISGS thermal generating stations are operating at 55% of their MCR during peak solar period. In view of lack of support from intrastate thermal generators in backing down of generation, under Emergency condition, TRAS down was implemented on several days from 25.05.2025 in ISTS RE solar generating stations having installed capacity of 250 MW or more. Accordingly, decisions regarding closing and bringing intrastate machines on bar need to be taken swiftly by SLDCs.

***However, as per recent analysis at NRLDC end there is lot of scope for further improvement in load generation balancing and maintaining drawl close to schedule by Rajasthan SLDC. Rajasthan SLDC may please provide update.***

#### **B.6. Delay in return of shutdown of Transmission elements and prolonged outage of elements affecting grid operation**

The shutdown of 765 KV Meerut-Koteshwar ckt.1 was approved from 11.07.2025 to 20.07.2025 for NHAH diversion works. Grid-India concerns regarding the N-1 non-compliance status during the shutdown period was strongly put up during the meeting called by NRPC with PGCIL, NHAH, GRID-INDIA, Tehri Hydro and SLDCs for facilitating the said shutdown. The generation evacuation of Tehri Hydro, Tehri PSP and Koteshwar Hydro was through the only available path i.e. 765 KV Meerut-Koteshwar ckt. 2. The shutdown was facilitated with the condition that the timeline of the shutdown would be strictly adhered.

However, there was inordinate delay in restoration of the said transmission line, and it has come to notice that the shutdown was taken despite of unresolved Right of Way issues which was already known to NHAH/PGCIL and ultimately the line was revived on 29.07.2025.

The tripping of 765 KV Meerut-Koteshwar ckt. 2 at 19:46 hours on 22.07.2025 on phase to Earth fault (B-N) led to loss of the only available evacuation path for generators at Tehri HEP, Tehri PSP and Koteshwar HEP. Generation loss of 1436 MW was observed due to the above line tripping. (Tehri HEP- 846 MW, Tehri PSP- 200 MW and Koteshwar HEP-390 MW). The transmission line could only be revived by 11:00 hrs of 23.07.2025 and the whole Tehri-Koteshwar generation complex was unavailable for generation during the said period. The non-utilisation of Hydro resources during this high demand period and spillage of Koteshwar hydro due to loss of evacuation path is a matter of concern and leads to challenges in maintaining grid parameters within safe and reliable limits.

Apart from this there are several other transmission elements whose shutdown was returned with delay from various utilities. It may be noted that Northern Region demand is on the high side with peak demand of the day in the range of 80-82 GW driven by Agriculture/paddy load along with hot and humid conditions. Further, various hydro units in the Northern Region are forced to go under outage due to high silt condition on short notice.

List of transmission elements wherein there was delay in return of shutdown by utilities is shown below:

| SL. No | Element Name  | Approved Shutdown (From) | Approved Shutdown (To) | Actual revival date | Reason   | Remarks  |
|--------|---|--------------------------|------------------------|---------------------|--|--|
| 1      | 400 KV Bawana CCGTB(DTL)-Bahadurgarh(PG) (PG) Ckt-1 | 24.07.2025               | 03.08.2025             | 06.08.2025          | for NHAI diversion works                                 |  |
|        | 400 KV Bawana CCGTB(DTL)-Bhiwani(PG) (PG)           |                          |                        | 06.08.2025          |  |  |
| 2      | 765 KV KOTESHWAR-MEERUT (PG) CKT-1                  | 11.07.2025               | 20.07.2025             | 29.07.2025          | for NHAI diversion works.                                | Generation loss of approx 1400MW due to tripping of remaining ckt 2 on 22.07.2025/19:46Hrs |
| 3      | 400 KV BHADLA-MERTA (RS) CKT-1                      | 03.05.2025/15:00         | 05.05.2025/06:00       | 09.05.2025          | To facilitate the work of Shifting / Height raising work | Re curtailment of 600MW during shutdown  |
|        | 400 KV BHADLA-JODHPUR (RS) CKT-1                    |                          |                        |                     |  |  |
| 4      | 400 KV RAJWEST(RW)-GSS PACHPADRA (RS) CKT-1         | 19.03.2025               | 31.03.2025             | 19.04.2025          | Height Raising and Shifting work                         |  |
|        | 400 KV RAJWEST(RW)-JODHPUR (RS) CKT-1               |                          |                        |                     |  |  |
| 5      | 400 KV KAITHAL-MALERKOTLA (PG) CKT-1                | 12.03.2025               | 22.03.2025             | 26.03.2025          | for NHAI diversion work.                                 |  |
| 6      | 400 KV JODHPUR-KANKANI (RS) CKT-1                   | 21.12.2024               | 31.12.2024             | 14.01.2025          | For Height Raising work                                  |  |
|        | 400 KV MERTA-KANKANI (RS) CKT-1                     |                          |                        |                     |  |  |

Several important transmission lines in the Northern Region are under prolonged outage due to tower collapse. The extended non-availability of these elements is impacting grid reliability, load transfer capability, and in some cases RE evacuation.

| Sr. No. | Element                               | Owner  | Outage Date | No. of Days Out | Reason                          |
|---------|---------------------------------------|--------|-------------|-----------------|---------------------------------|
| 1       | 220 kV Gazipur (DTL) – Sahibabad (UP) | UPPTCL | 30-04-2022  | 1158            | Bending of tower no. 4          |
| 2       | 220kV Gazipur(DTL)-Noida Sec. 62      |        |             |                 | Tower tilted at location no. 10 |

|   |   |        |            |     |   |
|---|---|--------|------------|-----|---|
| 3 | 220 kV Kishenpur (PG) – Mir Bazar (PDD) Ckt-1 | JKPTCL | 21-06-2024 | 375 | Tower foundation damaged at loc. no. KP-196     |
| 4 | 400 kV Jaisalmer – Barmer (RS) Ckt-2          | RRVPNL | 01-05-2025 | 61  | Tower collapse at 12 locations (Loc. no. 70–81) |
| 5 | 400 kV Jaisalmer – Barmer (RS) Ckt-1          |        | 01-05-2025 | 61  |   |

Further, number of other transmission elements are also under prolonged outage such as:

| S. No. | Element Name                                  | Owner  | Date       | Reason / Remarks   |
|--------|---|--------|------------|--|
| 1      | 400/220 kV 315 MVA ICT 1 at Muradnagar_1(UP)  | UPPTCL | 13-03-2020 | Buccholz relay alarm and Local Breaker Backup protection operated. |
| 2      | 400/220 kV 240 MVA ICT 3 at Moradabad(UP)     | UPPTCL | 13-12-2021 | Due to high DGA values, Hydrogen gas is above permissible limit.   |
| 3      | 400 KV Noida Sec 148-Noida Sec 123 (UP) Ckt-2 | UPPTCL | 09-03-2023 | Flashover Y-phase earth switch compartment at Noida Sector-148.    |

Number of Fixed Series capacitors (FSCs) are also under prolonged outage such as:

| Name of Elements (Owner: POWERGRID)                                 | Outage time/date | Reason of tripping   |
|---|------------------|--|
| FSC of 400 KV Fatehpur-Mainpuri (PG) Ckt-1 at Mainpuri (PG)         | 21:07 / 24.10.21 | BHEL breaker hydraulic pressure could not be developed in B phase and (loss of N2 pressure) doesn't allow the FSC-1 taken into service as reported by CPCC3. OEM support stopped |
| FSC of 400 KV Fatehpur-Mainpuri (PG) Ckt-2 at Mainpuri (PG)         | 08:25 / 29.10.21 | VME protection system was blocking the FSC back in service as reported by CPCC3. OEM support stopped   |
| FSC(40%) of 400 KV Kanpur-Ballabgarh (PG) Ckt-2 at Ballabgarh (PG)  | 10:25 / 23.09.22 | DC earth fault in main power supply. Safety clearance required.  |
| FSC(45%) of 400 KV Bareilly-Unnao (UP) Ckt-1 at Unnao(UP)           | 19:50 / 03.01.24 | Problem in GTE card of R phase and also unbalancing of one capacitor of B phase.   |
| FSC (40%) of 400 KV Kanpur-Ballabgarh (PG) Ckt-3 at Ballabgarh (PG) | 11:58 / 14.02.25 | For attending the capacitor unbalance alarm  |

***All transmission utilities are advised to strictly adhere to the approved timelines so that grid operation is not affected and other shutdown requests are also timely allowed. Further, it is requested to update likely revival date for these in the NRLDC outage portal and expedite revival of these transmission elements.***

***Members may please discuss.***

## **B.7. Demand forecasting and resource adequacy related**

Hon'ble CERC In the matter of Planning for safe, secure, and reliable integrated operation of the power system during critical periods arising on account of seasonal variations wherein the electricity demand increases rapidly by undertaking specific measures to mitigate the risks on the power system, under clause (h) of sub-section (1) of Section 79 of the Electricity Act, 2003 and the Regulation 31 of the Central Electricity Regulatory Commission (Indian Electricity Grid Code) Regulations, 2023 has issued suo-motto order 9/SM/2024 dated 07.10.2024.

Subsequently, a meeting was taken by Hon'ble CERC on 14.02.2025 with all NR SLDCs, NRLDC and NRPC to review the actions being taken at SLDC end on measures related to resource adequacy.

It is to be noted that CERC has also released "Report on Planning for safe, secure, and reliable integrated operation of the power system during critical periods arising on account of seasonal variations wherein the electricity demand increases rapidly by undertaking specific measures to mitigate the risks on the power system under Order dated 07.10.2024 in Suo-Moto Petition No. 9/SM/2024" on 29.04.2025.

In the report following actions have been suggested:

| Area               | Key Action   |
|--------------------|--|
| Power Procurement  | Advance contracts, banking arrangements  |
| Forecasting        | Tool access, RLDC coordination, automation incase of manpower issue, Feedback from DISCOM, |
| Manpower           | Approvals as per MoP guidelines, training  |
| Reserve Management | Enforce obligations, clarify reserve norms   |
| Thermal Generation | Enable operation at MTL, regulatory support from SERC                                      |
| SAMAST             | Ensure implementation within strict timelines  |

With reference to the Clause 31(2) of Central Electricity Regulatory Commission-IEGC Regulations, 2023 and the Operating Procedure of NRLDC prepared in accordance with the same, each SLDC has to furnish the demand estimation for day ahead, week ahead, month ahead (with time block wise granularity) and demand estimation for year ahead (with hour granularity). The sub-clause 31(2) (h) of IEGC-2023 states the following timeline for the submission of demand estimate data to RLDC.

| Type of Demand Estimation | Timeline                           |
|---------------------------|------------------------------------|
| Daily                     | 10:00 hours of previous day        |
| Weekly                    | First working day of previous week |
| Monthly                   | Fifth day of previous month        |
| Yearly                    | 30th September of previous year    |

**Status of Day Ahead Forecasting, week ahead, month-ahead and year-ahead submission status for Aug-2025 as per Clause 31(4) (a) & (b) of IEGC-2023 is shown below:**

| State/Entity        | Day Ahead   | Week Ahead              | Month Ahead   | Year-Ahead    |
|---------------------|---|-------------------------|---------------|---------------|
| Punjab              | As per Format                                       | As per Format           | As per Format | Not received  |
| Haryana             | Demand and Resource not as per format               | Only demand & irregular | Not received  | Not received  |
| Delhi               | Demand and Resource not as per format               | As per Format           | As per Format | Only Demand   |
| Rajasthan           | As per Format but irregular                         | As per Format           | Not received  | Not received  |
| Uttar Pradesh       | As per Format                                       | As per Format           | As per Format | As per Format |
| Uttarakhand         | Demand and Resource not as per format and irregular | As per Format           | As per Format | Not received  |
| Himachal Pradesh    | Demand and Resource not as per format               | As per Format           | As per Format | As per Format |
| J&K and Ladakh (UT) | Demand and Resource not as per format & irregular   | Not received            | Not received  | Not received  |
| Chandigarh (UT)     | As per Format                                       | Not received            | Not received  | Not received  |

In accordance with above, all SLDCs are requested to timely furnish the demand estimation data along with generation adequacy data as per the formats available at [https://drive.google.com/drive/folders/1KWY4G9gTBLV5wTJkhGEleRptKP-QbhjL?usp=drive\\_link](https://drive.google.com/drive/folders/1KWY4G9gTBLV5wTJkhGEleRptKP-QbhjL?usp=drive_link) to NRLDC through mail (nrldcmis@grid-india.in) and FTP as per above timeline.

All SLDCs need to take actions at their end for timely submission of demand forecasting and resource adequacy data on day-ahead, week-ahead, month ahead and year ahead basis.

***It may be noted that timeline for submission of year ahead data of 2026-27 is 30<sup>th</sup> Sep 2025.***

Further, NRLDC has also carried out month ahead resource adequacy analysis on regional basis for Sep 2025 as per data available at NRLDC through PRAS software. The results are attached as Annex B.V. The major inferences from results are:

***NRLDC had also organized training program for NR SLDCs on 29.07.2025 regarding Demand Forecast, RA Planning & Reserve Assessment for SLDCs of Northern Region***

#### **Self-audit related:**

As per IEGC Clause 56.2(c), 'The self-audit reports by users, QCAs, and SNAs shall be submitted to the concerned RLDC or SLDC, as the case may be.' Failure to submit the self-audit report within the stipulated timeframe would be considered a non-compliance with IEGC regulations.

During the 228th OCC meeting, CGM, NRLDC, reiterated the importance of conducting the self-audit exercise within the timelines mandated by regulations. He informed that NRLDC has already submitted its self-audit report to CERC and urged all stakeholders to do the same.

Self-audit report has been received from NHPC and Koteshwar THDC for F.Y. 2023-24.

During 233 OCC meeting,

NRLDC representative stated that:

- Data on day ahead basis received from some of the states (as shown in table) is not as per NRLDC format. It was further mentioned that NRLDC is in process of developing a code/program for automation of day-ahead resource adequacy. In case data is not received in formats circulated by NRLDC, it would not be possible to map/utilize the data submitted by states in the internal program being developed at NRLDC end.
- Self-audit report has been received from NHPC and Koteshwar THDC only for F.Y. 2023-24. As F.Y. 2024-25 has also completed recently, all utilities in Northern region are requested to carry out self-audit exercise and share report with NRLDC as per IEGC Clause 56.2(c).

As 31.07.2025 has already past, it is requested that all concerned users of NRLDC may carry out their self-audit and submit report to NRLDC at the earliest. List of NRLDC users is attached as **Annex B.VI**.

OCC asked all the states to take actions at their end to ensure compliance of all regulations and guidelines w.r.t. resource adequacy framework. OCC forum asked all concerned utilities to carry out self-audit exercise as per IEGC Clause 56.2(c), and submit the report to NRLDC.


***All concerned are requested to provide update. Members may please discuss.***



## B.8. Near real-time monitoring of silt at NRLDC for hydro generating stations

Availability of near real time silt measurement data to NRLDC/ SLDCs is helpful for real time system operation in view of frequent hydro generation outage due to silt. PPM numbers are being punched directly from the site/control room at NRLDC server providing silt measurement at NRLDC control room. During previous years also, for Nathpa Jhakri, Baspa, Karcham and other small HEPs of Uttarakhand, trends of silt data were made available at NRLDC & being monitored by system operators in real-time.

Sample plot showing outage of hydro generating stations due to high silt level leading sudden outage of hydro generating stations in Northern region is shown below:



Large hydro outage in short duration during monsoon on silt is a common phenomenon and the associated challenges have been highlighted in regular OCC/TCC meeting. The agreed action based on deliberation in various meetings are given below:

- Action for Generator
  - o Silt monitoring/Silt forecasting for planned hydro outage [Advance information]
  - o Reduction of Generation/Tripping of Units as per protocol (Staggering of units)
  - o Slow ramping down of generation on the units to be closed as per protocol.
- Action by SLDC/Constituents
  - o Generation reserve to be maintained
    - Own Generation
    - Contracted Generation from Other State/Traders
  - o Load management to be planned
  - o Optimization of Hydro generation as per demand requirement

In view of upcoming silt scenario, all hydro stations are requested to furnish the silt forecast data (near-real time silt measurement) for operational planning measures to control centers (RLDCs/SLDCs) as this would help them gain some lead-time for better tackling of hydro generator outage on silt.

NRLDC has also developed a portal for sharing of silt-data by hydro generating stations with NRLDC. Login credentials have been shared with all hydro generating stations for sharing of the data with NRLDC. NRLDC also demonstrated the portal in 233 OCC meeting on 15.07.2025.

Still, it is being observed that number of NR hydro plants are regularly not sharing the silt data with NRLDC control room.

Further, it is observed that even after repeated messages some states such as HP continue to overdraw from the grid in case of outage of hydro generating units on silt. Multiple violation messages were sent from NRLDC side on 21.07.2025 and 22.07.2025 to HP which was continuously overdrawing on 21.07.2025 during evening hours between 18:30 Hours to 23:00 Hours from the Grid. Further, the grid frequency was very low and minimum frequency recorded was 49.59 Hz. During this low frequency period, HP state control area was continuously overdrawing in the range of 610 to 650 MW and total over drawl quantum was 1.60 MUs on 21.07.2025. Such significant over-drawl during low frequency regime causes a serious threat to Grid stability and exposes the system to heightened contingency risk. It is further to be noted that HP state had not purchased the required quantum of power in RTM and was already selling in DAM. Similar, overdrawl by HP state was once again observed on 05.08.2025.

Himachal Sell in RTM and UI from Grid for 05.08.2025



***OCC forum may advise all hydro stations to timely share silt related information with NRLDC on newly developed portal and also follow protocol as approved by NRPC for taking units out in staggered manner in case of high silt.***

## **B.9. Mock testing of islanding scheme and simulation studies**

Following four islanding schemes are operational in the Northern Region: NAPP Islanding Scheme (Uttar Pradesh), RAPP Islanding Scheme (Rajasthan), Bawana Islanding Scheme (Delhi), and Unchahar Islanding Scheme (Uttar Pradesh).

During 233 OCC meeting, NRLDC representative presented the latest status of actions required on various islanding schemes.

| Scheme                          | UFR testing done | Basecase shared | SCADA display made |
|---------------------------------|------------------|-----------------|--------------------|
| NAPP Islanding scheme (UP)      | ☑ Yes            | ☑ Yes           | ☑ Yes              |
| RAPP Islanding scheme (Raj)     | ☑ Yes            | ☑ Yes           | ☑ Yes              |
| Bawana Islanding scheme (Delhi) | ✗ No             | ☑ Yes           | ☑ Yes              |
| Unchahar Islanding scheme(UP)   | ☑ Yes            | ✗ No            | ✗ No               |

It was also discussed that there have been recent directions from NPC and MoP also for islanding testing.

POWERGRID representative stated that pending testing of UFR at POWERGRID will be carried out shortly.

NRLDC asked DTL to share comprehensive testing report of islanding scheme after completion of testing exercise of Delhi islanding scheme.

MS NRPC expressed concern on delay in UFR testing of Delhi islanding scheme and asked all concerned to take necessary actions at the earliest and submit report to NRLDC/NRPC.

It was highlighted from NRLDC side that although SCADA displays have been made for islanding schemes, telemetry of site data to NRLDC is poor and most of the time, some or other data is missing. UFR testing report has been submitted by UP SLDC for Unchahar islanding scheme, however, basecase details and SCADA display are yet to be received at NRLDC end.

UP SLDC representative stated that SCADA display of Unchahar islanding scheme is available at UP SLDC and would be shared with NRLDC also.

***Concerned SLDCs are requested to provide update.***

#### **B.10. Multiple element tripping events in Northern region in the month of July 2025:**

A total of 21 grid events occurred in the month of July 2025 of which 14 are of GD-1 category 02 are of GI-2 Category and 05 are of GI-1 Category. The tripping report of all the events have been issued from NRLDC. A list of all these events along with the status of DR/EL & tripping detail submission is attached at **Annexure-B.VII**.

Maximum delayed clearance of fault observed in event of tripping event at 220/33kV RSDCL PSS2 RE station at 13:46 hrs on 04<sup>th</sup> July 2025 (As per PMU at Bhadla2(PG), R-Y phase to phase fault with delayed fault clearing time of 1200 msec is observed).

Delayed clearance of fault (more than 100ms for 400kV and 160ms for 220kV system) observed in total 06 events out of 21 grid events occurred in the month. In 05 (no.) of grid event, there was no fault in the grid.

***As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event and as per IEGC clause 37.2 (e), the user shall submit a detailed report in the case of grid disturbance or grid incidence within one (1) week of the occurrence of event to RLDC and RPC.***

It is observed that DR/EL & tripping report of most of the grid events are not being submitted as per timeline specified in IEGC 2023. Non availability to tripping details further hampers the grid event analysis at RLDC level.

**Members may take necessary preventive measures to avoid such grid incidents / disturbances in future and share the report of actions taken by respective utilities. Moreover, utilities may impress upon all concerned for providing the Preliminary Report, DR/EL & Detailed Report of the events to RLDC in line with the IEGC clause 37.2 (c) & (e).**

Members may like to discuss.

#### **B.11. Status of submission of DR/EL and tripping report of utilities for the month of July 2025:**

The status of receipt of DR/EL and tripping report of utilities for the month of **July 2025** is attached at **Annexure-B.VIII**. It is to be noted that as per the IEGC provision under clause 37.2 (c), the tripping report along with DR/EL has to be furnished within 24 hrs of the occurrence of the event. However, it is evident from the submitted data that reporting status of RE stations, SLDC-HR, SLDC-PS, SLDC-J&K, SLDC-HP, SLDC-Delhi, BBMB, NTPC, NHPC and RAPS is not satisfactory and needs improvement.

Members may please note and advise the concerned for timely submission of the information. It is requested that DR/EL of all the trippings shall be **uploaded on Web Based Tripping Monitoring System “<https://postda.nrldc.in/Default.aspx>”** within 24 hours of the events as per IEGC clause 37.2(c) and clause 15.3 of CEA grid standard. Apart from prints of DR outputs, the corresponding COMTRADE files (.cfg/.dat) may please also be submitted in tripping portal.

Members may like to discuss.

#### **B.12. Frequency response performance for the reportable events of month of July 2025:**

In the month of June 2025, 2 no. of reportable events were notified by NLDC for which FRC/ FRP need to be calculated. Description of the event is as given in the Table below:

| S. No. | Event Date | Time (In hrs.) | Event Description  | Starting Frequency (in Hz) | Nadir Frequency (in Hz) | End Frequency (in Hz) | $\Delta f(\text{Hz})$ | NR FRP during the event |
|--------|------------|----------------|--|----------------------------|-------------------------|-----------------------|-----------------------|-------------------------|
| 1      | 22-July-25 | 19:46 hrs      | As reported, at 19:46 hrs on 22nd July 2025, generation loss event of 1437MW occurred at Tehri, Koteshwar Hydro generation complex in NR. Hence generation loss of 1437 MW is considered for FRC/FRP Calculation.        | 49.942                     | 49.832                  | 49.874                | -0.068                | 1.31                    |
| 2      | 29-July-25 | 14:55 hrs      | As reported, at 14:55 hrs on 29 <sup>th</sup> July 2025, generation loss event of 1100 MW occurred at ACME_Fatehgarh_I in Rajasthan RE complex. Hence, generation loss of 1100 MW is considered for FRC/FRP Calculation. | 50.145                     | 50.044                  | 50.075                | -0.70                 | 0.95                    |

As per IEGC 2023 Clause 30.8, "The primary response of the generating units shall be verified by the Load Despatch Centres (LDCs) during grid events. The concerned generating station shall furnish the requisite data to the LDCs within two days of notification of reportable event by the NLDC."

As per IEGC 2023 Clause 30.10.(n), "Each control area shall assess its frequency response characteristics and share the assessment with the concerned RLDC along with high resolution data of at least 1 (one) second for regional entity generating stations and energy storage systems and 10 (ten) seconds for the state control area."

As per sub-clause (a(v)) of clause (9) of IEGC 2023 Annexure-2, "All the SLDCs shall work out FRC for all the intra-state entities (for events indicated by the Regional Load Despatch Centres) based on the HDR available at their respective SLDCs and submit the same to respective RLDC within six (6) working days after the event. (Format as per Table-B)."

As per sub-clause (a(vi)) of clause (9) of IEGC 2023 Annexure-2, "All regional entity generating stations shall also assess the FRC for their respective stations and submit the same to respective RLDC within six (6) working days. (Format as per Table-B). The high-resolution data (1 second or better resolution) of active power generation and frequency shall also be shared with RLDC."

Status of details received from constituents as on 05<sup>th</sup> August 2025 is:

|   |
|---|
| <b>FRC computation and data submission status</b> |
|---|

| S. No | Control Area           | Event Date   |              |
|-------|------------------------|--------------|--------------|
|       |                        | 22-07-2025   | 29-07-2025   |
| 1     | Punjab                 | Received     | Not Received |
| 2     | Haryana                | Received     | Not Received |
| 3     | Rajasthan              | Received     | Received     |
| 4     | Delhi                  | Received     | Not Received |
| 5     | Uttar Pradesh          | Received     | Received     |
| 6     | Uttarakhand            | Not Received | Not Received |
| 7     | Chandigarh*            | NA           | NA           |
| 8     | Himachal Pradesh       | Received     | Received     |
| 9     | J&K(UT) and Ladakh(UT) | Not Received | Not Received |
| 10    | Dadri -1 (TH)          | Received     | Received     |
| 11    | Dadri -2 (TH)          | Received     | Received     |
| 12    | Jhajjar (TH)           | Received     | Received     |
| 13    | Rihand-1 (TH)          | Received     | Received     |
| 14    | Rihand-2 (TH)          | Received     | Received     |
| 15    | Rihand-3 (TH)          | Received     | Received     |
| 16    | Shree Cement (TH)      | Not Received | Not Received |
| 17    | Singrauli (TH)         | Not Received | Not Received |
| 18    | Tanda-2 (TH)           | Received     | Received     |
| 19    | Unchahar-I (TH)        | Received     | Received     |
| 20    | Unchahar-II (TH)       | Received     | Received     |
| 21    | Unchahar-III (TH)      | Received     | Received     |
| 22    | Unchahar-IV (TH)       | Received     | Received     |
| 23    | Anta (G)               | Not Received | Received     |
| 24    | Auraiya (G)            | Not Received | Not Received |
| 25    | Dadri (G)              | Not Received | Not Received |
| 26    | AD Hydro (H)           | Received     | Received     |
| 27    | Bairasiul (H)          | Received     | Received     |
| 28    | Bhakra (H)             | Not Received | Not Received |
| 29    | Budhil (H)             | Not Received | Not Received |
| 30    | Chamera-1 (H)          | Received     | Received     |
| 31    | Chamera-2 (H)          | Not Received | Received     |
| 32    | Chamera-3 (H)          | Not Received | Not Received |
| 33    | Dehar (H)              | Not Received | Not Received |
| 34    | Dhauliganga (H)        | Received     | Not Received |
| 35    | Dulhasti (H)           | Received     | Received     |
| 36    | Karcham (H)            | Received     | Received     |
| 37    | Kishenganga            | Received     | Received     |
| 38    | Koldam (H)             | Received     | Received     |
| 39    | Koteshwar (H)          | NA           | Received     |
| 40    | Malana-2 (H)           | NA           | NA           |
| 41    | Nathpa Jhakri (H)      | Received     | Received     |
| 42    | Parbati-2 (H)          | Not Received | Not Received |
| 43    | Parbati-3 (H)          | Received     | Received     |
| 44    | Pong (H)               | Not Received | Not Received |
| 45    | Rampur (H)             | Received     | Received     |
| 46    | Sainj (H)              | Not Received | Not Received |
| 47    | Salal (H)              | Received     | Received     |

|    |                      |              |              |
|----|----------------------|--------------|--------------|
| 48 | Sewa-II (H)          | Not Received | Received     |
| 49 | Singoli Bhatwari (H) | Not Received | Not Received |
| 50 | Sorang (H)           | Not Received | Not Received |
| 51 | Tanakpur (H)         | Received     | Received     |
| 52 | Tehri (H)            | NA           | Received     |
| 53 | Uri-1 (H)            | Received     | Received     |
| 54 | Uri-2 (H)            | Not Received | Not Received |

Members are requested to share the FRC/FRP computation of their respective control area as per the timeline specified in IEGC 2023.

Frequency Response Performance (FRP) of generating stations for each reportable event are calculated based on the submitted high resolution data from generating stations. However, the generating stations for which data is not received till 05<sup>th</sup> August 2025, FRC/FRP as per NRLDC HDR data is used for computation of Average Monthly Frequency Response Performance, Beta ' $\beta$ ' for Generating Stations.

FRP values as considered (as per NRLDC HDR data) for the event of July 2025 is as follows:

| Frequency response Performance |                        |            |            |
|--------------------------------|------------------------|------------|------------|
| S. No                          | Control Area           | Event Date |            |
|                                |                        | 22-07-2025 | 29-07-2025 |
| 1                              | Punjab                 | 0.87       | 0.84       |
| 2                              | Haryana                | 2.60       | -0.29      |
| 3                              | Rajasthan              | 1.75       | 1.58       |
| 4                              | Delhi                  | 2.90       | 1.00       |
| 5                              | Uttar Pradesh          | 2.24       | -0.14      |
| 6                              | Uttarakhand            | -1.02      | -0.31      |
| 7                              | Chandigarh*            | NA         | NA         |
| 8                              | Himachal Pradesh       | 0.96       | -1.04      |
| 9                              | J&K(UT) and Ladakh(UT) | -0.34      | -0.34      |
| 10                             | Dadri -1 (TH)          | 4.63       | 0.18       |
| 11                             | Dadri -2 (TH)          | 16.24      | 1.02       |
| 12                             | Jhajjar (TH)           | 0.00       | 0.70       |
| 13                             | Rihand-1 (TH)          | 11.47      | -0.08      |
| 14                             | Rihand-2 (TH)          | 4.33       | 0.37       |
| 15                             | Rihand-3 (TH)          | 4.90       | 0.52       |
| 16                             | Shree Cement (TH)      | 2.86       | 16.17      |
| 17                             | Singrauli (TH)         | 0.75       | 0.02       |
| 18                             | Tanda-2 (TH)           | -0.68      | -0.07      |
| 19                             | Unchahar-I (TH)        | 10.79      | 0.00       |
| 20                             | Unchahar-II (TH)       | 0.02       | 6.41       |
| 21                             | Unchahar-III (TH)      | 5.01       | 0.99       |
| 22                             | Unchahar-IV (TH)       | 3.18       | 1.26       |
| 23                             | Anta (G)               | 3.13       | No Gen     |
| 24                             | Auraiya (G)            | 1.04       | No Gen     |
| 25                             | Dadri (G)              | 10.35      | No Gen     |
| 26                             | AD Hydro (H)           | 0.00       | 2.38       |



|    |                      |                |        |
|----|----------------------|----------------|--------|
| 27 | Bairasiul (H)        | 0.00           | 0.00   |
| 28 | Bhakra (H)           | -0.28          | 0.09   |
| 29 | Budhil (H)           | No Gen         | 0.35   |
| 30 | Chamera-1 (H)        | -1.31          | 0.08   |
| 31 | Chamera-2 (H)        | No Gen         | 4.09   |
| 32 | Chamera-3 (H)        | 0.00           | 0.00   |
| 33 | Dehar (H)            | 1.28           | 0.76   |
| 34 | Dhauliganga (H)      | 5.51           | 8.33   |
| 35 | Dulhasti (H)         | 0.28           | 2.48   |
| 36 | Karcham (H)          | No Gen         | 9.10   |
| 37 | Kishenganga          | -0.21          | -0.07  |
| 38 | Koldam (H)           | 0.09           | -0.43  |
| 39 | Koteshwar (H)        | Affected plant | 0.00   |
| 40 | Malana-2 (H)         | NA             | NA     |
| 41 | Nathpa Jhakri (H)    | No Gen         | 3.44   |
| 42 | Parbati-2 (H)        | No Gen         | No Gen |
| 43 | Parbati-3 (H)        | 0.00           | 1.79   |
| 44 | Pong (H)             | 0.43           | -0.52  |
| 45 | Rampur (H)           | No Gen         | 6.72   |
| 46 | Sainj (H)            | No Gen         | No Gen |
| 47 | Salal (H)            | -0.55          | -0.29  |
| 48 | Sewa-II (H)          | 0.00           | 0.00   |
| 49 | Singoli Bhatwari (H) | -0.43          | No Gen |
| 50 | Sorang (H)           | 0.20           | 0.19   |
| 51 | Tanakpur (H)         | -2.05          | -3.20  |
| 52 | Tehri (H)            | Affected plant | No Gen |
| 53 | Uri-1 (H)            | 0.65           | 0.74   |
| 54 | Uri-2 (H)            | -2.45          | -1.43  |

From the FRP data, it is observed that FRP of many of the control areas are not satisfactory. Therefore, it is requested to review the FRC/FRP, governor actions of your respective control area, necessary actions may be taken for improvement in the FRC/FRP.

ISGS were requested to confirm whether FGMO as per IEGC 2023 has been implemented at their respective stations or not. Updated sheet on the basis of details received is as follows:

| Sl. No. | Entity        | Capacity(MW) | Governor Mode (FGMO as per IEGC 2023) Yes or No | Droop setting (%) | Remarks (if any)     |
|---------|---------------|--------------|---|-------------------|----------------------|
| 1       | Dadri-1 (TH)  | 4*200        |   |                   |                      |
| 2       | Dadri -2 (TH) | 2*490        |   |                   |                      |
| 3       | Jhajjar (TH)  | 3*500        |   |                   |                      |
| 4       | Rihand-1 (TH) | 2*500        | Yes   | 5.0               | Under Implementation |
| 5       | Rihand-2 (TH) | 2*500        | Yes   | 5.0               | Under Implementation |



|    |                      |                             |     |     | n<br>Under<br>Implementatio<br>n |
|----|----------------------|-----------------------------|-----|-----|----------------------------------|
| 6  | Rihand-3 (TH)        | 2*500                       | Yes | 5.0 |                                  |
| 7  | Shree Cement (TH)    | ( 2 * 150 )                 |     |     |                                  |
| 8  | Singrauli (TH)       | 2*500+5*200                 |     |     |                                  |
| 9  | Tanda-2 (TH)         | 2*660                       |     |     |                                  |
| 10 | Unchahar stg-4 (TH)  | 1*500                       |     |     |                                  |
| 11 | Unchahar (TH)        | 2*210                       |     |     |                                  |
| 12 | Anta (G)             | ( 1 * 153.2 + 3 * 88.71 )   |     |     |                                  |
| 13 | Auraiya (G)          | ( 2 * 109.3 + 4 * 111.19 )  |     |     |                                  |
| 14 | Dadri (G)            | ( 2 * 154.51 + 4 * 130.19 ) |     |     |                                  |
| 15 | AD Hydro (H)         | ( 2 * 96 )                  | YES | 4.0 | -                                |
| 16 | Bairasiul (H)        | ( 3 * 60 )                  | Yes | 4.0 |                                  |
| 17 | Bhakra (H)           | ( 5 * 126 + 5 * 157 )       |     |     |                                  |
| 18 | Budhil (H)           | ( 2 * 35 )                  |     |     |                                  |
| 19 | Chamera-1 (H)        | ( 3 * 180 )                 | Yes | 5.0 |                                  |
| 20 | Chamera-2 (H)        | ( 3 * 100 )                 | Yes | 5.0 |                                  |
| 21 | Chamera-3 (H)        | ( 3 * 77 )                  | Yes | 4.0 |                                  |
| 22 | Dehar (H)            | ( 6 * 165 )                 |     |     |                                  |
| 23 | Dhauliganga (H)      | ( 4 * 70 )                  | Yes | 5.0 |                                  |
| 24 | Dulhasti (H)         | ( 3 * 130 )                 | Yes | 5.0 |                                  |
| 25 | Karcham (H)          | ( 4 * 261.25 )              | Yes | 5.0 |                                  |
| 26 | Kishenganga          | ( 3 * 110 )                 | Yes | 4.0 |                                  |
| 27 | Koldam (H)           | ( 4 * 200 )                 | Yes | 4.0 |                                  |
| 28 | Koteswar (H)         | ( 4 * 100 )                 | Yes | 4.0 |                                  |
| 29 | Malana-2 (H)         | ( 2 * 50 )                  |     |     |                                  |
| 30 | Nathpa Jhakri (H)    | ( 6 * 250 )                 | Yes | 5.5 |                                  |
| 31 | Parbati-2 (H)        | ( 4 * 200 )                 |     |     |                                  |
| 32 | Parbati-3 (H)        | ( 4 * 130 )                 | Yes | 4.0 |                                  |
| 33 | Pong (H)             | ( 6 * 66 )                  |     |     |                                  |
| 34 | Rampur (H)           | ( 6 * 68.67 )               |     |     |                                  |
| 35 | Sainj (H)            | ( 2 * 50 )                  |     |     |                                  |
| 36 | Salal (H)            | ( 6 * 115 )                 | Yes | 3.0 |                                  |
| 37 | Sewa-II (H)          | ( 3 * 40 )                  | Yes | 4.0 |                                  |
| 38 | Singoli Bhatwari (H) | ( 3 * 33 )                  |     |     |                                  |
| 39 | Sorang (H)           | ( 2 * 50 )                  |     |     |                                  |
| 40 | Tanakpur (H)         | ( 1 * 31.42 + 2 * 31.4 )    | Yes | 4.0 |                                  |
| 41 | Tehri (H)            | ( 4 * 250 )                 | Yes | 4.0 |                                  |
| 42 | Uri-1 (H)            | ( 4 * 120 )                 | Yes | 6.0 |                                  |
| 43 | Uri-2 (H)            | ( 4 * 60 )                  | Yes | 5.0 |                                  |

Constituents are requested to share the details of the droop w.r.t. their generating stations.

**Members are requested to analyse the frequency response of their respective control area and share the FRC/FRP analysis of generating stations along with unit wise 01 sec data as per timeline for ensuring IEGC compliance.**

Members may like to discuss.

### **B.13. Mock testing of System Protection Schemes (SPS) in Northern Region**

As per IEGC clause 16.2

*"For the operational SPS, RLDC or NLDC, as the case may be, in consultation with the concerned RPC(s) shall perform regular load flow and dynamic studies and mock testing for reviewing SPS parameters & functions, at least once in a year. RLDC or NLDC shall share the report of such studies and mock testing including any short comings to respective RPC(s). The data for such studies shall be provided by CTU to the concerned RPC, RLDC and NLDC."*

As per IEGC clause 16.3

*"The users and SLDCs shall report about the operation of SPS immediately and detailed report shall be submitted within three days of operation to the concerned RPC and RLDC in the format specified by the respective RPCs."*

There are 56 numbers of System Protection Scheme (SPS) approved in Northern Region. These SPS are implemented at major generation complexes, important evacuating transmission lines and ICTs which are N-1 non-complaint. System Protection Scheme Document of Northern Region has been revised/updated on 31st January 2025. Revised version of the document is available on the NRLDC website in Document section and can be accessed at below link: <https://newnr.nrlc.in/documents/Documents>.

In this regard, communication was sent to constituents through NRLDC letter dated 01.05.2024, 21.02.2025 & 05.03.2025 for conducting mock testing of SPS in their control area and continuous follow up is also being done in OCC & PSC meeting since May 2024.

During 2024-25, mock testing of 14 SPS out of total 55 SPS were not conducted. In view of high demand scenario during summer 2025-26, NLRDC vide letter dated 04.04.2025 requested all the concerned utility to conduct the mock testing of pending SPS by the end of April 2025. However, as reported, mock testing of 03 SPS out of pending 14 SPS have been done. In this regard, discussion was also held in 60<sup>th</sup> & 61<sup>st</sup> PSC meeting. PSC forum requested all the members to conduct the mock testing of all the SPS in their respective control area at the earliest.

Status of mock testing of all the SPS in NR is attached as **Annexure-B.IX**.

SLDC-Rajasthan may confirm whether SPS mock testing of Bhilwara S/s SPS has been conducted or not. Schedule for mock testing of SPS was 10.7.2025.

Status of follow-up actions w.r.t. some of the SPS are as follows:

- i. **SPS of HVDC Rihand-Dadri:** During mock testing of SPS of HVDC Rihand-Dadri on 20.03.2025, some issues were identified. SPS of HVDC Rihand-Dadri operated recently on 21.05.2025 during incident of outage of both poles. Desired SPS

actions were not observed at some of the stations. NRLDC vide letter dated 02.07.2025, requested POWERGRID to take necessary remedial measure and make complete SPS system healthy.

*During 233 OCC meeting, POWERGRID representative stated that the equipment's at Singrauli TPS end is owned by NTPC and need to be revived by them. SPS system at Rihand is healthy and operational. NTPC representative stated that as per details received from site, NTPC Singrauli team have initiated necessary actions in coordination with the POWERGRID.*

*NRLDC representative requested NTPC Singrauli and POWERGRID to coordinate and make SPS system healthy at Singrauli TPS.*

**NTPC may share the details of actions taken / planned to be taken to make the SPS system at Singrauli TPS healthy.**

- ii. **SPS of Anta, Kawai, Chhabra generation complex:** In one of the SPS cases i.e., N-1-1/ N-2 of 765kV Anta-Phagi 1 & 2, instantaneous generation backdown of ~2100 MW is designed as SPS action. In such scenario, to avoid overloading of WR-NR corridor and over drawl by Rajasthan, it was agreed that RVPNL shall implement the automatic load shedding of ~750 MW by 28.02.2018. However, as per details available, implementation of automatic load shedding as per SPS hasn't been done yet. This matter has already been discussed in PSC as well as OCC meetings on regular basis. The concern of grid security and reliability was also raised during request of shutdown of 765kV Anta-Phagi line. is requested to expedite implementation of the automatic load shedding of ~750 MW as per SPS (N-1-1/ N-2 contingency of 765kV Anta-Phagi-1 & 2).

*During 233 OCC meeting, SLDC-Rajasthan representative informed that study has been conducted in this regard and the case shall be put up in next OCC meeting for approval.*

**RVPNL may share the updates in this regard.**

- iii. **SPS of N.Jhajkri, Karcham, Rampur hydro generation complex:** Status of implementation of case-6(i) and corrective actions w.r.t case-6 (ii) need to be shared.
- iv. **SPS of HVDC Mundra-Mahendragarh: Continuous follow up is being done since 51<sup>st</sup> PSC meeting. As informed by ADANI, word order has been placed and SPS will be made healthy by end of December 2025.**

In view of high demand scenario and criticality of SPS of HVDC Mundra-Mahindergarh in case of any contingency, ADANI is requested to expedite the corrective actions and share the present status.

Further, Clause 16.2 of IEGC 2023 also mandates the mock testing of SPS for reviewing SPS parameters & functions, at least once a year. Mock testing of all the SPS needs to be conducted in 2025-26. In view of this following is requested:

- i. **Concerned constituents / utility are requested to conduct the mock testing of pending SPS (whose mock testing was not conducted in 2024-25) at the earliest.**
- ii. **Utilities are also requested to conduct the mock testing of SPS schemes in their respective control area w.r.t. year 2025-26.**
- iii. **In compliance with IEGC clause 16.2, users shall ensure that mock testing along with the review of SPS logic of all the SPS is conducted at least once a year.**
- iv. **Further In compliance with IEGC clause 16.3, users shall also share the detailed report of SPS operation in their respective control area within 3 days of its operation. Presently, no such report is being received.**

Further, during 60<sup>th</sup> PSC meeting, forum also decided to not disable the SPS where ICTs are now N-1 compliant after augmentation. It was decided that SPS may be kept enabled with logic based on loading instead of ICT tripping. Members are requested to share the confirmation in this regard.

Members may like to discuss.

**B.14. Voltage oscillations observed in the Rajasthan RE complex – Revision of NOC restriction for Northern Region ISGS RE plants whose GNA is yet to be effective and being scheduled under deemed T-GNA.**

As on 06.08.2025, total **22509 MW** of ISGS RE generation in Rajasthan have been commissioned and being scheduled. Out of **22509 MW**, **14343 MW** is having GNA effective (Complete ATS commissioned), and **8166 MW** is having Non-effective GNA (Complete ATS not yet commissioned).

It is pertinent to mention that total **8166 MW** of ISGS RE capacity is being given NOC for evacuation of Power under deemed T-GNA as GNA is yet to get effective (Complete ATS not yet commissioned). Out of **8166 MW** deemed T-GNA, **4042 MW** is being evacuated, and **4124 MW** is being restricted during Solar peak hrs (10:30-14:30hrs) due to non-availability of transmission system.

| <b>RE capacity commissioned (MW)</b> | <b>Effective GNA quantum (MW) (Complete ATS commissioned )</b> | <b>Non-effective GNA (T-GNA) quantum (MW) (Complete ATS not yet commissioned)</b> | <b>NOC allowed for evacuation under deemed T-GNA during Peak Solar hours (10:30hrs-14:30hrs) (MW)</b> | <b>Non-effective GNA (T-GNA) quantum restricted for evacuation during Peak Solar hours (10:30hrs-14:30hrs)</b> |
|--------------------------------------|--|---|---|--|
|                                      |  |   |   |  |

|              |              |             |             | (MW)        |
|--------------|--------------|-------------|-------------|-------------|
| <b>22509</b> | <b>14343</b> | <b>8166</b> | <b>4042</b> | <b>4124</b> |

Further, to facilitate the evacuation and to accommodate the ISGS RE generation whose GNA is yet to be effective (Complete ATS not yet commissioned) time block wise margin for deemed T-GNA have been given. NOC have been given for part capacity and part capacity have been restricted time block wise to accommodate & evacuate the maximum ISGS RE capacity with ensuring the Security & Reliability of the Grid in Rajasthan RE complex. Maximum Allowable capacity (MW) that can be scheduled and margin under deemed T-GNA for evacuation of ISGS RE generation whose GNA is yet to be effective (Complete ATS not yet commissioned) is tabulated below;

**Table-1: Margin for evacuation of NR ISGS RE capacity under deemed T-GNA whose ATS not yet commissioned**

| Margin for evacuation of NR ISGS RE capacity under deemed T-GNA |                    |   |                   |   |
|---|--------------------|---|-------------------|---|
| S. No.  | Time Block (hrs)   | Maximum Allowable capacity that can be scheduled (MW) | T-GNA Margin (MW) | Remarks   |
| 1   | Before 09:30 hrs   | 22509   | <b>8166</b>       | Full Requested NOC (Further RE addition can also be accommodated)   |
| 2   | 09:30 – 09:45      | 21378   | <b>7035</b>       | Need to be restricted because ISGS RE generation is reaching ~86% of Total Capacity being scheduled (in clear weather condition). |
| 3   | 09:45-10:00        | 20500   | <b>6157</b>       | Need to be restricted because ISGS RE generation is reaching ~90% of Total Capacity being scheduled (in clear weather condition). |
| 4   | <b>10:00-10:15</b> | <b>19769</b>  | <b>5426</b>       | Need to be restricted because ISGS RE generation is reaching ~93% of Total Capacity being scheduled (in clear weather condition). |
| 5   | <b>10:15-10:30</b> | <b>19000</b>  | <b>4657</b>       | Need to be restricted because ISGS RE generation is reaching ~97% of Total Capacity being scheduled (in clear weather condition). |
| 6   | <b>10:30-14:30</b> | <b>18385</b>  | <b>4042</b>       | Solar Peak hrs, Generation is reaching ~100% after 10:30hrs   |

|    |                    |              |             |   |
|----|--------------------|--------------|-------------|---|
|    |                    |              |             | and before 14:30 hrs, restricted NOC.   |
| 7  | <b>14:30-14:45</b> | <b>19000</b> | <b>4657</b> | Need to be restricted because ISGS RE generation is reaching ~97% of Total Capacity being scheduled (in clear weather condition). |
| 8  | <b>14:45-15:00</b> | <b>19769</b> | <b>5426</b> | Need to be restricted because ISGS RE generation is reaching ~93% of Total Capacity being scheduled (in clear weather condition). |
| 9  | 15:00-15:15        | 20500        | <b>6157</b> | Need to be restricted because ISGS RE generation is reaching ~90% of Total Capacity being scheduled (in clear weather condition). |
| 10 | 15:15-15:30        | 21378        | <b>7035</b> | Need to be restricted because ISGS RE generation is reaching ~86% of Total Capacity being scheduled (in clear weather condition). |
| 11 | 15:30-15:45        | 21378        | <b>7035</b> | Need to be restricted because ISGS RE generation is reaching ~86% of Total Capacity being scheduled (in clear weather condition). |
| 12 | After 15:45 hrs    | 22509        | <b>8166</b> | Full Requested NOC (Further RE addition can also be accommodated)   |

**Revision in NOC w.e.f. 08.08.2025 for evacuation of ISGS RE generation under deemed T-GNA whose associated Transmission system not yet commissioned:**

- o Earlier NOC restriction under deemed T-GNA started from 10:00 hrs with restriction in steps from 10:00-10:15 hrs & 10:15-10:30 hrs in staggered manner, 10:30-14:30 hrs flat and subsequently restriction lifted from 14:30 hrs with restriction lifted in steps from 14:30-14:45 hrs & 14:45-15:00 hrs in staggered manner, and Full requested NOC quantum before 10:00 hrs and after 15:00 hrs.
- o Now, NOC restriction under deemed T-GNA has been started from 09:30 hrs with restriction in steps from 09:30-10:30 hrs in staggered manner for each 15 min time block, 10:30-14:30 hrs flat and subsequently restriction lifted from 14:30 hrs with restriction lifted in steps from 14:30 hrs-15:45 hrs in staggered manner for each 15 min time block, and Full requested NOC quantum before 09:30 hrs and after 15:45 hrs (As given in **Table-1**).

**Transmission Constraint which are causing bottlenecking of RE power in Rajasthan REZ:**

1. Loading on 400kV Bhadla(RS)-Bikaner(RS) D/C line exceeding 750MW each ckt (750 MW: safe loading limit of each ckt) and reaching 780MW each ckt despite opening of both the Ckts of 400kV Bikaner(RS)-Sikar(PG) D/C line, hotspot comes beyond 780-800MW each ckt due to poor condition of line conductor, can't load more than 800 MW otherwise cascade tripping may occur.
2. Next (2nd) constraint is 765kV Bhadla-II-Ajmer D/C line angular separation under N-1 Contingency.
3. Issue of low SCR at Fatehgarh-II Pooling S/s, 4.1 at 400kV Fatehgarh-II (PG). Further RE penetration with this low SCR would cause oscillation in the complex. Sever Voltage oscillation observed on 02.08.2025 @14:35hrs (ISGS RE: 19373 MW), on 03.08.2025 @10:24hrs (ISGS RE: 18954 MW), on 03.08.2025 @14:35hrs (ISGS RE: 19629 MW), on 04.08.2025 @10:13hrs (ISGS RE: 18621 MW).
4. N-1 Non-compliance issue at 400kV Fatehgarh-III PS, as only 5 nos. of 500 MVA ICTs are there to evacuate 2190 MW of RE capacity connected at 220kV. N-1 loading limit of 5\*500 MVA ICTs at Fatehgarh-III PS is 2090 MW.

**The reasons for extended period of NOC restriction under deemed T-GNA are as follows:**

1. As RE generation is exceeding the 18385 MW quantum even before 10:30 hrs and after 14:30 hrs near boundary of 10:00hrs and 15:00hrs boundary. Hence, restriction on already issued NOC were reviewed and based on injection profile (under clear sky days), deemed T-GNA quantum is revised time block wise to keep total ISGS RE Injection below 18385 MW at any time to avoid any Voltage oscillation issues in Rajasthan RE complex and for ensuring the security of the Grid. Further, staggering has been done b/w 09:30-10:30hrs and 14:30-15:45 hrs also to accommodate more RE capacity and making the Solar ramping up/down smoother to avoid any sudden change in the system.
2. *High Wind scenario and continuous violation of Rajasthan:* Solar+Wind injection of ~6800MW against limit of 6000 MW despite several follow-up by NRLDC C/R but no actions from Rajasthan, left no options for C/R operator except managing at ISTS level.
3. Increase in Wind generation and thereby increase in Reactive power drawl by Rajasthan system resulting low voltage issue. With Active power drawl of merely 2600-3000 MW, Rajasthan is drawing ~3600 MVar from the Grid (ISTS). Huge Reactive power drawl by Rajasthan system is being managed by opening the Bus Reactors at nearby Substations and by increasing Reactive power from ISGS RE plant to ensure voltage stability of the complex.
4. *Coinciding of Solar and Wind generation:* Due to high Wind in morning & after-noon hours, net penetration of RE (Solar + Wind) in the Rajasthan RE complex becomes high (~22-23 GW) resulted depletion in SCR of the system during coinciding Solar & Wind penetration during morning & after-noon hours
5. Outage of 400kV Jaisalmer-Barmer D/C line in this High Wind season (Jul'25-Sept'25), Rajasthan earlier submitted the tentative deadline of 30.07.2025, revised tentative timeline for revival is 20.08.2025 as reported by Rajasthan.

6. Issue of STATCOM i.e. aggravation of Low amplitude high frequency oscillation into High amplitude high frequency oscillation under Low SCR scenario is yet to be resolved, on both 02.08.2025 & 03.08.2025, oscillation died out after taking STATCOM in Manual fixed-Q mode.
7. Due to fast ramping of Wind and any sudden change in system, lesser time left with C/R operator to take necessary measure if system is already on margin this results in severe voltage oscillation in the Rajasthan RE complex.

***Members may like to deliberate.***



Status of action taken on decision of 233<sup>rd</sup> OCC meeting of NRPC

| S.N. | Agenda  | Decision of 233 <sup>rd</sup> OCC meeting of NRPC  | Status of action taken               |
|------|---|--|--------------------------------------|
| 1    | Agenda. Rectification of the breaker and charging of the 220kV Sunam (PS)-Patran (IndiGrid) Circuit (Agenda by Punjab SLDC)                 | IndiGrid representative apprised that replacement is in process and expected to be done shortly.<br>MS, NRPC mentioned that owner of the asset may give application to electrical inspector for permission to commence or recommence supply after such installation has been disconnected for six months as per Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023. | IndiGrid to update the status.       |
| 2    | A.11 MoU between Powergrid and NTPC for O&M of 400 kV D/C Dadri – Harsh Vihar transmission lines and 400 kV Panipat-2 bays (Agenda by NTPC) | OCC Forum asked Powergrid to deliberate the matter bilaterally with NTPC and convey their decision on the matter to NTPC in the next 15 days.  | Powergrid to update the status.      |
| 3    | A.15 Shifting of 220kV Patti-Verpal Single Circuit from Verpal end to 400kV PGCIL Amritsar (Agenda by PSTCL)                                | OCC forum asked CTU to finalize the connectivity agreement within 15 days.   | CTU to update the status.            |
| 4    | A.21 Shutdown consent/Approval of Bus-1 & 2 at 400kV Ballabgarh and 220kV   | OCC forum asked Powergrid to bilaterally have a meeting with HVPNL and DTL to deliberate the   | Powergrid NR-1 to update the status. |

# Status of action taken on decision of 233<sup>rd</sup> OCC meeting of NRPC

|   |  |  |  |
|---|--|--|--|
|   | System at Hisar for Jack Bus Replacement work (Agenda by Powergrid NR-I)                       | matter and plan the shutdown with consent of HVPNL and DTL.  |  |
| 5 | Table agenda No. 2 - Controlling overloading of 400kV Jhatikra – Bamnauli Line (Agenda by DTL) | OCC forum directed POWERGRID and DTL to submit the signed report of the joint site visit to CEA within 15 days, clearly stating the scope of work to be undertaken for the removal of the LILO of the 400 kV Jhatikara–Bamnauli line at 400 kV Dwarka. | Powergrid NR-1 and DTL to update the status. |

## Follow up issues from previous OCC meetings

Annexure-A. II

|                  |  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
|------------------|--|---|---|--------------|---------------|---------|----------|-----------|----------|------|----------|------------------|---------------|----------|----------|-------------|----------|------|----------|---------------|----------|--------|----------|--------------|---------------|---------|-----------|-----------|-----------|------|-----------|------------------|-----------|----------|-----------|-------------|-----------|------|-----------|---------------|-----------|--------|-----------|
| 1                | Down Stream network by State utilities from ISTS Station                 | Augmentation of transformation capacity in various existing substations, addition of new substations along with line bays as well as requirement of line bays by STUs for downstream network are under implementation at various locations in Northern Region. Further, 220kV bays have already been commissioned at various substations in NR. For its utilization, downstream 220kV system needs to be commissioned.                    | List of downstream networks is enclosed in Annexure-A. II. I.   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| 2                | Progress of installing new capacitors and repair of defective capacitors | Information regarding installation of new capacitors and repair of defective capacitors is to be submitted to NRPC Secretariat.   | <div>Data upto following months, received from various states / UTs:</div> <table><tr><td>⊙ CHANDIGARH</td><td>Sep-2019</td></tr><tr><td>⊙ DELHI</td><td>Jul-2025</td></tr><tr><td>⊙ HARYANA</td><td>Apr-2025</td></tr><tr><td>⊙ HP</td><td>Mar-2025</td></tr><tr><td>⊙ J&amp;K and LADAKH</td><td>Not Available</td></tr><tr><td>⊙ PUNJAB</td><td>Apr-2025</td></tr><tr><td>⊙ RAJASTHAN</td><td>Jun-2025</td></tr><tr><td>⊙ UP</td><td>Jun-2025</td></tr><tr><td>⊙ UTTARAKHAND</td><td>Jul-2025</td></tr></table> <div>All States/UTs are requested to update status on monthly basis.</div>   | ⊙ CHANDIGARH | Sep-2019      | ⊙ DELHI | Jul-2025 | ⊙ HARYANA | Apr-2025 | ⊙ HP | Mar-2025 | ⊙ J&K and LADAKH | Not Available | ⊙ PUNJAB | Apr-2025 | ⊙ RAJASTHAN | Jun-2025 | ⊙ UP | Jun-2025 | ⊙ UTTARAKHAND | Jul-2025 |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ CHANDIGARH     | Sep-2019   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ DELHI          | Jul-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ HARYANA        | Apr-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ HP             | Mar-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ J&K and LADAKH | Not Available  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ PUNJAB         | Apr-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ RAJASTHAN      | Jun-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ UP             | Jun-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ UTTARAKHAND    | Jul-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| 3                | Healthiness of defence mechanism: Self-certification                     | <div>Report of mock exercise for healthiness of UFRs carried out by utilities themselves on quarterly basis is to be submitted to NRPC Secretariat and NRLDC. All utilities were advised to certify specifically, in the report that “All the UFRs are checked and found functional” .</div> <div>In compliance of NPC decision, NR states/constituents agreed to raise the AUFR settings by 0.2 Hz in 47th TCC/49th NRPC meetings.</div> | <div>Data upto following months, received from various states / UTs:</div> <table><tr><td>⊙ CHANDIGARH</td><td>Not Available</td></tr><tr><td>⊙ DELHI</td><td>Jul-2025</td></tr><tr><td>⊙ HARYANA</td><td>Jun-2025</td></tr><tr><td>⊙ HP</td><td>Jun-2025</td></tr><tr><td>⊙ J&amp;K and LADAKH</td><td>Not Available</td></tr><tr><td>⊙ PUNJAB</td><td>Jun-2025</td></tr><tr><td>⊙ RAJASTHAN</td><td>Dec-2024</td></tr><tr><td>⊙ UP</td><td>Jun-2025</td></tr><tr><td>⊙ UTTARAKHAND</td><td>Jul-2025</td></tr><tr><td>⊙ BBMB</td><td>Jun-2025</td></tr></table> <div>All States/UTs are requested to update status for healthiness of UFRs on monthly basis for islanding schemes and on quartely basis for the rest.</div> <div>Status:</div> <table><tr><td>⊙ CHANDIGARH</td><td>Not Available</td></tr><tr><td>⊙ DELHI</td><td>Increased</td></tr><tr><td>⊙ HARYANA</td><td>Increased</td></tr><tr><td>⊙ HP</td><td>Increased</td></tr><tr><td>⊙ J&amp;K and LADAKH</td><td>Increased</td></tr><tr><td>⊙ PUNJAB</td><td>Increased</td></tr><tr><td>⊙ RAJASTHAN</td><td>Increased</td></tr><tr><td>⊙ UP</td><td>Increased</td></tr><tr><td>⊙ UTTARAKHAND</td><td>Increased</td></tr><tr><td>⊙ BBMB</td><td>Increased</td></tr></table> | ⊙ CHANDIGARH | Not Available | ⊙ DELHI | Jul-2025 | ⊙ HARYANA | Jun-2025 | ⊙ HP | Jun-2025 | ⊙ J&K and LADAKH | Not Available | ⊙ PUNJAB | Jun-2025 | ⊙ RAJASTHAN | Dec-2024 | ⊙ UP | Jun-2025 | ⊙ UTTARAKHAND | Jul-2025 | ⊙ BBMB | Jun-2025 | ⊙ CHANDIGARH | Not Available | ⊙ DELHI | Increased | ⊙ HARYANA | Increased | ⊙ HP | Increased | ⊙ J&K and LADAKH | Increased | ⊙ PUNJAB | Increased | ⊙ RAJASTHAN | Increased | ⊙ UP | Increased | ⊙ UTTARAKHAND | Increased | ⊙ BBMB | Increased |
| ⊙ CHANDIGARH     | Not Available  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ DELHI          | Jul-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ HARYANA        | Jun-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ HP             | Jun-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ J&K and LADAKH | Not Available  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ PUNJAB         | Jun-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ RAJASTHAN      | Dec-2024   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ UP             | Jun-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ UTTARAKHAND    | Jul-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ BBMB           | Jun-2025   |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ CHANDIGARH     | Not Available  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ DELHI          | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ HARYANA        | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ HP             | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ J&K and LADAKH | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ PUNJAB         | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ RAJASTHAN      | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ UP             | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ UTTARAKHAND    | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |
| ⊙ BBMB           | Increased  |   |   |              |               |         |          |           |          |      |          |                  |               |          |          |             |          |      |          |               |          |        |          |              |               |         |           |           |           |      |           |                  |           |          |           |             |           |      |           |               |           |        |           |

|           |  |   |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|-----------|--|---|--|---|---------------------------------|-----------------------------------|---------------------------------|----------------------|------------------------|----------|---|-----------|----------|---|----|----------|--|------|----------|------------|------|---|------------|---------------|---|-------|--------|---|---------|--------|---|----|--------|---|----------------|--|---|--------|--------|---|-----------|--------|---|----|--------|---|-------------|--------|
| 4         | Status of Automatic Demand Management System in NR states/UT's           | The status of ADMS implementation in NR, which is mandated in clause 5.4.2 (d) of IEGC by SLDC/SEB/DISCOMs is presented in the following table:   | The status of ADMS implementation in NR is enclosed in <b>Annexure-A.II.II.</b>  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|           |  |   | ⊙ DELHI  | Scheme Implemented but operated in manual mode. |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|           |  |   | ⊙ HARYANA  | Scheme not implemented                          |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|           |  |   | ⊙ HP   | Scheme not implemented                          |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|           |  |   | ⊙ PUNJAB   | Scheme not implemented                          |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|           |  |   | ⊙ RAJASTHAN  | Under implementation.                           |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|           |  |   | ⊙ UP   | Scheme implemented by NPCIL only                |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|           |  |   | ⊙ UTTARAKHAND  | Scheme not implemented                          |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| 5         | Status of availability of ERS towers in NR                               | As per the decesion of 68th NRPC and 211th OCC meeting, ERS availability monitoring is being taken as rolling/follow-up agenda in OCC meetings for regular monitoring of ERS under different utilities in Northern region.  | As per the information received from different utilities in Northern region, updated status of availability of ERS towers in Northern Region attached as <b>Annexure-A.II.III.</b>   |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| 6         | Submission of breakup of Energy Consumption by the states                | All states/UTs are requested to submit the requisite data as per the billed data information in the format given as under:<br><table><tr><td>Category→</td><td>Consumption by Domestic Loads</td><td>Consumption by Commercial Loads</td><td>Consumption by Agricultural Loads</td><td>Consumption by Industrial Loads</td><td>Traction supply load</td><td>Miscellaneous / Others</td></tr><tr><td>&lt;Month&gt;</td><td></td><td></td><td></td><td></td><td></td><td></td></tr></table> | Category→  | Consumption by Domestic Loads                   | Consumption by Commercial Loads | Consumption by Agricultural Loads | Consumption by Industrial Loads | Traction supply load | Miscellaneous / Others | <Month>  |   |           |          |   |    |          | Status of the information submission (month) from states / utilities is as under:<br><table><tr><td></td><td>State / UT</td><td>Upto</td></tr><tr><td>⊙</td><td>CHANDIGARH</td><td>Not Submitted</td></tr><tr><td>⊙</td><td>DELHI</td><td>Jun-25</td></tr><tr><td>⊙</td><td>HARYANA</td><td>May-25</td></tr><tr><td>⊙</td><td>HP</td><td>Jul-25</td></tr><tr><td>⊙</td><td>J&amp;K and LADAKH</td><td>JPDCL- Mar' 24<br/>KPDCL- Not Submitted</td></tr><tr><td>⊙</td><td>PUNJAB</td><td>Apr-25</td></tr><tr><td>⊙</td><td>RAJASTHAN</td><td>Apr-25</td></tr><tr><td>⊙</td><td>UP</td><td>Feb-25</td></tr><tr><td>⊙</td><td>UTTARAKHAND</td><td>Jan-25</td></tr></table><br>Chandigarh is requested to submit the requisite data w.e.f. April 2018 as per the billed data information in the given format |      |          | State / UT | Upto | ⊙ | CHANDIGARH | Not Submitted | ⊙ | DELHI | Jun-25 | ⊙ | HARYANA | May-25 | ⊙ | HP | Jul-25 | ⊙ | J&K and LADAKH | JPDCL- Mar' 24<br>KPDCL- Not Submitted | ⊙ | PUNJAB | Apr-25 | ⊙ | RAJASTHAN | Apr-25 | ⊙ | UP | Feb-25 | ⊙ | UTTARAKHAND | Jan-25 |
| Category→ | Consumption by Domestic Loads  | Consumption by Commercial Loads   | Consumption by Agricultural Loads  | Consumption by Industrial Loads                 | Traction supply load            | Miscellaneous / Others            |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| <Month>   |  |   |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
|           | State / UT   | Upto  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | CHANDIGARH   | Not Submitted   |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | DELHI  | Jun-25  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | HARYANA  | May-25  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | HP   | Jul-25  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | J&K and LADAKH   | JPDCL- Mar' 24<br>KPDCL- Not Submitted  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | PUNJAB   | Apr-25  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | RAJASTHAN  | Apr-25  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | UP   | Feb-25  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | UTTARAKHAND  | Jan-25  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| 7         | Status of FGD installation vis-à-vis installation plan at identified TPS | List of FGDs to be installed in NR was finalized in the 36th TCC (special) meeting dt. 14.09.2017. All SLDCs were regularly requested since 144th OCC meeting to take up with the concerned generators where FGD was required to be installed.<br>Further, progress of FGD installation work on monthly basis is monitored in OCC meetings.   | Status of the information submission (month) from states / utilities is as under:<br><table><tr><td>⊙</td><td>HARYANA</td><td>Jun-2024</td></tr><tr><td>⊙</td><td>PUNJAB</td><td>Feb-2025</td></tr><tr><td>⊙</td><td>RAJASTHAN</td><td>Feb-2025</td></tr><tr><td>⊙</td><td>UP</td><td>Jan-2024</td></tr><tr><td>⊙</td><td>NTPC</td><td>Mar-2025</td></tr></table><br>FGD status details are enclosed as <b>Annexure-A. II. IV.</b><br>All States/utilities are requested to update status of FGD installation progress on monthly basis. |   | ⊙                               | HARYANA                           | Jun-2024                        | ⊙                    | PUNJAB                 | Feb-2025 | ⊙ | RAJASTHAN | Feb-2025 | ⊙ | UP | Jan-2024 | ⊙  | NTPC | Mar-2025 |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | HARYANA  | Jun-2024  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | PUNJAB   | Feb-2025  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | RAJASTHAN  | Feb-2025  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | UP   | Jan-2024  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| ⊙         | NTPC   | Mar-2025  |  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |
| 8         | Information about variable charges of all generating units in the Region | The variable charges detail for different generating units are available on the MERIT Order Portal.   | All states/UTs are requested to submit daily data on MERIT Order Portal timely.  |   |                                 |                                   |                                 |                      |                        |          |   |           |          |   |    |          |  |      |          |            |      |   |            |               |   |       |        |   |         |        |   |    |        |   |                |  |   |        |        |   |           |        |   |    |        |   |             |        |

|     |  |               |  |  |
|-----|--|---------------|--|--|
| 9   | Reactive compensation at 220 kV/ 400 kV level at 7 substations |               |  |  |
|     | State / Utility  | Substation    | Reactor                                    | Status   |
| i   | DTL  | Peeragarhi    | 1x50 MVar at 220 kV                        | 1x50 MVar Reactor at Peeragarhi has been commissioned on dated 18.09.2023  |
| ii  | DTL  | Harsh Vihar   | 2x50 MVar at 220 kV                        | 2x50 MVAR Reactor at Harsh Vihar has been commissioned on dated 31th March 2023.   |
| iii | DTL  | Mundka        | 1x125 MVar at 400 kV & 1x25 MVar at 220 kV | Bay work completed on 25.03.2023. Reactor part tender is dropped and at present same is under revision.  |
| iv  | DTL  | Bamnauli      | 2x25 MVar at 220 kV                        | Bay work completed on 25.03.2023. Reactor part tender is dropped and at present same is under revision.  |
| v   | DTL  | Indraprastha  | 2x25 MVar at 220 kV                        | Bay work completed on 07.11.2023. Reactor part tender is dropped and at present same is under revision.  |
| vi  | DTL  | Electric Lane | 1x50 MVar at 220 kV                        | Under Re-tendering due to Single Bid   |
| vii | PTCUL  | Kashipur      | 1x125 MVAR at 400 kV                       | The Letter of Award for "Procurement of 125 MVAR Reactor, Online DGA, ODS, NIFPS along with its accessories at 400 KV Sub-station Kashipur" against Tender Specification no. PTCUL/E-Tender/C&P-II/SS-12/2024-25 has been issued to M/s Bharat Heavy Electricals Limited, New Delhi on 26.06.2025. |

|  |  |  |                              |   |  | Annexure-A-II.I  |
|--|--|--|------------------------------|---|--|--|
| 1. Down Stream network by State utilities from ISTS Station: |  |  |                              |   |  |  |
| Sl. No.  | Substation                             | Downstream network bays                            | Status of bays               | Planned 220 kV system and Implementation status   | Revised Target                             | Remarks  |
| 1  | 400/220kV, 3x315 MVA Samba             | Commissioned: 8<br>Total: 8                        | Utilized: 6<br>Unutilized: 2 | • Network to be planned for 2 bays.   | -  | 02 No. of bays shall be utilized for LILO-II of 220kV Jatwal-Bishnah Transmission Line, the work of which is expected to begin on 16th July 2025. Updated in 233rd OCC by JKPTCL.  |
| 2  | 400/220kV, 2x315 MVA New Wanpoh        | Commissioned: 6<br>Total: 6                        | Utilized: 2<br>Unutilized: 4 | • 220 kV New Wanpoh - Alusteng D/c Line   | Mar'25                                     | 02 No. of bays are to be utilized for connecting 220kV New Wanpoh-Alusteng D/c Line. RoW issues persisting; At present new-wampoh-mirbazar 5km and harwan-alstung 16km have been completed, expected date of completion is Mar 2025 subject to availability of funds and resolving of RoW issues), Updated in 214th OCC by JKPTCL.   |
|  |  |  |                              | • 220 kV New Wanpoh - Mattan D/c Line   | End of 2024                                | 02 No. of bays are to be utilized for connecting 220kV New Wanpoh-Mattan D/c Line. The funding source for the project is being identified and the project is expected to be completed by ending 2024. Updated in 204th OCC by JKPTCL.  |
| 3  | 400/220kV, 2x315 MVA Amargarh          | Commissioned: 6<br>Total: 6                        | Utilized: 4<br>Unutilized: 2 | • 220kV D/C line from 400/220kV Kunzar - 220/33kV Sheeri  | End of 2024                                | 02 No. of bays are proposed to be utilized for connecting 220/132 kV GSS Loolipora. The funding source for the project is being identified and the project is expected to be completed by ending 2024. Updated in 204th OCC by JKPTCL.   |
| 4  | 400/220kV, 2x500 MVA Kurukshetra (GIS) | Commissioned: 8<br>Total: 8                        | Utilized: 6<br>Unutilized: 2 | • 220kV Bhadson (Kurukshetra) – Ramana Ramani D/c line  | Contractual completion date on 04.08.2025. | Under construction.Updated in 230rd OCC by HVPNL   |
| 5  | 400/220 kV, 2x315 MVA Dehradun         | Commissioned: 6<br>Total: 6                        | Utilized: 2<br>Unutilized: 4 | • Network to be planned for 4 bays  | -  | PTCUL to update the status.  |
| 6  | Shahjahanpur, 2x315 MVA 400/220 kV     | Commissioned: 6<br>Approved/Under Implementation:1 | Utilized: 7                  | • 220 kV D/C Shahjahanpur (PG) - Gola line  | Commissioned                               | Energization date: 26.10.2023 updated by UPPTCL in 215th OCC   |
|  |  |  |                              | • LILO of Sitapur – Shahjahanpur 220 kV SC line at Shahjahanpur (PG)  | Commissioned                               | Energization date: 25.02.2022 updated by UPPTCL in 196th OCC   |
| 7  | Hamirpur 400/220 kV Sub-station        | Commissioned: 8<br>Total: 8                        | Utilized: 4<br>Unutilized: 4 | • 220 kV Hamirpur-Dehan D/c line  | Commissioned                               | HPPTCL has commissioned the Planned 220kV Dehan-Hamirpur TL utilizing 2 No. 220kV Bays.Commissioned date: 09.06.2022. Updated in 198th OCC by HPPTCL   |
|  |  |  |                              | • Network to be planned for 4 bays  | -  | HPPTCL to update the status.   |
| 8  | Sikar 400/220kV, 1x 315 MVA S/s        | Commissioned: 8<br>Total: 8                        | Utilized: 6<br>Unutilized: 2 | • LILO of 220 kV Sikar (220 kV GSS)-Dhod S/c line at Sikar (PG)   | Commissioned                               | LILO of 220 kV S/C Sikar-Dhod line at 400 kV GSS PGCIL, Sikar has been charged on dt. 31.03.2022   |
|  |  |  |                              | • Network to be planned for 2 bays.   | -  | Against the 3rd ICT at 400 kV GSS Sikar, only 2 bays were constructed and same has been utilized by RVPN by constructing LILO of 220 kV S/C Sikar – Dhod line as updated by RVPNL in 195th OCC   |
| 9  | Bhiwani 400/220kV S/s                  | Commissioned: 6<br>Total: 6                        | Utilized: 2<br>Unutilized: 4 | • 220 kV D/C line Bhiwani (PG) – Bhiwani (HVPNL) line   | Commissioned                               | Updated in 202nd OCC by HVPNL  |
|  |  |  |                              | • 220 kV Bhiwani (PG) - Isherwal (HVPNL) D/c line.  | -  | Issue related to ROW as intimated in 228th OCC by HVPNL.<br><b>Status:</b><br>Work was stalled since 29.07.2021 due to ROW issues and farmers agitation and further restarted on 9.10.2023 with the help of district administration. Now, work was again stalled since30.11.2023 due to severe ROW issues.<br>Expected to be completed by 31.03.2025.<br>Foundation 209/212. Erection 193/212. Stinging 37.8/50.3 km |
|  |  |  |                              | • 220 kV Bhiwani (PG) - Dadhibana (HVPNL) D/c line.   | Oct'25                                     | Line work awarded to M/s R S Infra Projects Pvt. Ltd. Noida, Uttar Pradesh on dated 09.03.2024. Work of route plan and route alignment has been started by the firm as intimated in 218th OCC by HVPNL.  |
| 10   | Jind 400/220kV S/s                     | Commissioned: 4<br>Approved:4<br>Total: 8          | Utilized: 4<br>Unutilized: 0 | • LILO of both circuits of 220 kV Jind HVPNL to PTPS D/C line at 400 kV substation PGCIL Khatkar (Jind) with 0.5 sq inch ACSR conductor | Oct'25                                     | Erection and stringing work completed.The signing of Connection agreement amongst the Utilities is pending. Updated in 230th OCC by HVPNL.   |
| 11   | 400/220kV Tughlakabad GIS              | Commissioned: 6                                    | Utilized: 6                  | • RK Puram – Tughlakabad (UG Cable) 220kV D/c line – March 2023.  | Commissioned                               | Updated in 216th OCC by DTL  |
|  |  | Under Implementation: 4                            | Unutilized: 0                | • Masjid Mor – Tughlakabad 220kV D/c line.  | Commissioned                               | Updated in 216th OCC by DTL  |
| 12   | 400/220kV Kala Amb GIS (TBCB)          | Commissioned: 6<br>Total: 6                        | Utilized: 2<br>Unutilized: 2 | • HPPTCL has planned one no. of 220kV D/c line from Kala Amb 400/220kV S/s to 220/132kV Kala Amb S/s                                    | Commissioned                               | Energization date: 31.05.2024 updated by HPPTCL in 220th OCC   |
|  |  |  |                              | • HPPTCL has planned one no. of 220kV D/c line from Kala Amb 400/220kV S/s to 220/132kV Giri S/s  | -  | Tendering process is yet to be started.Updated in 219th OCC by HPPTCL  |
|  |  |  | Under Implementation:2       | • Network to be planned for 2 bays  | -  | HPPTCL to update the status.   |
| 13   | 400/220kV Kadarpur Sub-station         | Commissioned: 8<br>Total: 8                        | Utilized: 0<br>Unutilized: 8 | • D/C line Kadarpur - Pali D/C line Kadarpur - Sec-65   | Commissioned                               | Updated in 232nd OCC by HVPNL<br><b>Status:-</b><br>A-formats for FTC of line submitted on FTC portal of NRLDC on dated 09.04.25.  |

| Sl. No. | Substation                       | Downstream network bays                                | Status of bays   | Planned 220 kV system and Implementation status   | Revised Target | Remarks   |
|---------|----------------------------------|--|--|---|----------------|---|
| 14      | 400/220kV Sohna Road Sub-station | Commissioned: 8<br>Total: 8                            | Utilized: 4<br>Unutilized: 4                           | • LILO of both circuits of 220kV D/c Sohna-Rangla Rajpur at Roj Ka Meo line at 400kV Sohna Road | Oct'25         | Line work completed, but commissioning of 220kV substation Roj ka Meo is pending till now.. However, this arrangement will not lead to usage of additional bays i.e. no of utilised bays at Sohna road will remain same.Updated in 230th OCC by HVPNL   |
|         |                                  |  |  | • LILO of both circuits of 220kV D/c Badshahpur-Sec77 line at 400kV Sohna Road                  | -              | The matter is subjudice in Hon'ble Punjab & Haryana High court, Chandigarh Updated in 228th OCC by HVPNL.<br><b>Status:-</b><br>Earlier 02 nos 220 kV line bays were to be utilized for the 220 kV GIS S/Stn. Sec-77, Gurugram but due to denotification of land of the 220 kV GIS S/Stn. Sec-77 the said substation is now going to be dismantled and a new substation is proposed at Sec-75A, Gurugram. Now, these 02 no. 220 kV line bays may be utilized at 220 kV GIS S/Stn Sec-75A, Gurugram. |
| 15      | 400/220kV Prithla Sub-station    | Commissioned: 8<br>Approved: 2<br>Total: 10            | Utilized: 4<br>Unutilized: 4<br>Under Implementation:2 | • 220kV D/C line from Prithla to Harfali with LILO of one circuit at 220kV Meerpur Kurali       | Dec'25         | Contract awarded on 08.08.23 to M/s Skipper with completion in December 25.Updated in 230th OCC by HVPNL  |
|         |                                  |  |  | • LILO of both ckt of 220kV D/c Ranga Rajpur – Palwal line                                      | Commissioned   | Energization date: 31.12.2021. Updated in 198th OCC by HVPNL  |
|         |                                  |  |  | • 220kV D/C for Sector78, Faridabad   | 31.07.2025     | Issue related to ROW and Pending crossing approval from Northern Railways and DFCCIL. as intimated in 228th OCC by HVPNL.   |
|         |                                  |  |  | • Prithla - Sector 89 Faridabad 220kV D/c line  | Jul'25         | The work for construction of 220kV D/C Prithla-Sector-78 Faridabad line on multi circuit towers is delayed mainly due to severe resistance by local villagers & ROW problem at site during construction. Due to delay in construction of 220kV D/C Prithla-Sector-78 Faridabad line, the work for construction of 220kV D/C Prithla-Sector 89 Faridabad line might delay..Updated in 230th OCC by HVPNL   |
| 16      | 400/220kV Sonapat Sub-station    | Commissioned: 6<br>Under Implementation:2<br>Total: 8  | Utilized: 2<br>Unutilized: 4<br>Under Implementation:2 | • LILO of both circuits of 220kV Samalkha - Mohana line at Sonapat                              | Commissioned   | Commissioned as updated by HVPNL in 233rd OCC   |
|         |                                  |  |  | • Sonapat - HSIISC Rai 220kV D/c line   | Commissioned   | Energization date: 31.05.2024 updated by HVPNL in 220th OCC   |
|         |                                  |  |  | • Sonapat - Kharkhoda Pocket A 220kV D/c line   | 31.07.2025     | Updated in 232nd OCC by HVPNL.<br><b>Status:</b><br>Work order has been issued to M/s R.S Infra on dated 09.08.2023 by O/o CE/PD&C, Panchkula for construction of line.<br>Both bays are under construction and erection of electrical equipment is under progress.   |
| 17      | 400/220kV Neemrana Sub-station   | Commissioned: 6<br>Total: 6                            | Utilized: 4<br>Unutilized: 2                           | • LILO of Bhiwadi - Neemrana 220kV S/c line at Neemrana (PG)                                    | -              | Work is under progres. Stub Setting: 14/2017. Permission for Highway is awaited from concerned department as updated in 218th OCC by RVPNL.   |
| 18      | 400/220kV Kotputli Sub-station   | Commissioned: 6<br>Total: 6                            | Utilized: 4<br>Unutilized: 2                           | • Kotputli - Pathreda 220kV D/c line  | -              | Date of bid opening has been extended up to 30.04.2024 as updated in 218th OCC by RVPNL.  |
| 19      | 400/220kV Jalandhar Sub-station  | Commissioned: 10<br>Total: 10                          | Utilized: 8<br>Unutilized: 2                           | • LILO of 220 kV BBMB Jalandhar - Butari line at 400 kV PGCIL Jalandhar                         | -              | LILO of 220 kV BBMB Jalandhar - Butari line at 400 kV PGCIL Jalandhar being planned. Route plan and estimate of work sanctioned, DNIT has been sent to float tender as updated by PSTCL in 227th OCC  |
| 20      | 400/220kV Roorkee Sub-station    | Commissioned: 6<br>Total: 6                            | Utilized: 4<br>Unutilized: 2                           | • Roorkee (PG)-Pirankaliyar 220kV D/c line  | Commissioned   | Roorkee (PG)-Pirankaliyar 220kV D/c line commissioned in 2020 as intimated by PTCUL in 197th OCC  |
| 21      | 400/220kV Lucknow Sub-station    | Commissioned: 8<br>Total: 8                            | Utilized: 4<br>Unutilized: 4                           | • Network to be planned for 2 bays  | Commissioned   | • Lucknow -Kanduni, 220 kV D/C line work energized on 05.10.2023. Updated in 212th OCC by UPPTCL.<br>• No planning for 2 no. of bays upated by UPPTCL in 196th OCC. The same has been communicated to Powergrid.  |
| 22      | 400/220kV Gorakhpur Sub-station  | Commissioned: 6<br>Total: 6                            | Utilized: 4<br>Unutilized: 2                           | • Network to be planned for 2 bays  | Commissioned   | • Gorakhpur(PG)- Maharajganj, 220 kV D/C line energized on 27.09.2023 updated by UPPTCL in 212th OCC  |
| 23      | 400/220kV Fatehpur Sub-station   | Commissioned: 8<br>Under Implementation:2<br>Total: 10 | Utilized: 6<br>Unutilized: 2<br>Under Implementation:2 | • Network to be planned for 2 bays  | -              | • UPPTCL intimated that 02 no. of bays under finalization stage. In 201st OCC, UPPTCL intimated that it is finalized that Khaga s/s will be connected (tentative time 1.5 years).<br>• No planning for 2 no. of bays updated by UPPTCL in 196th OCC. The same has been communicated to Powergrid.   |



| Sl. No. | Substation                       | Downstream network bays  | Status of bays  | Planned 220 kV system and Implementation status  | Revised Target | Remarks   |
|---------|----------------------------------|--|---|--|----------------|---|
| 24      | 400/220kV Abdullapur Sub-station | Commissioned: 10<br>Under Implementation:2<br>Total: 12                      | Utilized: 10<br>Unutilized: 0<br>Under Implementation:2 | • Abdullapur – Rajokheri 220kV D/c line  | Commissioned   | Ckt-1 commissioned at 16:13hrs on dated 06.08.24 & Ckt-2 commissioned at 20:10 hrs on dated 05.08.24. Updated in 223rd OCC by HVPNL   |
| 25      | 400/220kV Pachkula Sub-station   | Commissioned: 8<br>Under tender:2<br>Total: 10<br>Out of these 10 nos. 220kV | Utilized: 2<br>Unutilized: 4<br>Under Implementation:2  | • Panchkula – Pinjore 220kV D/c line   | Commissioned   | Updated in 218th OCC by HVPNL   |
|         |                                  |  |   | • Panchkula – Sector-32 220kV D/c line   | Commissioned   | Energization date: 24.05.2024 updated by HVPNL in 220th OCC   |
|         |                                  |  |   | • Panchkula – Raiwali 220kV D/c line   | Commissioned   | Updated in 194th OCC by HVPNL   |
|         |                                  |  |   | • Panchkula – Sadhaura 220kV D/c line: Sep'23  | Jun'25         | Revised target date as confirmed by concerned XEN TS, Panchkula.Updated in 230th OCC by HVPNL   |
| 26      | 400/220kV Amritsar S/s           | Commissioned:7<br>Approved in 50th NRPC- 1 no.<br>Total: 8                   | Utilized: 6<br>Under Implementation:2                   | • Amritsar – Patti 220kV S/c line  | -              | Draft connectivity agreements for 220kV Rashiana-Amritsar has been received from CTU and the same under processing. Draft connectivity agreements for 220kV Patti-Amritsar line is under consideration by CTU. CTU is processing the agreement and PSTCL has provided with the requisite inputs/data to CTU. Updated in 232nd OCC by PSTCL.   |
|         |                                  |  |   | • Amritsar – Rashiana 220kV S/c line (2 bays shall be required for above lines. However, 1 unutilized bay shall be used for Patti and requirement of one additional bay approved for Rashiana by NRPC) | -              | Draft connectivity agreements for 220kV Rashiana-Amritsar & 220kV Patti-Amritsar lines are under consideration by CTU. CTU is processing the agreement and PSTCL has provided with the requisite inputs/data to CTU. Updated in 232nd OCC by PSTCL.   |
| 27      | 400/220kV Bagpat S/s             | Commissioned: 8<br>Total: 8  | Utilized:6<br>Unutilized: 2                             | • Bagpat - Modipuram 220kV D/c line  | Commissioned   | Updated in 201st OCC by UPPTCL  |
| 28      | 400/220kV Bahadurgarh S/s        | Commissioned: 4<br>Approved: 4<br>Total: 8                                   | Utilized:2<br>Unutilized: 2                             | • LILO of 220 kV Nunamajra- Daultabad S/c line at 400 kV Bahadurgarh PGCIL   | -              | Proposal turned down by CEA.Updated in 230th OCC by HVPNL.  |
|         |                                  |  |   | • Bahadurgarh - METL 220kV D/c line (Deposit work of M/s METL)   | 15.06.2026     | Updated in 230th OCC by HVPNL.<br><b>Status:</b><br>The work stands awarded to the M/s KRR and the execution work has been started at site. Partial route stands approved by the competent authority of the HVPNL. Further, 06 no. Foundation has been casted.  |
|         |                                  |  |   | • Bahadurgarh - Kharkhoda Pocket B 220kV D/c line  | 30.06.2025     | Updated in 230th OCC by HVPNL.<br><b>Status:</b><br>RoW issues which are being resolved with the help of Duty Magistrate.   |
| 29      | 400/220kV Jaipur (South) S/s     | Commissioned: 4<br>Total: 4  | Utilized:2<br>Unutilized: 2                             | • LILO of 220 kV S/C Dausa – Sawai Madhopur line at 400 kV GSS Jaipur South (PG)   | 06.10.2025     | Work order has been issued on 06.10.2023, work under progress as updated by RVPNL in 215th OCC  |
| 30      | 400/220kV Sohawal S/s            | Commissioned: 8<br>Total: 8  | Utilized: 8   | • Sohawal - Barabanki 220kV D/c line   | Commissioned   | Energization date: 14.04.2018 updated by UPPTCL in 196th OCC  |
|         |                                  |  |   | • Sohawal - New Tanda 220kV D/c line   | Commissioned   | Energization date: 28.05.2019 updated by UPPTCL in 196th OCC  |
|         |                                  |  |   | • Network to be planned for 2 bays   | Commissioned   | • Sohawal - Gonda 220kV S/c line (Energization date: 27.04.2020) updated by UPPTCL in 196th OCC<br>• Sohawal - Bahraich 220kV S/c line (Energization date: 15.02.2021) updated by UPPTCL in 196th OCC   |
| 31      | 400/220kV, Kankroli              | Commissioned: 6<br>Total: 6  | Utilized: 4<br>Unutilized: 2                            | • 220 kV D/C Kankroli(PG) - Nathdwara line   | -              | Standard bid document has been finalized on 13.08.2024 and bid is under preparation as updated by RVPN in 222nd OCC.  |
| 32      | 400/220kV, Manesar               | Commissioned: 8<br>Total: 8  | Utilized: 4<br>Unutilized: 4                            | • Network to be planned for 2 bays   | -              | Status:-<br>A proposal is being prepared for the creation of another 220kV D/C line from the 400kV substation Panchgaon (PG) to the 220kV substation Panchgaon (HVPNL), along with the LILO of one circuit of the 220kV D/C Panchgaon (PG) – Mau line at the 220kV substation Panchgaon to utilize two bays at the 400kV substation Panchgaon. The load flow study for this has already been completed. |
| 33      | 400/220kV, Saharanpur            | Commissioned: 6<br>Under Implementation:2<br>Total: 8                        | Utilized: 6<br>Unutilized: 0<br>Under Implementation:2  | • Network to be planned for 2 bays   | Commissioned   | Saharanpur(PG)-Devband D/c line (Energization date: 20.04.2023) updated by UPPTCL in 207th OCC  |
| 34      | 400/220kV, Wagoora               | Commissioned: 10<br>Total: 10  | Utilized: 6<br>Unutilized: 4                            | • Network to be planned for 4 bays   | -              | PDD, J&K to update the status.  |
| 35      | 400/220kV, Ludhiana              | Commissioned: 9<br>Total: 9  | Utilized: 8<br>Unutilized: 1                            | • Network to be planned for 1 bay  | Commissioned   | Direct circuit from 220 kV Lalton Kalan to Dhandari Kalan to be diverted to 400 kV PGCIL Ludhiana. Work completed , final agrement is expected to be signed by May'24. Updated in 218th OCC by PSTCL.   |
| 36      | 400/220kV, Chamba (Chamera Pool) | Commissioned: 3<br>Under tender:1<br>Total: 4                                | Utilized:3<br>Unutilized: 0<br>Under tender:1           | • Stringing of 2nd ckt of Chamera Pool – Karian 220kV D/c line   | Commissioned   | Stringing of 2nd Circuit of Chamera Pool-Karian Tansmission line has been completed & terminal bay at 400/220 kV chamera pooling substation (PGCIL) is commissioned on 20.01.2024. Updated in 217th OCC by HPPTCL.  |
| 37      | 400/220kV, Mainpuri              | Commissioned: 6<br>Under Implementation:2<br>Total: 8                        | Utilized: 6<br>Unutilized: 0<br>Under Implementation:2  | • Network to be planned for 2 bays   | -              | • 02 no. of bays under finalization stage updated by UPPTCL in 196th OCC. Mainpuri S/s planned. Land is not finalized, therefore timeline not available as intimated by UPPTCL in 201st OCC.  |

| Sl. No. | Substation         | Downstream network bays     | Status of bays               | Planned 220 kV system and Implementation status | Revised Target | Remarks   |
|---------|--------------------|-----------------------------|------------------------------|---|----------------|---|
| 38      | 400/220kV, Patiala | Commissioned: 8<br>Total: 8 | Utilized: 6<br>Unutilized: 2 | • 400 kV PGCIL Patiala - 220 kV Bhadson (D/C)   | -              | 2 Nos. bays for 400 kV PGCIL Patiala - 220 kV Bhadson (D/C) line being planned. Construction of boundary wall has started at 220 kv ss bhadson.yard work could not be started as approval for dismantaling existing 517 no tress is pending at district level committee which is competent for giving approval of dismantling of trees. Chairman of committee is DC pataiala.. as updated by PSTCL in 233th OCC meeting |

| Sl. No. | Substation | Downstream network bays | Status of bays | Planned 220 kV system and Implementation status | Revised Target | Remarks |
|---------|------------|-------------------------|----------------|---|----------------|---------|
|         |            |                         |                |   |                |         |

## Status of ADMS implementation in NR:

| Sl. No. | State / UT | Status  | Remarks  |
|---------|------------|---|--|
| 1       | DELHI      | Scheme Implemented but operated in manual mode. | Revised Standard Operating Procedure (SOP) of Automatic Demand Management Scheme (ADMS) in NCT of Delhi has been approved in 51st TCC and 76th NRPC meeting. In OCC meeting, DTL intimated that TPPDL has informed that they have engaged SCADA OEM for the implementation of ADMS. However, OEM has confirmed that incorporation of ADMS logic into the current SCADA system is not feasible and it would require an upgrade or refresh of the system, necessitating additional expenditure for which DERC has been approached. The complete implementation cycle is expected to be within 2 years. However, in the meantime considering the criticality, their in-house team is working to develop a trigger notification/alarm system for manual operation of breaker triggering from the control room and thereafter exploring the possibility of automatically triggering the breaker using the trigger notification. TPPDL has stated that they expect to complete it by August 2025, if materialized. BRPL and BYPL have informed that their existing SCADA system is obsolete and it is in the up-gradation phase by OEM. After the up-gradation of SCADA system, the ADMS is expected to be implemented in BRPL & BYPL by Oct 25. |
| 2       | HARYANA    | Scheme not implemented                          | <p>Haryana SLDC intimated that as per Joint Roadmap of implementation of ADMS in Haryana supplied to NRPC vide memo dated 17.10.2023 (Annexure-II), the implementation plan was proposed to be carried out in two parts, as mentioned below:</p> <p>PART-I: Control with Transmission Utility</p> <p>PART-II: Control with Distribution Utility</p> <p>It is pertinent to mention that as part of upcoming SCADA-EMS system i.e. upgradation of SCADA-EMS system, a feature in the name of LSS (Load Shedding Software)/ ADMS is part of the Technical Specification of project to be delivered. Therefore, the functionalities of ADMS application will be covered under 'Part-I: Control with Transmission Utility' will already be covered using the RTUs available at select substations along with the ADMS software being delivered by M/s GE under SCADA upgradation project.</p> <p>Hence, there is no need to acquire a separate ADMS application &amp; associated hardware for data centre for implementation of PART-I.</p> <p>Further for Part -II a committee has been constituted for further finalization of the ADMS module with control with Discoms is under discussions for preparation of DPR.</p>                     |
| 3       | HP         | Scheme not implemented                          | HPSDLC has kept the provision of ADMS in upgradation/replacement of SCADA system under ULDC Phase-III scheme for operating the feeders automatically through ADMS functionality. HP SLDC mentioned that logic regarding implementation of Automatic Demand Management System in HP Control Area has been finalized and finalization of feeders to give this load relief is pending. HPSEB had intimated that initially 142 Nos. of feeders were identified for operation under ADMS functionality but most of these feeders were from same sub-station. Therefore, now they have increased the no. of sub-station and identified the non-critical feeders. Load relief to be given through these feeders is under finalization. The revised feeder list from HPSEBL is awaited as intimated by HPSLDC.   |
| 4       | PUNJAB     | Scheme not implemented                          | <p>i. A committee comprising of following officers of PSPCL &amp; PSTCL has been constituted to finalize the logic regarding implementation of Automatic Demand Management System in Punjab Control Area.</p> <p>A meeting in this regard was held on dated 26-02-2024 at PSLDC Complex, Patiala. The committee deliberated various loading scenarios and proposed the following logic for the management of demand:</p> <ol style="list-style-type: none"> <li>1. If the frequency sustains below 49.90 Hz for duration of 3 minutes, the Automatic Demand Management System will initiate a 50% reduction in the Over Drawl.</li> <li>2. In case the frequency falls further below 49.85 Hz, the Over Drawl will be reduced to zero.</li> <li>3. The software at the SLDC end for ADMS shall be available with ULDC phase –III SCADA system which is under implementation.</li> </ol> <p>ii. In 222nd OCC, MS NRPC asked Punjab to co-ordinate with Powergrid for integration of their proposed logic with the ULDC phase-III SCADA system for timely implementation.</p>  |
| 5       | RAJASTHAN  | Under implementation                            | RVPN has pilot tested the logic of ADMS which is to be implemented for Rajasthan. In 232th OCC meeting, RVPN informed that 286 nos. of circuit breakers have been mapped to ADMS, all 286 circuit breakers tested upto yard individually. Total 650CBs are to be mapped in phased manner.  |

|   |             |                                  |   |
|---|-------------|----------------------------------|---|
| 6 | UP          | Scheme implemented by NPCIL only | <p>i. A meeting regarding ADMS was held on 15.01.2023 with the UPPCL under the chairmanship of MD UPPTCL</p> <p>ii. A committee formed for identification of load at 33 kV level under the chairmanship of Director (Distribution), UPPCL.</p> <p>iii. Another committee under the chairmanship of Director UPSLDC shall identify the technical and operational requirement for ADMS implementation</p> <p>iv. The software at the SLDC end for ADMS shall be available with ULDC phase –III SCADA system which is under implementation and likely to be commissioned by March 2025.(it is delayed)</p> <p>v. In order to operate identified 33 kV feeders under ADMS scheme, integration of 132 kV substations with SCADA system is under implementation in the Reliable Communication Scheme.</p> <p>vi. MS, NRPC apprised forum that a letter has been written to Director, SLDC for co-ordinatng with Director (Distribution), UPPCL for expediting the finalization of feeder list at 33kV for ADMS implementation.</p> <p>vii. Response from UPPCL regarding the finalization of feeder list at 33kV for ADMS implementation is awaited.</p> <p>ix. In 230th OCC meeting UP SLDC representative informed that feeder list at 33kV level for ADMS is awaited from UPPCL.</p>   |
| 7 | UTTARAKHAND | Scheme not implemented           | <p>i. UPCL has prepared a system architecture in which all the non-monitored sub-stions have been selected and 11kV feeders have been considered for ADMS operation. For the scheme, discom has also done group-wise selection of feeders and quantum of MW relief to be given for automatic demand response at 11kV level has also been decided. UPCL has awarded the tender for implementation of the aforementioned scheme to M/s Metergy Pvt.Ltd.</p> <p>ii. As per the status report submitted by M/s Metergy Pvt.Ltd, the survey work of 30 nos. incomer sites have been completed and order has been placed by UPCL for hardware equipments.</p> <p>iii. Uttarakhand SLDC informed that feeder list at 11kV level has been finalized and logic of ADMS implementation is under finalization.</p> <p>iv. Uttarakhand has intimated that It is bring to your notice that installation MFT( Multi Function Transducers) at various interstate points at PTCUL Substations under ADRS Project of UPCL is in progress.</p> <p>v. First Phase- Data Acquisition of 32 interstate points completed.</p> <p>vi. Second Phase-95 distribution side Substation work is on progress.</p> <p>vii In 230th OCC meeting Uttarakhand SLDC representative informed that Harbour installation and communication establishment has been done on 35 11kV feeders out of total 195 11kV feeders. The work is expected to be completed by December, 2025.</p> |

## Status of availability of ERS towers in NR

| Sl. No. | Transmission Utility                        | Voltage Level<br>(220kV/400kV/765kV/<br>500 kV HVDC etc.) | Length of the<br>transmission lines<br>owned by the Utility<br>(Ckt. Kms.) | Number of ERS Sets (towers)<br>available (Nos.) | ERS Set ( towers)<br>required as per the<br>Govt. norms. | Location  | Remarks   |
|---------|---|---|--|---|--|---|---|
| 1       | PTCUL                                       | 400kV   | 418.394  | NIL   | 1  |   | Tender has been scraped due to single bidder.   |
|         |   | 220kV   | 1045.135   | NIL   | 1  |   |   |
| 2       | Powergrid NR-1                              | 220 KV  | 1842.88  | NIL   | 1  |   |   |
|         |   | 400 KV  | 11074.26   | 12 Towers                                       | 3  | All 400kV ERS at Ballabgarh                                   | make-Lindsey  |
|         |   | 765 KV  | 4721.85  | 15 Towers                                       | 1  | All 765kV ERS at Meerut                                       | Make-SBB  |
|         |   | 500 KV HVDC   | 653.88   | NIL   | 1  |   |   |
|         |   | 800 KV HVDC   | 416.58   | NIL   | 1  |   |   |
| 3       | Powergrid NR-2                              | 66 KV   | 37.56  | Nil   | 1  |   | ERS tower available for 400KV rating can be used in place of lower as well as higher voltage Towers. In case used for 765KV Line, No of towers can be erected will reduce due to increase in Tower Hight. |
|         |   | 132 KV  | 262.7  | Nil   | 1  |   |   |
|         |   | 220 KV  | 2152   | Nil   | 1  |   |   |
|         |   | 400 KV  | 8097.3   | 02 Set (32 Towers)                              | 2  | Kishenpur & Jalandhar   |   |
|         |   | 765 KV  | 337.5  | Nil   | 1  |   |   |
| 4       | Powergrid NR-3                              | 800KV HVDC  | 2205   | NIL   | 1  |   | 400KV ERS will be also be used in other voltage level lines   |
|         |   | 500KV HVDC  | 2566   | NIL   | 1  |   |   |
|         |   | 765KV   | 4396   | NIL   | 1  |   |   |
|         |   | 400KV   | 12254  | 26 Towers                                       | 3  | Kanpur  |   |
|         |   | 220KV   | 1541   | NIL   | 1  |   |   |
|         |   | 132KV   | 207  | NIL   | 1  |   |   |
| 5       | PARBATI KOLDAM TRANSMISSION COMPANY LIMITED | 400kV   | 457  | NIL   | 1  |   | Procurement under process.  |
| 6       | PATRAN TRANSMISSION COMPANY LTD             | 400kV   | 0.4  | NIL   | 1  | It is kept in Bhopal and on need basis is moved across region | Not available, will tie up based on the requirements in future. However the parent company IndiGrid owns one set of ERS for all five regions.   |
| 7       | NRSS-XXIX TRANSMISSION LTD                  | 400kV   | 853  | NIL   | 1  |   |   |
| 8       | GURGAON PALWAL TRANSMISSION LTD             | 400kV   | 272  | NIL   | 1  |   |   |
| 9       | RAPP Transmission Company Limited.          | 400kV   | 402  | NIL   | 1  |   |   |
| 10      | NRSS XXXVI Transmission Limited             | 400kV   | 301.924  | NIL   | 1  |   | Element I - Operational comprising of 3 kms. Element II - Work Under Progress comprising of 221.924 kms. Element II - Work Under Progress comprising of 77 kms.   |
| 11      | HPPTCL                                      | 220 kV  | 659  | NIL   | 1  |   |   |
|         |   | 400 kV  | 75.7   | NIL   | 1  |   |   |
| 12      | RVPN  | 132 kV  | 18969.958  | 1   | 4  | 01 No. ERS available at 220 kV GSS Heerapura, Jaipur          | ERS proposed : 01 Set at 400 kV GSS, Jodhpur. 01 set at 400 kV GSS Ajmer  |
|         |   | 220 kV  | 16227.979  |   | 3  |   |   |
|         |   | 400 kV  | 6899.386   |   | 2  |   |   |
|         |   | 765 kV  | 425.498  |   | 1  |   |   |

| Sl. No. | Transmission Utility                       | Voltage Level<br>(220kV/400kV/765kV/<br>500 kV HVDC etc.) | Length of the<br>transmission lines<br>owned by the Utility<br>(Ckt. Kms.) | Number of ERS Sets (towers)<br>available (Nos.) | ERS Set ( towers)<br>required as per the Govt. norms. | Location                   | Remarks  |
|---------|--|---|--|---|---|----------------------------|--|
| 13      | DTL  | 220kV   | 915.498  | NIL   | 1   | 400kV Bamnauli Sub station | ERS tower available for 400KV rating can also be used for lower voltage lines as well  |
|         |  | 400kV   | 249.19   | 02 Sets (32 towers)                             | 1   |                            |  |
| 14      | JKPTCL                                     |   |  |   |   |                            | JKPTCL, Jammu: being procured<br>JKPTCL, Kashmir:10 tower procured (out of which 3 on loan to JKPTCL, Jammu)   |
| 15      | HVPN                                       |   |  |   |   |                            | HVPN has apprised that purchase order for procurement of 2 sets of Emergency Restoration System (ERS) in HVPNL has been issued to M/s Jost's Engineering Company Ltd., Mumbai  |
| 16      | PSTCL                                      | 400 kV  | 1666.43  | 2   | 2   |                            |  |
|         |  | 220 kV  | 7921.991   |   |   |                            |  |
| 17      | UPPTCL 1- Meerut                           | 132KV   | 27508.321  | 24 Nos(15 Running+9 Angle)                      |   | 400 kV S/s Gr. Noida       | ERS will be also be used in other voltage level lines.   |
|         |  | 220KV   | 14973.453  |   |   |                            |  |
|         |  | 400KV   | 6922.828   |   |   |                            |  |
|         | UPPTCL 2-Prayagraj                         | 765KV   | 839.37   | 24 Towers                                       |   | 220 kv S/s phulpur         | ERS will also be used in other voltage lines.  |
|         |  | 400KV   | 1804.257   |   |   |                            |  |
|         |  | 220KV   | 2578.932   |   |   |                            |  |
|         |  | 132KV   | 4714.768   |   |   |                            |  |
| 18      | POWERLINK                                  |   |  |   |   |                            |  |
| 19      | POWERGRID HIMACHAL TRANSMISSION LTD        |   |  |   |   |                            |  |
| 20      | Powergrid Ajmer Phagi Transmission Limited |   |  |   |   |                            |  |
| 21      | Powergrid Fatehgarh Transmission Limited   |   |  |   |   |                            |  |
| 22      | POWERGRID KALA AMB TRANSMISSION LTD        |   |  |   |   |                            |  |
| 23      | Powergrid Unchahar Transmission Ltd        |   |  |   |   |                            |  |
| 24      | Powergrid Khetri Transmission Limited      |   |  |   |   |                            |  |
| 25      | POWERGRID VARANASI TRANSMISSION SYSTEM LTD |   |  |   |   |                            |  |
| 26      | ADANI TRANSMISSION INDIA LIMITED           |   | 2090   | 1 Set (12 towers)                               | 1 set (12 towers)                                     | Sami (Gujarat)             | Make-Lindsey<br>ERS set available for 400KV & 500KV rating can be used for lower as well as higher voltage Towers. In case used for 765KV Line, No of towers can reduce due to increase in Tower Height & nos of conductors. |
| 27      | BIKANER KHETRI TRANSMISSION LIMITED        |   | 482  |   |   |                            |  |
| 28      | FATEHGARH BHADLA TRANSMISSION LIMITED      | 500 kV HVDC<br>400 kV HVAC                                | 291  |   |   |                            |  |
| 29      | NRSS-XXXI(B) TRANSMISSION LTD              | 400 kV  | 577.74   | Not Available                                   | Not Available   |                            | Tied up with M/s INDIGRID for providing ERS on need basis.   |
| 30      | ARAVALI POWER COMPANY PVT LTD              | 765 kv HVAC   |  |   |   |                            |  |

\*The transmission Utility with line length less than 500 ckt kms (of 400 KV lines) may be given option either to procure ERS or have agreement with other transmission utilities for providing ERS on mutually agreed terms, when need arises. (As per MoP directions)



| FGD COMMISSIONING STATUS |   |                         |                |   |  |  |  |
|--------------------------|---|-------------------------|----------------|---|--|--|--|
| S.No.                    | Utility                                 | Plant Name              | Unit           | Target Commissioning Date<br>(As updated by utility in OCC) | If commissioned , Actual Date<br>of Commissioning  | If not commissioned<br>, Target Date of<br>Commissioning |  |
| 1                        | Adani Power Ltd.                        | KAWAI TPS               | 1              | 31-Dec-24   |  | 31-Dec-29  |  |
| 2                        |   |                         | 2              | 31-Dec-24   |  | 31-Dec-29  |  |
| 3                        | APCPL                                   | INDIRA GANDHI STPP      | 1              |   | 3-May-24   |  |  |
| 4                        |   |                         | 2              | 30-Sep-23   | 27-Jan-25  |  |  |
| 5                        | GVK                                     | GOINDWAL SAHIB          | 3              | 30-Jun-23   |  | 31-May-25  |  |
| 6                        |   |                         | 1              | 30-Apr-20   | INFO NOT RECEIVED  |  |  |
| 7                        | NTPC                                    | DADRI NCTPP             | 2              | 29-Feb-20   |  |  |  |
| 8                        |   |                         | 1              | 31-Dec-20   | 31.12.2019,(DSI - Dry FGD)   |  |  |
| 9                        |   |                         | 2              | 31-Oct-20   | 27.12.2019,(DSI - Dry FGD)   |  |  |
| 10                       |   |                         | 3              | 31-Aug-20   | 27.07.2020,(DSI - Dry FGD)   |  |  |
| 11                       |   |                         | 4              | 30-Jun-20   | 14.07.2020,(DSI - Dry FGD)   |  |  |
| 12                       |   |                         | 5              | 30-Jun-22   | 15-Jun-22  |  |  |
| 13                       |   | RIHAND STPS             | 6              | 31-Mar-23   | 8-Feb-24   |  |  |
| 14                       |   |                         | 1              | 31-Dec-24   |  | 30-Nov-26  |  |
|                          |   |                         | 2              | 30-Jun-26   |  | 31-Aug-26  |  |
|                          |   |                         | 3              | 31-Dec-24   |  | 31-Dec-26  |  |
|                          |   |                         | 4              | 31-Mar-25   |  | 30-Sep-26  |  |
|                          |   |                         | 5              | 30-Jun-25   |  | 30-Jun-26  |  |
| 15                       |   | SINGRAULI STPS          | 6              | 31-Mar-25   |  | 31-Mar-25  |  |
| 16                       |   |                         | 1              | 31-Dec-24   |  | 30-Sep-25  |  |
| 17                       |   |                         | 2              | 31-Dec-24   |  | 30-Sep-25  |  |
| 18                       |   |                         | 3              | 31-Dec-24   |  | 30-Sep-25  |  |
| 19                       |   |                         | 4              | 31-Dec-24   |  | 31-Dec-25  |  |
| 20                       |   |                         | 5              | 31-Mar-25   |  | 31-Dec-25  |  |
| 21                       |   | UNCHAHAH TPS            | 6              | 30-Jun-24   |  | 31-Aug-25  |  |
| 22                       |   |                         | 7              | 31-Mar-24   | Hot Gas In completed on<br>26.03.2025  | 30-Jun-25  |  |
| 23                       |   |                         | 1              | 31-Dec-23   | 22-Feb-25  |  |  |
| 24                       |   |                         | 2              | 31-Dec-23   | 22-Feb-25  |  |  |
| 25                       |   |                         | 3              | 30-Sep-23   |  | 30-May-25  |  |
| 26                       |   |                         | 4              | 30-Sep-23   |  | 30-May-25  |  |
| 27                       |   | MEJA STAGE- 1           | 5              | 30-Sep-23   |  | 30-May-25  |  |
| 28                       |   |                         | 6              | 31-Aug-22   | 11-Oct-22  |  |  |
| 29                       |   |                         | 1              | 31-Oct-23   | 16-Jan-25  |  |  |
| 30                       |   |                         | 2              | 30-Jun-23   | 28-Feb-25  |  |  |
| 31                       |   |                         | TANDA STAGE -1 | 1   | No FGD   |  |  |
|                          |   |                         |                | 2   | No FGD   |  |  |
|                          |   | 3                       |                | No FGD  |  |  |  |
| 32                       |   | 4                       |                | No FGD  |  |  |  |
| 33                       |   | TANDA STAGE -2          | 5              | 31-Mar-23   | 28-Nov-24  |  |  |
| 34                       | 6                                       |                         | 30-Sep-23      |   | 30-May-25  |  |  |
| 35                       | L&T POWER DEVELOPMENT                   | NABHA TPP (RAJPURA TPP) | 1              | 30-Apr-21   | NPL has completed construction of FGD units for both of its units, which have been ready for |  |  |
| 36                       | 2                                       |                         | 28-Feb-21      |   |  |  |  |
| 37                       | TALWANDI SABO POWER LTD.                | TALWANDI SABO TPP       | 1              | 28-Feb-21   | INFO NOT RECEIVED  |  |  |
| 38                       |   |                         | 2              | 31-Dec-20   |  |  |  |
| 39                       |   |                         | 3              | 31-Oct-20   |  |  |  |
| 40                       | HGPCL                                   | PANIPAT TPS             | 6              | 31-Dec-25   |  |  |  |
| 41                       |   |                         | 7              | 31-Dec-25   |  |  |  |
| 42                       |   |                         | 8              | 31-Dec-25   |  |  |  |
| 43                       |   | RAJIV GANDHI TPS        | 1              | 31-Aug-27   |  |  |  |
| 44                       |   |                         | 2              | 31-Aug-27   |  |  |  |
| 45                       |   | YAMUNA NAGAR TPS        | 1              | 31-Aug-27   |  |  |  |
| 46                       | 2                                       |                         | 31-Aug-27      |   |  |  |  |
| 47                       | Lalitpur Power Gen. Company Ltd.        | LALITPUR TPS            | 1              | 31-Dec-26   |  |  |  |
| 48                       |   |                         | 2              | 30-Sep-26   |  |  |  |
| 49                       |   |                         | 3              | 30-Jun-26   |  |  |  |
| 50                       | Lanco Anpara Power Ltd.                 | ANPARA C TPS            | 1              | 31-Dec-25   |  |  |  |
| 51                       | 2                                       |                         | 31-Dec-25      |   |  |  |  |
| 52                       | Prayagraj Power Generation Company Ltd. |                         | PRAYAGRAJ TPP  | 1   | 31-Dec-26  |  |  |
| 53                       |   | 2                       |                | 31-Dec-26   |  |  |  |
| 54                       |   | 3                       |                | 31-Dec-26   |  |  |  |
| 55                       | PSPCL                                   | GH TPS (LEH.MOH.)       | 1              | 31-Dec-26   |  |  |  |
| 56                       |   |                         | 2              | 31-Dec-26   |  |  |  |
| 57                       |   |                         | 3              | 31-Dec-26   |  |  |  |
| 58                       |   |                         | 4              | 31-Dec-26   |  |  |  |
| 59                       |   | GGSSTP, Ropar           | 3              | 31-Dec-26   |  |  |  |
| 60                       |   |                         | 4              | 31-Dec-26   |  |  |  |
| 61                       | 5                                       |                         | 31-Dec-26      |   |  |  |  |
| 62                       | Rosa Power Supply Company               | ROSA TPP PH-I           | 6              | 30-Dec-26   |  |  |  |
| 63                       |   |                         | 1              | 31-Dec-26   |  |  |  |
| 64                       |   |                         | 2              | 31-Dec-26   |  |  |  |
| 65                       |   |                         | 3              | 31-Dec-26   |  |  |  |
| 66                       |   |                         | 4              | 31-Dec-26   |  |  |  |
| 67                       |   |                         | 5              | 30-Nov-25   |  |  |  |

|     |         |                 |    |           |  |  |
|-----|---------|-----------------|----|-----------|--|--|
| 68  | RRVUNL  | KOTA TPS        | 6  | 30-Nov-25 |  |  |
| 69  |         |                 | 7  | 30-Nov-25 |  |  |
| 70  |         | SURATGARH TPS   | 1  | 31-Dec-29 |  |  |
| 71  |         |                 | 2  | 31-Dec-29 |  |  |
| 72  |         |                 | 3  | 31-Dec-29 |  |  |
| 73  |         |                 | 4  | 31-Dec-29 |  |  |
| 74  |         |                 | 5  | 31-Dec-29 |  |  |
| 75  |         |                 | 6  | 31-Dec-29 |  |  |
| 76  |         | SURATGARH SCTPS | 7  | 28-Feb-26 |  |  |
| 77  |         |                 | 8  | 28-Feb-26 |  |  |
| 78  |         | CHHABRA TPP     | 1  | 31-Dec-29 |  |  |
| 79  |         |                 | 2  | 31-Dec-29 |  |  |
| 80  |         |                 | 3  | 31-Dec-29 |  |  |
| 81  |         |                 | 4  | 31-Dec-29 |  |  |
| 82  |         | CHHABRA SCPP    | 5  | 28-Feb-26 |  |  |
| 83  |         |                 | 6  | 28-Feb-26 |  |  |
| 84  |         | KALISINDH TPS   | 1  | 28-Feb-26 |  |  |
| 85  |         |                 | 2  | 28-Feb-26 |  |  |
| 86  | UPRVUNL | ANPARA TPS      | 1  | 31-Dec-25 |  |  |
| 87  |         |                 | 2  | 31-Dec-25 |  |  |
| 88  |         |                 | 3  | 31-Dec-25 |  |  |
| 89  |         |                 | 4  | 31-Dec-25 |  |  |
| 90  |         |                 | 5  | 31-Dec-25 |  |  |
| 91  |         |                 | 6  | 31-Dec-25 |  |  |
| 92  |         |                 | 7  | 31-Dec-25 |  |  |
| 93  |         | HARDUAGANJ TPS  | 8  | 31-Dec-26 |  |  |
| 94  |         |                 | 9  | 31-Dec-26 |  |  |
| 95  |         | OBRA TPS        | 9  | 31-Dec-26 |  |  |
| 96  |         |                 | 10 | 31-Dec-26 |  |  |
| 97  |         |                 | 11 | 31-Dec-26 |  |  |
| 98  |         |                 | 12 | 31-Dec-26 |  |  |
| 99  |         |                 | 13 | 31-Dec-26 |  |  |
| 100 |         | PARICHHA TPS    | 3  | 31-Dec-26 |  |  |
| 101 |         |                 | 4  | 31-Dec-26 |  |  |
| 102 |         |                 | 5  | 31-Dec-26 |  |  |
| 103 |         |                 | 6  | 31-Dec-26 |  |  |

## Annexure-A.III

### MIS Report for Status of Islanding Schemes Implemented Schemes

| Implemented Schemes |                     |           |             |   |     |     | SCADA Display Page | Remarks   |
|---------------------|---------------------|-----------|-------------|---|-----|-----|--------------------|---|
| Sl. No.             | Islanding Scheme    | SLDC      | Status      | Submission of Self Certification of Healthiness | SOP |     |                    |   |
| 1                   | NAPS IS             | UP        | Implemented | Yes (08-10-2021)                                | Yes | Yes |                    | -   |
| 2                   | RAPS IS             | Rajasthan | Implemented | 16-Aug-21                                       | Yes | Yes |                    | List of officials in-charge, format for generation, islanding scheme sld and relays in RAPPT IS submitted by RVPN on 04.12.2021.  |
| 3                   | Delhi IS            | Delhi     | Implemented |   |     |     |                    |   |
| 4                   | Lucknow-Unchahar IS | UP        | Implemented |   |     |     |                    | The data of 132 kV S/S Hussainganj is not available at UPSLDC due to lack of OPGW. The work of laying OPGW cable is under progress and same shall be completed by end of July 2025. |

|   | 20 |
|---|----|
| Under Implementation/ Newly Proposed/Under Discussion |    |

[illegible]

| S. No. | Name of Plant | Unit | Installed Capacity | MVA Rating | Make of Units | COD | GT Details    |                 |  | Mode of Fuel Transport (Pit Head/No n Pit-head) | Name of Utility | Sector | Control Area | Type | Real and Reactive Power Capability assessment. |              |                         | Assessment of Reactive Power Control Capability as per CEA Technical Standards for connectivity |              |                         | Model Validation and verification test for the complete Generator and Excitation System model including PSS. |              |                         | Model Validation and verification of Turbine/Governor and Load Control or Active Power/frequency Control Functions. |              |                         | Testing of Governor performance and Automatic Generation Control |              |                         |
|--------|---------------|------|--------------------|------------|---------------|-----|---------------|-----------------|--|---|-----------------|--------|--------------|------|--|--------------|-------------------------|---|--------------|-------------------------|--|--------------|-------------------------|---|--------------|-------------------------|--|--------------|-------------------------|
|        |               |      |                    |            |               |     | Voltage Ratio | GT MVA Capacity | Tap Ratio of GT (Present Tap/Total Taps) |   |                 |        |              |      | Last tested on (dd/mm/yyyy)                    | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)   | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)  | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)   | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)                                      | Whether due? | Tentative Schedule date |
| 1      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 2      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 3      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 4      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 5      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 6      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 7      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 8      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 9      |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |
| 10     |               |      |                    |            |               |     |               |                 |  |   |                 |        |              |      |  |              |                         |   |              |                         |  |              |                         |   |              |                         |  |              |                         |

Revised Simulation Models

Whether Revised Models Submitted?      Remarks

## Hydro Generators

[illegible]

### Revised Simulation Models

| Whether Revised Models Submitted? | Remarks |
|-----------------------------------|---------|
|-----------------------------------|---------|

As per guidelines the OEM representative must remain present at the time of Generator periodic testing hence looking to the age and present status of Units at Mahi PH-I, Letters Dated 12/07/2024 and 19/12/2024 have been sent to the OEM M/s BHEL, Bhopal, and accordingly the plan may be scheduled.

## Nuclear Generators

[illegible]

## Revised Simulation Models

| Whether Revised Models Submitted? | Remarks |
|-----------------------------------|---------|
|-----------------------------------|---------|

## Gas Based Generators

[illegible]

## Revised Simulation Models

| Whether Revised Models Submitted? | Remarks |
|-----------------------------------|---------|
|-----------------------------------|---------|

## Renewable Energy Plants

[illegible]

## Revised Simulation Models

| Whether Revised Models Submitted? | Remarks |
|-----------------------------------|---------|
|-----------------------------------|---------|



HVDC Links

| S. No | Name of Link | Type (LCC/VSC/Back-to-Back) | HVDC_Voltage (kV) | Converter-1  |        | Converter-2  |        | Master Converter Station | Pole_number | Length (km) | Capacity (MW) | Owner     | Forward Direction |                  |                        | Reverse Direction |                  |                        | Reactive Power Controller (RPC) Capability for HVDC/FACTS |              |                         | Filter bank adequacy assessment based on present grid condition, in consultation with NLDC. |              |                         |
|-------|--------------|-----------------------------|-------------------|--------------|--------|--------------|--------|--------------------------|-------------|-------------|---------------|-----------|-------------------|------------------|------------------------|-------------------|------------------|------------------------|---|--------------|-------------------------|---|--------------|-------------------------|
|       |              |                             |                   | Station Name | Region | Station Name | Region |                          |             |             |               |           | Maximum Capacity  | Minimum Capacity | Ground_return_capacity | Maximum Capacity  | Minimum Capacity | Ground_return_capacity | Last tested on (dd/mm/yyyy)                               | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)   | Whether due? | Tentative Schedule date |
| 1     |              |                             | 500               | APL-Mundra   | WR     | Mohindargarh | NR     |                          | 1           | 989         | 1,250         | ATIL      | 150               | 500              | 1250                   |                   |                  |                        |   | Due          |                         |   | Due          |                         |
| 2     |              |                             | 500               | APL-Mundra   |        | Mohindargarh |        |                          | 2           | 989         | 1,250         | ATIL      | 150               | 500              | 1250                   |                   |                  |                        |   | Due          |                         |   | Due          |                         |
| 3     |              | LCC                         | 800               | Champa_HVDC  | WR     | Kurukshetra  | NR     | Champa_HVDC              | 1           | 1,306       | 1,500         | POWERGRID | 150               | 1,500            | DMR path               | NA                | NA               | NA                     |   | Due          | Apr-2025                |   | Due          |                         |
| 4     |              | LCC                         | 800               | Champa_HVDC  | WR     | Kurukshetra  | NR     | Champa_HVDC              | 2           | 1,306       | 1,500         | POWERGRID | 150               | 1,500            | DMR path               | NA                | NA               | NA                     |   | Due          | Apr-2025                |   | Due          |                         |
| 5     |              | LCC                         | 800               | Champa_HVDC  | WR     | Kurukshetra  | NR     | Champa_HVDC              | 3           | 1,306       | 1,500         | POWERGRID | 150               | 1,500            | DMR path               | NA                | NA               | NA                     |   | Due          | Apr-2025                |   | Due          |                         |
| 6     |              | LCC                         | 800               | Champa_HVDC  | WR     | Kurukshetra  | NR     | Champa_HVDC              | 4           | 1,306       | 1,500         | POWERGRID | 150               | 1,500            | DMR path               | NA                | NA               | NA                     |   | Due          | Apr-2025                |   | Due          |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |

Revised Simulation Models

Whether Revised Models Submitted? Remarks

STATCOMs/SVCs

| S.No | Station     | Statcom | Capacity (MVAR) | Owner     | Make           | Reactive Power Controller (RPC) Capability for HVDC/FACTS |              |                         | Filter bank adequacy assessment based on present grid condition, in consultation with NLDC |              |                         | Validation of response by FACTS devices as per settings. |              |                         |
|------|-------------|---------|-----------------|-----------|----------------|---|--------------|-------------------------|--|--------------|-------------------------|--|--------------|-------------------------|
|      |             |         |                 |           |                | Last tested on (dd/mm/yyyy)                               | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)  | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)                              | Whether due? | Tentative Schedule date |
| 1    | Kurukshetra | TCR     | 500             | POWERGRID | GE Vernova T&D | NA  |              | NA                      | NA   |              | NA                      | Nov-2023   | No           | Sep-2028                |
| 2    | Fatehgarh-2 | STATCOM | ±/-600          | POWERGRID | SIEMENS        | Oct-2023  | No           | Sep-2028                | NA   |              | NA                      | Oct-2023   | No           | Sep-2028                |
| 3    | Bhadla-2    | STATCOM | ±/-600          | POWERGRID | SIEMENS        | Jun-2023  | No           | May-2028                | NA   |              | NA                      | Jun-2023   | No           | May-2028                |
| 4    | Bikaner-2   | STATCOM | ±/-300          | POWERGRID | SIEMENS        | Jul-2023  | No           | Jun-2028                | NA   |              | NA                      | Jul-2023   | No           | Jun-2028                |
|      |             |         |                 |           |                |   |              |                         |  |              |                         |  |              |                         |
|      |             |         |                 |           |                |   |              |                         |  |              |                         |  |              |                         |
|      |             |         |                 |           |                |   |              |                         |  |              |                         |  |              |                         |
|      |             |         |                 |           |                |   |              |                         |  |              |                         |  |              |                         |

Revised Simulation Models

Whether Revised Models Submitted?      Remarks

## FSCs/TCSCs

[illegible]

Series Reactor

| S.No | End 1 | End 2 | Line No. | End | Capacity | Make | Reactive Power Controller (RPC) Capability for HVDC/FACTS |              |                         | Filter bank adequacy assessment based on present grid condition, in consultation with NLDC |              |                         | Validation of response by FACTS devices as per settings. |              |                         |
|------|-------|-------|----------|-----|----------|------|---|--------------|-------------------------|--|--------------|-------------------------|--|--------------|-------------------------|
|      |       |       |          |     |          |      | Last tested on (dd/mm/yyyy)                               | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)  | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)                              | Whether due? | Tentative Schedule date |
| 1    |       |       |          |     |          |      |   |              |                         |  |              |                         |  |              |                         |

Revised Simulation Models

Whether Revised Models Submitted?      Remarks

## Annexure-A.IV.b

## Hydro Generators

| Revised Simulation Models |               |          |                    |            |               |             |               |                 |  |                         |                 |              |              |  |              |                         |   |              |                         |  |              |                         |   |              |                         |                                 |              |                         |                              |              |                         |                                   |         |
|---------------------------|---------------|----------|--------------------|------------|---------------|-------------|---------------|-----------------|--|-------------------------|-----------------|--------------|--------------|--|--------------|-------------------------|---|--------------|-------------------------|--|--------------|-------------------------|---|--------------|-------------------------|---------------------------------|--------------|-------------------------|------------------------------|--------------|-------------------------|-----------------------------------|---------|
| S. No.                    | Name of Plant | Unit     | Installed Capacity | MVA Rating | Make of Units | COD         | GT Details    |                 |  | Type (Pondage/RoR etc.) | Name of Utility | Sector       | Control Area | Real and Reactive Power Capability assessment. |              |                         | Assessment of Reactive Power Control Capability as per CEA Technical Standards for Connectivity |              |                         | Model Validation and verification test for the complete Generator and Excitation System model including PSS. |              |                         | Model Validation and verification of Turbine/Governor and Load Control or Active Power/Frequency Control Functions. |              |                         | Testing of Governor performance |              |                         | Automatic Generation Control |              |                         | Whether Revised Models Submitted? | Remarks |
|                           |               |          |                    |            |               |             | Voltage Ratio | GT MVA Capacity | Tap Ratio of GT (Present Tap/Total Taps) |                         |                 |              |              | Last tested on (dd/mm/yyyy)                    | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)   | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)  | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)   | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)     | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)  | Whether due? | Tentative Schedule date |                                   |         |
| 1                         | Bairasiul     | UNIT-I   | 60 MW              | 67 MVA     | M/S BHEL      | 18.05.1980  | 11kV/220kV    | 25 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 2                         | Bairasiul     | UNIT-II  | 60 MW              | 67 MVA     | M/S BHEL      | 19.05.1980  | 11kV/220kV    | 25 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 3                         | Bairasiul     | UNIT-III | 60 MW              | 67 MVA     | M/S BHEL      | 13.09.1981  | 11kV/220kV    | 25 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 4                         | Salal         | UNIT-I   | 115 MW             | 127.8 MVA  | M/S BHEL      | November'87 | 11kV/220kV    | 43.33 MVA       |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 5                         | Salal         | UNIT-II  | 115 MW             | 127.8 MVA  | M/S BHEL      | November'87 | 11kV/220kV    | 43.33 MVA       |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 6                         | Salal         | UNIT-III | 115 MW             | 127.8 MVA  | M/S BHEL      | November'87 | 11kV/220kV    | 43.33 MVA       |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 7                         | Salal         | UNIT-IV  | 115 MW             | 127.8 MVA  | M/S BHEL      | March'93    | 11kV/220kV    | 43.33 MVA       |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 8                         | Salal         | UNIT-V   | 115 MW             | 127.8 MVA  | M/S BHEL      | May'94      | 11kV/220kV    | 43.33 MVA       |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 9                         | Salal         | UNIT-VI  | 115 MW             | 127.8 MVA  | M/S BHEL      | February'95 | 11kV/220kV    | 43.33 MVA       |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 10                        | Tanakpur      | UNIT-I   | 31.4 MW            | 45 MVA     | M/S BHEL      | 31.03.1992  | 11kV/220kV    | 49.5 MVA        |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 11                        | Tanakpur      | UNIT-II  | 31.4 MW            | 45 MVA     | M/S BHEL      | 06.04.1992  | 11kV/220kV    | 49.5 MVA        |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 12                        | Tanakpur      | UNIT-III | 31.4 MW            | 45 MVA     | M/S BHEL      | 04.04.1992  | 11kV/220kV    | 49.5 MVA        |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 13                        | Chamera-I     | UNIT-I   | 180 MW             | 200 MVA    | GE, Canada    | 28.04.1992  | 13.8kV/400 KV | 75 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 14                        | Chamera-I     | UNIT-II  | 180 MW             | 200 MVA    | GE, Canada    | 25.04.1993  | 13.8kV/400 KV | 75 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 15                        | Chamera-I     | UNIT-III | 180 MW             | 200 MVA    | GE, Canada    | 22.04.1994  | 13.8kV/400 KV | 75 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 16                        | Uri-I         | UNIT-I   | 120 MW             | 136 MVA    | ABB           | 10.04.1997  | 13.8kV/400 KV | 50 MVA          |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 17                        | Uri-I         | UNIT-II  | 120 MW             | 136 MVA    | ABB           | 27.01.1997  | 13.8kV/400 KV | 50 MVA          |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 18                        | Uri-I         | UNIT-III | 120 MW             | 136 MVA    | ABB           | 03.03.1997  | 13.8kV/400 KV | 50 MVA          |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 19                        | Uri-I         | UNIT-IV  | 120 MW             | 136 MVA    | ABB           | 13.03.1997  | 13.8kV/400 KV | 50 MVA          |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 20                        | Chamera-II    | UNIT-I   | 100 MW             | 111.1 MVA  | GE            | 04.10.2003  | 11kV/400 KV   | 41 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 21                        | Chamera-II    | UNIT-II  | 100 MW             | 111.1 MVA  | GE            | 05.12.2003  | 11kV/400 KV   | 41 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 22                        | Chamera-II    | UNIT-III | 100 MW             | 111.1 MVA  | GE            | 26.02.2004  | 11kV/400 KV   | 41 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 23                        | Dulhasti      | UNIT-I   | 130 MW             | 145 MVA    | GEC ALSTHOM   | 28.03.2007  | 11kV/400 KV   | 48.33 MVA       |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 24                        | Dulhasti      | UNIT-II  | 130 MW             | 145 MVA    | GEC ALSTHOM   | 28.02.2007  | 11kV/400 KV   | 48.33 MVA       |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 25                        | Dulhasti      | UNIT-III | 130 MW             | 145 MVA    | GEC ALSTHOM   | 18.03.2007  | 11kV/400 KV   | 48.33 MVA       |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 26                        | Dhauliganga   | UNIT-I   | 70 MW              | 78 MVA     | Alstom/GE     | 14.10.2005  | 11kV/220kV    | 29 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 27                        | Dhauliganga   | UNIT-II  | 70 MW              | 78 MVA     | Alstom/GE     | 01.09.2005  | 11kV/220kV    | 29 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 28                        | Dhauliganga   | UNIT-III | 70 MW              | 78 MVA     | Alstom/GE     | 28.07.2005  | 11kV/220kV    | 29 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 29                        | Dhauliganga   | UNIT-IV  | 70 MW              | 78 MVA     | Alstom/GE     | 26.07.2005  | 11kV/220kV    | 29 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 30                        | Sewa-II       | UNIT-I   | 40 MW              | 50 MVA     | M/S BHEL      | 27.06.2010  | 11kV/132kV    | 50 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 31                        | Sewa-II       | UNIT-II  | 40 MW              | 50 MVA     | M/S BHEL      | 10.07.2010  | 11kV/132kV    | 50 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 32                        | Sewa-II       | UNIT-III | 40 MW              | 50 MVA     | M/S BHEL      | 27.07.2010  | 11kV/132kV    | 50 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 33                        | Uri-II        | UNIT-I   | 60 MW              | 67 MVA     | Alstom        | 25.09.2013  | 11kV/400 KV   | 25 MVA          |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 34                        | Uri-II        | UNIT-II  | 60 MW              | 67 MVA     | Alstom        | 25.11.2013  | 11kV/400 KV   | 25 MVA          |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 35                        | Uri-II        | UNIT-III | 60 MW              | 67 MVA     | Alstom        | 27.09.2013  | 11kV/400 KV   | 25 MVA          |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 36                        | Uri-II        | UNIT-IV  | 60 MW              | 67 MVA     | Alstom        | 02.02.2014  | 11kV/400 KV   | 25 MVA          |  | RoR                     | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |
| 37                        | Chamera-III   | UNIT-I   | 77 MW              | 85.56 MVA  | Alstom        | 27.06.2012  | 11kV/220kV    | 32 MVA          |  | Pondage                 | NHPC            | Power/Energy | Northern     |  | Yes          | Jan-Feb 2026            |   |              | Jan-Feb 2026            |  |              | Jan-Feb 2026            |   |              | Jan-Feb 2026            |                                 |              | Jan-Feb 2026            |                              |              |                         |                                   |         |

|    |             |          |        |            |          |            |               |        |  |         |      |              |          |                  |     |              |                  |     |              |                  |     |              |                  |     |              |                  |    |              |
|----|-------------|----------|--------|------------|----------|------------|---------------|--------|--|---------|------|--------------|----------|------------------|-----|--------------|------------------|-----|--------------|------------------|-----|--------------|------------------|-----|--------------|------------------|----|--------------|
| 38 | Chamera-III | UNIT-II  | 77 MW  | 85.56 MVA  | Alstom   | 10.06.2012 | 11kV/220kV    | 32 MVA |  | Pondage | NHPC | Power/Energy | Northern |                  | Yes | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 39 | Chamera-III | UNIT-III | 77 MW  | 85.56 MVA  | Alstom   | 07.06.2012 | 11kV/220kV    | 32 MVA |  | Pondage | NHPC | Power/Energy | Northern |                  | Yes | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 40 | Parbati-III | UNIT-I   | 130 MW | 145 MVA    | M/S BHEL | 17.02.2014 | 13.8kV/400 KV | 53 MVA |  | Pondage | NHPC | Power/Energy | Northern |                  | Yes | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 41 | Parbati-III | UNIT-II  | 130 MW | 145 MVA    | M/S BHEL | 27.02.2014 | 13.8kV/400 KV | 53 MVA |  | Pondage | NHPC | Power/Energy | Northern |                  | Yes | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 42 | Parbati-III | UNIT-III | 130 MW | 145 MVA    | M/S BHEL | 15.03.2014 | 13.8kV/400 KV | 53 MVA |  | Pondage | NHPC | Power/Energy | Northern |                  | Yes | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 43 | Parbati-III | UNIT-IV  | 130 MW | 145 MVA    | M/S BHEL | 22.05.2014 | 13.8kV/400 KV | 53 MVA |  | Pondage | NHPC | Power/Energy | Northern |                  | Yes | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |     | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 44 | Kishanganga | UNIT-I   | 110 MW | 122.22 MVA | M/S BHEL | 13.03.2018 | 13.8kV/220 KV | 45 MVA |  | Pondage | NHPC | Power/Energy | Northern | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 45 | Kishanganga | UNIT-II  | 110 MW | 122.22 MVA | M/S BHEL | 21.03.2018 | 13.8kV/220 KV | 45 MVA |  | Pondage | NHPC | Power/Energy | Northern | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 46 | Kishanganga | UNIT-III | 110 MW | 122.22 MVA | M/S BHEL | 30.03.2018 | 13.8kV/220 KV | 45 MVA |  | Pondage | NHPC | Power/Energy | Northern | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 | 01-03-2018       | Yes | Jan-Feb 2026 |                  |    | Jan-Feb 2026 |
| 47 | Parbati-II  | UNIT-I   | 200 MW | 222.22 MVA | M/S BHEL | 01.04.2025 | 13.8kV/400 KV | 82 MVA |  | Pondage | NHPC | Power/Energy | Northern | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No | 2030         |
| 48 | Parbati-II  | UNIT-II  | 200 MW | 222.22 MVA | M/S BHEL | 01.04.2025 | 13.8kV/400 KV | 82 MVA |  | Pondage | NHPC | Power/Energy | Northern | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No | 2030         |
| 49 | Parbati-II  | UNIT-III | 200 MW | 222.22 MVA | M/S BHEL | 01.04.2025 | 13.8kV/400 KV | 82 MVA |  | Pondage | NHPC | Power/Energy | Northern | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No | 2030         |
| 50 | Parbati-II  | UNIT-IV  | 200 MW | 222.22 MVA | M/S BHEL | 16.04.2025 | 13.8kV/400 KV | 82 MVA |  | Pondage | NHPC | Power/Energy | Northern | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No  | 2030         | March/April 2025 | No | 2030         |

|    |                     |   |        |         |               |            |              |     |           |  |                    |                  |          |   |     |        |   |     |        |   |     |        |        |    |        |        |    |        |          |     |        |
|----|---------------------|---|--------|---------|---------------|------------|--------------|-----|-----------|--|--------------------|------------------|----------|---|-----|--------|---|-----|--------|---|-----|--------|--------|----|--------|--------|----|--------|----------|-----|--------|
| 51 | Tehri HPN(4*250 MW) | 1 | 250 MW | 278 MVA | Power Machine | 09.07.2007 | 420/15.75 kV | 306 | 0.4 (2-5) |  | THDC India Limited | Power Generation | Northern | - | Yes | Mar-26 | - | Yes | Mar-26 | - | Yes | Mar-26 | Apr-23 | No | Mar-28 | Apr-23 | No | Mar-28 | Mar-2021 | Yes | Mar-26 |
| 52 |                     | 2 | 250 MW | 278 MVA |               | 30.01.2007 | 420/15.75 kV | 306 | 0.4 (2-5) |  |                    |                  |          |   |     |        |   |     |        |   |     |        |        |    |        |        |    |        |          |     |        |
| 53 |                     | 3 | 250 MW | 278 MVA |               | 09.11.2006 | 420/15.75 kV | 306 | 0.4 (2-5) |  |                    |                  |          |   |     |        |   |     |        |   |     |        |        |    |        |        |    |        |          |     |        |
| 54 |                     | 4 | 250 MW | 278 MVA |               | 22.09.2006 | 420/15.75 kV | 306 | 0.4 (2-5) |  |                    |                  |          |   |     |        |   |     |        |   |     |        |        |    |        |        |    |        |          |     |        |

|    |       |   |        |         |  |            |                |             |                 |     |      |              |       |            |    |   |            |    |   |            |    |   |            |    |   |            |     |            |            |     |            |
|----|-------|---|--------|---------|--|------------|----------------|-------------|-----------------|-----|------|--------------|-------|------------|----|---|------------|----|---|------------|----|---|------------|----|---|------------|-----|------------|------------|-----|------------|
| 55 | NIHPS | 1 | 250 MW | 278 MVA | EUCONA (Voith Siemens(Germany), GE Hydro (Oslo/Norway), Abtom(Germany), VA Tech(Italy), BHEL(India)) | 18.05.2004 | 15.75kV/ 400kV | 3 x 102 MVA | Tap Ratio - 2/5 | RoR | SIVN | Power/Energy | NRLDC | 18.02.2023 | No | - | 18.02.2023 | No | - | 18.02.2023 | No | - | 05.05.2022 | No | - | 09.02.2021 | Yes | 08.02.2026 | 09.02.2021 | Yes | 08.02.2026 |
| 56 | NIHPS | 2 | 250 MW | 278 MVA |  | 06.05.2004 |                |             |                 |     | SIVN |              | NRLDC | 28.02.2023 | No | - | 28.02.2023 | No | - | 28.02.2023 | No | - | 05.05.2022 | No | - | 09.02.2021 | Yes | 08.02.2026 | 09.02.2021 | Yes | 08.02.2026 |
| 57 | NIHPS | 3 | 250 MW | 278 MVA |  | 31.03.2004 |                |             |                 |     | SIVN |              | NRLDC | 20.02.2023 | No | - | 20.02.2023 | No | - | 20.02.2023 | No | - | 05.05.2022 | No | - | 09.02.2021 | Yes | 08.02.2026 | 09.02.2021 | Yes | 08.02.2026 |
| 58 | NIHPS | 4 | 250 MW | 278 MVA |  | 30.03.2004 |                |             |                 |     | SIVN |              | NRLDC | 19.02.2023 | No | - | 19.02.2023 | No | - | 19.02.2023 | No | - | 05.05.2022 | No | - | 09.02.2021 | Yes | 08.02.2026 | 09.02.2021 | Yes | 08.02.2026 |
| 59 | NIHPS | 5 | 250 MW | 278 MVA |  | 06.10.2003 |                |             |                 |     | SIVN |              | NRLDC | 10.02.2023 | No | - | 10.02.2023 | No | - | 10.02.2023 | No | - | 05.05.2022 | No | - | 09.02.2021 | Yes | 08.02.2026 | 09.02.2021 | Yes | 08.02.2026 |
| 60 | NIHPS | 6 | 250 MW | 278 MVA |  | 02.01.2004 |                |             |                 |     | SIVN |              | NRLDC | 11.02.2023 | No | - | 11.02.2023 | No | - | 11.02.2023 | No | - | 03.11.2023 | No | - | 09.02.2021 | Yes | 08.02.2026 | 09.02.2021 | Yes | 08.02.2026 |

HVDC Links

| S. No | Name of Link | Type (LCC/VSC/Back-to-Back) | HVDC_Voltage (kV) | Converter-1  |        | Converter-2  |        | Master Converter Station | Pole_number | Length (km) | Capacity (MW) | Owner     | Forward Direction |                  |                        | Reverse Direction |                  |                        | Reactive Power Controller (RPC) Capability for HVDC/FACTS |              |                         | Filter bank adequacy assessment based on present grid condition, in consultation with NLDC. |              |                         |
|-------|--------------|-----------------------------|-------------------|--------------|--------|--------------|--------|--------------------------|-------------|-------------|---------------|-----------|-------------------|------------------|------------------------|-------------------|------------------|------------------------|---|--------------|-------------------------|---|--------------|-------------------------|
|       |              |                             |                   | Station Name | Region | Station Name | Region |                          |             |             |               |           | Maximum Capacity  | Minimum Capacity | Ground_return_capacity | Maximum Capacity  | Minimum Capacity | Ground_return_capacity | Last tested on (dd/mm/yyyy)                               | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)   | Whether due? | Tentative Schedule date |
| 1     |              |                             | 500               | APL-Mundra   | WR     | Mohindargarh | NR     |                          | 1           | 989         | 1,250         | ATIL      | 150               | 500              | 1250                   |                   |                  |                        |   | Due          |                         |   | Due          |                         |
| 2     |              |                             | 500               | APL-Mundra   |        | Mohindargarh |        |                          | 2           | 989         | 1,250         | ATIL      | 150               | 500              | 1250                   |                   |                  |                        |   | Due          |                         |   | Due          |                         |
| 3     |              | LCC                         | 800               | Champa_HVDC  | WR     | Kurukshetra  | NR     | Champa_HVDC              | 1           | 1,306       | 1,500         | POWERGRID | 150               | 1,500            | DMR path               | NA                | NA               | NA                     |   | Due          | Apr-2025                |   | Due          |                         |
| 4     |              | LCC                         | 800               | Champa_HVDC  | WR     | Kurukshetra  | NR     | Champa_HVDC              | 2           | 1,306       | 1,500         | POWERGRID | 150               | 1,500            | DMR path               | NA                | NA               | NA                     |   | Due          | Apr-2025                |   | Due          |                         |
| 5     |              | LCC                         | 800               | Champa_HVDC  | WR     | Kurukshetra  | NR     | Champa_HVDC              | 3           | 1,306       | 1,500         | POWERGRID | 150               | 1,500            | DMR path               | NA                | NA               | NA                     |   | Due          | Apr-2025                |   | Due          |                         |
| 6     |              | LCC                         | 800               | Champa_HVDC  | WR     | Kurukshetra  | NR     | Champa_HVDC              | 4           | 1,306       | 1,500         | POWERGRID | 150               | 1,500            | DMR path               | NA                | NA               | NA                     |   | Due          | Apr-2025                |   | Due          |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |
|       |              |                             |                   |              |        |              |        |                          |             |             |               |           |                   |                  |                        |                   |                  |                        |   |              |                         |   |              |                         |

Revised Simulation Models

Whether Revised Models Submitted? Remarks

STATCOMs/SVCs

| S.No | Station     | Statcom | Capacity (MVAR) | Owner     | Make           | Reactive Power Controller (RPC) Capability for HVDC/FACTS |              |                         | Filter bank adequacy assessment based on present grid condition, in consultation with NLDC |              |                         | Validation of response by FACTS devices as per settings. |              |                         |
|------|-------------|---------|-----------------|-----------|----------------|---|--------------|-------------------------|--|--------------|-------------------------|--|--------------|-------------------------|
|      |             |         |                 |           |                | Last tested on (dd/mm/yyyy)                               | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)  | Whether due? | Tentative Schedule date | Last tested on (dd/mm/yyyy)                              | Whether due? | Tentative Schedule date |
| 1    | Kurukshetra | TCR     | 500             | POWERGRID | GE Vernova T&D | NA  |              | NA                      | NA   | NA           | NA                      | Nov-2023   | No           | Sep-2028                |
| 2    | Fatehgarh-2 | STATCOM | ±/-600          | POWERGRID | SIEMENS        | Oct-2023  | No           | Sep-2028                | NA   | NA           | NA                      | Oct-2023   | No           | Sep-2028                |
| 3    | Bhadla-2    | STATCOM | ±/-600          | POWERGRID | SIEMENS        | Jun-2023  | No           | May-2028                | NA   | NA           | NA                      | Jun-2023   | No           | May-2028                |
| 4    | Bikaner-2   | STATCOM | ±/-300          | POWERGRID | SIEMENS        | Jul-2023  | No           | Jun-2028                | NA   | NA           | NA                      | Jul-2023   | No           | Jun-2028                |
|      |             |         |                 |           |                |   |              |                         |  |              |                         |  |              |                         |
|      |             |         |                 |           |                |   |              |                         |  |              |                         |  |              |                         |
|      |             |         |                 |           |                |   |              |                         |  |              |                         |  |              |                         |
|      |             |         |                 |           |                |   |              |                         |  |              |                         |  |              |                         |

Revised Simulation Models

Whether Revised Models Submitted?      Remarks



| Sr. No. | State     | Organisation | Name of Project    | Unit No | Total Capacity (MW) | Technical Minimum Load Status (%) achieved by the Unit as intimated in 223rd OCC            | Reason for not achieving 55% Technical Minimum |
|---------|-----------|--------------|--------------------|---------|---------------------|---|--|
| 1       | Punjab    | GPGL (GVK)   | GOINDWAL SAHIB     | 1       | 270.00              | 60%   |  |
| 2       | Punjab    | GPGL (GVK)   | GOINDWAL SAHIB     | 2       | 270.00              | 60%   |  |
| 3       | Punjab    | PSPCL        | GH TPS (LEH.MOH.)  | 1       | 210.00              | 79%   |  |
| 4       | Punjab    | PSPCL        | GH TPS (LEH.MOH.)  | 2       | 210.00              | 79%   |  |
| 5       | Punjab    | PSPCL        | GH TPS (LEH.MOH.)  | 3       | 250.00              | 68%   |  |
| 6       | Punjab    | PSPCL        | GH TPS (LEH.MOH.)  | 4       | 250.00              | 68%   |  |
| 7       | Punjab    | PSPCL        | ROPAR TPS          | 3       | 210.00              | 75%   |  |
| 8       | Punjab    | PSPCL        | ROPAR TPS          | 4       | 210.00              | 75%   |  |
| 9       | Punjab    | PSPCL        | ROPAR TPS          | 5       | 210.00              | 75%   |  |
| 10      | Punjab    | PSPCL        | ROPAR TPS          | 6       | 210.00              | 75%   |  |
| 11      | Haryana   | HPGCL        | PANIPAT TPS        | 8       | 250.00              | Information Not Available   |  |
| 12      | Haryana   | HPGCL        | PANIPAT TPS        | 7       | 250.00              | Information Not Available   |  |
| 13      | Haryana   | HPGCL        | PANIPAT TPS        | 6       | 210.00              | Information Not Available   |  |
| 14      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 1       | 135.00              | 70%   |  |
| 15      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 2       | 135.00              | 70%   |  |
| 16      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 3       | 135.00              | 70%   |  |
| 17      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 4       | 135.00              | 70%   |  |
| 18      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 5       | 135.00              | 70%   |  |
| 19      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 6       | 135.00              | 70%   |  |
| 20      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 7       | 135.00              | 70%   |  |
| 21      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 8       | 135.00              | 70%   |  |
| 22      | Rajasthan | RRVUNL       | CHHABRA TPP        | 1       | 250.00              | 72.20%  |  |
| 23      | Rajasthan | RRVUNL       | CHHABRA TPP        | 2       | 250.00              | 72.20%  |  |
| 24      | Rajasthan | RRVUNL       | CHHABRA TPP        | 3       | 250.00              | 72.20%  |  |
| 25      | Rajasthan | RRVUNL       | CHHABRA TPP        | 4       | 250.00              | 72.20%  |  |
| 26      | Rajasthan | RRVUNL       | KALISINDH TPS      | 1       | 600.00              | 66.33%  |  |
| 27      | Rajasthan | RRVUNL       | KALISINDH TPS      | 2       | 600.00              | 66.33%  |  |
| 28      | Rajasthan | RRVUNL       | SURATGARH TPS      | 1       | 250.00              | 72.13%  |  |
| 29      | Rajasthan | RRVUNL       | SURATGARH TPS      | 2       | 250.00              | 72.13%  |  |
| 30      | Rajasthan | RRVUNL       | SURATGARH TPS      | 3       | 250.00              | 72.13%  |  |
| 31      | Rajasthan | RRVUNL       | SURATGARH TPS      | 4       | 250.00              | 72.13%  |  |
| 32      | Rajasthan | RRVUNL       | SURATGARH TPS      | 5       | 250.00              | 72.13%  |  |
| 33      | Rajasthan | RRVUNL       | SURATGARH TPS      | 6       | 250.00              | 72.13%  |  |
| 34      | Rajasthan | RRVUNL       | KOTA TPS           | 1       | 110.00              | 72.26%  |  |
| 35      | Rajasthan | RRVUNL       | KOTA TPS           | 2       | 110.00              | 72.26%  |  |
| 36      | Rajasthan | RRVUNL       | KOTA TPS           | 3       | 210.00              | 72.26%  |  |
| 37      | Rajasthan | RRVUNL       | KOTA TPS           | 4       | 210.00              | 72.26%  |  |
| 38      | Rajasthan | RRVUNL       | KOTA TPS           | 5       | 210.00              | 72.26%  |  |
| 39      | Rajasthan | RRVUNL       | KOTA TPS           | 6       | 195.00              | 72.26%  |  |
| 40      | Rajasthan | RRVUNL       | KOTA TPS           | 7       | 195.00              | 72.26%  |  |
| 41      | Rajasthan | NLC          | BARSINGAR LIGNITE  | 1       | 125.00              | Information Not Available   |  |
| 41      | Rajasthan | NLC          | BARSINGAR LIGNITE  | 2       | 125.00              | Information Not Available   |  |
| 41      | Rajasthan | RRVUNL       | GIRAL TPS          | 2       | 125.00              | Under is under shutdown from 2012 and likely to be scrapped as intimated by Rajasthann SLDC |  |
| 41      | Rajasthan | RRVUNL       | GIRAL TPS          | 1       | 125.00              | Under is under shutdown from 2012 and likely to be scrapped as intimated by Rajasthann SLDC |  |



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

उत्तर क्षेत्रीय विद्युत समिति

Northern Regional Power Committee

Annexure-A.VI

सेवा में,

As per attached list (via e-mail)

**विषय: Status of MTDL achieved in intra-state thermal generating stations of Punjab Rajasthan and Haryana - reg.**

महोदय/महोदया,

This is with reference to CEA's Gazette Notification issued on dated January 30, 2023, regarding the flexible operation of coal-fired thermal generating units, therein stating that all thermal generating units must have flexible operation capabilities with a minimum power level of 55% within one year of Notification, i.e. by January 2024 and with a minimum power level of 40 % (as per the Phasing Plan specified by the authority from time to time) at the following Ramp rate:

| From | To   | Ramp Rate |
|------|------|-----------|
| 40%  | 55%  | 1%        |
| 55%  | 70%  | 2%        |
| 70%  | 100% | 3%        |

2. CEA vide communication dated 30.05.2024 (**Annexure-I**) also had intimated that 55% flexible operation regulation is effective in the country from 1<sup>st</sup> February 2024.
3. The list of intra-state thermal generating stations of Punjab, Rajasthan and Haryana that have not achieved MTDL of 55% as per information noted in 223<sup>rd</sup> OCC meeting is attached at **Annexure-II**.
4. Concerned thermal generating stations mentioned at **Annexure-II** are requested to submit the reasons for not achieving 55% Technical Minimum Level.
5. SLDC's to co-ordinate with the intra-state thermal Plant (including IPP) of their respective control area for the requisite information.
6. It is requested the requisite information may kindly be provided latest by 10<sup>th</sup> August 2025 via email at [seo-nrpc@nic.in](mailto:seo-nrpc@nic.in).

This issues with the approval of Member Secretary, NRPC.

(डी. के. मीना)

अधीक्षण अभियंता (प्रचालन)

**List of addressees:**

1. Director (Generation), PSPCL ([dir-generation@pspcl.in](mailto:dir-generation@pspcl.in))
2. Director (Technical), RRVUNL ([director.tech@rrvun.com](mailto:director.tech@rrvun.com))
3. Director (Technical), HPGCL, ([dirtech@hpgcl.org.in](mailto:dirtech@hpgcl.org.in))
4. Head of Plant, Goindwal Sahib, GVK ([Bivashchandra.Ghosh@gvk.com](mailto:Bivashchandra.Ghosh@gvk.com))
5. Head of Plant, Rajwest Power Limited, JSW ([vijay.chintala@jsw.in](mailto:vijay.chintala@jsw.in))
6. Head of Plant, Barsingsar Lignite, NLC ([plan.btps@nlcindia.in](mailto:plan.btps@nlcindia.in))
7. Chief Engineer, Punjab SLDC ([ce-sldc@pstcl.org](mailto:ce-sldc@pstcl.org))
8. Chief Engineer, Rajasthan SLDC ([ce.ld@rvpn.co.in](mailto:ce.ld@rvpn.co.in))
9. Chief Engineer, Rajasthan SLDC ([cesocomml@hvpn.org.in](mailto:cesocomml@hvpn.org.in))



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
तापीय परियोजना नवीनीकरण एवं आधुनिकीकरण प्रभाग  
Thermal Project Renovation & Modernization Division

No. 2/3/TPRM/Flex./2024/ 484-572

Date: 30.05.2024


**Subject: Minimum Technical Load of Coal based Power Plants-reg.**

**Ref:** CEA (Flexible operation of coal Based Thermal Generating Units) Regulation, 2023

The increasing penetration of renewable generation in the grid is bringing various challenges in the power sector. The inconsistency of solar & wind power has to be managed by other sources of generation in order to ensure the grid security, reliability and stability. Hence, there is a demand of flexible power in the grid which is increasing day by day with growing capacity of solar and wind power. It is a fact that coal based power plants have the capability of providing flexible power in the grid by lowering minimum technical load and the cost is also comparatively low.

In view of the above CEA has issued a gazette notification dated January 30, 2023 for compulsory flexible operation of coal fired generating units with minimum technical load (MTL) of 55% and 40%. As per the CEA gazette notification extraordinary, part III, section 4, no. 61 (CG-DL-E-31012023-243299), the coal based thermal power generating units shall have flexible operation capability with minimum power level of 55% along with ramp rate of 2% per minute between 55% to 70% load and 3% per minute above 70% load within one year of notification of the above mentioned regulations i.e. by 31<sup>st</sup> Jan 2024. CEA has also notified phasing plans on 15.12.2023 for implementation of 40% minimum technical load (MTL) along with ramp rate of 1% per minute between 40% to 55%, 2% per minute between 55% to 70% load and 3% per minute above 70% load.

**It may be noted that the 55% flexible operation regulation is effective in the country from 1<sup>st</sup> February, 2024. In this regard it is requested to kindly provide the status as per attached format at earliest.**

  
(Rohit Yadav)  
Deputy Director, TPRM

To:

1. Managing Director, Tenughat Vidyut Nigam Ltd .Hinoo, Doranda, Ranchi - 834002, Jharkhand, Fax 0651 -2507460, Email: info@tvnl.in
2. MD/CMD, JSW Centre, Bandra Kurla Complex, Near MMRDA Grounds, Bandra



- East, Mumbai 400 051 Fax: +91 22 4286 3000, Email: [contact@jsw.in](mailto:contact@jsw.in)
3. CMD, Bajaj Bhawan , Jamnalal Bajaj Marg, B-10, Sector-3, Noida-201 301, Uttar Pradesh Tel. 0120-4045100, Email: [jkbajajtrust@gmail.com](mailto:jkbajajtrust@gmail.com)
  4. The Durgapur Projects Limited , Dr B C Roy Avenue, Durgapur- 713201, West Bengal , India, Email: [admin@dpl.net.in](mailto:admin@dpl.net.in)
  5. CMD, TRN Energy Pvt. Ltd. / ACB India LTD., 7th Floor, Corporate Tower, Ambience Mall, NH.-8, Gurgaon -122002 , Ph . 0124-2719000, Fax: 0124-2719185, Email: [legal.secretarial@acbindia.com](mailto:legal.secretarial@acbindia.com)
  6. CMD, DB Power Ltd, 3rd Floor, Naman Corporate Link, Opposite Dena Bank, C-31 , Block G, Bandra Kurla Complex, Bandra (E), Mumbai- 400 051 ,Tel No +91-22-7156 6000, Fax No +91 -22-26590264, Email: [sandeep.gurav@dbpower.in](mailto:sandeep.gurav@dbpower.in)
  7. CMD, Bharat Aluminium Company Limited , Aluminium Sadan, Core - 6, Scope Office Complex, Lodi Road , New Del hi – 110003, Email: [north.aluminium@vedanta.co.in](mailto:north.aluminium@vedanta.co.in)
  8. CMD, Tata Power, Bombay House, 24, Homi Mody Street, Mumbai 400 001 , Tel: (91 22) 66658282, Fax: (91 22) 6665 8801, Email: [tatapower@tatapower.com](mailto:tatapower@tatapower.com)
  9. CMD/ MD, Essar, Essar House, Opposite Gujarat College, Ellisbridge, Ahmedabad 380 006, Gujarat , India, Tel.: +91 -79-66086666 , Fax: +91-79-66086608, Email: [powersec@essarpower.co.in](mailto:powersec@essarpower.co.in)
  10. CMD, CESC Limited , CESC House, Chowringhee Square, Kolkata - 70000 I, Phone: 2225604049, Email: [cesclimited@rp-sg.in](mailto:cesclimited@rp-sg.in)
  11. CMD, Larsen & Toubro Limited, L&T House, Ballard Estate P. O. Box: 278, Mumbai 400001. Email: [Infodesk@larsentoubro.com](mailto:Infodesk@larsentoubro.com)
  12. MD, Haldia Energy Limited, 8, Chittaranjan Avenue, Barick Bhawan, 6th Floor, Kolkata 700072. Email: [ranajit.haldiaenergy@rp-sg.in](mailto:ranajit.haldiaenergy@rp-sg.in)
  13. CMD, Lalitpur Power Generation Company Limited, 106-107, Bajaj Bhawan , 10th Floor, Jamnalal Bajaj Marg, 226 Nariman Point, Mumbai -400021 ,Tel. +91-22-22049056 /58, Fax: +91 -22-22048681, Email: [cs@lpgcl.com](mailto:cs@lpgcl.com)
  14. Chairman, Reliance Centre, Santacruz, Near Prabhat Colony, Off. Western Express Highway, Santa Cruz (East), Mumbai 400 055 Tel: +91 22 3303 1000 Fax: +91 22 3303 3662, Email: [reliancepower.investors@relianceada.com](mailto:reliancepower.investors@relianceada.com)
  15. CMD, Lanco Anpara Power Limited , Plot No. 397, Phase-III , Udyog Vihar, Gurgaon-122016, New Delhi Region - India, Phone +91 -124 - 4741 000, Fax +91 -124 - 4741 024, Email: [info.power@lancogroup.com](mailto:info.power@lancogroup.com)
  16. MD, Talwandi Sabo Power Limited, Site Cum Regd. Office:, Village Banawala , Mansa - Talwandi Sabo Road, Distt. Mansa, Punjab - 15 1302 INDIA, Tel: +91 -1659-248000 Telefax: 01659-248083, Email: [tspl.commercial@vedanta.co.in](mailto:tspl.commercial@vedanta.co.in)
  17. CMD, GVK Power, Paigah House, 156-159, SP Road, Secunderabad 500003, Telangana, India., Telephone +91 -40-27902663/4, Email: [pvr@s@gvk.com](mailto:pvr@s@gvk.com)
  18. CMD, Prayagraj Power Generation Co. Ltd, Khan Semra, Uttar Pradesh 212106, Email: [ppgcl@ppgcl.co.in](mailto:ppgcl@ppgcl.co.in)
  19. Chairman, CSPDCL, Energy Info Tech Centre, Block No. 8, CS Power Companies Campus ,Daganiya, Raipur (CG), Pin – 492013, Email:
  20. Sterlite power Transmission Limited , Director, F-1 Mira Corporate Suits, 1 &2 floor, Mathura Road , Ishwar Nagar New Delhi, Delhi, New Delhi, Delhi 110065 Email: [amitabh.prasad@sterlite.com](mailto:amitabh.prasad@sterlite.com)
  21. Director, Adani Power Limited, Achalraj, Opp Mayor Bungalow, Law Garden, Ahmedabad-380006 ,Gujarat, India.,Tel:+91 79 2555 7555,Fax:+91 79 25557177 Email: [deepak.pandya@adani.com](mailto:deepak.pandya@adani.com)
  22. Director, Jaiprakash Power Ventures Limited, Complex of Jaypee Nigrie Super Thermal Power Plant, Tehsil Sarai, Nigrie, Singrauli , Madhya Pradesh - 486669 , India, Phone No: (7801 ) 286021 - 39, Fax: (780 I ) 286020, Email: [mm.sibbal@jalindia.co.in](mailto:mm.sibbal@jalindia.co.in)
  23. CMD, NLC India Ltd., First Floor, No.8, Mayor Sathyamurthy Road, FSD, Egmore Complex of Food Corporation of India, Chetpet, Chennai-60003 I ,Tamil Nadu, India. Ph No. 044-28364613,614,615,616,617 Fax. 044-28364619 Email: [cmd@nlcindia.com](mailto:cmd@nlcindia.com)



24. CMD, The Singareni Collieries Company Ltd., Kothagudem Collieries, Bhadradi Kothagudem Dist , Telangana State PIN: 507101. Ph No 08744-242301 /02/03/04 Fax: 08744-242305, Email: dp@scclmines.com
25. CMD, Hinduja National Power Corporation Limited , Hinduja House, 171 , Dr. Annie Besant Road,, Worli , Mumbai - 40001 8, India, Phone : +91 -22-24960707, Fax : +91 -22-24960747 Email: sunil.hnp@hindujagroup.com
26. CMD, R.K.M Powergen Private Limited , 14/45 Dr.Giriappa Road , T.Nagar,, Chennai - 600017, Tamil Nadu, India, Telephone : +91 -44-66291000, Email: m.malathi@rkmpowergen.in
27. Chairman, jhabua Power, Avantha Power & Infrastructure Limited, 6th floor, Vatika City Point, M.G. Road -Gurgaon - 122002, India, Tel: + (91 124) 439 2000, Fax: + (91 124) 437 6496, Email: communications@avanthapower.com
28. Chairman , KSK Energy Ventures Limited, 8-2-293/82/A/43 I/A, Road No:22 , Jubilee Hills, Hyderabad, Telangana 500033, India , Tel: 04023559922 /23/24/25 Fax: 04023559930, Email: info@ksk.co.in
29. Dy. General Manager, Mahatma Gandhi TPS, Jhajjar Power Ltd . (CLP India Co.), Tehsil Matenhail , Distt Jhajjar-124142, Email: rajiv.mishra @clpindia.in
30. Chairman, Adhunik Industries Ltd., Lansdowne Towers, 2/1 A, Sarat Bose Road Kolkata 700020, West Bengal , INDIA Tel: 033 3051 7100 Fax 033 22890285 Email: bharatarawal@adhunikgroup.co.in
31. Chairman , RattanIndia Power Limited, 5th Floor, Tower-8, World mark I , Aerocity,, New Delhi - 110037 Email: powersectt@rattanindia.com
32. CMD/MD, Taqa Neyveli Power Company Pvt Ltd, Uthangal, Tamil Nadu 607804, Email: raghu.nathan@taqaglobal.com
33. CMD/MD, Coastal Energy Pvt. Ltd , 5th Floor, Buhari Towers,4, Moores Road, Chennai - 600 006, INDIA Tel: +91 44 4397 4397. Fax: +91 44 2826 8316. Email: nadeem.ma@coastalenergen.com
34. MD/CMD, CLP India Private Limited, 7th Floor, FULCRUM , Sahar Road, Andheri (East), Mumbai - 400 099, Tel : +91 -22-6758 8888, Fax: +91 -22-6758 881 1/8833
35. MD/CMD, Dhariwal Infrastructure Limited., C-6, Tadali Growth Centre, MIDC Tadali, District: Chandrapur, Maharashtra - 442406, India., Phone:07172 645911/645912/645913, FAX : 07172 237992,Email : dhariwalinfrastructure@rp-sg.in
36. MD/CMD,Adhunik Group,14, N. S. Road, 2nd Floor, Kolkata 700001, West Bengal, INDIA
37. MD/CMD, Essar, Essar House, 11, Keshavrao Khadye Marg, Mahalaxmi, Mumbai 400034, Maharashtra, India Tel.: +91-22- 66601100Fax: +91-22-66601809
38. MD/CMD, Jindal Power Limited, Jindal Centre, 12, Bhikaiji Cama Place, New Delhi 110 066, India, Email: info@jindalpower.com
39. MD/CMD , Gujarat Mineral Development Corporation Limited , 132 feet - Ring Road, Vastrapur, Ahmedabad - 380052 Phone : 079-27913501, 27913200 Fax : 079-27913038 Email : contact@gmdcltd.com
40. MD/CMD, Gujarat Industries Power Company Ltd. , P.O. Petrochemical - 391346 Dist.: Vadodara, Gujarat - India Phone: +91-265-2232768 Fax: +91-265-2230029 Email: genbaroda@gipcl.com
41. MD/CMD Torrent Power Generation Ltd, Sola Road, Naranpura,Ahmedabad - 380 013 Ph +91 79 22551912 / 66551912 Email: connect.ahd@torrentpower.com
42. MD/CMD TAQA Neyveli Power Company Pvt. Ltd, 79 Kasturi Avenue, MRC Nagar, R A Puram, Chennai Pin:600028 India Tel: +91 44 4209 7811 Fax: +91 44 4209 7812
43. MD/CMD, M/S SKS ISPAT AND POWER LTD., B-501, Elegant Business Park, Andheri Kurla Road, J.B.Nagar, Andheri - (E), Mumbai - 400 059 Telephone: +91-22-3080 7000 Fax: +91-22-3080 7070 / 7080 E-Mail: corporateoffice@sksispat.com
44. MD/CMD , Sembcorp Energy India Limited, 5th floor, Tower C, Building No. 8, DLF Cybercity, Gurgaon 122002 Haryana, India Ph: (91) 12 4389 6700 Email: cs.india@sembcorp.com
45. MD/CMD, Hindustan Power projects Private Ltd., 239, Okhla Industrial Estate, Phase-



- III New Delhi-110020 Tel: +91-11-47624100, Fax: +91-11-47624229 Email: info.hpppl@hpppl.in
46. MD/CMD, JINDAL INDIA THERMAL POWER LIMITED , Plot No 12, Sector B-1, Local Shopping Complex , Vasant Kunj NEW DELHI 110 070 Tel: 011-26139256-65 Fax: 011-26125739, E-Mail: jitpl@jindalgroup.com
47. MD/CMD, Ind-Barath Power Infra Limited, Hyderabad, Plot No. 30-A, Road No. 1, Film Nagar, Jubilee Hills, Hyderabad - 500 096 , Andhra Pradesh, INDIA. Phone: +91-40-23553459 Fax: +91 40 23607522 Email: hyderabad@ibpil.com
48. MD/CMD, GMR Enterprises Private Limited, Third Floor, Old No.248/New No.114, Royapettah High Road, Royapettah, Chennai - 600 014 Email: Yogindu.Khajuria@gmrgroup.in
49. CMD, India Power Corporation Ltd., Plot No.X, 1, 2 & 3, Block – EP, Sector-V, Salt Lake City, Kolkata – 700091, Email: pr@indiapower.com, Fax: +91 33 2357 2452
50. Chairman/CMD, MAHAGENCO, Maharashtra State Power Generation Co. Ltd., Prakashgad, Plot No. G-9, Bandra (East) Mumbai-400 051
51. CMD/MD, East Coast Energy Pvt. Ltd., H. No. 7-1-50, Flat No. 203, Myneni Apartments, Dharam Karam Road, Ameerpet, Hyderabad TG 500016 Email: irp.eastcoast@bdo.in
52. MD/CMD, Lanco Amarkantak Pvt. Ltd., 397, Phase II, Udyog Vihar, Sector 20, Gurugram, Haryana 122008
53. MD/CMD, Vandana Vidyut Ltd., Vandana Bhawan M.G.Road, Raipur, Chhattisgarh 492001 Email: codinthree@rediffmail.com
54. MD/CMD, Visa Power Ltd., 8/10 Alipore Road, Kolkata, West Bengal 700027, Email ID: secretarial@visa-group.com
55. MD/CMD, Corporate Power Ltd., FE-83, SECTOR-III Salt Lake City, Ground Floor, Kolkata, West Bengal- 700106, Email : mcainfo@abhijeet.in
56. MD/CMD, Jinbhuvish Power Generation Pvt. Ltd., 101, E High Ct Rd, New Ramdaspath, Ramdaspath, Nagpur, Maharashtra 440010, Email: companylaw.info@gmail.com
57. MD/CMD, Shirpur Power Pvt. Ltd., 903, Shilp Building, Opposite Navrangpura Telephone Exchange, Ahmedabad, Gujarat- 380009, India, Email ID: nikunj.shah@shirpurpower.in
58. MD/CMD, D.B. Power (MP) Ltd., Office Block 1A,5th Floor, Corporate Block, DB City- Park, DB City, Arera Hills Opposite MP Nagar, Zone -I Bhopal, Madhya Pradesh- 462016, Email : sandeep.gurav@dbpower.in
59. MD/CMD, Ind Barath TPP Odisha, Ind Barath Energy Utkal Ltd., H NO. 8-5-210/43, Plot No 44, Shiva Enclave old Bowenpally, Secunderabad, Rangareddi Telangana 500011, Email : brs@ibpil.com
60. MD/CMD, KVK Nilanchal, Plot No. 484/A, Road No. 36, Jubilee Hills, Hyderabad- 500033, Email: srinivasaraoa@kvkenergy.com
61. MD/CMD, LBP Ltd., Lanco Babandh Thermal Power Plant, Plot # 4, Software Units Layout, HITEC City, Madhapur Hyderabad, Telangana 500081, Email: dheeraj.kumarmishra@lancogroup.com
62. MD/CMD, Monnet Power Company Ltd. (MPCL), Malibrahmani TPP, Monnet House, 11, Masjid Moth, Greater Kailash Part-II, New Delhi- 110048
63. MD/CMD, IBPIL- Tuticorin TPP (Ind- Barath), Plot No. 30-A, Road No. 1, Film Nagar, Jubilee Hills, Hyderabad - 500 096, Email: hyderabad@ibpil.com , chennai@ibpil.com
64. MD/CMD, SEPC Power Company Ltd., Tuticorin TPP Stage-IV, MEIL House, First Floor No 395 (Old No 280-A) Anna Salai, Teynampet, Chennai, Tamil Nadu 600018, Email ID: sepc.ppl@meilteam.in
65. MD/CMD, India Power Corporation (Haldia) Limited, Plot No. X1- 2 & 3, Block-EP, Sector - V, Salt Lake City, Kolkata - 700 091.
66. MD/CMD, Lanco Vidharbha Power Pvt. Ltd., 11th Milestone, Belgaon-Mandwa Road, PO Mandwa, Dist Wardha, Maharashtra -422001 Phone +91-715-2283715

67. MD/CMD, BLA Power Pvt. Ltd., 84 Maker Chambers III, Nariman Point, Mumbai, Maharashtra- 400021 Email: compsec@bla.co.in
68. MD/CMD, BRBCL (Bharatiya Rail Bijlee Company Ltd.), Bihar State Power Generation Company Ltd., 5th Floor, Vidyut Bhawan, Bailey Road, Patna-800001, Email ID : gmhrbspvgl@gmail.com
69. MD/CMD, Corporate Power Ltd., FE-83, Sector-III Salt Lake City, Ground Floor, Kolkata, West Bengal- 700106, Email ID : mcainfo@abhijeet.in
70. MD/CMD, Dishergarh Power Supply Company Ltd. (DPSCL), Plot No.- X-1, 2 & 3 Block EP Sector-V, Salt Lake, Kolkata 700091 Email: rpower.mcafiling@relianceada.com
71. MD/CMD, Essar Power Ltd., LGF, A-20, Kailash Colony, Hotel Conclave Complex, Block A, Kailash Colony, Greater Kailash, New Delhi, Delhi 110048 Email: Shailendra.saha@essarpower.co.in
72. CMD/MD, NTPC SAIL Power Company Ltd. (NSPCL), NBCC Tower, 15, 4th Floor, Bhikaji Cama Place, New Delhi
73. MD/CMD, Shirpur Power Pvt. Ltd., 903, Shilp Building, Opposite Navrangpura Telephone Exchange, Ahmedabad, Gujarat- 380009, India, Email ID: nikunj.shah@shirpurpower.in
74. Chairman, DVC, DVC Head Quarters, DVC Towers, VIP Rod, Kolkata-700054 Email id : chairman@dvc.gov.in
75. CMD/MD, Global Energy Pvt. Ltd. (GEPL), 2, Panchsheel Community Centre, New Delhi-110017 Email: gyansheel@globalenergy.net.in
76. Bishagarh, Email address: cmd.tsecl@rediffmail.com
77. NTEC , NTPC Tamil Nadu Energy Company Ltd. NTPC Tamil Nadu Energy Company Limited , Vallur Thermal Power Project, Vellivoyal chavadi, Ponneri Taluk, Thiruvallur, Tamil Nadu - 600 103
78. Vidarbha Industries Ltd. Subs of reliance Power, Email : rpower.mcafiling@relianceada.com
79. Korba West power Company Ltd., Avantha Power, Email: communications@avanthapower.com
80. MD/CMD, ITPCL, IL&FS Tamil Nadu Power Company Limited 4th Floor, KPR Tower, Old No. 21, New No. 2, 1st Street, Subba Rao Avenue, College Road, Chennai - 600 006, Email: [info@itpclindia.com](mailto:info@itpclindia.com)
81. Deputy General Manager (Electrical) Meenakshi Energy Pvt. Ltd. NSL ICON, Plot No. 1, 2, 3, 4 H-No-8-2-684/2/A, 2nd floor, Road No. 12, Banjara hills, Hyderabad-500034 Tel: 040-33872309/ 344/ 345 Fax: 040-33872323/ 23351530 Email: mepl@meenakshienergy.com
82. GM (O&M) Simhapuri Energy Pvt Ltd Madhucon Greenlands 6-3-866/2, 3rd Floor Begumpet, Hyderabad-500016 (AP) (T)- 040- 23412195/96, 23412297 (F)- 040 23412197, 23412298 , 08624- 213298/99 Email: [info@simhapurienergy.com](mailto:info@simhapurienergy.com) [sme@simhapurienergy.com](mailto:sme@simhapurienergy.com)

Copy for information to:

1. Secretary (Power), MOP
2. Chairman, CEA
3. Member (Thermal), CEA
4. Member Secretary (NRPC/ERPC/SERPC/WRPC)



## FORMAT

| S. No | Details   | Unit 1           | Unit2 | Unit3 | ----- |
|-------|---|------------------|-------|-------|-------|
| 1     | Name of Utility   |                  |       |       |       |
| 2     | Plant Name and Address  |                  |       |       |       |
| 3     | Capacity, MW  |                  |       |       |       |
| 4     | Date of Commissioning   |                  |       |       |       |
| 5     | Type of Unit: Supercritical/Subcritical/....  |                  |       |       |       |
| 6     | Net Heat rate<br>(i) Design Coal GCV<br>(ii) Actual Coal GCV  |                  |       |       |       |
| 7     | Maximum Ramp Rate Up<br>(last 2 years)  | Between 55%-70%  |       |       |       |
|       |   | Between 70%-100% |       |       |       |
| 8     | Maximum Ramp Rate Down<br>(last 2 years)  | Between 100%-70% |       |       |       |
|       |   | Between 70%-55%  |       |       |       |
| 9     | Whether 55% Minimum load Achieved (YES/NO)<br>i. If YES, specify the duration and time<br>i. If NO, specify the reason for the same and details of measures identified for implementation to achieve the same |                  |       |       |       |
| 10    | Whether desired ramp rates of 3% (100%-70%) and 2% (70%-55%) Achieved (YES/NO)<br><br>If NO, specify the reason for the same and details of measures identified for implementation to achieve the same        |                  |       |       |       |
| 11    | Tentative date of unit readiness for Sustainable running at 55% MTL with requisite ramp rates   |                  |       |       |       |
| 12    | Any other details   |                  |       |       |       |

| Sr. No. | State     | Organisation | Name of Project    | Unit No | Total Capacity (MW) | Technical Minimum Load Status (%) achieved by the Unit as intimated in 223rd OCC            | Reason for not achieving 55% Technical Minimum |
|---------|-----------|--------------|--------------------|---------|---------------------|---|--|
| 1       | Punjab    | GPGL (GVK)   | GOINDWAL SAHIB     | 1       | 270.00              | 60%   |  |
| 2       | Punjab    | GPGL (GVK)   | GOINDWAL SAHIB     | 2       | 270.00              | 60%   |  |
| 3       | Punjab    | PSPCL        | GH TPS (LEH.MOH.)  | 1       | 210.00              | 79%   |  |
| 4       | Punjab    | PSPCL        | GH TPS (LEH.MOH.)  | 2       | 210.00              | 79%   |  |
| 5       | Punjab    | PSPCL        | GH TPS (LEH.MOH.)  | 3       | 250.00              | 68%   |  |
| 6       | Punjab    | PSPCL        | GH TPS (LEH.MOH.)  | 4       | 250.00              | 68%   |  |
| 7       | Punjab    | PSPCL        | ROPAR TPS          | 3       | 210.00              | 75%   |  |
| 8       | Punjab    | PSPCL        | ROPAR TPS          | 4       | 210.00              | 75%   |  |
| 9       | Punjab    | PSPCL        | ROPAR TPS          | 5       | 210.00              | 75%   |  |
| 10      | Punjab    | PSPCL        | ROPAR TPS          | 6       | 210.00              | 75%   |  |
| 11      | Haryana   | HPGCL        | PANIPAT TPS        | 8       | 250.00              | Information Not Available   |  |
| 12      | Haryana   | HPGCL        | PANIPAT TPS        | 7       | 250.00              | Information Not Available   |  |
| 13      | Haryana   | HPGCL        | PANIPAT TPS        | 6       | 210.00              | Information Not Available   |  |
| 14      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 1       | 135.00              | 70%   |  |
| 15      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 2       | 135.00              | 70%   |  |
| 16      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 3       | 135.00              | 70%   |  |
| 17      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 4       | 135.00              | 70%   |  |
| 18      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 5       | 135.00              | 70%   |  |
| 19      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 6       | 135.00              | 70%   |  |
| 20      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 7       | 135.00              | 70%   |  |
| 21      | Rajasthan | RWPL (JSW)   | JALIPA KAPURDI TPP | 8       | 135.00              | 70%   |  |
| 22      | Rajasthan | RRVUNL       | CHHABRA TPP        | 1       | 250.00              | 72.20%  |  |
| 23      | Rajasthan | RRVUNL       | CHHABRA TPP        | 2       | 250.00              | 72.20%  |  |
| 24      | Rajasthan | RRVUNL       | CHHABRA TPP        | 3       | 250.00              | 72.20%  |  |
| 25      | Rajasthan | RRVUNL       | CHHABRA TPP        | 4       | 250.00              | 72.20%  |  |
| 26      | Rajasthan | RRVUNL       | KALISINDH TPS      | 1       | 600.00              | 66.33%  |  |
| 27      | Rajasthan | RRVUNL       | KALISINDH TPS      | 2       | 600.00              | 66.33%  |  |
| 28      | Rajasthan | RRVUNL       | SURATGARH TPS      | 1       | 250.00              | 72.13%  |  |
| 29      | Rajasthan | RRVUNL       | SURATGARH TPS      | 2       | 250.00              | 72.13%  |  |
| 30      | Rajasthan | RRVUNL       | SURATGARH TPS      | 3       | 250.00              | 72.13%  |  |
| 31      | Rajasthan | RRVUNL       | SURATGARH TPS      | 4       | 250.00              | 72.13%  |  |
| 32      | Rajasthan | RRVUNL       | SURATGARH TPS      | 5       | 250.00              | 72.13%  |  |
| 33      | Rajasthan | RRVUNL       | SURATGARH TPS      | 6       | 250.00              | 72.13%  |  |
| 34      | Rajasthan | RRVUNL       | KOTA TPS           | 1       | 110.00              | 72.26%  |  |
| 35      | Rajasthan | RRVUNL       | KOTA TPS           | 2       | 110.00              | 72.26%  |  |
| 36      | Rajasthan | RRVUNL       | KOTA TPS           | 3       | 210.00              | 72.26%  |  |
| 37      | Rajasthan | RRVUNL       | KOTA TPS           | 4       | 210.00              | 72.26%  |  |
| 38      | Rajasthan | RRVUNL       | KOTA TPS           | 5       | 210.00              | 72.26%  |  |
| 39      | Rajasthan | RRVUNL       | KOTA TPS           | 6       | 195.00              | 72.26%  |  |
| 40      | Rajasthan | RRVUNL       | KOTA TPS           | 7       | 195.00              | 72.26%  |  |
| 41      | Rajasthan | NLC          | BARSINGAR LIGNITE  | 1       | 125.00              | Information Not Available   |  |
| 41      | Rajasthan | NLC          | BARSINGAR LIGNITE  | 2       | 125.00              | Information Not Available   |  |
| 41      | Rajasthan | RRVUNL       | GIRAL TPS          | 2       | 125.00              | Under is under shutdown from 2012 and likely to be scrapped as intimated by Rajasthann SLDC |  |
| 41      | Rajasthan | RRVUNL       | GIRAL TPS          | 1       | 125.00              | Under is under shutdown from 2012 and likely to be scrapped as intimated by Rajasthann SLDC |  |



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

उत्तर क्षेत्रीय विद्युत समिति

Northern Regional Power Committee


**विषय: Unit wise Outage Maintenance schedule for the year 2026-27-reg.**

Central Electricity Authority vide its mail dated 10.07.2025 has sought information regarding the Unit Wise Planned Maintenance schedule for the year 2026-27. In this regard, please find enclosed herewith the data formats and the inputs desired:

1. Region-wise Unit Wise Planned Maintenance schedule for the year 2026-27 as per the format enclosed at **Annexure-I**.

Respective SLDC's of Northern Region are requested to co-ordinate with IPPs and State Generating Companies within their state and submit the data as per **Annexure-I**. Central Generating utilities are also requested to submit the abovementioned data as per Annexure-I.

The above information may kindly be submitted in the prescribed format by email to [seo-nrpc@nic.in](mailto:seo-nrpc@nic.in) by 31<sup>st</sup> August 2025.

  
(डी.के. मीना) 22/7/25-

अधीक्षण अभियंता (प्रचालन)

सेवा में,

1. All Chief Engineer SLDC's of Northern Region States and UT's
2. Central Generating Stations of Northern Region

Format for unit wise outage schedule of generating stations

Annexure-A.VII

|              |          |              |        |       |                       | Outage 1 |           |         |               | Outage 2 of same unit |           |         |               | Outage 3 of same unit |           |         |                  | Outage 4 of same unit |           |         |                  | Outage 5 of same unit |           |         |               |         |
|--------------|----------|--------------|--------|-------|-----------------------|----------|-----------|---------|---------------|-----------------------|-----------|---------|---------------|-----------------------|-----------|---------|------------------|-----------------------|-----------|---------|------------------|-----------------------|-----------|---------|---------------|---------|
| STATION NAME | UNIT NO. | STATION TYPE | REGION | STATE | ORGANIZATION/ UTILITY | CAPACITY | From_Date | To_Date | Outage_Reason | Remarks               | From_Date | To_Date | Outage_Reason | Remarks               | From_Date | To_Date | Outage_Reason_ID | Remarks               | From_Date | To_Date | Outage_Reason_ID | Remarks               | From_Date | To_Date | Outage_Reason | Remarks |
|              |          |              |        |       |                       |          |           |         |               |                       |           |         |               |                       |           |         |                  |                       |           |         |                  |                       |           |         |               |         |
|              |          |              |        |       |                       |          |           |         |               |                       |           |         |               |                       |           |         |                  |                       |           |         |                  |                       |           |         |               |         |

Note: Please don't leave any cell blank in columns of STATION NAME,UNIT NO.,STATION TYPE,REGION,STATE,UTILITY.

**Electricity Test & Commissioning Circle,Lucknow**  
**Priority wise opening of feeders connected on SPS at 400KV Sub - stations Bareilly**

| Name of S/S        | T/F Rating   | Tripping Logic Stage   |       | Tripping Logic Stage   |         |                                      |                               |
|--------------------|--------------|------------------------|-------|------------------------|---------|--------------------------------------|-------------------------------|
|                    |              | % Setting              | Time  | %Setting               | Time    | Priority of Feeders for load cut off | Average Load in MW Load in MW |
| 400KV S/S Bareilly | 315MVA - I   | 100-110<br>(454-500 A) | 5 Sec | Above 110%<br>(>500 A) | 1500 ms | 1-220KV Amaniya DC                   | 32                            |
|                    |              |                        |       |                        |         | 2-20KV Faridpur                      | 20                            |
|                    |              |                        |       |                        |         | 3-20KV Pilibhit DC                   | 130                           |
|                    | 315MVA - II  | 100-110<br>(454-500 A) | 5 Sec | Above 110%<br>(>500 A) | 1500 ms | 4- 220 KV Pantnagar                  | 118                           |
|                    |              |                        |       |                        |         | 5- 220 KV CB Ganj DC                 | 84                            |
|                    | 315MVA - III | 100-110<br>(454-500 A) | 5 Sec | Above 110%<br>(>500 A) | 1500 ms | 6- 220 KV Dohna DC                   | 70                            |

**Note:** Delay as mentioned in the above Tripping logics I& II is for initiation of tripping command. After initiation of tripping command, feeders will continue to trip as per priority without any time delay untill loading on ICT recahes below 100%.

| Overcurrent setting of ICTs at 400KV Sub - stations Bareilly |              |                       |
|--|--------------|-----------------------|
| Fault current with respect to full load (FL) current         | Current in A | OC trip time (in Sec) |
| 100% of FL   | -            | -                     |
| 105% of FL   | -            | -                     |
| 110% of FL pickup (500A)                                     | 501          | 1051                  |
| 120% of FL   | 545          | 24                    |
| 130% of FL   | 590          | 7.983                 |
| 140% of FL   | 635          | 6.22                  |

| Logic for proposed SPS (System Protection Scheme) for ICTs at 400kV Substation Panki |                |                           |            |   |                             |            |   |
|--|----------------|---------------------------|------------|---|-----------------------------|------------|---|
| Name of Substation   | ICT Rating     | Tripping Logic-I          |            |   | Tripping Logic-II           |            |   |
|  |                | % Setting                 | Time Delay | Priority of feeder for load cut off   | % Setting                   | Time Delay | Priority of feeder for load cut off   |
| 400kV Substation Panki   | 315MVA ICT- I  | 100-110% of rated current | 5 sec      | 1. 220kV Chibramau<br>2. 220kV RPH<br>3. 220kV Bithoor<br>4. 220kV Raniya<br>5. 132kV Dibiyapur<br>6. 132kV Dadanagar<br>7. 132kV Azad Nagar Ckt I & II | Above 110% of rated current | 1500 msec  | 1. 220kV Chibramau<br>2. 220kV RPH<br>3. 220kV Bithoor<br>4. 220kV Raniya<br>5. 132kV Dibiyapur<br>6. 132kV Dadanagar<br>7. 132kV Azad Nagar Ckt I & II |
|  | 500MVA ICT- II | 100-110% of rated current | 5 sec      | 1. 220kV Chibramau<br>2. 220kV RPH<br>3. 220kV Bithoor<br>4. 220kV Raniya<br>5. 132kV Dibiyapur<br>6. 132kV Dadanagar<br>7. 132kV Azad Nagar Ckt I & II | Above 110% of rated current | 1500 msec  | 1. 220kV Chibramau<br>2. 220kV RPH<br>3. 220kV Bithoor<br>4. 220kV Raniya<br>5. 132kV Dibiyapur<br>6. 132kV Dadanagar<br>7. 132kV Azad Nagar Ckt I & II |


**Note:** Delay as mentioned in the above Tripping logics I& II is for initiation of tripping command. After initiation of tripping command, feeders will continue to trip as per priority without any time delay untill loading on ICT recahes below 100%.

| Overcurrent setting of ICTs at Panki                 |                       |
|--|-----------------------|
| Fault current with respect to full load (FL) current | OC trip time (in Sec) |
| 100% of FL   | -                     |
| 105% of FL   | -                     |
| 110% of FL   | Pickup                |
| 120% of FL   | 11.498                |
| 130% of FL   | 7.983                 |
| 140% of FL   | 6.22                  |

# Study on Varanasi Islanding Scheme

Annexure-A.XI

**Brief Description** - Varanasi Islanding Scheme is proposed using generation from Anpara BTPS (2x500MW) and essential load of Varanasi Region.



- Following cases of Load- Generation scenario has been considered for steady state study:-

| Sl. No. | Case   | Area    | Number of Machine | Generation | Load                     |
|---------|--------|---------|-------------------|------------|--------------------------|
| 1       | Case-1 | A and B | 2                 | 874 MW     | 806 MW (Summer Peak)     |
| 2       | Case-2 | A and B | 2                 | 442 MW     | 435 MW (Winter Peak)     |
| 3       | Case-3 | A       | 1                 | 452 MW     | 440 MW ( Summer Peak )   |
| 4       | Case-4 | A       | 1                 | 310 MW     | 305 MW (Summer Off Peak) |
| 5       | Case-5 | A and B | 1                 | 409 MW     | 402 MW (Winter Peak)     |
| 6       | Case-6 | A and B | 1                 | 326 MW     | 322 MW (Winter Off Peak) |

- In case number 1, 2, 5 and 6 larger Island (Considering Both A and B) is considered. List of the substations are as follows ( Refer to Annexure-I)

| S.no | Name of Substation             | S.no | Name of Substation    |
|------|--------------------------------|------|-----------------------|
| 1    | 220kV Gajokhar (Only Bus Used) | 10   | 132kV Raja Ka Talab   |
| 2    | 220 kV Bhelupur                | 11   | 132kV Sarnath         |
| 3    | 220kV Raja Ka Talab            | 12   | 132kV Manduadih       |
| 4    | 220kV Virapatti TSS            | 13   | 132kV Kaithi          |
| 5    | 220kV Sahupuri                 | 14   | 132kV Aurihar TSS     |
| 6    | 132KV DLW (Only Bus Used)      | 15   | 132 KV Varanasi Cantt |
| 7    | 132 KV BHU                     | 16   | 132kV Bina            |
| 8    | 132kV Kursato                  | 17   | 132 kV Alaipur        |
| 9    | 132kV Narainpur                | 18   | 132kV Leedopur        |

- In case number 3 and 4 smaller Island (Considering A only) is considered. List of the substations are as follows ( Refer to Annexure-II)

| S.no | Name of Substation             | S.no | Name of Substation    |
|------|--------------------------------|------|-----------------------|
| 1    | 220kV Gajokhar (Only Bus used) | 6    | 132kV Manduadih       |
| 2    | 220kV Virapatti TSS            | 7    | 132 KV Varanasi Cantt |
| 3    | 132KV DLW (Only Bus Used)      | 8    | 132kV Aurihar TSS     |
| 4    | 132 KV BHU                     | 9    | 132kV Bina            |
| 5    | 132kV Leedopur                 |      |                       |



## 1. Case 1

- Actual Ex- bus Generation =874 (2x437)MW
- Actual load met =806MW
- In this scenario of Load-Generation, low voltages are observed at many substations.
- Voltage profile of various buses of island is as follows-

| Bus Number | Bus Name     | Base kV | Voltage (pu) |  | Bus Number | Bus Name     | Base kV | Voltage (pu) |
|------------|--------------|---------|--------------|--|------------|--------------|---------|--------------|
| 151055     | SAHUPR1      | 132     | 0.6462       |  | 151664     | BHU          | 132     | 0.6277       |
| 151056     | SARNATH1     | 132     | 0.6905       |  | 151793     | SAHUPURI BII | 132     | 0.6268       |
| 151069     | ANPARA       | 132     | 1.0172       |  | 151884     | ALAIPUR      | 132     | 0.6547       |
| 151113     | CHUNNAR      | 132     | 0.6447       |  | 152065     | SAHUPU_N     | 220     | 0.6423       |
| 151136     | GAJOKHAR     | 132     | 0.6923       |  | 152066     | SARNATH2     | 220     | 0.7957       |
| 151170     | BINA         | 132     | 1.0111       |  | 152078     | GAJOKHA      | 220     | 0.7635       |
| 151173     | RAJAKATALAB  | 132     | 0.6422       |  | 152085     | BHELUPUR     | 220     | 0.6381       |
| 151212     | VARANSI CANT | 132     | 0.6397       |  | 152169     | BHADAURA     | 220     | 0.7122       |
| 151222     | LEEDOPUR     | 132     | 0.6703       |  | 152173     | RAJA KATALAB | 220     | 0.6432       |
| 151267     | MANDUADI     | 132     | 0.6316       |  | 152215     | SAHUPURI BII | 220     | 0.6423       |
| 151301     | NARAINPU     | 132     | 0.6433       |  | 152236     | BHADOHI      | 220     | 0.6433       |
| 151436     | KURSATO      | 132     | 0.6422       |  | 152245     | SAHUPURI_4_2 | 220     | 0.6421       |
| 151534     | AURIHAR_TSS  | 132     | 0.6835       |  | 152279     | VIRAPATTI    | 220     | 0.7908       |
| 151600     | RAJAKATALB_2 | 132     | 0.6422       |  | 154014     | ANPARA4      | 400     | 1.0300       |
| 151661     | KAITHI       | 132     | 0.6874       |  | 154019     | SARNATH4     | 400     | 0.8671       |
| 151662     | DLW          | 132     | 0.6359       |  |            |              |         |              |

- List of lines under overloading

| Sl. No. | Name of Transmission line         | % Overloading |
|---------|-----------------------------------|---------------|
| 1.      | 132kV Varanasi Cantt-DLW line     | 135.7         |
| 2.      | 132kV Maduadih-DLW line           | 112.9         |
| 3.      | 132kV Sarnath-Leedopur line       | 114.9         |
| 4.      | 132kV Sarnath-Leedopur line       | 114.9         |
| 5.      | 132kV Sarnath-Sanath (220) line   | 116.3         |
| 6.      | 132kV Gajokhar-Kursato line       | 179.7         |
| 7.      | 132kV Leedopur –Alaipur line      | 109.4         |
| 8.      | 132kV Kursato –Raja ka Talab line | 112.9         |

## 2. Case 2

- Actual Ex- bus Generation =442 (2x221)MW
- Actual load met =435MW
- **Steady state generation of units is less than technical minimum**
- No under voltage and over loading is observed.
- Voltage profile of various buses of island is as follows-

| Bus Number | Bus Name     | Base kV | Voltage (pu) |  | Bus Number | Bus Name     | Base kV | Voltage (pu) |
|------------|--------------|---------|--------------|--|------------|--------------|---------|--------------|
| 151055     | SAHUPR1      | 132     | 0.9889       |  | 151664     | BHU          | 132     | 0.9775       |
| 151056     | SARNATH1     | 132     | 0.9913       |  | 151793     | SAHUPURI BII | 132     | 0.9774       |
| 151069     | ANPARA       | 132     | 1.0219       |  | 151884     | ALAIPUR      | 132     | 0.9851       |
| 151113     | CHUNNAR      | 132     | 0.9918       |  | 152065     | SAHUPU_N     | 220     | 0.9878       |
| 151136     | GAJOKHAR     | 132     | 0.9904       |  | 152066     | SARNATH2     | 220     | 1.0022       |
| 151170     | BINA         | 132     | 1.0173       |  | 152078     | GAJOKHA      | 220     | 0.9975       |
| 151173     | RAJAKATALAB  | 132     | 0.9826       |  | 152085     | BHELUPUR     | 220     | 0.9871       |
| 151212     | VARANSI CANT | 132     | 0.9798       |  | 152169     | BHADAURA     | 220     | 0.9984       |
| 151222     | LEEDOPUR     | 132     | 0.9871       |  | 152173     | RAJA KATALAB | 220     | 0.9871       |
| 151267     | MANDUADI     | 132     | 0.9783       |  | 152215     | SAHUPURI BII | 220     | 0.9878       |
| 151301     | NARAINPU     | 132     | 0.9906       |  | 152236     | BHADOHI      | 220     | 0.9871       |
| 151436     | KURSATO      | 132     | 0.9826       |  | 152245     | SAHUPURI_4_2 | 220     | 0.9878       |
| 151534     | AURIHAR_TSS  | 132     | 0.9916       |  | 152279     | VIRAPATTI    | 220     | 1.0004       |
| 151600     | RAJAKATALB_2 | 132     | 0.9826       |  | 154014     | ANPARA4      | 400     | 1.0300       |
| 151661     | KAITHI       | 132     | 0.9905       |  | 154019     | SARNATH4     | 400     | 1.0080       |
| 151662     | DLW          | 132     | 0.9790       |  |            |              |         |              |

### 3. Case 3

- Actual Ex- bus Generation =452 (1X452)MW
- Actual load met =440 MW
- No over loading is observed.
- Under Voltage at some substations is observed.
- Voltage profile of various buses of island is as follows-

| Bus Number | Bus Name     | Base kV | Voltage (pu) | Bus Number | Bus Name  | Base kV | Voltage (pu) |
|------------|--------------|---------|--------------|------------|-----------|---------|--------------|
| 151056     | SARNATH1     | 132     | 0.9098       | 151662     | DLW       | 132     | 0.8818       |
| 151136     | GAJOKHAR     | 132     | 0.9335       | 151664     | BHU       | 132     | 0.8780       |
| 151170     | BINA         | 132     | 1.0111       | 152066     | SARNATH2  | 220     | 0.9569       |
| 151069     | ANPARA       | 132     | 1.0172       | 152078     | GAJOKHA   | 220     | 0.9498       |
| 151212     | VARANSI CANT | 132     | 0.8833       | 152279     | VIRAPATTI | 220     | 0.9529       |
| 151222     | LEEDOPUR     | 132     | 0.8999       | 154014     | ANPARA4   | 400     | 1.0300       |
| 151267     | MANDUADI     | 132     | 0.8797       | 154019     | SARNATH4  | 400     | 0.9783       |
| 151534     | AURIHAR_TSS  | 132     | 0.9046       |            |           |         |              |

### 4. Case 4

- Actual Ex- bus Generation =310 (1x310)MW
- Actual load met =305 MW
- No under voltage and over loading is observed.
- Voltage profile of various buses of Islanding is as follows-

| Bus Number | Bus Name     | Base kV | Voltage (pu) | Bus Number | Bus Name  | Base kV | Voltage (pu) |
|------------|--------------|---------|--------------|------------|-----------|---------|--------------|
| 151056     | SARNATH1     | 132     | 0.9627       | 151664     | BHU       | 132     | 0.9448       |
| 151136     | GAJOKHAR     | 132     | 0.9770       | 151662     | DLW       | 132     | 0.9470       |
| 151170     | BINA         | 132     | 1.0111       | 152066     | SARNATH2  | 220.0   | 0.9893       |
| 151069     | ANPARA       | 132     | 1.0172       | 152078     | GAJOKHA   | 220     | 0.9857       |
| 151212     | VARANSI CANT | 132     | 0.9478       | 152279     | VIRAPATTI | 220     | 0.9868       |
| 151222     | LEEDOPUR     | 132     | 0.9570       | 154014     | ANPARA4   | 400     | 1.0300       |
| 151267     | MANDUADI     | 132     | 0.9458       | 154019     | SARNATH4  | 400     | 1.0006       |
| 151534     | AURIHAR_TSS  | 132     | 0.9578       |            |           |         |              |

## 5. Case 5

- Actual Ex- bus Generation =409 (1x409)MW
- Actual load met =402 MW
- No under voltage and over loading is observed
- Voltage profile of various buses of Islanding is as follows-

| Bus Number | Bus Name     | Base kV | Voltage (pu) |  | Bus Number | Bus Name     | Base kV | Voltage (pu) |
|------------|--------------|---------|--------------|--|------------|--------------|---------|--------------|
| 151055     | SAHUPR1      | 132     | 0.9747       |  | 151664     | BHU          | 132     | 0.9636       |
| 151056     | SARNATH1     | 132     | 0.9783       |  | 151793     | SAHUPURI BII | 132     | 0.9635       |
| 151069     | ANPARA       | 132     | 1.0172       |  | 151884     | ALAIPUR      | 132     | 0.9709       |
| 151113     | CHUNNAR      | 132     | 0.9773       |  | 152065     | SAHUPU_N     | 220     | 0.9741       |
| 151136     | GAJOKHAR     | 132     | 0.9825       |  | 152066     | SARNATH2     | 220     | 0.9954       |
| 151170     | BINA         | 132     | 1.0111       |  | 152078     | GAJOKHA      | 220     | 0.9908       |
| 151173     | RAJAKATALAB  | 132     | 0.9698       |  | 152085     | BHELUPUR     | 220     | 0.9732       |
| 151212     | VARANSI CANT | 132     | 0.9662       |  | 152169     | BHADAURA     | 220     | 0.9880       |
| 151222     | LEEDOPUR     | 132     | 0.9736       |  | 152173     | RAJA KATALAB | 220     | 0.9738       |
| 151267     | MANDUADI     | 132     | 0.9647       |  | 152215     | SAHUPURI BII | 220     | 0.9741       |
| 151301     | NARAINPU     | 132     | 0.9760       |  | 152236     | BHADOHI      | 220     | 0.9739       |
| 151436     | KURSATO      | 132     | 0.9698       |  | 152245     | SAHUPURI_4_2 | 220     | 0.9740       |
| 151534     | AURIHAR_TSS  | 132     | 0.9786       |  | 152279     | VIRAPATTI    | 220     | 0.9930       |
| 151600     | RAJAKATALB_2 | 132     | 0.9698       |  | 154014     | ANPARA4      | 400     | 1.0300       |
| 151661     | KAITHI       | 132     | 0.9774       |  | 154019     | SARNATH4     | 400     | 1.0038       |
| 151662     | DLW          | 132     | 0.9656       |  |            |              |         |              |

## 6. Case 6


- Actual Ex- bus Generation =326 (1x326)MW
- Actual load met =322 MW
- No under voltage and over loading is observed
- Voltage profile of various buses of Islanding is as follows-

| Bus Number | Bus Name     | Base kV | Voltage (pu) |  | Bus Number | Bus Name     | Base kV | Voltage (pu) |
|------------|--------------|---------|--------------|--|------------|--------------|---------|--------------|
| 151055     | SAHUPR1      | 132     | 1.0076       |  | 151664     | BHU          | 132     | 0.9933       |
| 151056     | SARNATH1     | 132     | 1.0041       |  | 151793     | SAHUPURI BII | 132     | 0.9931       |
| 151069     | ANPARA       | 132     | 1.0172       |  | 151884     | ALAIPUR      | 132     | 1.0032       |
| 151113     | CHUNNAR      | 132     | 1.0110       |  | 152065     | SAHUPU_N     | 220     | 1.0062       |
| 151136     | GAJOKHAR     | 132     | 1.0079       |  | 152066     | SARNATH2     | 220     | 1.0127       |
| 151170     | BINA         | 132     | 1.0111       |  | 152078     | GAJOKHA      | 220     | 1.0107       |
| 151173     | RAJAKATALAB  | 132     | 1.0022       |  | 152085     | BHELUPUR     | 220     | 1.0057       |
| 151212     | VARANSI CANT | 132     | 0.9958       |  | 152169     | BHADAURA     | 220     | 1.0134       |
| 151222     | LEEDOPUR     | 132     | 1.0019       |  | 152173     | RAJA KATALAB | 220     | 1.0061       |
| 151267     | MANDUADI     | 132     | 0.9941       |  | 152215     | SAHUPURI BII | 220     | 1.0062       |
| 151301     | NARAINPU     | 132     | 1.0099       |  | 152236     | BHADOHI      | 220     | 1.0061       |
| 151436     | KURSATO      | 132     | 1.0022       |  | 152245     | SAHUPURI_4_2 | 220     | 1.0061       |
| 151534     | AURIHAR_TSS  | 132     | 0.9994       |  | 152279     | VIRAPATTI    | 220     | 1.0103       |
| 151600     | RAJAKATALB_2 | 132     | 1.0022       |  | 154014     | ANPARA4      | 400     | 1.0300       |
| 151661     | KAITHI       | 132     | 1.0034       |  | 154019     | SARNATH4     | 400     | 1.0158       |
| 151662     | DLW          | 132     | 0.9951       |  |            |              |         |              |


## Final Observations:

1. As per the study, Islanding Scheme does not seem feasible in cases 1, due to under voltage observed at various node when 2 machine are taken considering area A & B both, while in case 2 the load of area A & B is less than technical minimum of 2x500 MW units at Anpara BTPS for Winter scenario.
2. In case no. 3 and 4, one machine has been taken with load form Area A for summer scenario. Voltages and loading of transmission lines are within limit. However, for winter scenario, the load of area A is less than technical minimum of 1x500 MW units at Anpara BTPS. Therefore, to ensure technical minimum of unit, load of area A and B both has been taken in case no 5 and 6 for winter scenario

### Block Diagram of Varanasi islanding scheme (Area A and B)



## Block Diagram of Varanasi islanding scheme (Area A)



1. Time grading may be done in terms of severity of overloading as follows:

**a) Loading > 95% of rated capacity - delay of 3 sec for activation of SPS.**

**b) Loading>110% of rated capacity - delay of 1500ms for activation of SPS**

2. Once SPS gets activated, tripping of feeders (based on priority) should be done by SPS without any intentional delay until loading gets below 95% of rated capacity

3. Overcurrent pick up value must be coordinated in such a way that SPS comes into action before overcurrent protection.

Based on above comments, SPS logic recommended by UPSLDC is as follows:

| Cases  | % Setting   | Time Delay | Priority of feeder for load cut off |
|--------|---|------------|-------------------------------------|
| Case-1 | Loading on ICT >95% but less than 110% of rated current | 3 sec      | 1. 220kV Kirawali                   |
|        |   |            | 2. 220kV Samsabad                   |
|        |   |            | 3. 220kV Bharatpur                  |
| Case-2 | Loading on ICT>110% of rated current                    | 1500 ms    | 1. 220kV Kirawali                   |
|        |   |            | 2. 220kV Samsabad                   |
|        |   |            | 3. 220kV Bharatpur                  |

**Note: Delay as mentioned in the above Tripping logics I& II is for initiation of tripping command. After initiation of tripping command, feeders will continue to trip as per priority without any time delay until loading on ICT reaches below 95%.**



## National Load Despatch Centre

### Import Capability of Punjab for September 2025

\

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]

**National Load Despatch Centre**  
**Import Capability of Uttar Pradesh for September 2025**

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]

## National Load Despatch Centre

### Import Capability of Haryana for September 2025

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]

## National Load Despatch Centre

### Import Capability of Rajasthan for September 2025

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]

## National Load Despatch Centre

### Import Capability of Delhi for September 2025

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]

## National Load Despatch Centre

### Import Capability of Uttarakhand for September 2025

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]

## National Load Despatch Centre

### Import Capability of HP for September 2025

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]

## National Load Despatch Centre

### Import Capability of J&K for September 2025

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]



## National Load Despatch Centre

### Import Capability of Chandigarh for September 2025

Issue Date: -

Issue Time: 1600

Revision No. 0

[illegible]


# Northern Region SPS Details

Annexure-B.III


| S. No. | Group   | Delhi   |                   | UP   |                   | Rajasthan  |                   | Haryana  |                   | Punjab  |                   | Group Total |
|--------|---------|---|-------------------|--|-------------------|--|-------------------|--|-------------------|---|-------------------|-------------|
|        |         | Load  | Planned Load (MW) | Load   | Planned Load (MW) | Load   | Planned Load (MW) | Load   | Planned Load (MW) | Load  | Planned Load (MW) |             |
| 1      | Group-A | Mandola (PG)-<br>220 kV Narela D/C<br>NSD-70D                                   | 150               | Feeders from<br>220/132 kV<br>Muradnagar old S/S<br>132 kV Niwai Road<br>132 kV Modi Steel<br>132 kV Merta<br>2*63 MVA X-Mer   | 100               | 220/132 kV Alwar-<br>132 kV GSS Pinan<br>400/220 kV Merta -<br>132 kV GSS Roon   | 25                |  |                   | 220/66 kV Malerkotla<br>66 kV Malerkotla ckt<br>66 kV Naudhrani ckt   | 35                | 310         |
| 2      | Group-B | Mandola (PG) -<br>220 kV Gopalpur D/C   | 200               |  |                   | 220/132 kV Ratangarh-<br>132 kV Sandar Sahar   | 25                | Panipat (BBMB)<br>100 MVA, 220/33 kV ICT   | 50                |   |                   | 275         |
| 3      | Group-C |   |                   | Feeders from<br>220/132 kV Modipuram<br>Sub-station,<br>132 kV Sardhana,<br>Kankankhera, Kapsad,<br>Kankankhera-2, 132/33kV<br>40MVA+63MVA ICT-2&3<br>33 kV Ladies Park,<br>33 kV Pallavpuram,<br>33 kV Siwaya | 100               | 400/220 kV Merta -<br>132 kV GSS Merta City<br>132 kV GSS Lamba+<br>Gotan<br>132 kV GSS Kuchera  | 60                | 220kV Dhanoda-<br>220kV Lala Ahir Ckt-1<br>220kV Lala Ahir Ckt-2<br>(Load Relief: 220/132kV,<br>100MVA T/F + 220/33kV,<br>100MVA T/F)<br>220kV Charkhi Dadri-<br>220kV Lala Ahir<br>(Load Relief: 3*100MVA<br>220/132kV Rewan) | 91                | 220/66 kV Gobindgarh-<br>1<br>66 kV Chouhwa ckt-1,<br>66 kV Chouhwa ckt-2,<br>66 kV Talwara ckt-1,<br>66 kV Talwara ckt-2<br>66 kV Focal Point  | 71                | 322         |
| 4      | Group-D |   |                   |  |                   | 220/132 kV Alwar-<br>132 kV GSS Bansoor<br>132 kV GSS Malekheda<br>132 kV Ramgarh  | 60                | 220kV Charkhi Dadri-<br>220kV Mohindergarh Ckt-1<br>(Radial load-49MW)<br>220kV Mohindergarh Ckt-2<br>(Radial load of Namaul-<br>38MW)   | 87                | 220/66 kV Lathokalan-<br>66kV Gill Road ckt-1<br>66kV Gill Road ckt-2<br>66kV Ferozpur<br>66 kV Sarinh  | 114.25            | 261.25      |
| 5      | Group-E |   |                   | 220 kV Mainpuri -<br>2 x 132/33 kV, 63 MVA<br>T/F (20 MW-60 MW)  | 60                | 220/132kV Bhikwara-<br>132 kV GSS Gangapur,<br>132 kV GSS<br>Devgarh+Kareda,<br>132 kV GSS Danta   | 105               | 132kV PTPS-<br>132kV Chandauli<br>132kV Munak<br><br>220kV Dhanoda-<br>220/132 kV 100 MVA X-Mer  | 88                | 220 kV Jamsheri-<br>66 kV Nakodar Road-1<br>66 kV Nakodar Road-2  | 100               | 343         |
| 6      | Group-F |   |                   | 220 kV Nara-<br>132/33 kV, 40 MVA T/F<br>132/33 kV, 2*63 MVA T/F<br>(32 MW-52 MW)  | 60                | 220/132 kV Alwar<br>132 kV GSS Alwar (Local<br>Load)<br><br>220/132kV Kota-<br>Kota local load<br>(40/50MVA TF)<br>132 kV Nanta(Talera)<br><br>220/132 kV Beawar-<br>132 kV GSS Ber Jaitaran | 100               | Samaypur (BBMB) -<br>220 kV Palwal D/C (MW)<br>(35MW)<br><br>220kV Narwana-<br>2*100MVA 220/132kV T/F at<br>220 kV Narwana   | 65                | 220 Mohali-1-<br>66 kV Mohali Phase-7<br>66 kV Mohali Phase-8B<br>66 kV Mohali Sector-71<br>66 kV Mohali Phase-1  | 100               | 305         |
| 7      | Group-G |   |                   |  |                   | 220/132 kV Ratangarh-<br>132 kV Ratangarh Inter-<br>Connector<br>132 kV Fatehpur<br>220/132 kV Beawar-<br>132 kV GSS Masuda,<br>132 kV GSS Asind,<br>Beawar Local Load                       | 100               | 132kV Charkhi Dadri<br>132kV Dadri city,<br>132kV Matenhail,<br>132kV Kalanaur,<br>132kV Bahu<br>132/33kV T/F 20/25MVA<br>132/133V T/F 16/20 MVA   | 75                | 220 kV Ablawal-<br>66 kV Rakhra-I & II,<br>66 kV Rakhra-III & IV  | 100               | 275         |
| 8      | Group-H |   |                   |  |                   | 220/132kV Bhikwara-<br>132 kV Bhikwara Local<br>Load   | 12                | 220kV Fatehabad(PGCIL)-<br>220kV Fatehabad Ckt-1<br>220kV Fatehabad Ckt-2<br>220kV Sirsa   | 45                | 220kV Ajitwal-<br>66 kV Golia ckt<br>66 kV Doudhar<br>66 kV Chogawan ckt-1<br>66 kV Chogawan ckt-2  | 15                | 72          |
| 9      | Group-I |   |                   | 220kV Saharanpur-<br>220/132kV, 40MVA T/F-1<br>220/132kV, 40MVA T/F-<br>132kV Ambala Road<br>132 kV Gagaheri ckt   | 100               | 220/132 kV Ratangarh-<br>132kV GSS Momasari<br>Patlisar  | 35                | 132kV Safidon-<br>220/132kV, 100MVA T/F-1<br>220/132kV, 100MVA T/F-2   | 60                | 220kV Dhandari-2-<br>66/11kV T-2<br>66/11kV T-4<br>66kV Sherpur Ckt-1<br>66kV Sherpur Ckt-2   | 109               | 294         |
| 10     | Group-J |   |                   | 220kV Nanuta-<br>132/33kV, 63MVA T/F-1<br>132/33kV, 63MVA T/F-2<br>132kV Deoband ckt<br>132 kV Gangoh ckt<br>132 kV Rampur-<br>Maniharan<br>132 kV Shanti-Shyamla  | 155               | 220/132 kV Debari-<br>132kV GSS Mavli<br>132kV GSS Bhatewar<br>132 kV Debari local load  | 90                | 220kV Hissar(PGCIL)-<br>220kV Sangwan Ckt-1<br>220kV Sangwan Ckt-2   | 45                | Ablawal -<br>66kV Barn<br>66kV passiana-1<br>Bahadurgarh-<br>66kV Bahadurgarh-1<br>66kV Ghanour<br>66kV Patalla<br>66kV Barn-1<br>66kV Barn-2   | 153.1             | 443.1       |
| 11     | Group-K | 400/220kV Bamnauti-<br>220kV Pappankala Ckt-<br>1<br>220kV Pappankala Ckt-<br>2 | 200               |  |                   | 220/132 kV Chittorgarh-<br>132 kV GSS Ajolia ka<br>khera+Bassi<br>132 kV Senthil<br>Chittorgarh local load   | 65                | 220kV Nunamajra-<br>220/132kV, 100MVA T/F-1<br>220/132kV, 100MVA T/F-2<br><br>220kV Prem Nagar<br>Bhiwani (BBMB)-<br>Bapora Ckt-1<br>Bapora Ckt-2  | 57                | 220 kV Mohali-1<br>(Sector-80)<br>66kV CHD-1<br>66kV CHD-2<br>66kV CHD-3<br>66kV CHD-4<br>66kV Incoming-1<br>66kV Incoming-2<br>66kV Incoming-3<br>220kV Gobindgarh-2<br>MGG<br>66kV Khanna Ckt-1<br>66kV Khanna Ckt-2<br>66kV Badinpur<br>66kV Central<br>66kV Grain Market<br>66kV Bhari<br>66/11kV T-2<br>66/11kV T-4<br>66/11kV T-6 | 90                | 412         |
| TOTAL  |         |   | 660               |  | 665               |  | 677               |  | 643               |   | 887.35            | 3312.4      |

Fig-1: Load Details

Drawl Vs Schedule Vs Frequency - Rajasthan (04-08-2025)




Drawl Vs Schedule Vs Frequency - Rajasthan (03-08-2025)







### Drawl Vs Schedule Vs Frequency - Rajasthan (02-08-2025)



### Drawl Vs Schedule Vs Frequency - Rajasthan (01-08-2025)




Drawl Vs Schedule Vs Frequency - Rajasthan (29-07-2025)





Drawl Vs Schedule Vs Frequency - Rajasthan (28-07-2025)





# Resource Adequacy

---

**PRAS results- Northern Region**  
**Month ahead for Sep-2025**

# Resource Adequacy - PRAS

- The Probabilistic Resource Adequacy Study (PRAS) for the month of Sep 2025 has been carried out for the Northern Region to assess the sufficiency of available generation resources to meet the projected demand under varying scenarios. The study was conducted using 1000 probabilistic scenarios, with median results presented to reflect expected system behavior under typical conditions.
- To evaluate the net load that must be met by dispatchable thermal generation, the projected regional demand for Sep 2025 was first estimated. From this demand, the expected contribution from non-thermal resources **solar, wind, hydro, and nuclear** was subtracted, based on historical generation profiles observed for these sources during the same period in past years. This approach ensures that the inherent variability and diurnal patterns of renewable generation are accurately captured in the analysis.
- For thermal generation, a detailed availability assessment was carried out using the following assumptions:

## **Planned Outages:**

Unit-wise planned outages for the month of Sep 2025 were incorporated as per the data available in the latest LGBR. This reflects scheduled maintenance and other operational constraints known in advance.

## **Forced Outages:**

A Monte Carlo simulation approach was adopted to model forced outages of thermal generating units. This stochastic simulation utilized historical outage and revival rates specific to each unit and capacity. The probabilistic nature of this method allows for modeling of unplanned events, enhancing the robustness of the adequacy assessment.

Two distinct scenarios were modeled to analyze the role of inter-regional power exchanges in meeting regional adequacy requirements:


### **1. Scenario without Inter-Regional T-GNA Contracts**

- In this base case scenario, no inter-regional transmission capacity contracted through T-GNA was modeled.
- Under this scenario, the study indicated higher Loss of Load Probability (LOLP) and increased Expected Unserved Energy (EUE), highlighting potential shortfalls due to the limited flexibility in accessing external generation.

### **2. Scenario with Past-Year IR Flow Profile**


- In the second scenario, the actual inter-regional power flow patterns from Sep 2024 were incorporated as a proxy for expected support in Sep 2025. This approach reflects realistic inter-regional exchange behavior under comparable seasonal conditions and operating constraints.
- This demonstrated a notable reduction in LOLP and EUE values, indicating enhanced adequacy due to the implicit support from neighboring regions.

# 2. (A) Resource Adequacy results (with Sep 2024 IR schedule)







2.(C) Resource Adequacy results (with Sep 2024 IR schedule)



2. (D) Resource Adequacy results (with Sep 2024 IR schedule)




# Way forward

- Inter-Regional Modeling will be undertaken by incorporating actual power flow data from WBES to improve the accuracy of inter-regional support estimation.
- Intra-Day and Day-Ahead Resource Adequacy Monitoring will be conducted using data submitted by the states, with integrated WBES data, as outlined in the subsequent slides.
- Month-Ahead PRAS Studies will be conducted at the state level.
- Week-Ahead and Year-Ahead PRAS Studies will be carried out at both regional and state levels.



# RA Planning for Intra day and Day ahead



# RA Planning for Intra day and Day ahead

The demand forecast and self-generation forecast, as currently submitted by the states via email, will be shifted to the designated portal in due course. For both day-ahead and intra-day monitoring, the drawl from the grid shall be considered as per WBES, as detailed below. Stacking of both demand and generation will provide a clear picture of shortage period.

|      |  |
|------|--|
| ISGS | <ul style="list-style-type: none"><li>• Entitlement from each of the Generator in all the regions.</li></ul>                                       |
| GNA  | <ul style="list-style-type: none"><li>• Requisition Quantum of the buyer for each of the GNA Contracts (incl. REMC).</li></ul>                     |
| TGNA | <ul style="list-style-type: none"><li>• Scheduled Quantum from each of the T-GNA (including REMC) Contracts</li></ul>                              |
| DAM  | <ul style="list-style-type: none"><li>• Net Scheduled Quantum from each of the Day-Ahead Market Exchange and Products (DAM, GDAM, HPDAM)</li></ul> |
| RTM  | <ul style="list-style-type: none"><li>• Net Scheduled Quantum from each of the Real-Time Market Exchange.</li></ul>                                |

| Sl No | Entity Name   | User Type                 | Registration No | Registration Date | Registered Capacity | Length | MVA Capacity |
|-------|---|---------------------------|-----------------|-------------------|---------------------|--------|--------------|
| 1     | ACC Limited (Tikaria)                                     | Buyer                     | NRRAC18BU       | 01-04-2025        | 0                   | 0      | 0            |
| 2     | ACC Limited (Unit-Gagal)                                  | Buyer                     | NRRAC18BU       | 22-01-2025        | 0                   | 0      | 0            |
| 3     | Ambuja Cements Limited (Bathinda)                         | Buyer                     | NRRAM68BU       | 03-03-2025        | 0                   | 0      | 0            |
| 4     | Ambuja Cements Limited (Unit Roorkee)                     | Buyer                     | NRRAM78BU       | 03-03-2025        | 0                   | 0      | 0            |
| 5     | Ambuja Cements Limited (Unit-Marwar)                      | Buyer                     | NRRAM18BU       | 22-01-2025        | 0                   | 0      | 0            |
| 6     | Ambuja Cements Limited (Unit-Rabiyawas)                   | Buyer                     | NRRAM28BU       | 22-01-2025        | 0                   | 0      | 0            |
| 7     | Ambuja Cements Limited (Unit-Rauri)                       | Buyer                     | NRRACL8BU       | 29-01-2025        | 0                   | 0      | 0            |
| 8     | Ambuja Cements Limited (Unit-Suli)                        | Buyer                     | NRRACL8BU       | 29-01-2025        | 0                   | 0      | 0            |
| 9     | Ambuja Cements Limited Ropar                              | Buyer                     | NRRAM58BU       | 03-03-2025        | 0                   | 0      | 0            |
| 10    | Asian Fine Cements Private Limited                        | Buyer                     | NRRAS18BU       | 03-03-2025        | 0                   | 0      | 0            |
| 11    | Delhi Buyer(DMRC Ltd)                                     | Buyer                     | NRRDMRBY        | 26-02-2021        | 0                   | 0      | 0            |
| 12    | Delhi International Airport Limited                       | Buyer                     | NRRDE18BU       | 31-07-2023        | 0                   | 0      | 0            |
| 13    | Government of Himachal Pradesh _Chamera1HEP               | Buyer                     | NRRGO48BU       | 07-08-2024        | 0                   | 0      | 0            |
| 14    | Government of Himachal Pradesh _Chamera3HEP               | Buyer                     | NRRGO78BU       | 07-08-2024        | 0                   | 0      | 0            |
| 15    | Government of Himachal Pradesh _CHAMERA2HEP               | Buyer                     | NRRGO58BU       | 07-08-2024        | 0                   | 0      | 0            |
| 16    | Government of Himachal Pradesh_BairasuliHEP               | Buyer                     | NRRGO28BU       | 07-08-2024        | 0                   | 0      | 0            |
| 17    | Government of Himachal Pradesh_Koldam HEP                 | Buyer                     | NRRGO18BU       | 07-08-2024        | 0                   | 0      | 0            |
| 18    | Government of Himachal Pradesh_NJHPS                      | Buyer                     | NRRGO88BU       | 07-08-2024        | 0                   | 0      | 0            |
| 19    | Government of Himachal Pradesh_Parbat3HEP                 | Buyer                     | NRRGO68BU       | 07-08-2024        | 0                   | 0      | 0            |
| 20    | Government of Himachal Pradesh_RampurHEP                  | Buyer                     | NRRGO38BU       | 07-08-2024        | 0                   | 0      | 0            |
| 21    | Government of Himachal Pradesh_Parbat2HEP                 | Buyer                     | NRRGO98BU       | 29-04-2025        | 0                   | 0      | 0            |
| 22    | LINDE INDIA LIMITED                                       | Buyer                     | NRRU18BU        | 24-12-2024        | 0                   | 0      | 0            |
| 23    | National Fertilizers Limited, Nangal Punjab               | Buyer                     | NRRNFNBY        | 26-03-2018        | 0                   | 0      | 0            |
| 24    | Northern Central Railway                                  | Buyer                     | NRRRL18Y        | 20-05-2011        | 0                   | 0      | 0            |
| 25    | NVVN (SNA NEA-UP)   | Buyer                     | NRRNE18BU       | 29-04-2024        | 0                   | 0      | 0            |
| 26    | NVVNL (SNA Nepal)   | Buyer                     | NRRNVNBY        | 30-03-2020        | 0                   | 0      | 0            |
| 27    | PG-HVDC-NR  | Buyer                     | NRRPGHBY        | 30-11-2023        | 0                   | 0      | 0            |
| 28    | Chandigarh Power Distribution Limited                     | Distribution Licensee     | NRRCH1DL        | 27-02-2025        | 0                   | 0      | 0            |
| 29    | Delhi   | Distribution Licensee     | NRRDL1DS        | 02-07-2010        | 0                   | 0      | 0            |
| 30    | Haryana   | Distribution Licensee     | NRRHR1DS        | 21-09-2011        | 0                   | 0      | 0            |
| 31    | Himachal Pradesh  | Distribution Licensee     | NRRHP1DS        | 09-06-2011        | 0                   | 0      | 0            |
| 32    | Punjab  | Distribution Licensee     | NRRPU1DS        | 30-08-2010        | 0                   | 0      | 0            |
| 33    | Rajasthan   | Distribution Licensee     | NRRRJ1DS        | 10-08-2011        | 0                   | 0      | 0            |
| 34    | UT Chandigarh   | Distribution Licensee     | NRRCH1DS        | 10-08-2011        | 0                   | 0      | 0            |
| 35    | UT J&K  | Distribution Licensee     | NRRJ1DS         | 30-09-2011        | 0                   | 0      | 0            |
| 36    | Uttar Pradesh   | Distribution Licensee     | NRRUP1DS        | 15-07-2011        | 0                   | 0      | 0            |
| 37    | Uttarakhand   | Distribution Licensee     | NRRUA1DS        | 03-08-2011        | 0                   | 0      | 0            |
| 38    | ADHPL   | Generating Station        | NRRAD1SL        | 10-09-2010        | 192                 | 0      | 0            |
| 39    | Anta GPP  | Generating Station        | NRRAN1GN        | 09-06-2011        | 419                 | 0      | 0            |
| 40    | Auraiya GPP   | Generating Station        | NRRAU1GN        | 09-06-2011        | 663                 | 0      | 0            |
| 41    | Bairasuli HPS   | Generating Station        | NRRBS1GN        | 01-06-2011        | 180                 | 0      | 0            |
| 42    | Bhakra Complex  | Generating Station        | NRRBC1GN        | 05-02-2016        | 1568.73             | 0      | 0            |
| 43    | Budhli, HPS   | Generating Station        | NRRBD1SL        | 22-05-2012        | 70                  | 0      | 0            |
| 44    | Chamera-I HPS   | Generating Station        | NRRCM1GN        | 04-06-2010        | 540                 | 0      | 0            |
| 45    | Chamera-II HPS  | Generating Station        | NRRCM2GN        | 09-06-2011        | 300                 | 0      | 0            |
| 46    | Chamera-III HPS   | Generating Station        | NRRCM3GN        | 26-03-2012        | 231                 | 0      | 0            |
| 47    | Dadri GPP   | Generating Station        | NRRDD1GN        | 05-05-2011        | 830                 | 0      | 0            |
| 48    | Dadri NCTPS   | Generating Station        | NRRDA1GN        | 07-04-2010        | 840                 | 0      | 0            |
| 49    | Dadri Stage-II NCTPS                                      | Generating Station        | NRRDA2GN        | 05-05-2011        | 980                 | 0      | 0            |
| 50    | Dehar HEP   | Generating Station        | NRRDE1GN        | 05-02-2016        | 990                 | 0      | 0            |
| 51    | Dhauliganga HPS   | Generating Station        | NRRDG1GN        | 29-06-2011        | 280                 | 0      | 0            |
| 52    | Dulhasti HPS  | Generating Station        | NRRDU1GN        | 09-05-2011        | 390                 | 0      | 0            |
| 53    | IGSTPS  | Generating Station        | NRRIG1GN        | 02-12-2010        | 1500                | 0      | 0            |
| 54    | Khurja STPP   | Generating Station        | NRRKH1GN        | 06-09-2022        | 1320                | 0      | 0            |
| 55    | Kishanganga HEP   | Generating Station        | NRRKG1GN        | 01-03-2018        | 330                 | 0      | 0            |
| 56    | Koteshwar HPS   | Generating Station        | NRRKT1GN        | 25-06-2011        | 400                 | 0      | 0            |
| 57    | KWHP  | Generating Station        | NRRKW1GN        | 18-05-2011        | 1045                | 0      | 0            |
| 59    | NAPS  | Generating Station        | NRRNA1GN        | 10-05-2011        | 440                 | 0      | 0            |
| 60    | Nathpa-Jhakri HPS   | Generating Station        | NRRNJ1GN        | 06-07-2010        | 1500                | 0      | 0            |
| 61    | NTPC KOLDAM HYDRO ELECTRIC POWER PLANT                    | Generating Station        | NRRKD1GN        | 08-04-2015        | 800                 | 0      | 0            |
| 62    | Parbati-II, HEP   | Generating Station        | NRRPB2GN        | 18-09-2018        | 800                 | 0      | 0            |
| 63    | Parbati-III, HEP  | Generating Station        | NRRPB3GN        | 22-08-2013        | 520                 | 0      | 0            |
| 64    | Pong HEP  | Generating Station        | NRRPO1GN        | 05-02-2016        | 396                 | 0      | 0            |
| 65    | Rampur HEP  | Generating Station        | NRRRS1GN        | 07-02-2014        | 412                 | 0      | 0            |
| 66    | RAPP-788, NPCIL   | Generating Station        | NRRRADGN        | 04-04-2019        | 1400                | 0      | 0            |
| 67    | RAPS-B  | Generating Station        | NRRRABGN        | 09-05-2011        | 440                 | 0      | 0            |
| 68    | RAPS-C  | Generating Station        | NRRRACGN        | 27-05-2011        | 440                 | 0      | 0            |
| 69    | Rihand-I STPS   | Generating Station        | NRRRI1GN        | 27-11-2011        | 1000                | 0      | 0            |
| 70    | Rihand-II STPS  | Generating Station        | NRRRI2GN        | 27-11-2011        | 1000                | 0      | 0            |
| 71    | Rihand-III, STPS  | Generating Station        | NRRRI3GN        | 25-04-2012        | 1000                | 0      | 0            |
| 72    | Sainj HEP   | Generating Station        | NRRSJ1GN        | 26-05-2017        | 100                 | 0      | 0            |
| 73    | Salal HPS   | Generating Station        | NRRSL1GN        | 20-05-2011        | 690                 | 0      | 0            |
| 74    | SCL Bewar   | Generating Station        | NRRBW1SL        | 12-04-2011        | 300                 | 0      | 0            |
| 75    | SEWA-II   | Generating Station        | NRRSW1GN        | 09-05-2011        | 120                 | 0      | 0            |
| 76    | Singoli-Bhatwari HEP                                      | Generating Station        | NRRSBHGN        | 19-10-2020        | 99                  | 0      | 0            |
| 77    | Singrauli Small Hydro Station                             | Generating Station        | NRRSH1GN        | 29-08-2017        | 8                   | 0      | 0            |
| 78    | Singrauli STPS  | Generating Station        | NRRSI1GN        | 04-05-2011        | 2000                | 0      | 0            |
| 79    | SORANG HEP  | Generating Station        | NRRSP1GN        | 23-09-2013        | 100                 | 0      | 0            |
| 80    | Tanakpur HPS  | Generating Station        | NRRTP1GN        | 01-06-2011        | 94                  | 0      | 0            |
| 81    | Tanda Stage II  | Generating Station        | NRRTN2GN        | 07-11-2019        | 1320                | 0      | 0            |
| 82    | Tehri HPS   | Generating Station        | NRRTE1GN        | 20-04-2010        | 1000                | 0      | 0            |
| 83    | Tehri PSP   | Generating Station        | NRRTE1GS        | 16-08-2024        | 1000                | 0      | 0            |
| 84    | Unchahar-I TPS  | Generating Station        | NRRUN1GN        | 10-05-2017        | 420                 | 0      | 0            |
| 85    | Unchahar-II TPS   | Generating Station        | NRRUN2GN        | 10-05-2017        | 420                 | 0      | 0            |
| 86    | Unchahar-III TPS  | Generating Station        | NRRUN3GN        | 10-05-2017        | 210                 | 0      | 0            |
| 87    | Unchahar-IV TPS   | Generating Station        | NRRUN4GN        | 22-12-2016        | 500                 | 0      | 0            |
| 88    | URI 2 HEP   | Generating Station        | NRRUR2GN        | 14-03-2013        | 240                 | 0      | 0            |
| 89    | Uri HPS   | Generating Station        | NRRUR1GN        | 18-05-2011        | 480                 | 0      | 0            |
| 90    | UT J&K Seller   | Generating Station        | NRRJK1SL        | 23-07-2021        | 0                   | 0      | 0            |
| 91    | Adani Renewable Energy Park Rajasthan Limited Fatehgarh-I | Others (SPPD/ WPPD/ HPPD) | NRRAR1HPPD      | 15-11-2021        | 1406                | 0      | 0            |
| 92    | Prerak Greentech Private Limited                          | Others (SPPD/ WPPD/ HPPD) | NRRPSPPD        | 28-12-2023        | 400                 | 0      | 0            |
| 93    | Rajasthan Solar Park Development Company Limited          | Others (SPPD/ WPPD/ HPPD) | NRRRS1SPPD      | 21-07-2023        | 190                 | 0      | 0            |
| 94    | Adani Renewable Energy Holding Five Limited               | QCA                       | NRRAD1QCAA      | 21-03-2025        | 0                   | 0      | 0            |
| 95    | Emsys Energy Services Private Limited Bhadla-I            | QCA                       | NRRREM2QCAA     | 28-02-2025        | 0                   | 0      | 0            |
| 96    | Emsys Energy Services Private Limited Bikaner-I           | QCA                       | NRRREM1QCAA     | 31-01-2025        | 0                   | 0      | 0            |
| 97    | Emsys Energy Services Private Limited Bikaner-II          | QCA                       | NRRREM3QCAA     | 16-05-2025        | 0                   | 0      | 0            |
| 98    | Manikaran Analytics Limited (Fatehgarh II)                | QCA                       | NRRMA3QCAA      | 30-04-2025        | 0                   | 0      | 0            |
| 99    | Manikaran Analytics Limited Fatehgarh-I                   | QCA                       | NRRMA2QCAA      | 06-03-2025        | 0                   | 0      | 0            |

|     |  |        |           |            |         |   |   |
|-----|--|--------|-----------|------------|---------|---|---|
| 100 | Manikaran Analytics Limited Fatehgarh-III                    | QCA    | NRRMA1QCA | 04-01-2025 | 0       | 0 | 0 |
| 101 | ABC Renewable Energy (RJ-01) Private Limited                 | REGS   | NRRABCGN  | 12-04-2022 | 300     | 0 | 0 |
| 102 | ACME Chittorgarh Solar Energy Pvt Ltd                        | REGS   | NRRAC1GN  | 03-10-2019 | 250     | 0 | 0 |
| 103 | ACME Deoghar Solar Power Private Limited                     | REGS   | NRRADS5GN | 02-04-2024 | 300     | 0 | 0 |
| 104 | ACME Dhaulpur Powertech Private Limited                      | REGS   | NRRADPGN  | 16-10-2024 | 300     | 0 | 0 |
| 105 | ACME Heergarh Powertech Private Limited                      | REGS   | NRRAC2GN  | 24-03-2022 | 300     | 0 | 0 |
| 106 | ACME Phalodi Solar Energy Private Limited                    | REGS   | NRRAS5GN  | 05-09-2024 | 300     | 0 | 0 |
| 107 | ACME Raisar Solar Energy Private Limited                     | REGS   | NRRARS5GN | 16-10-2024 | 300     | 0 | 0 |
| 108 | ACME Sikar Solar Private Limited                             | REGS   | NRRAS5GN  | 12-02-2025 | 300     | 0 | 0 |
| 109 | Adani Green Energy Twenty Five Limited                       | REGS   | NRRAG25GN | 14-08-2024 | 500     | 0 | 0 |
| 110 | Adani Green Energy Twenty Four Limited                       | REGS   | NRRAG24GN | 19-11-2024 | 500     | 0 | 0 |
| 111 | Adani Hybrid Energy Jaisalmer Four Limited Fatehgarh-I       | REGS   | NRRAH4GN  | 16-11-2021 | 1110.36 | 0 | 0 |
| 112 | Adani Hybrid Energy Jaisalmer One Limited                    | REGS   | NRRAH1GN  | 26-07-2021 | 461     | 0 | 0 |
| 113 | Adani Hybrid Energy Jaisalmer Three Limited                  | REGS   | NRRAH3GN  | 01-10-2021 | 375.8   | 0 | 0 |
| 114 | Adani Hybrid Energy Jaisalmer Two Limited                    | REGS   | NRRAH2GN  | 01-10-2021 | 375.8   | 0 | 0 |
| 115 | Adani Renewable Energy (RJ) Limited Rawara                   | REGS   | NRRAS1GN  | 13-04-2020 | 200     | 0 | 0 |
| 116 | Adani Solar Energy Four Limited, Rawara                      | REGS   | NRRKS1GN  | 13-04-2020 | 50      | 0 | 0 |
| 117 | Adani Solar Energy Jaisalmer One Private Limited             | REGS   | NRRAS1GN  | 13-10-2022 | 526.87  | 0 | 0 |
| 118 | Adani Solar Energy Jaisalmer Two Private Limited             | REGS   | NRRS33GN  | 11-08-2021 | 150     | 0 | 0 |
| 119 | Adani Solar Energy Jaisalmer Two Private Limited (Project-2) | REGS   | NRRS8P2GN | 12-09-2023 | 150     | 0 | 0 |
| 120 | Adani Solar Energy Jodhpur Five Private Limited Bhadla       | REGS   | NRRS81GN  | 26-04-2019 | 200     | 0 | 0 |
| 121 | Adani Solar Energy Jodhpur Six Private Limited               | REGS   | NRRAS6GN  | 26-06-2025 | 50      | 0 | 0 |
| 122 | Adani Solar Energy Jodhpur Two Limited, Rawara               | REGS   | NRRAG1GN  | 06-07-2020 | 50      | 0 | 0 |
| 123 | Adani Solar Energy RJ One Private Limited Bhadla             | REGS   | NRRS86GN  | 07-05-2021 | 300     | 0 | 0 |
| 124 | ADANI SOLAR ENRGY RJ TWO PRIVATE LIMITED                     | REGS   | NRRAS2GN  | 17-01-2024 | 180     | 0 | 0 |
| 125 | ADEPT RENEWABLE TECHNOLOGIES PRIVATE LIMITED                 | REGS   | NRRARTGN  | 01-01-2024 | 110     | 0 | 0 |
| 126 | Altra Xergi Power Private Limited                            | REGS   | NRRAXPGN  | 05-12-2023 | 380     | 0 | 0 |
| 127 | AMP ENERGY GREEN FIVE PRIVATE LIMITED                        | REGS   | NRRAS5GN  | 28-03-2024 | 100     | 0 | 0 |
| 128 | AMP ENERGY GREEN FOUR PRIVATE LIMITED                        | REGS   | NRRAG4GN  | 16-10-2024 | 100     | 0 | 0 |
| 129 | AMP ENERGY Green Six Private Limited                         | REGS   | NRRAMPGN  | 31-10-2023 | 100     | 0 | 0 |
| 130 | AMPLUS AGES PRIVATE LIMITED                                  | REGS   | NRRRAAGN  | 30-10-2023 | 100     | 0 | 0 |
| 131 | Auraiya Solar Power Plant NTPC Ltd.                          | REGS   | NRRAS5GN  | 28-09-2020 | 40      | 0 | 0 |
| 132 | Avaada RJHN Private Limited Bikaner                          | REGS   | NRRAS2GN  | 09-12-2021 | 240     | 0 | 0 |
| 133 | Avaada Sunce Energy Private Limited Bikaner                  | REGS   | NRRAS1GN  | 03-12-2021 | 350     | 0 | 0 |
| 134 | Avaada Sunrays Energy Private Limited                        | REGS   | NRRAS4GN  | 29-07-2022 | 320     | 0 | 0 |
| 135 | Avaada Sustainable RJProject Private Limited Bikaner         | REGS   | NRRAS3GN  | 05-01-2022 | 300     | 0 | 0 |
| 136 | Ayana Renewable Power One Private Limited, Bikaner           | REGS   | NRRAS1GN  | 30-12-2021 | 300     | 0 | 0 |
| 137 | AYANA RENEWABLE POWER THREE PRIVATE LIMITED                  | REGS   | NRRAS3GN  | 30-03-2024 | 300     | 0 | 0 |
| 138 | Azure Power Forty One Private Limited Bhadla                 | REGS   | NRRAS4GN  | 07-07-2021 | 300     | 0 | 0 |
| 139 | Azure Power Forty Three Private Limited                      | REGS   | NRRAS3GN  | 09-11-2020 | 600     | 0 | 0 |
| 140 | AZURE POWER INDIA Pvt. Ltd., Bhadla (SPD)                    | REGS   | NRRAB1GN  | 23-04-2019 | 200     | 0 | 0 |
| 141 | Azure Power Maple Private Limited                            | REGS   | NRRAS5GN  | 27-09-2021 | 300     | 0 | 0 |
| 142 | Azure Power Thirty Four Pvt. Ltd. Bhadla                     | REGS   | NRRAS2GN  | 29-08-2019 | 130     | 0 | 0 |
| 143 | Banderwala Solar Plant TPSEL                                 | REGS   | NRRTP2GN  | 01-02-2024 | 300     | 0 | 0 |
| 144 | Clean Solar Power (Bhadla) Pvt. Ltd                          | REGS   | NRRCB1GN  | 03-10-2019 | 300     | 0 | 0 |
| 145 | Clean Solar Power (Jodhpur) Private Limited Bhadla           | REGS   | NRRCB2GN  | 09-02-2022 | 250     | 0 | 0 |
| 146 | DADRI SOLAR PV POWER STATION                                 | REGS   | NRRDS1GN  | 06-02-2013 | 5       | 0 | 0 |
| 147 | Devikot Solar Power Plant NGEL                               | REGS   | NRRND1GN  | 10-11-2022 | 240     | 0 | 0 |
| 148 | Eden Renewable Alma Private Limited                          | REGS   | NRRERAGN  | 22-05-2025 | 300     | 0 | 0 |
| 149 | Eden Renewable Cite Private Limited                          | REGS   | NRRD1GN   | 31-05-2021 | 300     | 0 | 0 |
| 150 | Gorbea Solar Private Limited                                 | REGS   | NRRGSPGN  | 13-01-2025 | 300     | 0 | 0 |
| 151 | Grian Energy Private Limited                                 | REGS   | NRRRGEGN  | 30-10-2023 | 100     | 0 | 0 |
| 152 | Juna Renewable Energy Private Limited                        | REGS   | NRRJREGN  | 04-04-2025 | 335     | 0 | 0 |
| 153 | JUNIPER GREEN COSMIC PRIVATE LIMITED                         | REGS   | NRRJG1GN  | 06-08-2024 | 100     | 0 | 0 |
| 154 | Juniper Nirjara Energy Private Limited                       | REGS   | NRRJNEGN  | 07-02-2025 | 50      | 0 | 0 |
| 155 | Karinsar Solar Plant NHPC Ltd                                | REGS   | NRRKNHSPD | 07-03-2025 | 300     | 0 | 0 |
| 156 | Khidrat Renewable Energy Private Limited                     | REGS   | NRRKREGN  | 15-04-2025 | 300     | 0 | 0 |
| 157 | Kolayat Solar Power Plant NGEL                               | REGS   | NRRNK1GN  | 06-06-2022 | 550     | 0 | 0 |
| 158 | Mega Solis Renewables Private Limited                        | REGS   | NRRMRS5GN | 04-02-2021 | 250     | 0 | 0 |
| 159 | Mega Suryaurja Private Limited                               | REGS   | NRRMS1GN  | 09-05-2022 | 250     | 0 | 0 |
| 160 | Neemba Solar Plant Renew Surya Vihaan Private Limited        | REGS   | NRRRV2GN  | 21-03-2025 | 200     | 0 | 0 |
| 161 | Nidan Solar Power Plant NGEL                                 | REGS   | NRRNSFGN  | 03-12-2021 | 296     | 0 | 0 |
| 162 | Nokh Solar Power Plant NTPC Limited                          | REGS   | NRRNSPGN  | 24-01-2025 | 735     | 0 | 0 |
| 163 | Nokhra Solar Plant NGEL                                      | REGS   | NRRNN1GN  | 25-11-2022 | 300     | 0 | 0 |
| 164 | NTPC ANTA SOLAR PV STATION                                   | REGS   | NRRASPGN  | 26-03-2024 | 90      | 0 | 0 |
| 165 | Onevolt Energy Private Limited                               | REGS   | NRRDEPGN  | 11-09-2023 | 100     | 0 | 0 |
| 166 | Phalodi Solar Plant ASERJ2PL                                 | REGS   | NRRAS3GN  | 27-03-2024 | 150     | 0 | 0 |
| 167 | ReNew Solar Energy Jharkhand Three Pvt. Ltd.                 | REGS   | NRRRF2GN  | 11-08-2021 | 300     | 0 | 0 |
| 168 | Renew Solar Power Pvt Ltd, Bikaner (250MW)                   | REGS   | NRRRB2GN  | 22-10-2019 | 250     | 0 | 0 |
| 169 | RENEW SOLAR POWER Pvt. Ltd. Bhadla, (SPD)                    | REGS   | NRRRB1GN  | 22-04-2019 | 50      | 0 | 0 |
| 170 | ReNew Solar Urja Pvt Ltd                                     | REGS   | NRRRF4GN  | 22-11-2021 | 300     | 0 | 0 |
| 171 | Renew Sun Bright Private Limited                             | REGS   | NRRRF3GN  | 14-10-2021 | 300     | 0 | 0 |
| 172 | Renew Surya Aayan Private Limited                            | REGS   | NRRRSAGN  | 27-12-2023 | 300     | 0 | 0 |
| 173 | Renew Surya Jyoti Private Limited                            | REGS   | NRRRS1GN  | 20-03-2025 | 210     | 0 | 0 |
| 174 | Renew Surya Pratap Private Limited                           | REGS   | NRRRSPGN  | 08-12-2023 | 200     | 0 | 0 |
| 175 | Renew Surya Ravi Private Limited Bikaner                     | REGS   | NRRRB3GN  | 12-01-2022 | 300     | 0 | 0 |
| 176 | Renew Surya Roshni Private Limited                           | REGS   | NRRRSRGN  | 25-01-2024 | 423     | 0 | 0 |
| 177 | Renew Surya Vihaan Private Limited                           | REGS   | NRRRSVGN  | 12-12-2023 | 100     | 0 | 0 |
| 178 | Rising Sun Energy (K) Private Limited                        | REGS   | NRRRSEGN  | 21-07-2023 | 190     | 0 | 0 |
| 179 | Serentica Renewables India 4 Private Limited                 | REGS   | NRRSR4GN  | 07-03-2024 | 180     | 0 | 0 |
| 180 | SERENTICA RENEWABLES INDIA 5 PVT LTD                         | REGS   | NRRSR5GN  | 27-03-2024 | 220     | 0 | 0 |
| 181 | SINGRAULI SOLAR PV POWER STATION                             | REGS   | NRRSS1GN  | 26-12-2014 | 15      | 0 | 0 |
| 182 | SJVN Green Energy Ltd (SGEL)                                 | REGS   | NRRSGEGN  | 05-03-2025 | 1000    | 0 | 0 |
| 183 | Solar Power Plant of Ambuja Cements Limited                  | REGS   | NRRAC1GN  | 30-06-2025 | 150     | 0 | 0 |
| 184 | Solzen Urja Private Limited                                  | REGS   | NRRRF1GN  | 23-07-2021 | 300     | 0 | 0 |
| 185 | Tata Power Green Energy Limited                              | REGS   | NRRTPGGN  | 04-07-2022 | 225     | 0 | 0 |
| 186 | Thar Surya 1 Private Limited                                 | REGS   | NRRTS1GN  | 14-01-2022 | 300     | 0 | 0 |
| 187 | TP Saurya Limited  | REGS   | NRRTPSGN  | 18-05-2023 | 110     | 0 | 0 |
| 188 | TPREL (Chhayan)  | REGS   | NRRTC1GN  | 21-08-2019 | 300     | 0 | 0 |
| 189 | TRANSITION CLEANTECH SERVICES PRIVATE LIMITED                | REGS   | NRRTC5GN  | 30-01-2024 | 24.4    | 0 | 0 |
| 190 | TRANSITION ENERGY SERVICES PRIVATE LIMITED                   | REGS   | NRRTESGN  | 08-01-2024 | 84.4    | 0 | 0 |
| 191 | TRANSITION GREEN ENERGY PRIVATE LIMITED                      | REGS   | NRRTEGEGN | 19-03-2024 | 100     | 0 | 0 |
| 192 | TRANSITION SUSTAINABLE ENERGY SERVICES ONE PRIVATE LIMITED   | REGS   | NRRTS2GN  | 16-09-2024 | 55.6    | 0 | 0 |
| 193 | TRANSITION SUSTAINABLE ENERGY SERVICES PRIVATE LIMITED       | REGS   | NRRTSEGN  | 19-03-2024 | 50      | 0 | 0 |
| 194 | Uncharhar Solar PV Plant                                     | REGS   | NRRUS1GN  | 27-03-2014 | 10      | 0 | 0 |
| 195 | XL Xergi Power Private Limited                               | REGS   | NRRXPGN   | 11-04-2025 | 400     | 0 | 0 |
| 196 | Delhi Seller (PPCL, Bawana)                                  | Seller | NRRPPDSL  | 01-03-2021 | 274     | 0 | 0 |
| 197 | Haryana Seller   | Seller | NRRHR1SL  | 21-09-2011 | 124     | 0 | 0 |
| 198 | HP Seller  | Seller | NRRHP1SL  | 09-06-2011 | 217.1   | 0 | 0 |

|     |  |                       |          |            |    |          |        |
|-----|--|-----------------------|----------|------------|----|----------|--------|
| 200 | Rajasthan Seller                                   | Seller                | NRRRJ1SL | 10-08-2011 | 58 | 0        | 0      |
| 201 | UP Seller (MUNPL)                                  | Seller                | NRRMU1SL | 26-02-2021 | 0  | 0        | 0      |
| 202 | AD Hydro Power Limited (ADHPL)                     | Transmission Licensee | NRRAD1TL | 08-05-2023 | 0  | 353.3    | 0      |
| 203 | Adani Transmission India Ltd.                      | Transmission Licensee | NRRAP1TL | 23-09-2013 | 0  | 2528     | 0      |
| 204 | Aravali Power Company Private Limited              | Transmission Licensee | NRRAR1TL | 02-04-2014 | 0  | 131.38   | 0      |
| 205 | BIKANER-KHETRI TRANSMISSION LIMITED                | Transmission Licensee | NRRBK1TL | 23-04-2021 | 0  | 481.3    | 0      |
| 206 | Fatehgarh Bhadla Transmission Limited              | Transmission Licensee | NRRFB1TL | 16-12-2020 | 0  | 291.94   | 0      |
| 207 | Gurgoan Palwal Transmission Limited                | Transmission Licensee | NRRGP1TL | 26-04-2019 | 0  | 272.92   | 3000   |
| 208 | NRSS XXIX Transmission Ltd.                        | Transmission Licensee | NRRN29TL | 05-06-2015 | 0  | 853.62   | 630    |
| 209 | NRSS XXXI (B) Transmission Ltd.                    | Transmission Licensee | NRR318TL | 23-11-2016 | 0  | 577.6    | 0      |
| 210 | NRSS XXXVI Transmission Ltd.                       | Transmission Licensee | NRRN36TL | 14-06-2017 | 0  | 225      | 0      |
| 211 | Parbati Koldam Transmission Company LTD.           | Transmission Licensee | NRRPK1TL | 11-02-2014 | 0  | 457.92   | 0      |
| 212 | PATRAN TRANSMISSION COMPANY LIMITED                | Transmission Licensee | NRRPT1TL | 07-05-2016 | 0  | 0.1      | 1500   |
| 213 | Power Grid Corporation India Ltd.                  | Transmission Licensee | NRRPG1TL | 09-06-2011 | 0  | 52875.64 | 155465 |
| 214 | Power Transmission corporation of Uttarakhand Ltd. | Transmission Licensee | NRRUT1TL | 29-09-2016 | 0  | 178.48   | 950    |
| 215 | POWERGRID AJMER PHAGI TRANSMISSION LIMITED         | Transmission Licensee | NRRPAPTL | 07-03-2022 | 0  | 268.8    | 0      |
| 216 | Powergrid Aligarh Sikar Transmission Limited       | Transmission Licensee | NRRPASTL | 08-08-2023 | 0  | 513.874  | 0      |
| 217 | POWERGRID BEAWAR DAUSA TRANSMISSION LIMITED        | Transmission Licensee | NRRPBDTL | 10-06-2025 | 0  | 1365.89  | 3000   |
| 218 | POWERGRID BHADLA SIKAR TRANSMISSION LIMITED        | Transmission Licensee | NRRPBSTL | 17-10-2024 | 0  | 0        | 0      |
| 219 | Powergrid Bhadla Transmission Limited              | Transmission Licensee | NRRPB2TL | 27-04-2023 | 0  | 202.23   | 0      |
| 220 | POWERGRID BIKANER TRANSMISSION SYSTEM LIMITED      | Transmission Licensee | NRRPB1TL | 14-09-2022 | 0  | 1353.32  | 4000   |
| 221 | POWERGRID Fatehgarh Transmission Limited           | Transmission Licensee | NRRPF1TL | 13-07-2021 | 0  | 370.37   | 0      |
| 222 | Powergrid Himachal Transmission Limited            | Transmission Licensee | NRRJP1TL | 16-05-2011 | 0  | 448.95   | 0      |
| 223 | POWERGRID KALA AMB Transmission Ltd.               | Transmission Licensee | NRRPGKTL | 03-07-2017 | 0  | 2.47     | 630    |
| 224 | Powergrid Khetri Transmission System Limited       | Transmission Licensee | NRRKT1TL | 26-07-2021 | 0  | 448.2    | 3000   |
| 225 | POWERGRID NARELA TRANSMISSION LIMITED              | Transmission Licensee | NRRPN1TL | 02-02-2024 | 0  | 0        | 0      |
| 226 | POWERGRID NEEMUCH TRANSMISSION LIMITED             | Transmission Licensee | NRRPNTTL | 20-02-2024 | 0  | 116.2    | 1000   |
| 227 | POWERGRID RAMGARH TRANSMISSION LIMITED             | Transmission Licensee | NRRPR1TL | 27-06-2023 | 0  | 188.12   | 3500   |
| 228 | POWERGRID SIKAR TRANSMISSION LIMITED               | Transmission Licensee | NRRPS1TL | 24-05-2024 | 0  | 885.544  | 3000   |
| 229 | POWERGRID UNCHAHAR TRANSMISSION Ltd.               | Transmission Licensee | NRRPU1TL | 31-03-2017 | 0  | 106.74   | 0      |
| 230 | Powergrid Varanasi Transmission System Limited     | Transmission Licensee | NRRPV1TL | 14-07-2021 | 0  | 189.42   | 0      |
| 231 | POWERLINKS Transmission Limited                    | Transmission Licensee | NRRPL1TL | 07-04-2010 | 0  | 1224.11  | 0      |
| 232 | RAPP Transmission Company Ltd.                     | Transmission Licensee | NRRRA1TL | 29-09-2015 | 0  | 201.6    | 0      |

Note :

1. Malana -II HPS (Registration No - NRRMA2SL) has been de- registered from 05.12.2019 due to change in control area from NRLDC to HP SLDC
2. Mahoba Solar (UP) Pvt Ltd. has been registered as Adani Renewable Energy (RJ) Limited Rawara (NRRAS1GN)
3. Name of Kilaj Solar (Maharashtra) Private Limited Rawara has been changed to Adani Solar Energy Four Private Limited. Rawara
4. Name of 'Jaypee Powergrid Limited' has been changed to 'Powergrid Himachal Transmission Limited'
5. Name of 'SB ENERGY FOUR PRIVATE LIMITED, Bhadla,' has been changed to 'Adani Solar Energy Jodhpur Five Private Limited' vide letter dated 12.04.2022
6. Name of 'SB Energy Six Private Limited (SPD)' has been changed to 'Adani Solar Energy RJ One Private Limited' vide letter dated 12.04.2022
7. Name of "Adani Solar Energy Four Private Limited Rawara" has been changed to Adani Solar Energy Four Limited, Rawara on dated 07.09.2022
8. Name of "Devikot Solar Power Plant NTPC Ltd" has been changed to "Devikot Solar Power Plant NGEL" on dated 15.05.2023
9. Name of "Nidan Solar Power Plant NTPC LTD" has been changed to "Nidan Solar Power Plant NGEL" on dated 15.05.2023
10. Name of "Nokhra Solar Plant NTPC LTD" has been changed to "Nokhra Solar Plant NGEL" on dated 15.05.2023
11. Name of "Kolayat Solar Power Plant NTPC LTD" has been changed to "Kolayat Solar Power Plant NGEL" on dated 26.06.2023
12. Name of "SBSR Power Cleantech Eleven Private Limited, Bikaner" has been changed to "Adani Solar Energy Jaisalmer Two Private Limited" on dated 07.08.2023.
13. Name of "RENEW SUN WAVES PRIVATE LIMITED" has been changed to "Solzen Urja Private Limited" on dated 29.05.2025.

## Grid Event summary for July 2025

| S.No. | Category of Grid Incident/<br>Disturbance | Name of Elements<br>(Tripped/Manually opened)   | Affected Area | Owner/ Agency   | Outage    |       | Energy Unserved due to Generation loss (MU) | Energy Unserved due to Load loss (MU) | Loss of generation / loss of load during the Grid Disturbance |                | % Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Disturbance |                  | Antecedent Generation/Load in the Regional Grid |                      | Fault Clearance time (in ms) | Compliance of Protection Protocol/Standard |                        |   | Remarks |
|-------|---|---|---------------|-----------------|-----------|-------|---|---------------------------------------|---|----------------|---|------------------|---|----------------------|------------------------------|--|------------------------|---|---------|
|       | ( GI-I to GD-V)                           |   |               |                 | Date      | Time  |   |                                       | Generation Loss(MW)   | Load Loss (MW) | % Generation Loss(MW)   | % Load Loss (MW) | Antecedent Generation (MW)                      | Antecedent Load (MW) |                              | Flash Report Submission (Y/N)              | DR/EL Submission (Y/N) | Detail Tripping Report Submission (Y/N) |         |
| 1     | GD-1                                      | 1) 220 KV Mogal(PG)-Moga(PS) (PSTCL) Ckt-2<br>2) 220 KV Mogal(PG)-Moga(PS) (PSTCL) Ckt-3<br>3) 220 KV Mogal(PG)-Moga(PS) (PSTCL) Ckt-4<br>4) 220 KV Mogal(PS)-Kotkaror (PSTCL) Ckt-1<br>5) 220 KV Mogal(PS)-Kotkaror (PSTCL) Ckt-2<br>6) 220KV Mogal(PS)-Sadiq Ckt<br>7) 220KV GHTP-Himmatpura (PS) Ckt-1<br>8) 220KV GHTP-Himmatpura (PS) Ckt-2<br>9) 220 KV Mogal(PG)-Badhni kalan(PS) (PSTCL) Ckt-1<br>10) 220 KV Mogal(PG)-Ajitwal(PS) (PSTCL) Ckt-1<br>11) 220KV Ajitwal-Himmatpura (PS) Ckt<br>12) 220KV Badhni kalan-Himmatpura (PS) Ckt | Punjab        | PGCIL, PSTCL    | 1-Jul-25  | 11:06 | 0   | 0.446                                 | 0   | 582            | 0.000   | 0.880            | 59227   | 66112                | 240                          | Y(d)                                       | Y(d)                   | Y                                       |         |
| 2     | GI-1                                      | 1) 220/33 kv 100 MVA ICT 2 at RSDCL(PSS2)_SL_BHD2_PG<br>2) 220/33 kv 100 MVA ICT 3 at RSDCL(PSS2)_SL_BHD2_PG  | Rajasthan     | RSDCL PSS2      | 3-Jul-25  | 11:21 | 0   | 0                                     | 165   | 0              | 0.271   | 0.000            | 60870   | 73042                | NA                           | N  | N                      | N                                       |         |
| 3     | GI-1                                      | 1) 220/33 kv 100 MVA ICT 1 at RSDCL(PSS2)_SL_BHD2_PG  | Rajasthan     | RSDCL PSS2      | 4-Jul-25  | 13:46 | 0   | 0                                     | 225   | 0              | 0.345   | 0.000            | 65126   | 78965                | 1200                         | N  | N                      | N                                       |         |
| 4     | GI-1                                      | 1) 220 kv Patparganj-IPPOS (DTL) Ckt-1<br>2) 220 kv Patparganj-IPPOS (DTL) Ckt-2<br>3) 220 kv Patparganj-Geeta Colony (DTL) Ckt-1<br>4) 220 kv Patparganj-Geeta Colony (DTL) Ckt-2<br>5) 220 kv Patparganj-Ghazipur (DTL) Ckt<br>6) 220/66kv 100MVA ICT-1 at Patparganj(DTL)<br>7) 220/66kv 100MVA ICT-2 at Patparganj(DTL)<br>8) 220 kv Rajghat-IPPOS (DTL) Ckt-1<br>9) 220 kv Rajghat-IPPOS (DTL) Ckt-2<br>10) 104 MW GT-1 at Pragati (PPCL)<br>11) 122 MW STG at Pragati (PPCL)  | Delhi         | DTL, PPCL       | 9-Jul-25  | 17:31 | 0   | 0.045                                 | 184   | 270            | 0.333   | 0.394            | 55296   | 68469                | 120                          | Y(d)                                       | N                      | N                                       |         |
| 5     | GD-1                                      | 1) 220 KV Bhadla(PG)-ESUCRL SL_BHD_PG (ESUCRL) (ESUCRL) Ckt-1   | Rajasthan     | ESUCRL, PGCIL   | 10-Jul-25 | 13:15 | 0   | 0                                     | 410   | 0              | 0.703   | 0.000            | 58326   | 63284                | 120                          | Y(d)(PG),<br>N(ESUCRL)                     | Y(d)(PG),<br>N(ESUCRL) | Y(d)(PG),<br>N(ESUCRL)                  |         |
| 6     | GI-1                                      | 1) 220 KV Mandola(PG)-Narela(DV) (DTL) Ckt-1<br>2) 220 KV Mandola(PG)-Narela(DV) (DTL) Ckt-2  | Delhi         | PGCIL, DTL      | 10-Jul-25 | 15:41 | 0   | 0.089                                 | 0   | 280            | 0.000   | 0.431            | 58212   | 64979                | 480                          | Y(d)                                       | N                      | N                                       |         |
| 7     | GD-1                                      | 1) 220KV Bus 1 at Jamalpur(BB)<br>2) 220KV Bus 2 at Jamalpur(BB)<br>3) 220 KV Jalandhar-Jamalpur (BB) Ckt-1<br>4) 220 KV Jalandhar-Jamalpur (BB) Ckt-2<br>5) 220 KV Jamalpur(BB)-Sangrur(BB) (BBMB) Ckt-1<br>6) 220 KV Jamalpur(BB)-Sangrur(BB) (BBMB) Ckt-2<br>7) 220 KV Ganguwal-Jamalpur (BB) Ckt-1<br>8) 220 KV Ganguwal-Jamalpur (BB) Ckt-2<br>9) 220 KV Bhakra_R-Jamalpur (BB) Ckt-1<br>10) 220 KV Bhakra_R-Jamalpur (BB) Ckt-2   | Punjab        | BBMB            | 12-Jul-25 | 11:43 | 0   | 0.462                                 | 0   | 355            | 0.000   | 0.496            | 59924   | 71529                | 120                          | Y  | N                      | N                                       |         |
| 8     | GD-1                                      | 1) 400 KV Bikaner_2 (PBTSL)-SJVN_GEL_SL_BKN2 (SJVNGEL_BKN2) Ckt   | Rajasthan     | PGCIL, SJVN GEL | 12-Jul-25 | 15:41 | 0   | 0                                     | 270   | 0              | 0.441   | 0.000            | 61285   | 69260                | NA                           | N  | N                      | N                                       |         |

| S.No. | Category of Grid Incident/<br>Disturbance | Name of Elements<br>(Tripped/Manually opened)   | Affected Area     | Owner/ Agency         | Outage    |       | Energy Unserved due to Generation loss (MU) | Energy Unserved due to Load loss (MU) | Loss of generation / loss of load during the Grid Disturbance |                | % Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Disturbance |                  | Antecedent Generation/Load in the Regional Grid |                      | Fault Clearance time (in ms) | Compliance of Protection Protocol/Standard |                           |   | Remarks  |
|-------|---|---|-------------------|-----------------------|-----------|-------|---|---------------------------------------|---|----------------|---|------------------|---|----------------------|------------------------------|--|---------------------------|---|--|
|       |   |   |                   |                       | Date      | Time  |   |                                       | Generation Loss(MW)   | Load Loss (MW) | % Generation Loss(MW)   | % Load Loss (MW) | Antecedent Generation (MW)                      | Antecedent Load (MW) |                              | Flash Report Submission (Y/N)              | DR/EL Submission (Y/N)    | Detail Tripping Report Submission (Y/N) |  |
| 9     | GD-1                                      | 1) 220 KV Khodri(UK)-Majri(HP) (UK) Ckt-1<br>2) 220 KV Khodri(UK)-Majri(HP) (UK) Ckt-2<br>3) 220 KV Khodri - Chhibro (UK) Ckt-1<br>4) 220 KV Khodri - Chhibro (UK) Ckt-2<br>5) 220 KV Sarsawan(UP)-Khodri(UK) (UP) Ckt<br>6) 220 KV Saharanpur(UP)-Khodri(UK) (UP) Ckt<br>7) 220/132 kv 100 MVA ICT at Khodri(UK)<br>8) 30 MW Unit-1 at Khodri(UK)<br>9) 30 MW Unit-2 at Khodri(UK)<br>10) 30 MW Unit-3 at Khodri(UK)<br>11) 30 MW Unit-4 at Khodri(UK)<br>12) 60 MW Unit-1 at Chhibro(UK)<br>13) 60 MW Unit-2 at Chhibro(UK)<br>14) 60 MW Unit-3 at Chhibro(UK)<br>15) 60 MW Unit-4 at Chhibro(UK) | Uttarakhand       | PTCUL, HPPTCL, UPPTCL | 15-Jul-25 | 12:28 | 0   | 0                                     | 290   | 0              | 0.483   | 0.000            | 60021   | 66509                | 240                          | Y(d)                                       | Y(d)(Utt), Y(d)(HP) N(UP) | N (Partial details received)            | Detailed report yet to be received from UUVUNL/PTCUL |
| 10    | GD-1                                      | 1) 220 KV Kishenpur(PG)- Salal(NH) (PG) Ckt-1<br>2) 220 KV Kishenpur(PG)-Salal(NH) (PG) Ckt-2<br>3) 220 KV Kishenpur(PG)- Salal(NH) (PG) Ckt-3<br>4) 220 KV Kishenpur(PG)-Salal(NH) (PG) Ckt-4<br>5) 220 KV Salal(NH)-Jammu(PDD) (PG) Ckt-1<br>6) 220 KV Salal(NH)-Jammu(PDD) (PG) Ckt-2<br>7) 115 MW Unit-1 at Salal HEP<br>8) 115 MW Unit-2 at Salal HEP<br>9) 115 MW Unit-3 at Salal HEP<br>10) 115 MW Unit-5 at Salal HEP<br>11) 115 MW Unit-6 at Salal HEP   | Jammu and Kashmir | PGCIL, NHPC, PDD JK   | 15-Jul-25 | 11:17 | 0   | 0.125                                 | 395   | 175            | 0.663   | 0.266            | 59590   | 65841                | 80                           | Y(d)                                       | Y(d)                      | Y(d)                                    |  |
| 11    | GD-1                                      | 1) 220 KV Alusteng-Drass (PG) Ckt   | Jammu and Kashmir | PGCIL                 | 16-Jul-25 | 13:42 | 0   | 0                                     | 62  | 0              | 0.101   | 0.000            | 61467   | 65038                | 80                           | Y(d)                                       | Y(d)(PG), N(J&K)          | Y(d)(PG), N(J&K)                        |  |
| 12    | GI-2                                      | 1) 400 KV OBRA_C_TPS-OBRA_B (UP) CKT<br>2) 400 KV ANPARA-OBRA_B (UP) CKT<br>3) 400 KV OBRA_B-SULTANPUR (UP) CKT<br>4) 400 KV OBRA_B-ALLAHABAD REWA ROAD (UP) CKT<br>5) 200 MW UNIT-9 AT OBRA TPS<br>6) 200 MW UNIT-10 AT OBRA TPS<br>7) 200 MW UNIT-11 AT OBRA TPS<br>8) 200 MW UNIT-13 AT OBRA TPS   | Uttar Pradesh     | UPPTCL                | 16-Jul-25 | 17:05 | 0   | 0                                     | 355   | 0              | 0.625   | 0.000            | 56777   | 63505                | NA                           | Y(d)                                       | Y(d)                      | Y(d)                                    |  |
| 13    | GI-1                                      | 1) 220 KV Khodri(UK)-Majri(HP) (UK) Ckt-1<br>2) 220 KV Khodri(UK)-Majri(HP) (UK) Ckt-2<br>3) 220 KV Khodri - Chhibro (UK) Ckt-2<br>4) 220 KV Saharanpur(UP)-Khodri(UK) (UP) Ckt<br>5) 220/132 kv 100 MVA ICT at Khodri(UK)<br>6) 30 MW Unit-2 at Khodri(UK)<br>7) 30 MW Unit-3 at Khodri(UK)<br>8) 30 MW Unit-4 at Khodri(UK)<br>9) 60 MW Unit-3 at Chhibro(UK)   | Uttarakhand       | PTCUL, HPPTCL, UPPTCL | 20-Jul-25 | 18:44 | 0   | 0                                     | 114   | 0              | 0.218   | 0.000            | 52315   | 66401                | 160                          | Partial details received                   | Partial details received  | Partial details received                |  |
| 14    | GD-1                                      | 1) 220 KV Bhadla_2 (PG)-RSDCL(PSS2)_SL_BHD2_PG (RSDCL) Ckt-1  | Rajasthan         | RSDCL PSS2, PGCIL     | 22-Jul-25 | 09:49 | 0   | 0                                     | 229   | 0              | 0.380   | 0.000            | 60273   | 68952                | 520                          | N  | N                         | N                                       |  |
| 15    | GD-1                                      | 1) 765kV Koteswar-Meerut (PG) ckt-2<br>2) 250 MW Tehri HEP Unit-1<br>3) 250 MW Tehri HEP Unit-2<br>4) 250 MW Tehri HEP Unit-3<br>5) 250 MW Tehri HEP Unit-4<br>6) 250 MW Tehri PSP HEP Unit-5<br>7) 100 MW Koteswar HEP Unit-1<br>8) 100 MW Koteswar HEP Unit-2<br>9) 100 MW Koteswar HEP Unit-3<br>10) 100 MW Koteswar HEP Unit-4  | Uttarakhand       | PGCIL, THDC           | 22-Jul-25 | 19:46 | 0   | 0                                     | 1435  | 0              | 2.705   | 0.000            | 53059   | 71591                | 80                           | Y(d)                                       | Y(d)                      | Y(d)                                    |  |
| 16    | GD-1                                      | 1) 220KV Bus 2A at Panipat(BB)<br>2) 400/220KV 500 MVA ICT-2 at Panipat(BB)<br>3) 220 KV Panipat-Dhulkote(BB) Ckt-2<br>4) 220 KV Panipat(BB)-Panipat Th(HR) Ckt-2<br>5) 220 KV Panipat(BB)-Narela (DTL) Ckt-2<br>6) 220 KV Panipat(BB)-Charkhi Dadri Ckt<br>7) 220/66kV 60 MVA Transformer-2 at Panipat(BB)<br>8) 400/220KV 450 MVA ICT-1 at Panipat(BB)<br>9) 220 KV Ganguwali-Jagadhri Ckt  | Haryana           | HVPNL, BBMS, DTL      | 24-Jul-25 | 09:49 | 0   | 0.506                                 | 0   | 515            | 0.000   | 0.728            | 65937   | 70779                | 240                          | Y(d)                                       | Y(d)                      | Y(d)                                    |  |



| S.No. | Category of Grid Incident/<br>Disturbance | Name of Elements<br>(Tripped/Manually opened)  | Affected Area     | Owner/ Agency    | Outage    |       | Energy Unserved due to Generation loss (MU) | Energy Unserved due to Load loss (MU) | Loss of generation / loss of load during the Grid Disturbance |                | % Loss of generation / loss of load w.r.t Antecedent Generation/Load in the Regional Grid during the Grid Disturbance |                  | Antecedent Generation/Load in the Regional Grid |                      | Fault Clearance time (in ms) | Compliance of Protection Protocol/Standard |                        |   | Remarks  |
|-------|---|--|-------------------|------------------|-----------|-------|---|---------------------------------------|---|----------------|---|------------------|---|----------------------|------------------------------|--|------------------------|---|--|
|       | ( GI-I to GD-V)                           |  |                   |                  | Date      | Time  |   |                                       | Generation Loss(MW)   | Load Loss (MW) | % Generation Loss(MW)   | % Load Loss (MW) | Antecedent Generation (MW)                      | Antecedent Load (MW) |                              | Flash Report Submission (Y/N)              | DR/EL Submission (Y/N) | Detail Tripping Report Submission (Y/N) |  |
| 17    | GD-1                                      | 1) 220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-1<br>2) 220 KV Amargarh (INDIGRID)-Ziankote(JK) (PDD JK) Ckt-2   | Jammu and Kashmir | INDIGRID, PDD JK | 24-Jul-25 | 10:18 | 0   | 1.433                                 | 0   | 400            | 0.000   | 0.556            | 68479   | 71887                | 120                          | Y(d)                                       | Y(d)(PG), N(J&K)       | N                                       |  |
| 18    | GD-1                                      | 1) 400 KV Uri_2(NH)-Wagoora(PG) (PG) Ckt<br>2) 60 MW Uri-II HPS - UNIT 1<br>3) 60 MW Uri-II HPS - UNIT 2<br>4) 60 MW Uri-II HPS - UNIT 3<br>5) 60 MW Uri-II HPS - UNIT 4           | Jammu and Kashmir | PGCIL, NHPC      | 25-Jul-25 | 13:44 | 0   | 0                                     | 240   | 0              | 0.357   | 0.000            | 67308   | 80494                | NA                           | Y(d)                                       | Y(d)                   | Y(d)                                    |  |
| 19    | GD-1                                      | 1) 220 KV Dandharikalan(PS)-Ludhiana(PG) (PSTCL) Ckt-1<br>2) 220 KV Dandharikalan(PS)-Ludhiana(PG) (PSTCL) Ckt-2   | Punjab            | PGCIL, PSTCL     | 26-Jul-25 | 12:05 | 0   | 0.455                                 | 0   | 220            | 0.000   | 0.290            | 64426   | 75949                | 120                          | Y(d)                                       | N                      | N                                       | DR/EL & tripping report not received from PSTCL      |
| 20    | GD-1                                      | 1) 220kV Kangoo-Raruri(HP) Ckt<br>2) 220 KV Dehar(BB)-Kangoo(HP) (HP) Ckt<br>3) 132 KV Dehar(BB)-Kangoo(HP) (HPPTCL) Ckt<br>4) 220/132kV 80/100 MVA ICT at Kangoo(HP)              | Himachal Pradesh  | HPPTCL, BBMB     | 27-Jul-25 | 16:46 | 0   | 0.25                                  | 0   | 75             | 0.000   | 0.105            | 55959   | 71103                | 120                          | Y(d)(HP), N(BBMB)                          | N                      | N                                       |  |
| 21    | GI-2                                      | 1) 400 KV Vindhyachal(PG)-Vindhyachal(NT) (PG) Ckt-1<br>2) 400 KV Vindhyachal(PG)-Vindhyachal(NT) (PG) Ckt-2<br>3) 70 KV Vindhyachal(PG) Pole-1<br>4) 70 KV Vindhyachal(PG) Pole-2 | Uttar Pradesh     | PGCIL, NTPC      | 30-Jul-25 | 20:25 | 0   | 0                                     | 0   | 0              | 0.000   | 0.000            | 55429   | 75651                | NA                           | Y  | Y                      | Y                                       | Tripping initiated from Vindhyachal(NTPC) end in WR. |

**Status of submission of FIR/DR/EL/Tripping Report  
on NR Tripping Portal**

**Time Period: 1st July 2025 - 31st July 2025**

| S. No. | Utility                                | Total No. of tripping | First Information Report (Not Received) |     | Disturbance Recorder (Not Received) | Disturbance Recorder (NA) as informed by utility | Disturbance Recorder (Not Received) | Event Logger (Not Received) | Event Logger (NA) as informed by utility | Event Logger (Not Received) | Tripping Report (Not Received) | Tripping Report (NA) as informed by utility | Tripping Report (Not Received) | Remark                                 |
|--------|--|-----------------------|---|-----|-------------------------------------|--|-------------------------------------|-----------------------------|--|-----------------------------|--------------------------------|---|--------------------------------|--|
|        |  |                       | Value                                   | %   | Value                               |  | %                                   | Value                       |  | %                           | Value                          |   | %                              |  |
| 1      | ACME SOLAR HOLDINGS LIMITED            | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            | DR, EL & Tripping report not submitted |
| 2      | AD HYDRO                               | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 3      | ADANI GREEN ENERGY TWENTY FIVE LIMITED | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 4      | AHEJ4L                                 | 2                     | 1                                       | 50  | 1                                   | 0  | 50                                  | 1                           | 0  | 50                          | 1                              | 0   | 50                             |  |
| 5      | AHEJOL                                 | 2                     | 2                                       | 100 | 0                                   | 0  | 0                                   | 2                           | 0  | 100                         | 2                              | 0   | 100                            |  |
| 6      | ALTRA XERGI POWER PVT LTD              | 2                     | 2                                       | 100 | 2                                   | 0  | 100                                 | 2                           | 0  | 100                         | 2                              | 0   | 100                            |  |
| 7      | ANTA-NT                                | 4                     | 4                                       | 100 | 4                                   | 0  | 100                                 | 4                           | 0  | 100                         | 4                              | 0   | 100                            |  |
| 8      | AP43L                                  | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 9      | AREPRL                                 | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 10     | AURAIYA-NT                             | 4                     | 4                                       | 100 | 0                                   | 0  | 0                                   | 1                           | 0  | 25                          | 2                              | 0   | 50                             |  |
| 11     | BAIRASUIL-NH                           | 2                     | 2                                       | 100 | 2                                   | 0  | 100                                 | 2                           | 0  | 100                         | 2                              | 0   | 100                            |  |
| 12     | BANDERWALA_TPSL                        | 1                     | 0                                       | 0   | 0                                   | 0  | 0                                   | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 13     | BBMB                                   | 99                    | 9                                       | 9   | 10                                  | 54   | 22                                  | 12                          | 51                                       | 25                          | 10                             | 6   | 11                             |  |
| 14     | CPCC1                                  | 70                    | 17                                      | 24  | 21                                  | 14   | 38                                  | 27                          | 14                                       | 48                          | 23                             | 0   | 33                             |  |
| 15     | CPCC2                                  | 30                    | 0                                       | 0   | 0                                   | 13   | 0                                   | 0                           | 12                                       | 0                           | 0                              | 1   | 0                              | Details received                       |
| 16     | CPCC3                                  | 51                    | 0                                       | 0   | 0                                   | 11   | 0                                   | 1                           | 9  | 2                           | 0                              | 6   | 0                              |  |
| 17     | DADRI-NT                               | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            | DR, EL & Tripping report not           |
| 18     | DULHASTI-NH                            | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 19     | ESUCRL                                 | 3                     | 3                                       | 100 | 3                                   | 0  | 100                                 | 3                           | 0  | 100                         | 3                              | 0   | 100                            |  |
| 20     | FBTL                                   | 2                     | 1                                       | 50  | 1                                   | 0  | 50                                  | 1                           | 0  | 50                          | 1                              | 0   | 50                             |  |
| 21     | INDIGRID                               | 4                     | 4                                       | 100 | 4                                   | 0  | 100                                 | 4                           | 0  | 100                         | 4                              | 0   | 100                            |  |

**Status of submission of FIR/DR/EL/Tripping Report  
on NR Tripping Portal**

**Time Period: 1st July 2025 - 31st July 2025**

| S. No. | Utility                   | Total No. of tripping | First Information Report (Not Received) |     | Disturbance Recorder (Not Received) | Disturbance Recorder (NA) as informed by utility | Disturbance Recorder (Not Received) | Event Logger (Not Received) | Event Logger (NA) as informed by utility | Event Logger (Not Received) | Tripping Report (Not Received) | Tripping Report (NA) as informed by utility | Tripping Report (Not Received) | Remark                                 |
|--------|---------------------------|-----------------------|---|-----|-------------------------------------|--|-------------------------------------|-----------------------------|--|-----------------------------|--------------------------------|---|--------------------------------|--|
|        |                           |                       | Value                                   | %   | Value                               |  | %                                   | Value                       |  | %                           | Value                          |   | %                              |  |
| 22     | JHAJJAR                   | 2                     | 0                                       | 0   | 0                                   | 1  | 0                                   | 0                           | 1  | 0                           | 2                              | 0   | 100                            | submitted                              |
| 23     | KARCHAM                   | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 24     | KHURJA STPP               | 2                     | 2                                       | 100 | 2                                   | 0  | 100                                 | 2                           | 0  | 100                         | 2                              | 0   | 100                            |  |
| 25     | KOTESHWAR                 | 6                     | 6                                       | 100 | 6                                   | 0  | 100                                 | 6                           | 0  | 100                         | 6                              | 0   | 100                            |  |
| 26     | Mega_SuryaUrja            | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 27     | NAPP                      | 8                     | 0                                       | 0   | 1                                   | 2  | 17                                  | 1                           | 2  | 17                          | 0                              | 0   | 0                              | Details received                       |
| 28     | NJPC                      | 1                     | 0                                       | 0   | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 0                              | 0   | 0                              | DR, EL & Tripping report not submitted |
| 29     | PARBATI-II-NH             | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            | Details received                       |
| 30     | RAMPUR                    | 2                     | 0                                       | 0   | 0                                   | 1  | 0                                   | 0                           | 0  | 0                           | 0                              | 0   | 0                              | DR, EL & Tripping report not submitted |
| 31     | RAPPA                     | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 32     | RAPPB                     | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 33     | RAPPC                     | 1                     | 1                                       | 100 | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            | DR, EL & Tripping report not submitted |
| 34     | RENEW SUN BRIGHT (RSBPL)  | 1                     | 0                                       | 0   | 0                                   | 0  | 0                                   | 0                           | 0  | 0                           | 0                              | 0   | 0                              |  |
| 35     | RSDCL                     | 4                     | 4                                       | 100 | 4                                   | 0  | 100                                 | 4                           | 0  | 100                         | 4                              | 0   | 100                            |  |
| 36     | SALAL-NH                  | 7                     | 1                                       | 14  | 1                                   | 4  | 33                                  | 1                           | 0  | 14                          | 1                              | 0   | 14                             |  |
| 37     | SEWA-2-NH                 | 3                     | 3                                       | 100 | 3                                   | 0  | 100                                 | 3                           | 0  | 100                         | 3                              | 0   | 100                            |  |
| 38     | SINGOLI                   | 2                     | 2                                       | 100 | 2                                   | 0  | 100                                 | 2                           | 0  | 100                         | 2                              | 0   | 100                            |  |
| 39     | SINGRAULI-NT              | 2                     | 2                                       | 100 | 2                                   | 0  | 100                                 | 2                           | 0  | 100                         | 2                              | 0   | 100                            |  |
| 40     | SJVN GREEN ENERGY LIMITED | 7                     | 7                                       | 100 | 7                                   | 0  | 100                                 | 7                           | 0  | 100                         | 7                              | 0   | 100                            |  |
| 41     | SLDC-CHD                  | 2                     | 2                                       | 100 | 2                                   | 0  | 100                                 | 2                           | 0  | 100                         | 2                              | 0   | 100                            |  |
| 42     | SLDC-DV                   | 21                    | 5                                       | 24  | 9                                   | 6  | 60                                  | 9                           | 6  | 60                          | 10                             | 0   | 48                             |  |
| 43     | SLDC-HP                   | 23                    | 1                                       | 4   | 18                                  | 0  | 78                                  | 18                          | 0  | 78                          | 1                              | 0   | 4                              |  |
| 44     | SLDC-HR                   | 25                    | 15                                      | 60  | 15                                  | 4  | 71                                  | 15                          | 4  | 71                          | 16                             | 0   | 64                             |  |

**Status of submission of FIR/DR/EL/Tripping Report  
on NR Tripping Portal**

**Time Period: 1st July 2025 - 31st July 2025**

| S. No.                    | Utility      | Total No. of tripping | First Information Report (Not Received) |           | Disturbance Recorder (Not Received) | Disturbance Recorder (NA) as informed by utility | Disturbance Recorder (Not Received) | Event Logger (Not Received) | Event Logger (NA) as informed by utility | Event Logger (Not Received) | Tripping Report (Not Received) | Tripping Report (NA) as informed by utility | Tripping Report (Not Received) | Remark                                 |
|---------------------------|--------------|-----------------------|---|-----------|-------------------------------------|--|-------------------------------------|-----------------------------|--|-----------------------------|--------------------------------|---|--------------------------------|--|
|                           |              |                       | Value                                   | %         | Value                               |  | %                                   | Value                       |  | %                           | Value                          |   | %                              |  |
| 45                        | SLDC-JK      | 11                    | 0                                       | 0         | 9                                   | 0  | 82                                  | 9                           | 0  | 82                          | 6                              | 0   | 55                             |  |
| 46                        | SLDC-PS      | 33                    | 8                                       | 24        | 26                                  | 3  | 87                                  | 26                          | 1  | 81                          | 30                             | 1   | 94                             |  |
| 47                        | SLDC-RS      | 67                    | 2                                       | 3         | 8                                   | 1  | 12                                  | 8                           | 1  | 12                          | 13                             | 0   | 19                             |  |
| 48                        | SLDC-UK      | 21                    | 2                                       | 10        | 4                                   | 4  | 24                                  | 5                           | 2  | 26                          | 2                              | 0   | 10                             |  |
| 49                        | SLDC-UP      | 111                   | 22                                      | 20        | 22                                  | 11   | 22                                  | 23                          | 26                                       | 27                          | 22                             | 4   | 21                             |  |
| 50                        | STERLITE     | 5                     | 3                                       | 60        | 2                                   | 1  | 50                                  | 2                           | 1  | 50                          | 2                              | 3   | 100                            |  |
| 51                        | TANDA-NT     | 1                     | 0                                       | 0         | 0                                   | 0  | 0                                   | 0                           | 0  | 0                           | 0                              | 0   | 0                              | Details received                       |
| 52                        | TEHRI        | 8                     | 0                                       | 0         | 0                                   | 0  | 0                                   | 0                           | 0  | 0                           | 6                              | 0   | 75                             | DR, EL & Tripping report not submitted |
| 53                        | UNCHAHAAR-NT | 1                     | 1                                       | 100       | 1                                   | 0  | 100                                 | 1                           | 0  | 100                         | 1                              | 0   | 100                            |  |
| 54                        | URI-II-NH    | 5                     | 0                                       | 0         | 0                                   | 4  | 0                                   | 0                           | 0  | 0                           | 0                              | 0   | 0                              | Details received                       |
| <b>Total in NR Region</b> |              | <b>670</b>            | <b>150</b>                              | <b>22</b> | <b>206</b>                          | <b>134</b>                                       | <b>38</b>                           | <b>221</b>                  | <b>130</b>                               | <b>41</b>                   | <b>208</b>                     | <b>21</b>                                   | <b>32</b>                      |  |

*As per the IEGC provision under clause 37.2 (c), detailed tripping report along with DR & EL has to be furnished within 24 hrs of the occurrence of the event*

## Status of Mock Test of SPS in NR during 2025-26

| Sr. No. | Scheme Name   | Owner / Agency                    | Commission Year | Last Review | Mock testing conducted before 2025-26       | Tentative Schedule of SPS Mock testing to be conducted during 2025-26 | Date of SPS Mock testing conducted during 2025-26 | Remarks   |
|---------|---|-----------------------------------|-----------------|-------------|---|---|---|---|
| 1       | SPS for WR-NR corridor - 765kV Agra-Gwalior D/C   | POWERGRID                         |                 |             | 27-03-2025                                  | Feb-26  |   |   |
| 2       | SPS for contingency due to tripping of HVDC Mundra-Mahendergarh   | ADANI                             |                 |             |   | SPS Unhealthy   |   | As reported by ADANI, work order has been placed and action plan also have been received. Tentative timeline for revival of SPS is by December 2025.                                  |
| 3       | SPS for high capacity 400 kV Muzaffarpur-Gorakhpur D/C Inter-regional tie-line related contingency        | POWERGRID                         |                 |             |   | Schedule awaited  |   | Not conducted in 2024-25 also.  |
| 4       | SPS for 1500 MW HVDC Rihand-Dadri Bipole related contingency  | POWERGRID                         |                 |             | 19-03-2025 and 20-03-2025                   | Jan-26  |   | During mock testing, issue identified at Singrauli, Malerkotla. During recent operation on 21.05.2025, non-operation of SPS at Muradnagar, Modipuram, Malerkotla, Singrauli observed. |
| 5       | System Protection Scheme (SPS) for HVDC Balia-Bhiwadi Bipole  | POWERGRID                         |                 |             |   | Sep-25  |   | Not conducted in 2024-25 also   |
| 6       | SPS for reliable evacuation of power from NJPS, Rampur, Sawra Kuddu, Baspa Sorang and Karcham Wangtoo HEP | SJVN/HPPTCL/JS W/POWERGRID/SORANG |                 |             | 19-12-2024                                  | Dec-25  |   | Case-6(i): Under implementation stage (tentative by 15th August 2025), Case 6(ii): communication card issue at Wangtoo(HP)  |
| 7       | SPS for Reliable Evacuation of Ropar Generation   | PSTCL                             |                 |             |   | SPS Unhealthy   |   | As reported by PSTCL, SPS need to be reviewed whether it is required or not.  |
| 8       | SPS for Reliable Evacuation of Rosa Generation  | UPPTCL                            |                 |             | 20-04-2024                                  | conducted   | 12-04-2025  | Mock test report received (Review to be done in view of commissioning of 400kV Rosa-Badaun D/C in April 2021.)  |
| 9       | SPS for contingency due to tripping of evacuating lines from Narora Atomic Power Station                  | NAPS / UPPTCL                     |                 |             |   | Schedule awaited  |   | Not conducted in 2024-25 also. As reported by UPPTCL, no SPS system is in service at Narora S/s.  |
| 10      | SPS for evacuation of Kawai TPS, Kalisindh TPS generation complex   | RVPNL                             |                 |             | 14-03-2025 (Partial)                        | conducted   | 26-04-2025  | Study w.r.t. Automatic load shedding part has been done. Proposed Will be put up in 234 OCC   |
| 11      | SPS for evacuation of Anpara Generation Complex   | UPPTCL                            |                 |             | 08-10-2024 (unit-7) and 19-10-2024 (unit-6) | Schedule awaited  |   |   |
| 12      | SPS for evacuation of Lalitpur TPS Generation   | UPPTCL                            |                 |             | 21-05-2024                                  | conducted   | 09-04-2025  | Mock test report received   |
| 13      | SPS for Reliable Evacuation of Bara TPS Generation  | UPPTCL                            |                 |             | 20-11-2024                                  | conducted   | 23-05-2025  | Mock test report received   |
| 14      | SPS for Lahal Generation  | HPPTCL                            |                 |             | 08-07-2020                                  | Schedule awaited  |   | As reported by HPPTCL, SPS at Lahal not required now.   |
| 15      | SPS for Transformers at Ballabgarh (PG) substation  | POWERGRID                         |                 |             |   | Schedule awaited  |   | Not conducted in 2024-25 also. SPS. SPS may be kept with revised logic (logic based on the loading)   |
| 16      | SPS for Transformers at Maharanibagh (PG) substation  | POWERGRID                         |                 |             |   | conducted   | Apr-25  | Mock test report received   |
| 17      | SPS for Transformers at Mandola (PG) substation   | POWERGRID                         |                 |             |   | conducted   | Apr-25  | Mock test report received   |
| 18      | SPS for Transformers at Bamnauli (DTL) Substation   | DTL                               |                 |             |   | Schedule awaited  |   | Not conducted in 2024-25 also. SPS. SPS may be kept with revised logic (logic based on the loading)   |
| 19      | SPS for Transformers at Moradabad (UPPTCL) Substation   | Uttar Pradesh                     |                 |             | 20-04-2024                                  | conducted   | 02-04-2025  | Mock test report pending  |
| 20      | SPS for Transformers at Muradnagar (UPPTCL) Substation  | UPPTCL                            |                 |             | 27-03-2025                                  | Mar-26  |   |   |
| 21      | SPS for Transformers at Muzaffarnagar(UPPTCL) Substation  | UPPTCL                            |                 |             | 27-03-2025                                  | Mar-26  |   |   |
| 22      | SPS for Transformers at Greater Noida(UPPTCL) Substation  | UPPTCL                            |                 |             |   | SPS Unhealthy   |   | SPS Unhealthy; SPS may be kept with revised logic (logic based on the loading)  |
| 23      | SPS for Transformers at Agra (UPPTCL) Substation  | UPPTCL                            |                 |             | 21-03-2025                                  | Schedule awaited  |   |   |
| 24      | SPS for Transformers at 400kV Sarojininagar (UPPTCL) Substation   | UPPTCL                            |                 |             | 15-05-2024                                  | Schedule awaited  |   |   |
| 25      | SPS for Transformers at 220kV Sarojininagar (UPPTCL) Substation   | UPPTCL                            |                 |             | 06-06-2024                                  | Schedule awaited  |   |   |
| 26      | SPS for Transformers at 400kV Unnao (UPPTCL) Substation   | UPPTCL                            |                 |             | 19-05-2023                                  | SPS made healthy on 27.05.2025  |   | Mock test report pending  |
| 27      | SPS for Transformers at 400kV Sultanpur (UPPTCL) Substation   | UPPTCL                            |                 |             |   | SPS made healthy on 05.05.2025  |   | Mock test report pending  |

|    |   |           |  |  |                           |                               |            |  |
|----|---|-----------|--|--|---------------------------|-------------------------------|------------|--|
| 28 | SPS for Transformers at 400kV Bareilly (UPPTCL) Substation                | UPPTCL    |  |  |                           | SPS disabled without approval |            | Not conducted in 2024-25 also. SPS. SPS need to be enabled at the earliest. Case of SPS has been put up with transmission wing |
| 29 | SPS for Transformers at 400kV Azamgarh (UPPTCL) Substation                | UPPTCL    |  |  | 06-05-2024                | conducted                     | 19-04-2025 | Mock test report pending   |
| 30 | SPS for Transformers at 400kV Mau (UPPTCL) Substation                     | UPPTCL    |  |  | 27-04-2024                | conducted                     | 21-04-2025 | Mock test report pending   |
| 31 | SPS for Transformers at 400kV Gorakhpur (UPPTCL) Substation               | UPPTCL    |  |  | 27-04-2024                | conducted                     | 21-04-2025 | Mock test report pending   |
| 32 | SPS for Transformers at 400kV Sarnath (UPPTCL) Substation                 | UPPTCL    |  |  | 23-05-2024                | conducted                     | 01-04-2025 | Mock test report received  |
| 33 | SPS for Transformer at 400kV Rajpura (PSTCL) Substation                   | PSTCL     |  |  | 31-01-2025                | Schedule awaited              |            |  |
| 34 | SPS for Transformers at 400kV Mundka (DTL) Substation                     | DTL       |  |  | 03-02-2025                | Schedule awaited              |            |  |
| 35 | SPS for Transformers at 400kV Deepalpur (JKTPL) Substation                | HVPNL     |  |  |                           | conducted                     | 08-05-2025 | Mock test report pending   |
| 36 | SPS for Transformers at 400kV Ajmer (RVPN) Substation                     | RVPNL     |  |  | 10-09-2024                | 10-09-2025                    |            |  |
| 37 | SPS for Transformers at 400kV Merta (RVPN) Substation                     | RVPNL     |  |  | 12-09-2024                | 12-09-2025                    |            |  |
| 38 | SPS for Transformers at 400kV Chittorgarh (RVPN) Substation               | RVPNL     |  |  | 31-08-2024 and 05-09-2024 | 05-09-2025                    |            |  |
| 39 | SPS for Transformers at 400kV Jodhpur (RVPN) Substation                   | RVPNL     |  |  | 24-09-2024                | 24-09-2025                    |            |  |
| 40 | SPS for Transformers at 400kV Bhadla (RVPN) Substation                    | RVPNL     |  |  | 27-09-2024                | 27-09-2025                    |            |  |
| 41 | SPS for Transformers at 400kV Ratangarh (RVPN) Substation                 | RVPNL     |  |  | 20-09-2024                | 20-09-2025                    |            |  |
| 42 | SPS for Transformers at 400kV Nehtaur(WUPPTCL) Substation                 | UPPTCL    |  |  | 11-01-2025                | Schedule awaited              |            |  |
| 43 | SPS for Transformers at Obra TPS  | UPPTCL    |  |  | 20-05-2024                | Schedule awaited              |            |  |
| 44 | SPS for Transformers at 400kV Kashipur (PTCUL) substation                 | PTCUL     |  |  | Septemeber 2024           | Sep-25                        |            |  |
| 45 | SPS for Transformers at 400kV Fatehgarh Solar Park (AREPRL)               | ADANI     |  |  |                           | conducted                     | 19-04-2025 | Mock test report received.   |
| 46 | SPS to relive transmission congestion in RE complex (Bhadla2)             | POWERGRID |  |  |                           | Schedule awaited              |            | Not conducted in 2024-25 also  |
| 47 | SPS for Transformers at 400kV Bikaner (RVPN) Substation                   | RVPNL     |  |  | 26-09-2024                | 26-09-2025                    |            |  |
| 48 | SPS for Transformers at 400kV Bawana (DTL) Substation                     | DTL       |  |  | 04-01-2025                | Dec-25                        |            |  |
| 49 | SPS for Transformers at 400kV Bhilwara (RVPN) Substation                  | RVPNL     |  |  | 09-07-2024 and 10-07-2024 | 10-07-2025                    |            |  |
| 50 | SPS for Transformers at 400kV Hinduan (RVPN) Substation                   | RVPNL     |  |  | 26-09-2024                | 26-09-2025                    |            |  |
| 51 | SPS for Transformers at 400kV Suratgarh (RVPN) Substation                 | RVPNL     |  |  | 20-10-2024                | 20-10-2025                    |            |  |
| 52 | SPS for Transformers at 400kV Babai(RS) Substation                        | RVPNL     |  |  | 20-10-2024                | 20-10-2025                    |            |  |
| 53 | SPS for Transformers at 400kV Allahabad(PG) Substation                    | UPPTCL    |  |  |                           | Schedule awaited              |            | Not conducted in 2024-25 also  |
| 54 | SPS for Transformers at 400kV Jaunpur(UP) Substation                      | UPPTCL    |  |  |                           |                               |            | Yet to be implemented  |
| 55 | SPS for Transformers at 765kV Jhatikara(PG) Substation (Bamnauli section) | POWERGRID |  |  |                           | conducted                     | Jun-25     | Mock test report received.   |
|    | SPS for Transformers at 765kV Jhatikara(PG) Substation (Mundka section)   |           |  |  |                           | conducted                     | Jun-25     |  |
| 56 | SPS for Transformers at 765kV Bhiwani(PG) Substation                      | POWERGRID |  |  |                           | SPS implemented               |            | Mock test report received.   |