



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
उत्तर क्षेत्रीय विद्युत समिति
Northern Regional Power Committee

संख्या: NRPC/OPR/106/02/5178-81

दिनांक: 21.05.2019

To,

- 1) GM, NRLDC, New Delhi
- 2) DGM (SO), Delhi SLDC, New Delhi
- 3) SE (SLDC), Haryana SLDC, Panipat
- 4) AGM, APCPL, Jhajjar

विषय: Minutes of meeting held on 14.05.2019 to discuss modalities regarding procedure when only one beneficiary is requesting for Unit to be on BAR.

उपरोक्त विषय पर दिनांक 14.05.2019 को उ.क्षे.वि.स. सचिवालय में आयोजित बैठक का कार्यवृत्त संलग्न है।

संलग्नक: यथोपरि

-sd-

(सौमित्र मजूमदार)
अधीक्षण अभियंता (प्रचालन)

Minutes of the meeting held on 14.05.2019 at NRPC Sectt. to discuss modalities regarding procedure when only one beneficiary is requesting for Unit to be on BAR

In pursuance of the decision taken in the 158th OCC meeting dated 23.04.2019, a meeting was held on 14.05.2019 at NRPC Sect., New Delhi to discuss modalities when only one beneficiary agrees to keep the machine on bar during off peak hours and subsequently its requested share of power during peak hours gets reduced when the second state punches requisition from the same machine on bar as per its entitlement. The list of participants for the meeting is enclosed as **Annexure-I**.

2. Member Secretary, NRPC welcomed all participants and mentioned that both Delhi and Haryana raised concern in the past when their requested schedule was not fulfilled from APCPL Jhajjar. MS, NRPC requested the representatives of NRLDC, Delhi, Haryana and APCPL Jhajjar to explain the matter.

3. GM, NRLDC explained that issue arises when only one beneficiary agrees to run the machine at Technical Minimum during off-peak in order to meet its requirement during peak period. The other beneficiary does not request for power initially; but later during exigency, punches requisition from the same running machine as per its entitlement, due to which requested schedule of the first beneficiary is not fulfilled. It was mentioned that such problems have been faced by both Delhi and Haryana at different points of time. Further, it was stated that beneficiaries are entitled to get proportional schedule on running units as per IEGC. However, it would be ethical that the entity agreeing to run the unit by ensuring technical minimum during low demand hours should get requested power during high demand period.

4. Representative of APCPL explained that there are 3 machines in APCL Jhajjar each having 500MW installed capacity and ex-bar capacity of 471.25 MW. Haryana and Delhi both have share of 46.2% in Jhajjar (i.e., 217.7 MW in each machine). Technical Minimum of each machine is 259.18 MW.

5. Representative from TPDDL suggested to establish documented procedure that can be followed by both beneficiaries so that scheduling can be done transparently.

6. Decisions taken in the meeting are as under:

- i. In case only one beneficiary wants to keep the machine(s) on bar and agrees to provide technical minimum schedule for the same during off peak hours, he would have the first right to schedule power up to the DC on bar of the machine or Entitlement of the beneficiary from that machine, whichever is lower.
- ii. In case the other beneficiary wishes to schedule power from the machine in which it had surrendered power, consent of the beneficiary on whose request the machine has been kept on bar would be required. For this purpose, SLDCs shall adopt a uniform SOP. The SLDC (A) which wishes to schedule power shall send the mail, stating the quantum and duration of power required, to the SLDC (B) which was providing technical minimum schedule. After obtaining consent from its DISCOMs, SLDC (B) shall give its consent to SLDC (A) to punch the agreed schedule in WBES of NRLDC. SLDC (A) shall punch the schedule in

WBES only after obtaining this consent through mail and forwarding it to NRLDC. Consent of SLDC (B) would also be required in case URS is available in the machine on bar.

- iii. In case SLDC (B) does not give consent, SLDC (A) may request NRLDC to bring the other unit(s) of APCPL Jhajjar on bar. In this scenario, SLDC (A) shall wait till the start-up time of other unit before it can punch its requisition in WBES.
- iv. No changes would be made in the WBES software of NRLDC to prevent SLDC (A) from punching requisition up to its entitlement from the machine on bar.
- v. All stakeholders are expected to behave ethically and follow this mutually agreed procedure to avoid scheduling related issues.

List of participants for the meeting to discuss regarding procedure when only one beneficiary is requesting for Unit to be on BAR.

Date: 14.05.2019

Sl No	Name	Designation	Organization	Tel. No. / Mobile No.	E-mail
1	Rajesh Kumar	Manager	NRUDC	9560032972	r.kumar@posoco.in
2	Ashutosh Kumar Pandey	Asst. Manager	NR LDC	9599112720	ashutosh.pandey@posoco.in
3	ABHISHEK JAIN	DGM	APCPL JHAJJAR	9729042596	abhishekjain@ntpc.co.in
4	P. MEDIRATTA	AGM	APCPL JHAJJAR	9416212411	pmediratta@ntpc.co.in
5	SHREYANS NAVAL	Sr. Manager	BRPL	9312518646	shreyansnaval@relianceada.com
6	ARVIND CHAUDHRY	Xm/so	HPPE, Hamirgama	9357189063	UCR PANCHKULA18@gmail.com
7	Mukesh Dadhich	As VP	BYPL	9350261451.	mukesh.dadhich@relianceada.com.
8	NAVEEN GOEL	Manager	Delhi SDC	9999533950	naveengoel06@gmail.com
9	SANDEEP KUMAR	Sr. Manager	TPDDL	9971174097	Sandeep.K@TataPower-DDL.com
10	SUJATA GURUJI	Sr. Manager	TP-DDL	9971395315	sujata.guruji@tatapower-ddl.com
11.	N.K. MAJICAR	PC(SDC)	HVPM SDC	9966219042	sldehayana co@gmail.com

Sl No	Name	Designation	Organization	Tel. No. / Mobile No.	E-mail
11	P. Devanand	Add. GM	TPDDL	9871800506	p.devanand@ tatapower-ddl.com
12	राजीव पौरवाल	महाप्रबंधक	NRDC,	9871581133	sk.porwal@posoco.in
13	M. M. Hassan	GM	NRDC	9810952965	m.hassan@posoco.in
14	A. K. Chawla	Sr GM	NRDC	965008671	A.K.Chawla@posoco.in
15					
16					
17					
18					
19					
20					
21					
22					