

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	(वास्तविक) वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days	
NTPC										
Singrauli STPS	1	200	01.04.19	15.05.19	45	CHO+DDCMIS	02-04-2019 22:31	26-05-2019 08:27		Annual maintenance
	2	200	22.03.20	25.03.20	4	Boiler License Renewal				
	3	200	14.12.19	17.12.19	4	Boiler License Renewal				
	4	200				NIL				
	5	200	01.07.19	04.08.19	35	CHO+DDCMIS				
	6	500	01.12.19	25.12.19	25	Boiler				
	7	500				NIL				
Rihand-I	1	500	15.12.19	28.01.19	45	CHO:boiler,HP/IP/LP,R&M of Mill APH				
	2	500	16.09.19	10.10.19	25	Boiler+APH seal Adjustment				
Rihand-II	3	500				NIL				
	4	500	01.04.19	30.04.19	30	Boiler+LPT+GEN+TG shaft-2 vibrations	27-05-2019 14:40	30-05-2019 02:36		Boiler Tube Leakage
Rihand-III	5	500				NIL				
	6	500	08.07.19	06.08.19	30	Boiler+LPT+GEN+HIGH tg bg-5Y vibrations				
Unchahar -I	1	210	18.11.19	12.12.19	25	Boiler+RLA Boiler+Gen+MOP				
	2	210				NIL				
Unchahar -II	3	210	1-May-19	25-May-19	25	Boiler+RLA Boiler+Gen+MOP	09-06-2019 04:00	12-07-2019 07:12		Annual overhauling for 25 days
	4	210				NIL				
Unchahar -III	5	210				NIL				
Unchahar IV	6	500				NIL				
Tanda-TPS (CSGS Dedicated to UP)	1	110	01.09.19	20.09.19	20	Boiler Inspection				
	2	110	01.07.19	30.07.19	30	Boiler Inspection+ TG Brq Inspector+ LPT O/H+ Gen Brq	25-04-2019 00:35	26-06-2019 03:42		Annual overhauling.
	3	110				NIL				
	4	110				NIL				
Dadri (NCTPS)	1	210	26-Apr-19	2-May-19	7	BLR+DSI				
	2	210	15-Oct-19	21-Oct-19	7	BLR+DSI				
	3	210	25-Sep-19	1-Oct-19	7	BLR+DSI				
	4	210	19-Aug-19	12-Sep-19	25	BLR+DSI				
	5	490				NIL				
	6	490	4-Nov-19	18-Dec-19	45	Boiler+LPT+Combustion modification				
Anta GPS	GT 1	88.7	5-Apr-19	8-Apr-19	4	Minor Inspection (12000 VOH)				
	GT 2	88.7	1-Apr-19	30-Apr-19	30	Major Inspection				
			25-Oct-19	28-Oct-19	4	Major Inspection (4000 VOH)				
	GT 3	88.7	26-Jul-19	31-Jul-19	6	Major Inspection (8000 VOH)				
	ST G	153.2	1-Apr-19	20-Apr-19	20	ST major O/H & LP blade carrier checking				
Auriya GPS	GT 1	111.19	30-Apr-19	30-Apr-19	1	BLR				
			2-Jul-19	16-Jul-19	15	Tie & Filter replacement				
			1-Nov-19	2-Nov-19	2	Filter replacement				
	GT 2	111.19	15-Jun-19	15-Jun-19	1	BLR				
			10-Nov-19	11-Nov-19	2	Filter replacement				
	GT 3	111.19	1-Dec-19	1-Dec-19	1	BLR				
	GT 4	111.19	18-Feb-20	18-Feb-19	1	BLR				
	ST 1	109.3	02-Jul-19	31-Jul-19	30	Major overhaul				
ST 2	109.3				NIL					
Dadri GPS	GT 1	130.19	1-Aug-19	30-Aug-19	30	MJ+GEN				
			19-Dec-19	20-Dec-19	2	AFR				
			19-Jan-20	20-Jan-20	2	BLR				
			15-Feb-20	19-Feb-20	5	4000 EOH+CW				
	GT 2	130.19	22-Jun-19	28-Jun-19	7	800 EOH+BLR				
			24-Nov-19	28-Nov-19	5	4000 EOH+AFR				
			2-Jan-20	2-Jan-20	1	CW				
			12-Jun-19	18-Jun-19	7	8000 EOH				
	GT 3	130.19	9-Dec-19	13-Dec-19	5	4000EOH+AFR	27-06-2019 06:00	01-07-2019 21:14		Overhauling work.
			19-Jan-20	20-Jan-20	2	BLR+CW				
			24-May-19	30-May-19	7	8000EOH+AFR				
	GT 4	130.19	12-Nov-19	21-Nov-19	10	FTH+AFR				
			1-Jan-20	1-Jan-20	1	CW				
ST 1	154.51	1-Aug-19	10-Aug-19	10	Annual S/D+ Codenser cleaning					

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	(वास्तविक) वार्षिक आउटटेज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks	
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days		
	ST 2	154.51	12-Nov-19	21-Nov-19	10	Annual S/D+ Codenser cleaning					
Faridabad GPS (CSGS Dedicated to Haryana)	GT 1	137.758				NIL					
	GT 2	137.758									
	STG	156.08									
Koldam HEP (NTPC)	1	200	17-Dec-19	21-Dec-19	5	Annual Inspection					
	2	200	7-Jan-20	11-Jan-20	5	Annual Inspection					
	3	200	4-Feb-20	8-Feb-20	5	Annual Inspection					
	4	200	25-Feb-20	29-Feb-20	5	Annual Inspection					
IGSTPP,Jhajjar	1	500	1-Nov-19	25-Nov-19	25	Boiler Annual Overhaul + LP Turbine Replacement					
	2	500				NIL					
	3	500	8-Apr-19	12-May-19	35	Boiler Annual Overhaul + LP Turbine replacement + Generator Chg	08-04-2019 00:00	05-06-2019 15:31		Annual maintenance	
NPCIL											
NAPS	1	220				NIL					
	2	220	01.02.2020	01.03.2020	30	Biennial Shut Down					
RAPS - A(CSGS Dedicated to Rai)	2	200	01.04.2019	30.09.2019	180	Annual Maintenance					
RAPS - B	3	220				NIL					
	4	220				NIL					
RAPS - C	5	220				NIL					
	6	220				NIL					
NHPC											
Baira Siul(3x60)	1	60	1-Dec-19	20-Dec-19	20	Annual Maintenance					
	2	60	1-Jan-20	20-Jan-20	20	Annual Maintenance					
	3	60				NIL					
Salal(6x115)	1	115	27-Feb-20	17-Mar-20	20	Annual Maintenance					
	2	115	6-Feb-20	25-Feb-20	20	Annual Maintenance					
	3	115	16-Feb-20	4-Feb-20	20	Annual Maintenance					
	4	115	26-Dec-19	14-Jan-20	20	Annual Maintenance					
	5	115	5-Dec-19	24-Dec-19	20	Annual Maintenance					
	6	115	1-Oct-19	29-Nov-19	60	Capital Maintenance					
Chamera - I(3x180)	1	180	5-Dec-19	25-Dec-19	21	Annual Maintenance					
	2	180	27-Dec-19	16-Jan-20	21	Annual Maintenance					
	3	180	18-Jan-20	7-Feb-20	21	Annual Maintenance					
Chamera - II(3x100)	1	100	11-Nov-19	25-Nov-19	15	Annual Maintenance					
	2	100	13-Dec-19	16-Jan-20	35	Capital Maintenance					
	3	100	27-Nov-19	11-Dec-19	15	Annual Maintenance					
Chamera - III(3x77)	1	77	2-Jan-20	16-Jan-20	15	Annual Maintenance					
	2	77	17-Jan-20	31-Jan-20	15	Annual Maintenance					
	3	77	1-Feb-20	15-Feb-20	15	Annual Maintenance					
Uri(4x120)	1	120	27-Nov-19	26-Dec-19	30	Capital Maintenance					
	2	120	27-Dec-19	25-Jan-20	30	Capital Maintenance					
	3	120	15-Oct-19	3-Nov-19	20	Annual Maintenance					
	4	120	5-Nov-19	24-Nov-19	20	Annual Maintenance					
Tanakpur(3x31.4)	1	31.4	15-Nov-19	19-Dec-19	35	Annual Maintenance					
	2	31.4	21-Dec-19	4-Apr-20	106	Annual Maintenance					
	3	31.4	10-Apr-20	14-May-20	35	Annual Maintenance					
Uri III(4x60)	1	60	1-Nov-19	20-Nov-19	20	Annual Maintenance	17-04-2019 05:01	18-04-2019 18:06		Due to silt flushing	
	2	60	24-Nov-19	13-Dec-19	20	Annual Maintenance	17-04-2019 05:03	18-04-2019 17:33		Due to silt flushing	
	3	60	17-Dec-19	5-Jan-20	20	Annual Maintenance	17-04-2019 05:03	18-04-2019 17:48		Due to silt flushing	
	4	60	9-Jan-20	28-Jan-20	20	Annual Maintenance	17-04-2019 05:01	18-04-2019 17:55		Due to silt flushing	
Dhauliganga(4x70)	1	70	15-Nov-19	6-Dec-19	22	Annual Maintenance	27-06-2019 00:00	27-06-2019 18:51		MANDATORY SILT FLUSHING	
	2	70	9-Dec-19	30-Dec-19	22	Annual Maintenance	27-06-2019 00:00	27-06-2019 19:12		MANDATORY SILT FLUSHING	
	3	70	3-Jan-20	24-Jan-20	22	Annual Maintenance	27-06-2019 00:01	27-06-2019 20:05		MANDATORY SILT FLUSHING	
	4	70	28-Jan-20	18-Feb-20	22	Annual Maintenance	27-06-2019 00:01	27-06-2019 18:44		MANDATORY SILT FLUSHING	
Dulhasti(3x130)	1	130	1-Dec-19	20-Dec-19	20	Annual Maintenance	08-06-2019 11:30	12-06-2019 22:25		Runner replacement	
	2	130	22-Dec-19	10-Jan-20	20	Annual Maintenance					
	3	130	12-Jan-20	31-Jan-20	20	Annual Maintenance	05-05-2019 00:00	02-06-2019 17:24		S/D for turbine inspection miscellaneous	
PARRATI-III(4x130)	1	130	15-Nov-19	9-Dec-19	25	Annual Maintenance					
	2	130	11-Dec-19	4-Jan-20	25	Annual Maintenance					

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	वास्तविक वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days	
	3	130	6-Jan-20	30-Jan-20	25	Annual Maintenance				
	4	130	1-Feb-20	25-Feb-20	25	Annual Maintenance				
	1	40	15-Nov-19	5-Dec-19	21	Annual Maintenance				
	2	40	8-Dec-19	28-Dec-19	21	Annual Maintenance				
SEWA -- II(3x40)	3	40	1-Jan-20	21-Jan-20	21	Annual Maintenance				
Nimmo Bazgo	1	15	20-Aug-19	09-Oct-19	51	Capital Maintenance				
	2	15	15-Oct-19	07-Nov-19	24	Annual Maintenance				
	3	15	10-Nov-19	03-Dec-19	24	Annual Maintenance				
Chutak	1	11	25-Oct-19	23-Nov-19	30	Annual Maintenance				
	2	11	26-Nov-19	25-Dec-19	30	Annual Maintenance				
	3	11	27-Dec-19	25-Jan-20	30	Annual Maintenance				
	4	11	29-Jan-20	27-Feb-20	30	Annual Maintenance				
K' GANGA	1	110	14-Dec-19	28-Dec-19	15	Annual Maintenance				
	2	110	30-Dec-19	13-Jan-20	15	Annual Maintenance				
	3	110	15-Jan-20	29-Jan-20	15	Annual Maintenance				
BBMB										
Bhakra	1	108	11-Oct-19	18-Jun-20	252	RM&U				
	2	126	25-Nov-19	24-Dec-19	20	Annual Maintenance				
	3	108	1-Feb-19	10-Oct-19	252	RM&U				
	3	108	4-Mar-20	23-Mar-20	20	Annual Maintenance	01-04-2019 09:20 *			Renovation and Modernisation of unit/capacity enhancement f
	3	108	25-Mar-20	16-Apr-20	23	Capital Mtc of Penstock Head Gate & Gate Hoist				
	4	126	14-Oct-19	2-Nov-19	20	Annual Maintenance	04-04-2019 00:00	21-05-2019 12:56		Runner modification and Annual Maintenance.
	5	126	20-Jan-20	8-Feb-20	20	Annual Maintenance				
	6	157	25-Sep-19	12-Oct-19	18	Annual Maintenance				
	7	157	1-Oct-19	28-Feb-20	151	Annual Maintenance				
	8	157	16-Dec-19	4-Jan-20	20	Annual Maintenance				
	9	157	10-Feb-20	2-Mar-20	22	Annual Maintenance				
10	157	4-Nov-19	23-Nov-19	20	Annual Maintenance					
IL TF	150 MVA	6-Jan-20	17-Jan-20	12	Annual Maintenance					
Ganguwal	1	27.99	15-Apr-19	18-Apr-19	4	Quartely Maintenance				
			02-Sep-19	8-Sep-19	7	Half yearly Maintenance				
			20-Jan-20	29-Jan-20	10	Annual Maintenance				
	2	24.20	27-May-19	2-Jun-19	7	Half yearly Maintenance				
			30-Sep-19	9-Oct-19	10	Annual Maintenance				
			06-Jan-20	9-Jan-20	4	Quartely Maintenance				
	3	24.20	06-May-19	15-May-19	10	Annual Maintenance				
			21-Oct-19	27-Oct-19	7	Half yearly Maintenance				
			3-Feb-20	6-Feb-20	4	Quartely Maintenance				
Kotla	1	28.94	2-Apr-19	11-Apr-19	10	Annual Maintenance				
			14-Oct-19	20-Oct-19	7	Half yearly Maintenance				
			13-Jan-20	16-Jan-20	4	Quartely Maintenance				
	2	24.20	3-Jun-19	6-Jun-19	4	Quartely Maintenance				
			16-Sep-19	22-Sep-19	7	Half yearly Maintenance				
			16-Mar-20	25-Mar-20	10	Annual Maintenance				
			20-May-19	23-May-19	4	Quartely Maintenance				
	3	24.20	11-Nov-19	20-Nov-19	10	Annual Maintenance				
			17-Feb-20	20-Feb-20	4	Half yearly Maintenance				
Dehar	1	165	18-Jan-19	6-Feb-19	20	Annual Maintenance				
	2	165	2-Jan-20	31-Mar-20	90	Capital Maintenance				
	3	165	1-Oct-19	20-Jan-20	112	R&M of stator winding & capital Mtc Work				
	4	165	20-Nov-19	9-Dec-19	20	Annual Maintenance				
	5	165	23-Oct-19	11-Nov-19	20	Annual Maintenance				
	6	165	12-Feb-20	2-Mar-20	20	Annual Maintenance				
	1	66	16-Apr-19	5-May-19	20	Annual Maintenance				
		66	18-Nov-19	24-Nov-19	7	Half yearly Maintenance				
		66	26-Mar-20	14-Apr-20	20	Annual Maintenance				

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	(वास्तविक) वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days	
Pong	2	66	1-Nov-18	31-Aug-19	304	Capital Maintenance + Replacement of stator				
		66	21-Sep-19	20-Oct-19	30	Replacement of governor				
	3	66	17-Mar-19	15-Apr-19	30	Annual Mtc+ replacement of governor				
		66	28-Oct-19	3-Nov-19	7	Half yearly Maintenance				
		66	6-Mar-20	25-Mar-20	20	Annual Maintenance				
	4	66	26-May-19	14-Jun-19	20	Annual Maintenance				
		66	21-Oct-19	27-Oct-19	7	Half yearly Maintenance				
		66	1-Dec-19	3-Mar-20	94	Capital Maintenance				
	5	66	4-Nov-19	10-Nov-19	7	Half yearly Maintenance				
		66	15-Feb-20	5-Mar-20	20	Annual Maintenance				
		66	6-May-19	25-May-19	20	Annual Maintenance				
	6	66	6-Mar-00	11-Nov-19	17-Nov-19	7	Half yearly Maintenance			
SJVNL										
Rampur(6x68.67)	1	68.67	1.12.2019	15.3.2020	105	R&M				
	2	68.67								
	3	68.67								
	4	68.67								
	5	68.67								
	6	68.67								
Nathpa-Jhakri(6x250)	1	250	1.12.2019	28.2.2020	88	R&M				
	2	250								
	3	250								
	4	250								
	5	250								
	6	250								
THDC										
Tehri HPP	1	250	1.4.2019	30.4.2019	30	Annual Maintenance				
	2	250	1.3.2020	30.3.2020	30	Annual Maintenance				
	3	250	1.5.2019	30.5.2019	30	Annual Maintenance	25-04-2019 08:00	20-05-2019 13:45		For Annual Maintenance work.
	4	250	1.6.2019	30.6.2019	30	Annual Maintenance				
Koteswar HEP	1	100	1.5.2019	14.6.2019	45	Annual Maintenance	09-04-2019 10:00	30-04-2019 17:00		Annual maintenance .
	2	100	1.10.2019	14.11.2019	45	Annual Maintenance				
	3	100	16.11.2019	30.12.2019	45	Annual Maintenance				
	4	100	17.3.2020	30.4.2020	45	Annual Maintenance				
DELHI										
Delhi(GTs)-(6x30+3x34)	1	30	25.03.2019	13.04.2019	20	Hot Gas Path Inspection (HGPI)				
	2	30	14.04.2019	23.04.2019	10	Combustion Inspection (CI)				
	3	30								
	4	30								
	5	30								
	6	30				NIL				
	ST HRSG-1(05.06.2019)									
	ST HRSG-2(06.06.2019)	30	25.03.2019	23.04.2019	30	Major Inspection				
	ST HRSG-3									
	ST HRSG-4	30								
ST HRSG-5										
ST HRSG-6	30				NIL					
RTPS-2X67.5	1	67.5								
	2	67.5				NIL				
PRAGATI - I	1-GT	104	01.10.2019	10.10.2019	10	Combustion Inspection				
			Dec2019		2	Air inlet filter replacement				
	2-GT	104	01.03.2020	20.03.2020	20	Hot Gas Path Inspection (HGPI)				
3-ST	122				NIL					
1-GT (02.11.2019)	216	01.11.2019	03.11.2019	3	Boroscopic Inspection (B.I.)					

केन्द्र / Station	Unit	केन्द्र क्षमता Station Capacity (MW)	वार्षिक आउटटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	(वास्तविक) वार्षिक आउटटेज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days	
PRAGATI - III(BAWANA)	2-GT (02.11.2019)	216	15.11.2019	17.11.2019	3	Boroscopic Inspection (B.I.)				
	3-GT (03.03.2020)	216	01.03.2020	21.03.2020	21	Hot Gas Path Inspection (HGPI)				
	4-GT (03.03.2020)	216	15.06.2019	17.06.2019	3	Boroscopic Inspection (B.I.)				
	1-ST	253.6	01.12.2019	03.12.2019	3	Boroscopic Inspection (B.I.)				
	2-ST	253.6				NIL				
RITHALA(NDPL)	1-GT	31.6								
	2-GT	31.6								
	3-ST	31.6				NIL				
HARYANA										
Haryana(PTPS)-(4x110+2x210+2x250)	1	110				Retired				
	2	110								
	3	110								
	4	110								
	5	210				NIL				
	6	210				NIL				
	7	250	01.09.2019	30.09.2019	30	Annual Overhauling				
	8	250				NIL				
DCRTPP Yamuna Nagar (2x300)	1	300				NIL				
	2	300	01.04.2019	14.06.2019	75	Capital Overhauling and Repair of ESPs				
RGTPP HISSAR(2x600)	1	600	01.10.2019	14.12.2019	75	Capital Overhauling and Rehabilitation of ESPs to meet new Environment norms fixed by MoEF				
	2	600				NIL				
MGTPS CLP Jhhajhar	1	660	20.03.2020	31.03.2020	12	Capital Overhaul(Will extend upto 08th May)	02-04-2019 12:54	07-04-2019 16:54		Less Demand
	2	660	1.04.2019	05.05.2019	35	Annual Maintenance	16-04-2019 00:54	23-04-2019 15:14		Less Demand
RAJASTHAN										
KTPS(2x110+3x210+2x195)	1	110	22.08.19	05.09.19	15	Annual Overhaul				
	2	110	16.06.19	30.06.19	15	Annual Overhaul				
	3	210	01.04.19	27.05.19	57	Annual Capital Overhaul	11-05-2019 12:59	16-05-2019 19:05		Less Demand
	4	210	18.05.19	01.06.19	15	Annual Overhaul				
	5	210	01.06.19	15.06.19	15	Annual Overhaul				
	6	195	01.07.19	06.08.19	37	Annual Overhaul & Inspection of Bearing	17-04-2019 16:04	18-04-2019 20:39		Less Demand
	7	195	07.08.19	21.08.19	15	Annual Overhaul				
RAMGARH GAS CCPP	GT-1	35.5	01.06.19	15.06.19	15	Combustion Inspection (Upgradation of Control system of GT-1&HRSG-1)				
	GT-2	37.5	01.05.19	21.05.19	21	HGPI & Generator Overhaul (Upgradation of Control system of GT-2&HRSG-2)				
	STG-1	37.5	01.05.19	21.05.19	21	Turbine & Generator Overhaul				
	GT-3	110								
	STG-II	50				NIL				
SURATGARH TPS	1	250				NIL				
	2	250								
	3	250	11.09.19	30.09.19	20	Annual Overhaul				
	4	250				NIL				
	5	250	20.08.19	08.09.19	20	Annual Overhaul				
	6	250	01.07.19	14.08.19	45	Annual Capital Overhaul				
DHOLPUR GAS CCPP	GT-1	110								
	GT-2	110								
	STG	110				NIL				
Kalisindh TPP	1	600	21.07.19	10.08.19	21	Annual Overhaul				
	2	600	16.08.19	5.09.19	21	Annual Overhaul				
GIRAL	1	125				NIL				
	2	125								
CHHABRA TPS	1	250	12.07.19	31.07.19	20	Annual Overhaul				
	2	250	25.07.19	13.08.19	20	Annual Overhaul	04-07-2019 00:06 *			Annual maintenance
	3	250	05.04.19	24.04.19	20	Annual Overhaul				
	4	250	01.07.19	20.07.19	20	Annual Overhaul	08-05-2019 00:07	30-05-2019 12:47		Annual maintenance
	5	660	01.07.19	21.07.19	21	Annual Overhaul	27-05-2019 00:10	17-07-2019 05:20		Capital Overhauling
	6	660	25.07.19	14.08.19	21	Annual Overhaul	04-06-2019 04:22	04-06-2019 11:55		Due to Electrical Fault.

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	(वास्तविक) वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days	
BARSINGAR LTPS(NLC)	1	125	05.06.19	04.07.19	30	Annual Maintenance of Boiler including statutory inspection.	23-05-2019 07:46	02-07-2019 17:58	Annual maintenance Major overhauling.	
	2	125	18.04.19	01.06.19	45	Annual Maintenance of Boiler including statutory inspection.	12-04-2019 00:17	28-05-2019 05:49		
Adani-Rajasthan	1	660 MW				NIL			Annual overhauling for 20 days	
	2	660 MW	01.01.20	30.01.20	30	Capital Overhaul	20-06-2019 00:06	11-07-2019 21:24		
RAJWEST Power(8x135)	1	135	15-Apr-19	26-Apr-19	12	Refractory maintenance & Boiler Inspection				
			10-Jun-19	17-Jun-19	8	Annual Overhaul/ Boiler overhaul				
			01-Jan-20	25-Jan-20	25	Capital Overhaul				
	2	135	19-May-19	26-May-19	8	Refractory maintenance & Boiler Inspection				
			24-Jun-19	01-Jul-19	8	Annual Overhaul/ Boiler overhaul				
			03-Sep-19	10-Sep-19	8	Refractory maintenance & Boiler Inspection				
	3	135	02-Jun-19	09-Jun-19	8	Refractory maintenance & Boiler Inspection				
			20-Oct-19	27-Oct-19	8	Refractory maintenance & Boiler Inspection				
			31-Dec-19	07-Jan-20	8	Annual Overhaul/ Boiler overhaul				
	4	135	24-Aug-19	31-Aug-19	8	Refractory maintenance & Boiler Inspection				
			01-Dec-19	08-Dec-19	8	Refractory maintenance & Boiler Inspection				
			19-Feb-20	26-Feb-20	8	Annual Overhaul/ Boiler overhaul				
	5	135	28-Apr-19	09-May-19	12	Refractory maintenance & Boiler Inspection				
			01-Jul-19	25-Jul-19	25	Capital Overhaul				
			06-Oct-19	13-Oct-19	8	Annual Overhaul/ Boiler overhaul				
	6	135	11-May-19	18-May-19	8	Refractory maintenance & Boiler Inspection				
			19-Aug-19	26-Aug-19	8	Refractory maintenance & Boiler Inspection				
			11-Oct-19	18-Oct-19	8	Annual Overhaul/ Boiler overhaul				
	7	135	03-Apr-19	10-Apr-19	8	Annual Overhaul/ Boiler overhaul				
			20-Jul-19	27-Jul-19	8	Refractory maintenance & Boiler Inspection				
			08-Feb-20	15-Feb-20	8	Refractory maintenance & Boiler Inspection				
	8	135	05-Apr-19	12-Apr-19	8	Annual Overhaul/ Boiler overhaul				
			30-Jan-20	06-Feb-20	8	Refractory maintenance & Boiler Inspection				
			12-Mar-20	19-Mar-20	8	Refractory maintenance & Boiler Inspection				
Mahi Hydel, Banswara	PH-1	25	25.05.19	23.06.19	30	Annual Maintenance				
			01.06.19	30.06.19	30	Annual Maintenance				
	PH-2	45	25.05.19	23.06.19	30	Annual Maintenance				
			01.06.19	30.06.19	30	Annual Maintenance				
RANA PRATAP SAGAR HYDEL POWER STATION, RAWATBHATA	1	43	01.04.19	15.04.19	15	Annual Checks & Maintenance works				
	2	43	01.05.19	15.05.19	15	Annual Checks & Maintenance works				
	3	43	01.06.19	15.06.19	15	Annual Checks & Maintenance works				
	4	43	01.07.19	15.07.19	15	Annual Checks & Maintenance works				
JAWHAR SAGAR HYDEL POWER POWER STATION, JAWAHAR SAGAR	1	33	01.04.19	15.04.19	15	Annual Checks & routine Maintenance works				
	2	33	06.05.19	15.06.19	40	Repairing of Hydraulic Cylinder of penstock gate and Annual Checks & routine Maintenance works				
	3	33	18.04.19	02.05.19	15	Annual Checks & routine Maintenance works				
UTTAR PRADESH										
ANPARA(3x210+2x500)	1	210	01-Mar-20	18-Mar-20	18	Mini Overhaul				
	2	210	01-Apr-19	30-Apr-19	30	Annual Maintenance				
	3	210	20-Jan-20	04-Mar-20	45	Capital Overhauling				
	4	500	01-Nov-19	15-Dec-19	45	Capital Overhaul				
	5	500	01-Dec-19	18-Dec-19	18	Mini Overhaul				
	6	500	01-Jan-20	18-Jan-20	18	Mini Overhaul				
	7	500	01-Dec-19	30-Dec-19	30	Annual Maintenance				
OBRA(4x40+3x94+5x200)	7	94	Unit# 7 To be Proposed for deletion.							
	9	200	14-Mar-20	31-Mar-20	18	Mini Overhaul				
	10	200	14-Jan-20	31-Jan-20	18	Mini Overhaul				
	11	200	01-Feb-20	01-Mar-20	30	Annual Maintenance				
	12	200								
	13	200				NIL				
PARICHHHA(2x110+2x210)	1	110	Unit# 1 To be Proposed for deletion.							
	2	110	13-Apr-19	30-Apr-19	18	Mini Overhaul				
	3	210	01-Feb-20	01-Mar-20	30	Annual Maintenance				
	4	210	01-Nov-19	18-Nov-19	18	Mini Overhaul				
	5	250	01-Mar-20	30-Mar-20	30	Annual Maintenance				
	6	250	14-Dec-19	31-Dec-19	18	Mini Overhaul				
PANKI(1x32+2x105)	3	105				NIL				

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	(वास्तविक) वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks	
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days		
	4	105									
H'GANJ'(2x40+2x55+2x60+1x105+2x250)	7	110	14-Oct-19	31-Oct-19	18	Mini Overhaul					
	8	250	01-Dec-19	18-Dec-19	18	Mini Overhaul					
	9	250	01-Jan-20	30-Jan-20	30	Annual Maintenance					
Rosa(4x300)	1	300				NIL					
	2	300	01-Nov-19	15-Dec-19	45	Annual Overhaul					
	3	300				NIL					
	4	300	01-Feb-20	20-Feb-20	20	Boiler OH					
ANPARA - C(IPP)LANCO	1	600	12-Mar-20	29-Mar-20	18	Annual Overhaul					
	2	600	20-Jul-19	08-Aug-19	20	Annual Overhaul					
Lalitpur	1	660				NIL					
	2	660	04.02.20	28-Feb-20	25	Annual Overhaul					
	3	660	01.03.20	25.03.20	25	Annual Overhaul					
Bara	1	660				NIL					
	2	660	10-Nov-19	30-Nov-19	20	Boiler OH	26-05-2019 13:50	26-05-2019 16:31		Low Hydrogen pressure	
	3	660	10-Dec-19	30-Dec-19	20	Annual Maintenance					
IPGCL(GTPS)	GT#1	30	25.03.2019	13.04.2019	20	Hot Gas Path Inspection(HGPI)					
	GT#2	30	14.04.2019	23.04.2019	10	Combustion Inspection(CI)					
	SGT#1	30	25.03.2019	23.04.2019	30	Major Inspection					
PPCL(PPS-I)	GT#1	104	01.10.2019	10.10.2019	10	Combustion Inspection(CI)					
				Dec2019	2	Air inlet filter replacement					
	GT#2	104	01.03.2020	20.03.2020	20	Hot Gas Path Inspection(HGPI)					
				Dec2019	2	Air inlet filter replacement					
PPCL(PPS-III)	GT#1	216	01.11.2019	03.11.2019	3	Boroscopic Inspection (B.I)					
		216	15.11.2019	17.11.2019	3	Boroscopic Inspection (B.I)					
	GT#2	216	01.03.2020	21.03.2020	21	Hot Gas Path Inspection(HGPI)					
	GT#3	216	03.30.2019	04.01.2019	3	Boroscopic Inspection (B.I)					
	GT#4	216	01.12.2019	03.12.2019	3	Boroscopic Inspection (B.I)					
UTTARAKHAND											
Gama Infraprop Pvt.Ltd.	GT-1,STG	107	03.03.20	12.03.20	10	Annual Inspection and Overhauling					
	GT-1,STG	107									
	GT-1,STG	107									
	GT-1,STG	107									
	GT-1,STG	107									
	GT-1,STG	107									
Sravanthi Energy Pvt Ltd Phase-1	GT-1	71.5	04.05.19	05.05.19	1	Offline Water wash and Air intake filter replacement					
	GT-1	71.5	04.08.19	05.08.19	1	Offline Water wash and Air intake filter replacement					
	GT-1	71.5	04.11.19	05.11.19	1	Offline Water wash and Air intake filter replacement					
	GT-1	71.5	05.02.20	07.02.20	2	Offline Water wash and essential corrective maintenance					
	GT-2	71.5	03.01.19	04.01.19	1	Offline Water wash and Air intake filter replacement					
	GT 2	71.5	03.09.19	04.09.19	1	Offline Water wash and Air intake filter replacement					
	GT-2	71.5	03.12.19	04.12.19	1	Offline Water wash and Air intake filter replacement					
	GT-2	71.5	03.03.20	05.03.20	2	Offline Water wash					
	HRSG-1	125	05.02.20	07.02.20	3	Hadro Test & IBR statutory Inspection-License Renewal					
	HRSG-2	125	03.03.20	05.03.20	3	meja					
				04.11.19	05.11.19	1	Offline Water wash and Air intake filter replacement				
	GT-3	71.5	07.03.20	08.03.20	1	Offline Water wash and Air intake filter replacement					
	GT-4	71.5	05.12.19	06.12.19	1	Offline Water wash and Air intake filter replacement					
GTG	71	20.09.19	25.09.19	5	Corrective Maintenance work						
Chibro	1	60	15.11.19	05.12.19	21	Annual Maintenance					
	2	60	11.12.19	31.12.19	21	Annual Maintenance					
	3	60	08.01.20	28.01.20	21	Annual Maintenance					
	4	60	05.02.20	25.02.20	21	Annual Maintenance					
Khodri	1	30	01.11.19	25.11.19	25	Annual Maintenance					
	2	30	01.12.19	25.12.19	25	Annual Maintenance					
	3	30	01.01.20	25.01.20	25	Annual Maintenance					

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	(वास्तविक) वार्षिक आउटेज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days	
	4	30	01.02.20	25.02.20	25	Annual Maintenance				
Dhakrani	1	11.25	01.04.19	29.05.19	59	Capital Maintenance (shall start from 30-01-2019)				
	2	11.25	30.01.20	04.03.20	35	Annual Maintenance				
	3	11.25	23.12.19	26.01.20	35	Annual Maintenance				
	4	11.25	15.11.19	19.12.19	35	Annual Maintenance				
Dhalipur	1	17	09.12.19	31.03.20	114	RMU (shall continue up to 08-08-2020)				
	2	17	01.04.19	08.07.19	99	RMU (shall start from 09-12-2018)				
	3	17	01.01.20	04.02.20	35	Annual Maintenance				
Kulhal	1	10	01.04.19	30.04.19	30	Annual Maintenance				
	2	10	15.11.19	14.03.20	121	Capital Maintenance				
	3	10				NIL				
Tiloth	1	30	01.04.19	12.12.19	256	Comprehensive RMU				
	2	30	15.07.19	04.08.19	21	Routine Maintenance During Monsoon				
	3	30	15.01.20	14.02.20	31	Routine Maintenance During Lean discharge period				
	4	30	15.07.19	14.08.19	31	Routine Maintenance During Monsoon				
Chilla	1	36	01.12.19	31.03.20	121	RMU of Unit No.1 Proposed and shall continue up to 31-10-2021				
	2	36	01.12.19	04.01.20	35	Annual Maintenance of unit No.2				
	3	36	07.02.20	13.03.20	36	Annual Maintenance of unit No.3				
	4	36	01.04.19	30.11.19	244	Annual Maintenance				
Pathri	1	6.8	08.10.19	27.10.19	20	Annual Maintenance				
	2	6.8	08.10.19	27.10.19	20	Annual Maintenance				
	3	6.8	08.10.19	27.10.19	20	Annual Maintenance				
Mohd.pur	1	3.1	08.10.19	27.10.19	20	Annual Maintenance				
	2	3.1	08.10.19	27.10.19	20	Annual Maintenance				
	3	3.1	08.10.19	27.10.19	20	Annual Maintenance				
Ramganga	1	66	15.06.19	09.02.20	240	Capital Overhaul				
	2	66	20.07.19	23.08.19	35	Annual Maintenance				
	3	66	01.04.19	30.01.19	91	Capital Overhaul				
Khatima	1	13.8	22.02.20	27.03.20	35	Annual Maintenance				
	2	13.8	10.01.20	13.02.20	35	Annual Maintenance				
	3	13.8	22.11.19	31.12.19	40	Annual Maintenance				
MB-II	1	76	25.10.19	28.12.19	65	Annual Maintenance				
	2	76	15.11.19	18.01.20	65	Annual Maintenance				
	3	76	05.01.20	09.03.20	65	Annual Maintenance				
	4	76	25.01.20	29.03.20	65	Annual Maintenance				
PUNJAB										
GGSSTP Ropar	3	210				NIL				
	4	210	15.11.19	19.12.19	35	Capital Maint. Boiler O/H, TG Bearing inspection, Generator O/H				
	5	210				NIL				
	6	210				NIL				
GHTP Lehra Mohabbat	1	210	15.01.20	28.02.20	45	Capital Overhauling: HP, IP & LP Turbines/Furnace/Generator				
	2	210	01.04.19	20.04.19	20	Annual Overhauling				
	3	250				NIL				
	4	250				NIL				
NPL	1	700	08.11.19	21.01.20	75	Major Overhaul				
	2	700	15.03.20	21.03.20	7	Maintenance Shutdown				
TSPL	1	660	01.04.19	10.04.19	10	Annual Over Hauling				
	2	660				NIL				
	3	660	01.11.18	22.11.18	22	Annual Over Hauling				
GVK	1	270	25.11.19	15.12.19	21	Maintenance Shutdown				
	2	270				NIL				
HIMACHAL PRADESH										
Larji (3*42MW)	1	42	15.02.2020	25.03.2020	40 days	Annual Maintenance of M/Cs and associated equipments				
	2	42	26.12.2019	08.02.2020	45days					
	3	42	01.11.2019	10.12.2019	40days					

केंद्र / Station	Unit	केंद्र क्षमता Station Capacity (MW)	वार्षिक आऊटैज योजना के अनुसार अनुरक्षण शेड्यूल Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Reason	(वास्तविक) वार्षिक आऊटैज योजना के अनुसार अनुरक्षण शेड्यूल (Actual) Maintenance Schedule as per Annual Outage Planning			अभ्युक्तियाँ Remarks
			से / From	तक / To	दिनों की संख्या No of Days		से / From	तक / To	दिनों की संख्या No of Days	
Bhaba (3*40MW)	1	40	05.01.2020	15.02.2020	41 days	Annual Maintenance of M/Cs and associated equipments				
	2	40	26.12.2019	08.02.2020	44 days					
	3	40	05.11.2019	31.12.2019	56 days					
Bassi (4*15MW)	1	16.5	15.10.2019	30.11.2019	47 days	To carried out the annual maintenance of machine during lean season				
	2	16.5	15.11.2019	27.12.2019	43 days					
	3	16.5	23.01.2019	05.03.2019	42 days					
	4	16.5	02.01.2019	10.02.2019	40days					
Giri (2*30MW)	1	30	15.04.2019	15.05.2019	30 days	Annual Maintenance of M/Cs and associated equipments				
	2	30	15.12.2019	15.01.2020	30 days					
Ghanvi (2*11.25MW)	1	11.25	01.12.2019	31.01.2020	60 days	Annual Maintenance of M/Cs and associated equipments				
	2	11.25	01.02.2019	31.03.2019	60 days					
Ghanvi II (2*5MW)	1	5	01.12.2018	31.01.2019	60 days	Annual Maintenance of M/Cs and associated equipments				
	2	5	01.02.2019	31.03.2019	60 days					
Andhara (3*5.65MW)	1	5.65	20.12.2019	25.01.2020	36 days	Annual Maintenance of M/Cs and associated equipments				
	2	5.65	05.11.2019	15.12.2019	40 days					
	3	5.65	15.11.2019	8.12.2019	41 days					
Baner (3*4MW)	1	4	01.11.2018	30.11.2018	30 days	Annual Maintenance of M/Cs and associated equipments				
	2	4	01.12.2018	31.12.2018	31 days					
	3	4	01.01.2020	31.01.2020	31 days					
Khaulii (2*6MW)	1	6	07.11.2018	31.12.2018	55 days	Annual Maintenance of M/Cs and associated equipments				
	2	6	01.01.2020	28.02.2020	58 days					
Gaj (3*3.5MW)	1	3.5	17.10.2019	19.11.2019	34 days	Annual Maintenance of M/Cs and associated equipments				
	2	3.5	21.11.2019	29.12.2019	39 days					
	3	3.5	30.12.2019	03.02.2020	39 days					
Binwa (2*3MW)	1	3	14.11.2019	12.12.2019	29 days	Annual Maintenance of M/Cs and associated equipments				
	2	3	13.12.2019	15.01.2020	33 days					
Baspa II (3*100MW)	1	100	15.01.2020	24.01.2020	10 days	Due to lean period the planned annual maintenance of units one basis, does not affect the generation as no spillage takes place due to very less inflow				
	2	100	01.02.2020	10.02.2020	10 days					
	3	100	21.02.2020	02.03.2020	10 days					
Malana HEP (2*43MW)	1	43	15.01.2020	03.02.2020	20 days	Annual Maintenance				
	2	43	07.02.2020	26.02.2020	21 days					
IA Hydo Energy Pvt. Ltd (3*12MW)	1	12	01.012.2019	15.12.2019	15 days	Annual Maintenance				
	2	12	16.12.2019	30.12.2019	15 days					
	3	12	02.01.2020	16.01.2020	15 days					
Kashag HEP	1	65	30.04.2019	30.05.2019	30 day	Monthly Maintenance				
	2	65	31.05.2019	15.06.2019	15 day					
	3	65	30.06.2019	15.07.2020	15 day					
Sainj HEP (2*50MW)	1	50	15.11.2019	15.12.2019	30 days	Monthly Maintenance				
	2	50	16.12.2019	15.01.2020	30 days					
Kanchanjunga Power Company Pvt. Ltd.	1	8	11.11.2019	18.11.2019	7 days	Monthly Maintenance				
Nanti Hydro	1	6.5	15.11.2019	30.11.2019	15 days	Annual Maintenance				
	2	6.5	01.02.2020	19.01.2020	20 days					
Suryakanta Hydro	2	7	01.02.2020	19.01.2020	20 days	Annual Maintenance				