

सत्यमेव जयते
भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

उत्तर क्षेत्रीय विद्युत समिति

Northern Regional Power Committee

दिनांक: 25.11.2025

सेवा में/ To,

1. General Manager (Commercial.), NTPC Ltd, EOC-Noida
2. General Manager (O&M), IGSTPS- Jhajjar (Haryana)
3. General Manager (CSO), SJVN Ltd., Shimla
4. General Manager (Commercial), NHPC Ltd., Faridabad
5. General Manager (Commercial), JSW Hydro Ltd., Delhi

विषय: अक्टूबर, 2025 के बिलिंग माह के लिए Average Monthly Frequency Response Performance- Beta 'β' ।

महोदय,

केंद्रीय विद्युत विनियामक आयोग (CERC) द्वारा पत्र संख्या L-1/268/2022/CERC दिनांक 23 अक्टूबर, 2024 के माध्यम से स्वीकृत "औसत मासिक आवृत्ति प्रतिक्रिया प्रदर्शन - बीटा (β)" की गणना की कार्यप्रणाली के अनुसार, जो CERC (शुल्क की शर्तें और नियम), 2024 के विनियम 62(5) और 65(4) के प्रावधानों के अंतर्गत है, NRLDC ने अक्टूबर 2025 के बिलिंग माह के लिए 'बीटा (β)' की गणना प्रस्तुत की है।

NRLDC द्वारा प्रस्तुत बीटा (β) को उक्त प्रक्रिया के अंतर्गत प्रमाणित किया जाता है और इसे टैरिफ विनियम, 2024 और संबंधित प्रक्रिया के प्रावधानों के तहत विद्युत उत्पादन केंद्रों द्वारा अवलोकन के लिए संलग्न किया गया है।

In accordance with methodology for computation of Average Monthly Frequency Response Performance- Beta 'β' approved by Central Electricity Regulatory Commission vide its letter no. L-1/268/2022/CERC dated 23rd October, 2024 under provision of the Regulation 62(5) and 65(4) of the CERC (Terms and Conditions of Tariff) Regulations, 2024, NRLDC furnished 'Beta-β' computation for a billing month of October, 2025.

The Beta 'β', furnished by NRLDC is certified herewith under the said procedure and enclosed herewith for perusal by generating stations under the provisions of Tariff Regulations, 2024 and procedure thereof.

अनुलग्नक- यथोपरि।

भवदीय

Signed by Anzum Parwej

Date: 25-11-2025 16:23:27

(अंजुम परवेज)

अधीक्षण अभियंता (वाणिज्य)

**Average Monthly Frequency Response Performance- Beta 'β'
for billing month of October 2025**

Stations	Beta 'β'		Stations	Beta 'β'
ANTA GPP	No Data		PARBATI-III	0.29
AURAIYA GPP	No Data		RAMPUR HEP	1.00
BAIRASIUL HEP	1.00		RIHAND STPS	1.00
CHAMERA HEP	No Data		RIHAND-II STPS	0.39
CHAMERA-II HEP	0.00		RIHAND-III STPS	0.00
CHAMERA-III HEP	No Data		SALAL HEP	0.18
DADRI GPP	No Data		SEWA-II HEP	1.00
DADRI TPS	1.00		SINGRAULI STPS	1.00
DADRI-II TPS	1.00		TANAKPUR HEP	0.00
DHAULIGANGA HEP	1.00		TANDA-II STPS	1.00
DULHASTI HEP	0.00		TEHRI HEP	No Data
IGSTPS-JHAJJAR	1.00		UNCHAHAAR-I TPS	1.00
Karcham Wangtoo HEP	0.00		UNCHAHAAR-II TPS	1.00
KISHANGANGA HEP	0.00		UNCHAHAAR-III TPS	1.00
KOLDAM HEP	No Data		UNCHAHAAR-IV TPS	1.00
KOTESHWAR	1.00		URI HEP	1.00
NATHPA JHAKRI HEP	0.37		URI-II HEP	0.00
PARBATI-II	0.00			
Remarks	1. High Resolution Data (1 sec or better resolution) submitted by generating station 2. RLDC HDR Data (10 sec or better resolution)			